Water Test Results 2016

FIELD ID #	BUILD #	DATE SAMPLED	CONCENTRATION in ppb
88-1-GLR-W-DW	88	7/19/2016	< 2.0
88-1-GLR-N-BF-1	88	7/19/2016	7.4
88-1-GLR-N-BF-3	88	7/19/2016	3.7
88-1-BRG-S-BF-1	88	7/19/2016	3.8
88-1-BRG-S-BF-2	88	7/19/2016	2.9
88-1-KIT-E-FP-1	88	7/19/2016	8.4
88-1-KIT-E-FP-2	88	7/19/2016	5.3
88-1-KIT-N-FP-3	88	7/19/2016	< 2.0
88-1-KIT-S-FP-4	88	7/19/2016	2
88-1-KIT-W-DS	88	7/19/2016	7
88-1-KIT-S-HS	88	7/19/2016	4.5
88-1-HKIT-N-DW	88	7/19/2016	< 2.0
88-1-HBR-E-BF-1	88	7/19/2016	4.5
88-1-H102-S-DW	88	7/19/2016	8.4
88-1-HGR-W-BF-2	88	7/19/2016	6.3
88-1-MO-W-BF	88	7/19/2016	2.7
88-2-GUID-W-BF	88	7/19/2016	7.1
88-2-HGR-W-BF-2	88	7/19/2016	5.4
88-2-H208-S-DW	88	7/19/2016	< 2.0
88-2-HBR-E-BF-1	88	7/19/2016	3.3
88-2-HBR-E-BF-2	88	7/19/2016	< 2.0
88-2-206-W-CF-1	88	7/19/2016	43.2
88-2-206-W-CF-2	88	7/19/2016	7.1
88-2-206-W-CF-3	88	7/19/2016	17.5
88-2-206-W-CF-4	88	7/19/2016	154
88-2-NUR-S-BF	88	7/19/2016	4.1
88-2-HNUR-N-WC	88	7/19/2016	< 2.0
88-2-205-W-CF-1	88	7/19/2016	24.3
88-2-205-N-CF-4	88	7/19/2016	78.7
88-2-210-W-CF-1	88	7/19/2016	173
88-2-210-W-CF-2	88	7/19/2016	165
88-2-210-W-CF-3	88	7/19/2016	140
88-2-210-W-CF-4	88	7/19/2016	11.3
88-2-210-W-CF-5	88	7/19/2016	4.9
88-2-TR-S-TF	88	7/19/2016	13.1
88-2-TR-S-BF	88	7/19/2016	9.6

ROOM / LOCATION ID

BRG = Boys Restroom in Gym
GLR = Girls Locker Room
GUID = Guidance Office Bathroom
H = Hallway (if precedes room location)
HBR = Hallway Boys Restroom
HGR = Hallway Girls Restroom

Water Test Results 2016

KIT = Kitchen
MO = Main Office
NUR = Nurses Office
TR = Teachers Lounge

OUTLET TYPE
BF = Bathroom Faucet
CF = Classroom Faucet
DS = Dishwashing Sink
DW = Drinking Water Fountain
FP = Food Prep
HS = Hand Sink
KC = Kitchen Faucet, Cold
NS = Nurses Sink
TF = Teachers Faucet
WC = Water Cooler