

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax:cs@emsl.com
EMSL-CIN-01

EMSL Order ID: 012520391
LIMS Reference ID: AD20391
EMSL Customer ID: EPIC62

Attention: James Eberts
Epic Environmental Services, LLC [EPIC62]
80 Fork Bridge Road
Pittsgrove, NJ 08318
(856) 205-1077
jeberts@epicenviro.com

Project Name: Pine Hill - Overbrook HS LIW

Customer PO: 24-1032
EMSL Sales Rep: Justin Monturano
Received: 05/05/2025 12:00
Reported: 05/22/2025 11:55

Analytical Results

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: OVR - FB/Field Blank Lims Reference ID: AD20391-01 Matrix: Drinking Water Sampled: 05/03/25 00:00:00									
Metals									
Lead	ND		1	1.00	µg/L	05/19/25 14:01	05/20/25 11:52	PL	EPA 200.8 (DA)/EPA 200.8
Sample: OVR-WC-01-GLR Lims Reference ID: AD20391-02 Matrix: Drinking Water Sampled: 05/03/25 06:09:00									
Metals									
Lead	ND		1	1.00	µg/L	05/19/25 14:01	05/20/25 11:57	PL	EPA 200.8 (DA)/EPA 200.8
Sample: OVR-BF-01-GLR Lims Reference ID: AD20391-03 Matrix: Drinking Water Sampled: 05/03/25 06:10:00									
Metals									
Lead	ND		1	1.00	µg/L	05/19/25 14:01	05/20/25 11:59	PL	EPA 200.8 (DA)/EPA 200.8
Sample: OHS-WC-HALL1 Lims Reference ID: AD20391-04 Matrix: Drinking Water Sampled: 05/03/25 06:12:00									
Metals									
Lead	ND		1	1.00	µg/L	05/19/25 14:01	05/20/25 12:01	PL	EPA 200.8 (DA)/EPA 200.8
Sample: OHS-BF-HALL1 Lims Reference ID: AD20391-05 Matrix: Drinking Water Sampled: 05/03/25 06:13:00									
Metals									
Lead	ND		1	1.00	µg/L	05/19/25 14:01	05/20/25 12:03	PL	EPA 200.8 (DA)/EPA 200.8
Sample: OVR-BF-01-HALL1B Lims Reference ID: AD20391-06 Matrix: Drinking Water Sampled: 05/03/25 06:15:00									
Metals									
Lead	ND		1	1.00	µg/L	05/19/25 14:01	05/20/25 12:05	PL	EPA 200.8 (DA)/EPA 200.8
Sample: OVR-WC-01-HALL1B Lims Reference ID: AD20391-07 Matrix: Drinking Water Sampled: 05/03/25 06:16:00									
Metals									
Lead	ND		1	1.00	µg/L	05/19/25 14:01	05/20/25 12:07	PL	EPA 200.8 (DA)/EPA 200.8
Sample: OVR-IM-01-TRAIN/Ice Machine Lims Reference ID: AD20391-08 Matrix: Drinking Water Sampled: 05/03/25 06:18:00									
Metals									
Lead	ND		1	1.00	µg/L	05/19/25 14:01	05/20/25 12:13	PL	EPA 200.8 (DA)/EPA 200.8
Sample: OVR-SO-01-TRAIN Lims Reference ID: AD20391-09 Matrix: Drinking Water Sampled: 05/03/25 06:20:00									
Metals									
Lead	7.77		1	1.00	µg/L	05/19/25 14:01	05/20/25 12:15	PL	EPA 200.8 (DA)/EPA 200.8

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax:cs@emsl.com
EMSL-CIN-01

EMSL Order ID: 012520391
LIMS Reference ID: AD20391
EMSL Customer ID: EPIC62

Attention: James Eberts

Epic Environmental Services, LLC [EPIC62]
80 Fork Bridge Road
Pittsgrove, NJ 08318
(856) 205-1077
jeberts@epicenviro.com

Project Name:

Pine Hill - Overbrook HS LIW

Customer PO:

24-1032

EMSL Sales Rep:

Justin Monturano

Received:

05/05/2025 12:00

Reported:

05/22/2025 11:55

Analytical Results
(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: OVR-HB-01-TRAIN Lims Reference ID: AD20391-11 Matrix: Drinking Water Sampled: 05/03/25 06:22:00									
Metals									
Lead	2.19		1	1.00	µg/L	05/19/25 14:01	05/20/25 12:20	PL	EPA 200.8 (DA)/EPA 200.8
Sample: OVR-WC-01-HALL1A Lims Reference ID: AD20391-13 Matrix: Drinking Water Sampled: 05/03/25 06:24:00									
Metals									
Lead	ND		1	1.00	µg/L	05/19/25 14:01	05/20/25 12:22	PL	EPA 200.8 (DA)/EPA 200.8
Sample: OVR-BF-01-HALL1A Lims Reference ID: AD20391-14 Matrix: Drinking Water Sampled: 05/03/25 06:25:00									
Metals									
Lead	ND		1	1.00	µg/L	05/19/25 14:01	05/20/25 12:24	PL	EPA 200.8 (DA)/EPA 200.8
Sample: OVR-KC-01-KITCH1 Lims Reference ID: AD20391-15 Matrix: Drinking Water Sampled: 05/03/25 06:27:00									
Metals									
Lead	6.59		1	1.00	µg/L	05/19/25 14:01	05/20/25 12:26	PL	EPA 200.8 (DA)/EPA 200.8
Sample: OVR-KC-01-KITCH2 Lims Reference ID: AD20391-17 Matrix: Drinking Water Sampled: 05/03/25 06:30:00									
Metals									
Lead	5.53		1	1.00	µg/L	05/19/25 14:01	05/20/25 12:28	PL	EPA 200.8 (DA)/EPA 200.8
Sample: OVR-KC-01-KITCH3 Lims Reference ID: AD20391-19 Matrix: Drinking Water Sampled: 05/03/25 06:33:00									
Metals									
Lead	3.45		1	1.00	µg/L	05/19/25 14:01	05/20/25 12:30	PL	EPA 200.8 (DA)/EPA 200.8
Sample: OVR-IM-01-KITCH/Ice Machine Lims Reference ID: AD20391-21 Matrix: Drinking Water Sampled: 05/03/25 06:36:00									
Metals									
Lead	ND		1	1.00	µg/L	05/19/25 16:58	05/20/25 16:00	JW1	EPA 200.8 (Dig)/EPA 200.8
Sample: OVR-WC-01-HALL2 Lims Reference ID: AD20391-22 Matrix: Drinking Water Sampled: 05/03/25 06:38:00									
Metals									
Lead	ND		1	1.00	µg/L	05/19/25 14:01	05/20/25 12:32	PL	EPA 200.8 (DA)/EPA 200.8
Sample: OVR-BF-01-HALL2 Lims Reference ID: AD20391-23 Matrix: Drinking Water Sampled: 05/03/25 06:39:00									
Metals									
Lead	ND		1	1.00	µg/L	05/19/25 14:04	05/20/25 13:03	PL	EPA 200.8 (DA)/EPA 200.8

Attention: James Eberts
Epic Environmental Services, LLC [EPIC62]
80 Fork Bridge Road
Pittsgrove, NJ 08318
(856) 205-1077
jeberts@epicenviro.com

Project Name: Pine Hill - Overbrook HS LIW

Customer PO: 24-1032
EMSL Sales Rep: Justin Monturano
Received: 05/05/2025 12:00
Reported: 05/22/2025 11:55

Analytical Results (Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: OVR-WC-02-HALL3									
Lims Reference ID:		AD20391-24		Matrix: Drinking Water				Sampled: 05/03/25 06:41:00	
Metals									
Lead	ND	1	1.00	µg/L	05/19/25 14:04	05/20/25 13:09	PL	EPA 200.8 (DA)/EPA 200.8	
Sample: OVR-BF-2-HALL3									
Lims Reference ID:		AD20391-25		Matrix: Drinking Water				Sampled: 05/03/25 06:42:00	
Metals									
Lead	ND	1	1.00	µg/L	05/19/25 14:04	05/20/25 13:10	PL	EPA 200.8 (DA)/EPA 200.8	
Sample: OVR-WC-01-HALL3									
Lims Reference ID:		AD20391-26		Matrix: Drinking Water				Sampled: 05/03/25 06:44:00	
Metals									
Lead	ND	1	1.00	µg/L	05/19/25 14:04	05/20/25 13:12	PL	EPA 200.8 (DA)/EPA 200.8	
Sample: OVR-BF-01-HALL3									
Lims Reference ID:		AD20391-27		Matrix: Drinking Water				Sampled: 05/03/25 06:45:00	
Metals									
Lead	ND	1	1.00	µg/L	05/19/25 14:04	05/20/25 13:14	PL	EPA 200.8 (DA)/EPA 200.8	
Sample: OVR-WC-01-HALL									
Lims Reference ID:		AD20391-28		Matrix: Drinking Water				Sampled: 05/03/25 06:47:00	
Metals									
Lead	ND	1	1.00	µg/L	05/19/25 14:04	05/20/25 13:20	PL	EPA 200.8 (DA)/EPA 200.8	
Sample: OVR-WC-02-HALL									
Lims Reference ID:		AD20391-29		Matrix: Drinking Water				Sampled: 05/03/25 06:49:00	
Metals									
Lead	ND	1	1.00	µg/L	05/19/25 14:04	05/20/25 13:22	PL	EPA 200.8 (DA)/EPA 200.8	
Sample: OVR-BF-01-HALL									
Lims Reference ID:		AD20391-30		Matrix: Drinking Water				Sampled: 05/03/25 06:47:00	
Metals									
Lead	ND	1	1.00	µg/L	05/19/25 14:04	05/20/25 13:24	PL	EPA 200.8 (DA)/EPA 200.8	
Sample: OVR-BF-02-HALL									
Lims Reference ID:		AD20391-31		Matrix: Drinking Water				Sampled: 05/03/25 06:49:00	
Metals									
Lead	ND	1	1.00	µg/L	05/19/25 14:04	05/20/25 13:26	PL	EPA 200.8 (DA)/EPA 200.8	
Sample: OVR-CS-02-B213(3)									
Lims Reference ID:		AD20391-32		Matrix: Drinking Water				Sampled: 05/03/25 06:51:00	
Metals									
Lead	5.49	1	1.00	µg/L	05/19/25 14:04	05/20/25 13:28	PL	EPA 200.8 (DA)/EPA 200.8	

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax:cs@emsl.com
EMSL-CIN-01

EMSL Order ID: 012520391
LIMS Reference ID: AD20391
EMSL Customer ID: EPIC62

Attention: James Eberts

Epic Environmental Services, LLC [EPIC62]
80 Fork Bridge Road
Pittsgrove, NJ 08318
(856) 205-1077
jeberts@epicenviro.com

Project Name:

Pine Hill - Overbrook HS LIW

Customer PO:

24-1032

EMSL Sales Rep:

Justin Monturano

Received:

05/05/2025 12:00

Reported:

05/22/2025 11:55

Analytical Results
(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: OVR-CS-02-B213(2) Lims Reference ID: AD20391-34 Matrix: Drinking Water Sampled: 05/03/25 06:53:00									
Metals									
Lead	2.30		1	1.00	µg/L	05/19/25 14:04	05/20/25 13:30	PL	EPA 200.8 (DA)/EPA 200.8
Sample: OVR-CS-02-B213(1) Lims Reference ID: AD20391-36 Matrix: Drinking Water Sampled: 05/03/25 06:55:00									
Metals									
Lead	66.1		1	1.00	µg/L	05/19/25 14:04	05/20/25 13:35	PL	EPA 200.8 (DA)/EPA 200.8
Sample: OVR-CS-02-B213(1) (Flush) Lims Reference ID: AD20391-37 Matrix: Drinking Water Sampled: 05/03/25 06:56:00									
Metals									
Lead	5.82		1	1.00	µg/L	05/21/25 09:55	05/21/25 21:57	PL	EPA 200.8 (DA)/EPA 200.8
Sample: OVR-CS-02-B213(4) Lims Reference ID: AD20391-38 Matrix: Drinking Water Sampled: 05/03/25 06:57:00									
Metals									
Lead	4.25		1	1.00	µg/L	05/19/25 14:04	05/20/25 13:37	PL	EPA 200.8 (DA)/EPA 200.8
Sample: OVR-WC-01-HALL5 Lims Reference ID: AD20391-40 Matrix: Drinking Water Sampled: 05/03/25 07:00:00									
Metals									
Lead	ND		1	1.00	µg/L	05/19/25 14:04	05/20/25 13:43	PL	EPA 200.8 (DA)/EPA 200.8
Sample: OVR-BF-01-HALL5 Lims Reference ID: AD20391-41 Matrix: Drinking Water Sampled: 05/03/25 07:00:00									
Metals									
Lead	ND		1	1.00	µg/L	05/19/25 14:04	05/20/25 13:45	PL	EPA 200.8 (DA)/EPA 200.8
Sample: OVR-WC-02-HALL2 Lims Reference ID: AD20391-42 Matrix: Drinking Water Sampled: 05/03/25 07:02:00									
Metals									
Lead	ND		1	1.00	µg/L	05/19/25 14:04	05/20/25 13:47	PL	EPA 200.8 (DA)/EPA 200.8
Sample: OVR-BF-02-HALL2 Lims Reference ID: AD20391-43 Matrix: Drinking Water Sampled: 05/03/25 07:03:00									
Metals									
Lead	ND		1	1.00	µg/L	05/19/25 14:04	05/20/25 13:49	PL	EPA 200.8 (DA)/EPA 200.8

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax:cs@emsl.com
EMSL-CIN-01

EMSL Order ID: 012520391
LIMS Reference ID: AD20391
EMSL Customer ID: EPIC62

Attention: James Eberts

Epic Environmental Services, LLC [EPIC62]
80 Fork Bridge Road
Pittsgrove, NJ 08318
(856) 205-1077
jeberts@epicenviro.com

Project Name:

Pine Hill - Overbrook HS LIW

Customer PO:

24-1032

EMSL Sales Rep:

Justin Monturano

Received:

05/05/2025 12:00

Reported:

05/22/2025 11:55

Certified Analyses included in this Report**Analyte****Certifications*****EPA 200.8 in Drinking Water***

Lead

NJDEP

List of Certifications

Code	Description	Number	Expires
PADEP	Pennsylvania Department of Environmental Protection	2845.25	11/30/2025
NYSDOH	New York State Department of Health ELAP	10872	04/01/2025
NJDEP	New Jersey Department of Environmental Protection	03036	06/30/2025
MADEP	Massachusetts Department of Environmental Protection	M-NJ337	06/30/2025
CTDPH	Connecticut Department of Public Health	PH-0270	06/23/2026
California ELAP	California Water Boards	1877	06/30/2025
AIHA LAP	American Industrial Hygiene Association (AIHA LAP, LLC)	100194	05/01/2025
A2LA	A2LA Environmental Certificate	2845.01	07/31/2026

Please see the specific Field of Testing (FOT) on www.emsl.com <<http://www.emsl.com>> for a complete listing of parameters for which EMSL is certified.

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax:cs@emsl.com
EMSL-CIN-01

EMSL Order ID: 012520391
LIMS Reference ID: AD20391
EMSL Customer ID: EPIC62

Attention: James Eberts

Epic Environmental Services, LLC [EPIC62]
80 Fork Bridge Road
Pittsgrove, NJ 08318
(856) 205-1077
jeberts@epicenviro.com

Project Name:

Pine Hill - Overbrook HS LIW

Customer PO:

24-1032

EMSL Sales Rep:

Justin Monturano

Received:

05/05/2025 12:00

Reported:

05/22/2025 11:55

Notes and Definitions

Item	Definition
(Dig)	For metals analysis, sample was digested.
[2C]	Reported from the second channel in dual column analysis.
DA	Direct Analysis
DF	Dilution Factor
MDL	Method Detection Limit.
ND	Analyte was NOT DETECTED at or above the detection limit.
NR	Spike/Surrogate showed no recovery.
Q	Qualifier
RCS	Respirable Crystalline Silica
RL	Reporting Limit
Wet	Sample is not dry weight corrected.

Measurement of uncertainty and any applicable definitions of method modifications are available upon request. Per EPA NLLAP policy, sample results are not blank corrected.

Owen McKenna Laboratory Manager or other approved signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted.



Environmental Chemistry
Chain of Custody
EMSL Order Number (Lab Use Only):

AD20391

EMSL Analytical, Inc.
200 Route 130 North

Cinnaminson, NJ 08077
PHONE: 1-800-220-3675
FAX: (856) 786-5974

Report To Contact Name: James Eberts				Bill To Company: Epic Environmental Services, LLC											
Company Name: Epic Environmental Services, LLC				Attention To: James Eberts / Timothy Eberts											
Street: 80 Fork Bridge Road				Street: 80 Fork Bridge Road											
City: Pittsgrove		State/Province: NJ		Zip/Postal Code: 08318		City: Pittsgrove		State/Province: NJ		Zip/Postal Code: 08318					
Phone : 856-205-1077		Fax :		Phone: 856-205-1077		Fax:									
Project Name: Pine Hill-Overbrook HS LTW				Email Results To: jeberts@epicenviro.com / teberts@epicenviro.com				Purchase Order: 24-1032							
U.S. State where Samples Collected: NJ				Number of Samples in Shipment: 44				Date of Shipment: 5/5/2025							
Sample for Compliance? Yes ☒ No ☐ If yes, NPDES? ☐ Other (Specify):															
Samples Collected by: EMSL ☐ Client ☒ check one				Sampled By (Signature): Casey Lyons				Samples Received Chilled (Y/N)							
Standard Turnaround Time: ☒ 2 Weeks				The following TATs are subject to lab approval: ☐ 1 Week ☐ 4 Days ☐ 3 Days ☐ 2 Days ☐ 1 Day											
Failure to complete will hinder processing of samples			Matrix		Preservative		List Test(s) Needed								
Client Sample ID			Comp	Grab	Collect Date/Time	W=Water S=Soil A=Air SL=Sludge O= Other	1=HCL 2=HNO3 3=H2SO4 4=ICE 5=Other	EPA 200.8			Field pH	Field pH Test Time	Field Temp. Deg C	Field Temp. Test Time	Comments
1 OVR -FB			☐	☒	5/3/25 NIA	W	2	X							Field Blank
2 OVR-WC-01-GLR			☐	☒	0609	W		X							
3 OVR-BF-01-GLR			☐	☒	0610	W		X							
4 OHS-WC-HALL1			☐	☒	0612	W		X							
5 OHS-BF-HALL1			☐	☒	✓ 0613	W	✓	X							
Released By (Signature)				Date & Time				Received By				Date & Time			
Casey Lyons				5/5/2025				A. Monnelly (WR)				5/5/25 12pm			
Please indicate reporting requirements: ☒ Results Only ☐ Results and QC ☐ Reduced Deliverables ☐ Disk Deliverable ☐ Other															
Instructions or Comments:												Note: Field pH and Field Temperature are tested on the same day as the date of sample collection.			
Analyze FIRST DRAW Samples. Analyze FLUSH samples if corresponding First Draw result is above 15.5 ppb												Records			

Page 1 of 4 pages

(Lab) Received Temperature: _____ °C

HNO₃ added @ 3:15 pm on 5/5/2025



EMSL ANALYTICAL, INC.
LABORATORY • PRODUCTS • TRAINING

EMSL ANALYTICAL, INC.
LABORATORY • PRODUCTS • TRAINING

Environmental Chemistry Chain of Custody

EMSL Order Number (Lab Use Only):

AD20391

PHONE:
FAX:

Additional Pages of the Chain of Custody are only necessary if needed for additional sample information

Failure to complete will hinder processing of samples			Matrix	Preservative	List Test(s) Needed							Comments		
Client Sample ID	Comp	Grab	Collect Date/Time	W=Water S=Soil A=Air SL=Sludge O= Other	1=HCL 2=HNO3 3=H2SO4 4=ICE 5=Other	EPA 200.8				Field pH	Field pH Test Time		Field Temp Deg C	Field Temp Test Time
6 OVR-BF-01-HALL1B	☐	☐	5/3/25 0615	W	2									
7 OVR-WC-01-HALL1B	☐	☐	0616	W										
8 OVR-IM-01-TRAIN	☐	☐	0618	W										Ice Machine
9 OVR-SO-01-TRAIN	☐	☒	0620	W										
10 ↓ (Flush)	☐	☒	0621	W										Flush
11 OVR-HB-01-TRAIN	☐	☒	0622	W										
12 ↓ (Flush)	☐	☒	0622	W										Flush
13 OVR-WC-01-HALL1A	☐	☒	0624	W										
14 OVR-BF-01-HALL1A	☐	☒	0625	W										
15 OVR-KC-01-KITCH1	☐	☒	0627	W										
16 ↓ (Flush)	☐	☒	0628	W										Flush
17 OVR-KC-01-KITCH2	☐	☒	0630	W										
18 ↓ (Flush)	☐	☒	0631	W										Flush
19 OVR-KC-01-KITCH3	☐	☒	0633	W										
20 ↓ (Flush)	☐	☒	0634	W										Flush
21 OVR-IM-01-KITCH	☐	☒	0636	W										Ice Machine
22 OVR-WC-01-HALL2	☐	☒	↓ 0638	W	↓									

(Lab) Received Temperature: _____ °C

Environmental Chemistry
Chain of Custody
 EMSL Order Number (Lab Use Only):

AD20391

PHONE:
 FAX:

Additional Pages of the Chain of Custody are only necessary if needed for additional sample information

Failure to complete will hinder processing of samples				Matrix	Preservative	List Test(s) Needed							Comments	
Client Sample ID	Comp	Grab	Collect Date/Time	W=Water S=Soil A=Air SL=Sludge O= Other	1=HCL 2=HNO3 3=H2SO4 4=ICE 5=Other	EPA 200. 8				Field pH	Field pH Test Time	Field Temp Deg C		Field Temp Test Time
23 OVR-BF-01-HALL2	☐	☐	5/3/25 0639	W	2									
24 OVR-WC-02-HALL3	☐	☐	0641	W										
25 OVR-BF-02-HALL3	☐	☐	0642	W										
26 OVR-WC-01-HALL3	☐	☒	0644	W										
27 OVR-BF-01-HALL3	☐	☒	0645	W										
28 OVR-WC-01-HALL	☐	☒	0647	W										
29 OVR-WC-01-HALL	☐	☒	0649	W										
30 OVR-BF-01-HALL	☐	☒	0647	W										
31 OVR-BF-02-HALL	☐	☒	0649	W										
32 OVR-CS-02-B213(3)	☐	☒	0651	W										
33 ↓ (Flush)	☐	☒	0652	W										Flush
34 OVR-CS-02-B213(2)	☐	☒	0653	W										
35 ↓ (Flush)	☐	☒	0654	W										Flush
36 OVR-CS-02-B213(1)	☐	☒	0655	W										
37 ↓ (Flush)	☐	☒	0656	W										Flush
38 OVR-CS-02-B213(4)	☐	☒	0657	W										
39 ↓ (Flush)	☐	☒	0658	W										Flush

(Lab) Received Temperature: _____ °C

EMSL ANALYTICAL, INC.
LABORATORY PRODUCTS TRAINING

EMSL ANALYTICAL, INC.
LABORATORY PRODUCTS TRAINING

Environmental Chemistry Chain of Custody

EMSL Order Number (Lab Use Only):

AD26391

PHONE:
FAX:

Additional Pages of the Chain of Custody are only necessary if needed for additional sample information

Failure to complete will hinder processing of samples			Matrix	Preservative	List Test(s) Needed							Comments	
Client Sample ID	Comp	Grab	W=Water S=Soil A=Air SL=Sludge O= Other	1=HCL 2=HNO3 3=H2SO4 4=ICE 5=Other	EPA 200.8				Field pH	Field pH Test Time	Field Temp Deg C		Field Temp Test Time
40 OVR-WC-01-HALL5	☐	☐	5/3/25 0700	W	2								
41 OVR-BF-02-HALL5	☐	☐	0700	W	↓								
42 OVR-WC-02-HALL2	☐	☐	0702	W	↓								
43 OVR-BF-02-HALL2	☐	☒	0703	W	↓								
	☐	☒		W	—								
	☐	☒		W									
	☐	☒		W									
	☐	☒		W									
	☐	☒		W									
	☐	☒		W									
	☐	☒		W									
	☐	☒		W									
	☐	☒		W									
	☐	☒		W									
	☐	☒		W									
	☐	☒		W									
	☐	☒		W									

(Lab) Received Temperature: _____ °C