



CERTIFICATE OF ANALYSIS

Customer : Garden State Environmental
555 South Broad Street, Suite K
Glen Rock, NJ 07452

Project ID : Rahway Franklin Elementary School (9248) 1809 St. Georges Ave, Rahway, NJ
PAS Project ID : P25-03567

Matrix : Drinking Water
Report Date : 5/20/2025

PAS Sample ID	Client ID	Analysis	Results	Units	DF	PQL	MDL	MCL	Method	Date Sampled	Date Analyzed
P25-03567-01	FRK-1-F3A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/23/25 11:25	5/12/25 15:47
P25-03567-02	FRK-1-BF01A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/23/25 11:27	5/12/25 15:51
P25-03567-03	FRK-1-F2A	Lead	1.52 J	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/23/25 11:31	5/12/25 15:55
P25-03567-04	FRK-1-F1A	Lead	1.31 J	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/23/25 11:34	5/12/25 15:59
P25-03567-05	FRK-1-S3A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/23/25 11:37	5/12/25 16:03
P25-03567-06	FRK-1-S1A	Lead	1.31 J	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/23/25 11:40	5/12/25 16:07
P25-03567-07	FRK-1-WF01A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/23/25 11:44	5/12/25 16:11
P25-03567-08	FRK-1-S7A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/23/25 11:48	5/12/25 16:15
P25-03567-09	FRK-1-H01A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/23/25 11:51	5/12/25 16:19
P25-03567-10	FRK-1-S8A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/23/25 11:53	5/12/25 16:31
P25-03567-11	FRK-1-H02A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/23/25 11:55	5/12/25 16:35
P25-03567-12	FRK-1-S9A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/23/25 11:59	5/12/25 16:39
P25-03567-13	FRK-1-WC02A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/23/25 12:02	5/12/25 16:43
P25-03567-14	FRK-1-BF02A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/23/25 12:05	5/12/25 16:59
P25-03567-15	FRK-1-F11A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/23/25 12:09	5/12/25 17:03
P25-03567-16	FRK-1-F12A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/23/25 12:11	5/12/25 17:30
P25-03567-17	FRK-1-F10A	Lead	0.910 J	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/23/25 12:14	5/12/25 17:34
P25-03567-18	FRK-1-S17A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/23/25 12:18	5/12/25 17:38
P25-03567-19	FRK-1-S16A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/23/25 12:21	5/12/25 17:42
P25-03567-20	FRK-1-F8A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/23/25 12:24	5/12/25 17:46
P25-03567-21	FRK-2-WC01A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/23/25 12:30	5/12/25 17:50
P25-03567-22	FRK-2-BF01A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/23/25 12:30	5/12/25 17:54
P25-03567-23	FRK-2-F14A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/23/25 12:36	5/12/25 17:58
P25-03567-24	FRK-2-F15A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/23/25 12:39	5/12/25 18:02
P25-03567-25	FRK-2-F17A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/23/25 12:41	5/12/25 18:15
P25-03567-26	FRK-2-F16A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/23/25 12:45	5/12/25 18:19
P25-03567-27	FRK-2-F19A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/23/25 12:51	5/12/25 18:23
P25-03567-28	FRK-2-F18A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/23/25 12:55	5/12/25 18:27
P25-03567-29	FRK-4-23-FBA	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/23/25 12:56	5/12/25 18:31

Except for the parameters tested, York Analytical makes no representation as to the fitness or quality of the water sample taken.

PQL = Practical Quantitation Limit
MDL = Minimum Detection Limit
MCL = Maximum Contaminant Level
DF = Dilution Factor
ND = Analyzed for but not detected
J = Estimated result
* NJ Dept of Education & Dept of Children & Families Action Level

All samples are analyzed in accordance with
New Jersey Department of Environmental
Protection Protocol

Kelly Hogan - Quality Assurance Officer