

**Districtwide Lead in Drinking Water
Sampling and Remediation Plan for 2023-2025 Compliance.**

Edgemont UFSD

May 2025

Enviroscience Project #23148



2150 Smithtown Ave., Suite 3, Ronkonkoma, NY 11779

T: 631.580.3191 • **F:** 631.580.3195 • **W:** envirohealth.org

DISTRICTWIDE LEAD IN DRINKING WATER SAMPLING AND REMEDIATION PLAN

2023-2025

MAY 2025

ENVIROSCIENCE PROJECT #23148

Prepared for: EDGEMONT UFSD
300 White Oak Lane
Scarsdale, NY 10583

Prepared by: ENVIROSCIENCE CONSULTANTS, LLC
2150 Smithtown Avenue
Ronkonkoma, New York 11779
(631) 580-3191

Project Manager: *Pam Chadderton*

TABLE OF CONTENTS

<u>Section</u>	<u>Title</u>
1.0	Executive Summary
2.0	Sampling Methodology
3.0	Initial Results

Appendices

Appendix A	Greenville Elementary School
Appendix B	Seely Place Elementary School
Appendix C	Edgemont Jr./Sr. High School

1.0 EXECUTIVE SUMMARY

The Edgemont UFSD has developed their Lead in Drinking Water Sampling and Remediation Plan for the 2023-2025 compliance period, as required by the New York State Department of Health (Public Health Law Sections 1370-a and 1110, Subpart 67-4 Lead Testing in School Drinking Water).

In accordance with the regulation, this Lead Remediation Plan is prepared to identify locations deemed as Applicable Drinking Water Sources and report first draw sample results, to mitigate locations where sample results exceed 5 parts per billion, to identify locations deemed as Non-Applicable Water Sources, communicate this designation to building occupants, and to develop strategies for monitoring locations deemed Non-Applicable Water Sources to insure building occupants do not consume water from these locations.

The following locations within the Edgemont UFSD buildings have been deemed Applicable Drinking Water Sources by the administration:

- 1) Water fountains and bottle filling stations;
- 2) Kitchen water faucets and pot fillers used in food preparation;
- 3) Ice machines
- 4) Faculty Room sinks

First draw samples were collected from each of these locations within the district and analyzed by a New York State Department of Health ELAP certified laboratory. The chains of custody are available upon request. For results at or below 5 ppb, no further action is required until 2028. For locations above 5 ppb, options include: second and third draw sample collection to determine source of lead, designation of the location as Non-applicable Water Source, or permanent removal of the fixture from the location. In either case, the result was communicated by Enviroscience Consultants, and the fixture was shut off by the district immediately upon receipt of results.

The following locations within the Edgemont UFSD buildings were deemed Non-Applicable Water Sources by the administration:

- 1) Science Laboratory sinks
- 2) Art Room sinks
- 3) Technical and Home Economic Classroom sinks
- 4) Other Classroom sinks
- 5) Bathroom sinks
- 6) Outside spigots
- 7) Custodial Closet sinks
- 8) Mixed Valve sinks (or hot only)
- 9) Nurse's Office sinks

In these cases, the Edgemont UFSD staff have placed signs adjacent to the fixture to notify occupants that the water is not intended for consumption. To further support this protocol, the following management of the locations is required:

- 1) Science Laboratory sinks - communicate in writing with students that these locations are for science experiments and hand washing only, not for consumption. This is most easily accomplished by including this language in the laboratory safety paperwork distributed to students at the beginning of the school year. This program should be monitored by the respective science teachers, and any deficiencies reported for assessment and revision, if necessary, by the Facilities Department.
- 2) Art Room sinks - communicate in writing to students that these locations are for cleaning of art supplies and hand washing only, not for consumption. This is most easily accomplished by including this language in the course paperwork distributed to students at the beginning of the school year. This program should be monitored by the respective art teachers, and any deficiencies reported for assessment and revision, if necessary, by the Facilities Department.
- 3) Technical Classroom sinks - classrooms in this category often include wood shop or auto mechanics classrooms, where students are to hand wash after bathroom usage or activities as part of a regular hygiene program. It may include Home Economics classrooms, where water is used for hand washing and cleaning and not used for drinking or cooking. This program should be monitored by teachers and staff to ensure consumption is not taking place, and any deficiencies reported for assessment and revision, if necessary, by the Facilities Department.

- 4) Other classroom sinks - classrooms in this category often include elementary classrooms, where students are to hand wash after bathroom usage or activities as part of a regular hygiene program. This program should be monitored by teachers and staff to ensure consumption is not taking place, and any deficiencies reported for assessment and revision, if necessary, by the Facilities Department.
- 5) Bathroom sinks - in intermediate buildings, signage should be sufficient for communicating the concept of hand washing only. In elementary schools, personal hygiene should be integrated into curriculum to ensure students understand bathroom sinks are for hand washing only, and not consumption. Further, show what the signage looks like in bathrooms, so they learn to recognize its meaning. This program should be monitored by teachers and staff to ensure consumption is not taking place, and any deficiencies reported for assessment and revision, if necessary, by the Facilities Department.
- 6) Outside spigots - all-weather signage will be installed at each location. Further, spigots will have a special key maintained by the custodial staff to ensure that non-authorized persons do not fill sports coolers or use hoses for consumption. This program should be monitored by custodial staff to ensure consumption is not taking place, and any deficiencies reported for assessment and revision, if necessary, by the Facilities Department.
- 7) Custodial Closet sinks - these locations should be accessed by custodial personnel only and locked when not in use. Access to others should be restricted. This program should be monitored by custodial staff to ensure consumption is not taking place, and any deficiencies reported for assessment and revision, if necessary, by the Facilities Department.
- 8) Mixed Valve sinks (or hot only) – per Public Health Law Sections 1370-a and 1110, Subpart 67-4 Lead Testing in School Drinking Water mixed valve or hot water only sources are not required to be sampled. Signage is required for these sources. Signage should be sufficient for communicating the concept of hand washing only. In elementary schools, personal hygiene should be integrated into curriculum to ensure students understand bathroom sinks are for hand washing only, and not consumption. Further, show what the signage looks like so they learn to recognize its meaning. This program should be monitored by teachers and staff to ensure consumption is not

taking place, and any deficiencies reported for assessment and revision, if necessary, by the Facilities Department.

- 9) Nurse's Office sinks – these may include office sinks, exam room sinks, and bathroom sinks within the Nurse's Office. These locations should be signed and monitored by the Staff, if bottled water is provided for consumption or for taking medication.

All locations deemed non-applicable, but do not have signs, should be taken offline until signs have been posted. Signs are suggested to have pictures that instruct for handwashing only, do not drink.

2.0 SAMPLING METHODOLOGY

In accordance with the regulation, Enviroscience Consultants, LLC performed initial water sampling at the Edgemont UFSD buildings on May 13,14 & 15, 2025. Samples were collected in wide-mouth 250 milliliter containers and were collected in the morning hours before the facilities opened. The water sources were not used for at least 8 hours and not more than 18 hours prior to sampling. Unique source numbers and designations were assigned to each source location. Unique sample identification numbers were assigned to each sample taken. The key to fixture type codes and source designations are shown below.

Code Key for Lead in Water					
Fixture Type Codes					
BF	Bottle Filler	SK	Sink	SS	Slop Sink
HB	Hose Bib	SL	Supply Line	V	Valve
IM	Ice Machine	SP	Spigot	WC	Water Cooler
OS	Other Source	SPY	Spray	WF	Water Fountain
PF	Pot Filler				
Source Designations					
App	Applicable	N/A	Non-applicable		

3.0 Initial Results

All water source locations in each of the school buildings were assessed. Water source locations identified as drinking water sources were considered Applicable, and first draw

samples were collected. Water source locations identified as non-drinking water sources were considered non-applicable and these locations were documented.

The results of the initial sampling and the use of signs warning against water use at non-applicable sources is documented in the School Water Outlet Inventory for each building.

There were no elevated results in any of the outlets sampled.

Appendix A

Greenville Elementary School

Space #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
1001-1	Classroom A2	SK	N/A		5/14/2025	-	-	-	Sign
1001-2	Classroom A2	SK	N/A		5/14/2025	-	-	-	Sign
1001-3	Classroom A2	SK	N/A		5/14/2025	-	-	-	Sign
1001-4	Classroom A2	SK	N/A		5/14/2025	-	-	-	Sign
1001-5	Classroom A2	SK	N/A		5/14/2025	-	-	-	Sign
1001-6	Classroom A2	SK	N/A		5/14/2025	-	-	-	Sign
1002-1	Classroom A3	SK	N/A		5/14/2025	-	-	-	Sign
1002-2	Classroom A3	WF	N/A		5/14/2025	-	-	-	Turned Off; Sign
1003-1	Boy's Bathroom	SK	N/A		5/14/2025	-	-	-	Sign
1003-2	Boy's Bathroom	SK	N/A		5/14/2025	-	-	-	Sign
1004-01	Girl's Bathroom	SK	N/A		5/14/2025	-	-	-	Sign
1004-02	Girl's Bathroom	SK	N/A		5/14/2025	-	-	-	Sign
1005-1	Hallway @ Nurse's Office	WF	App	<1.0	5/14/2025	-	-	-	-
1005-2	Hallway @ Nurse's Office	BF	App	<1.0	5/14/2025	-	-	-	-
1006-1	Janitor's Closet	SS	N/A		5/14/2025	-	-	-	Sign
1007-1	Nurse's Office	SK	N/A		5/14/2025	-	-	-	Bottled Water Provided Mixed Valve; Sign
1008-1	Faculty Restroom	SK	N/A		5/14/2025	-	-	-	Sign
1009-1	Faculty Restroom	SK	N/A		5/14/2025	-	-	-	Sign

Space #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
1010-1	Classroom A5	SK	N/A		5/14/2025	-	-	-	Mixed Valve; Sign
1010-2	Classroom A5	WF	N/A		5/14/2025	-	-	-	Turned Off; Sign
1011-1	Classroom A6	SK	N/A		5/14/2025	-	-	-	Mixed Valve; Sign
1011-2	Classroom A6	WF	N/A		5/14/2025	-	-	-	Turned Off; Sign
1012-1	Classroom A7	SK	N/A		5/14/2025	-	-	-	Mixed Valve; Sign
1012-2	Classroom A7	WF	N/A		5/14/2025	-	-	-	Turned Off; Sign
1013-1	Classroom A8	SK	N/A		5/14/2025	-	-	-	Mixed Valve; Sign
1013-2	Classroom A8	WF	N/A		5/14/2025	-	-	-	Turned Off; Sign
1014-1	Classroom A9	SK	N/A		5/14/2025	-	-	-	Mixed Valve; Sign
1014-2	Classroom A9	WF	N/A		5/14/2025	-	-	-	Turned Off; Sign
1015-1	Classroom A10	SK	N/A		5/14/2025	-	-	-	Mixed Valve; Sign
1015-2	Classroom A10	WF	N/A		5/14/2025	-	-	-	Turned Off; Sign
1016-1	Classroom A11	SK	N/A		5/14/2025	-	-	-	Sign
1017-1	Classroom A12	SK	N/A		5/14/2025	-	-	-	Mixed Valve; Sign
1017-2	Classroom A12	WF	N/A		5/14/2025	-	-	-	Turned Off; Sign
1018-1	Hallway @ Gymnasium	WF	App	<1.0	5/14/2025	-	-	-	-
1018-2	Hallway @ Gymnasium	BF	App	2.0	5/14/2025	-	-	-	-
1019-1	Bathroom @ Band Room	SK	N/A		5/14/2025	-	-	-	Sign

Space #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
1020-1	Janitor's Closet	SS	N/A		5/14/2025	-	-	-	Sign
1021-1	Boy's Locker - Bathroom	SK	N/A		5/14/2025	-	-	-	Sign
1022-1	Boy's Bathroom	SK	N/A		5/14/2025	-	-	-	Sign
1022-2	Boy's Bathroom	SK	N/A		5/14/2025	-	-	-	Sign
1022-3	Boy's Bathroom	SK	N/A		5/14/2025	-	-	-	Sign
1023-1	Reading Office	WF	App	<1.0	5/14/2025	-	-	-	-
1024-1	Girl's Bathroom	SK	N/A		5/14/2025	-	-	-	Sign
1024-2	Girl's Bathroom	SK	N/A		5/14/2025	-	-	-	Sign
1024-3	Girl's Bathroom	SK	N/A		5/14/2025	-	-	-	Sign
1025-1	Janitor's Closet	SS	N/A		5/14/2025	-	-	-	Sign
1026-1	Classroom B9	SK	N/A		5/14/2025	-	-	-	Sign
1026-2	Classroom B9	SK	N/A		5/14/2025	-	-	-	Sign
1026-3	Classroom B9	SK	N/A		5/14/2025	-	-	-	Sign
1026-4	Classroom B9	SK	N/A		5/14/2025	-	-	-	Sign
1027-1	Classroom B8	SK	N/A		5/14/2025	-	-	-	Sign
1027-2	Classroom B8	WF	N/A		5/14/2025	-	-	-	Turned Off; Sign
1027-3	Classroom B8 - Bathroom	SK	N/A		5/14/2025	-	-	-	Sign
1028-1	Classroom B7	SK	N/A		5/14/2025	-	-	-	Sign

Space #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
1029-1	Hallway @ Classrooms B5/B7	WF	App	<1.0	5/14/2025	-	-	-	-
1030-1	Classroom B5	SK	N/A		5/14/2025	-	-	-	Sign
1030-2	Classroom B5/B7 Bathrooms	SK	N/A		5/14/2025	-	-	-	Sign
1030-3	Classroom B5/B7 Bathrooms	SK	N/A		5/14/2025	-	-	-	Sign
1030-4	Classroom B5/B7 Bathrooms	WF	N/A		5/14/2025	-	-	-	Turned Off; Sign
1031-1	Classroom B6 - Bathroom	SK	N/A		5/14/2025	-	-	-	Sign
1032-1	Classroom B3	SK	N/A		5/14/2025	-	-	-	Sign
1033-1	Classroom B2 (Faculty Room)	SK	App	<1.0	5/14/2025	-	-	-	-
1033-2	Classroom B2 (Faculty Room)	SPY	N/A		5/14/2025	-	-	-	Removed From Service
1034-1	Classroom B1	SK	N/A		5/14/2025	-	-	-	Sign
1034-2	Classroom B1/B3 Bathrooms	SK	N/A		5/14/2025	-	-	-	Sign
1034-3	Classroom B1/B3 Bathrooms	SK	N/A		5/14/2025	-	-	-	Sign
1034-4	Classroom B1/B3 Bathrooms	WF	N/A		5/14/2025	-	-	-	Turned Off; Sign
1035-1	Janitor's Closet	SS	N/A		5/14/2025	-	-	-	Sign
1036-1	Faculty Restroom	SK	N/A		5/14/2025	-	-	-	Sign
1037-1	Faculty Restroom	SK	N/A		5/14/2025	-	-	-	Sign
1038-1	Hallway @ Main Entry Lobby	WF	App	<1.0	5/14/2025	-	-	-	-
1038-2	Hallway @ Main Entry Lobby	BF	App	<1.0	5/14/2025	-	-	-	-

Space #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
1039-1	Restroom	SK	N/A		5/14/2025	-	-	-	Sign
1040-1	Custodian Restroom	SK	N/A		5/14/2025	-	-	-	Sign
1041-1	Cafeteria	WF	App	<1.0	5/14/2025	-	-	-	-
1041-2	Cafeteria	BF	App	<1.0	5/14/2025	-	-	-	-
1042-1	Kitchen Galley	SK	N/A		5/14/2025	-	-	-	Sign
1043-1	Janitor's Closet	SS	N/A		5/14/2025	-	-	-	Sign
1044-1	Classroom C1	SK	N/A		5/14/2025	-	-	-	Sign
1044-2	Classroom C1	WF	N/A		5/14/2025	-	-	-	Turned Off; Sign
1044-3	Classroom C1 - Bathroom	SK	N/A		5/14/2025	-	-	-	Sign
1045-1	Classroom C6	SK	N/A		5/14/2025	-	-	-	Sign
1045-2	Classroom C6	WF	N/A		5/14/2025	-	-	-	Turned Off; Sign
1045-3	Classroom C6 - Bathroom	SK	N/A		5/14/2025	-	-	-	Sign
1046-1	Classroom C3	SK	N/A		5/14/2025	-	-	-	Sign
1046-2	Classroom C3	WF	N/A		5/14/2025	-	-	-	Turned Off; Sign
1046-3	Classroom C3 - Bathroom	SK	N/A		5/14/2025	-	-	-	Sign
1047-1	Classroom C8	SK	N/A		5/14/2025	-	-	-	Sign
1047-2	Classroom C8	WF	N/A		5/14/2025	-	-	-	Turned Off; Sign
1047-3	Classroom C8 - Bathroom	SK	N/A		5/14/2025	-	-	-	Sign

Space #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
1048-1	Classroom C5	SK	N/A		5/14/2025	-	-	-	Sign
1048-2	Classroom C5	WF	N/A		5/14/2025	-	-	-	Turned Off; Sign
1048-3	Classroom C5 - Bathroom	SK	N/A		5/14/2025	-	-	-	Sign
1049-1	Classroom C10	SK	N/A		5/14/2025	-	-	-	Sign
1049-2	Classroom C10	WF	N/A		5/14/2025	-	-	-	Turned Off; Sign
1049-3	Classroom C10 - Bathroom	SK	N/A		5/14/2025	-	-	-	Sign
1050-1	Hallway @ Classrooms C5/C7	WF	App	<1.0	5/14/2025	-	-	-	-
1050-2	Hallway @ Classrooms C5/C7	BF	App	<1.0	5/14/2025	-	-	-	-
1051-1	Classroom C12	SK	N/A		5/14/2025	-	-	-	Sign
1051-2	Classroom C12	WF	N/A		5/14/2025	-	-	-	Turned Off; Sign
1051-3	Classroom C12 - Bathroom	SK	N/A		5/14/2025	-	-	-	Sign
1052-1	Classroom C7	SK	N/A		5/14/2025	-	-	-	Sign
1052-2	Classroom C7 - Bathroom	SK	N/A		5/14/2025	-	-	-	Sign
1053-1	Classroom C14 - Bathroom	SK	N/A		5/14/2025	-	-	-	Sign
1054-1	Hallway @ Multi-Purpose Room	WF	App	<1.0	5/14/2025	-	-	-	-
1054-2	Hallway @ Multi-Purpose Room	BF	App	<1.0	5/14/2025	-	-	-	-
1054-3	Hallway @ Multi-Purpose Room	WF	N/A		5/14/2025	-	-	-	Removed From Service
1055-1	Multi-Purpose Room Alcove	WF	App	<1.0	5/14/2025	-	-	-	-

Space #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
1055-2	Multi-Purpose Room Alcove	BF	App	<1.0	5/14/2025	-	-	-	-
1055-3	Multi-Purpose Room Alcove	WF	N/A		5/14/2025	-	-	-	Removed From Service
1055-4	Multi-Purpose Room - Bathroom	SK	N/A		5/14/2025	-	-	-	Sign
1056-1	Boiler Room	SS	N/A		5/14/2025	-	-	-	Sign

Laboratory Report

NYE Report #: 2502211-33350

May 15, 2025

Project Manager
Enviroscience Consultants, Inc.
2150 Smithtown Avenue
Ronkonkoma, NY 11779

Project: Edgemont UFSD; Greenville Elementary School

Dear Project Manager,


Enclosed is the Laboratory Analytical Report for potable water sample(s) received on May 14, 2025. New York Environmental analyzed the samples on May 15, 2025 for Lead (Pb) by EPA Method 200.9 Rev. 2.2.

If there are any questions regarding the analyses, please feel free to contact us at your convenience. New York Environmental is a NELAP accredited laboratory. Attached reported results meet the requirements of the NELAP standards unless otherwise noted.

Samples' analytical results relate only to the samples tested, in the condition received by the laboratory. This report shall not be reproduced except in its entirety without written approval of the laboratory.

We sincerely thank you for your business, and look forward to being of service for your future environmental testing needs.

Sincerely,



Li Tsang, Laboratory Director

Date Collected:	14 May 2025
Date Received:	14 May 2025
Date Analyzed:	15 May 2025

Analytical Method:	EPA 200.9 Rev. 2.2
Analyte, Matrix:	Lead, Potable Water

Lab ID	CID	Sample Location/Description	LOQ	Result	Units	Flag
250514J015	1	Classroom B2 (Faculty) - SK, Initial	0.001	<0.001	mg/L	
250514J016	2	Hallway Classrooms B5/B7 - WF, Initial	0.001	<0.001	mg/L	
250514J017	3	Reading Office - Sk, Initial	0.001	<0.001	mg/L	
250514J018	4	Hallway @ Gymnasium - BF, Initial	0.001	0.002	mg/L	
250514J019	5	Hallway @ Gymnasium - WF, Initial	0.001	<0.001	mg/L	
250514J020	6	Hallway @ Nurses Office - BF, Initial	0.001	<0.001	mg/L	
250514J021	7	Hallway @ Nurses Office - WF, Initial	0.001	<0.001	mg/L	
250514J022	8	Hallway @ Main Entry Lobby - BF, Initial	0.001	<0.001	mg/L	
250514J023	9	Hallway @ Main Entry Lobby - WF, Initial	0.001	<0.001	mg/L	
250514J024	10	Cafeteria - BF, Initial	0.001	<0.001	mg/L	
250514J025	11	Cafeteria - WF, Initial	0.001	<0.001	mg/L	
250514J026	12	Hallway @ Classrooms C5/C7 - BF, Initial	0.001	<0.001	mg/L	
250514J027	13	Hallway @ Classrooms C5/C7 - WF, Initial	0.001	<0.001	mg/L	
250514J028	14	Hallway @ Multi-Purpose Room - BF, Initial	0.001	<0.001	mg/L	
250514J029	15	Hallway @ Multi-Purpose Room - WF, Initial	0.001	<0.001	mg/L	
250514J030	16	Multipurpose Room Alcove - BF, Initial	0.001	<0.001	mg/L	
250514J031	17	Multipurpose Room Alcove - WF, Initial	0.001	<0.001	mg/L	

Comment:

CID: Client ID LOQ: Limit of Quantitation

Appendix B

Seely Place Elementary School

Space #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
1001-1	Orchestra 002	SK	N/A		5/13/2025	-	-	-	Sign
1002-1	Cafeteria	SK	N/A		5/13/2025	-	-	-	Sign
1002-2	Cafeteria	WF	App	<1.0	5/13/2025	-	-	-	-
1002-3	Cafeteria	BF	App	<1.0	5/13/2025	-	-	-	-
1002-4	Cafeteria	WF	N/A		5/13/2025	-	-	-	Removed From Service
1003-1	Boy's Bathroom	SK	N/A		5/13/2025	-	-	-	Sign
1003-2	Boy's Bathroom	HB	N/A		5/13/2025	-	-	-	Sign
1004-1	Music Room 003	SK	N/A		5/13/2025	-	-	-	Sign
1004-2	Music Room 003	SK	N/A		5/13/2025	-	-	-	Sign
1004-3	Music Room 003	SK	N/A		5/13/2025	-	-	-	Sign
1005-1	Girl's Bathroom	SK	N/A		5/13/2025	-	-	-	Sign
1005-2	Girl's Bathroom	SK	N/A		5/13/2025	-	-	-	Sign
1005-3	Girl's Bathroom	HB	N/A		5/13/2025	-	-	-	Sign
1006-1	Boiler Room	SS	N/A		5/13/2025	-	-	-	Sign
1006-2	Boiler Room - Bathroom	SK	N/A		5/13/2025	-	-	-	Sign
1007-1	Boy's Bathrooms	SK	N/A		5/13/2025	-	-	-	Sign
1007-2	Boy's Bathrooms	SK	N/A		5/13/2025	-	-	-	Sign
1007-3	Boy's Bathrooms	HB	N/A		5/13/2025	-	-	-	Sign

Space #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
1008-1	Hallway @ Classroom 006	WF	App	<1.0	5/13/2025	-	-	-	-
1008-2	Hallway @ Classroom 006	BF	App	<1.0	5/13/2025	-	-	-	-
1009-1	Janitor's Closet	SS	N/A		5/13/2025	-	-	-	Sign
1010-1	Office 008	SK	N/A		5/13/2025	-	-	-	Sign
1011-1	Classroom 006	SK	N/A		5/13/2025	-	-	-	Sign
1011-2	Classroom 006	SK	N/A		5/13/2025	-	-	-	Sign
1011-3	Classroom 006	SK	N/A		5/13/2025	-	-	-	Sign
1011-4	Classroom 006	SK	N/A		5/13/2025	-	-	-	Sign
1011-5	Classroom 006	SK	N/A		5/13/2025	-	-	-	Sign
1012-1	Office 007	SK	N/A		5/13/2025	-	-	-	Sign
1013-1	Girl's Bathrooms	SK	N/A		5/13/2025	-	-	-	Sign
1013-2	Girl's Bathrooms	SK	N/A		5/13/2025	-	-	-	Sign
1013-3	Girl's Bathrooms	HB	N/A		5/13/2025	-	-	-	Sign
2001-1	Classroom 101 - Coat Room	SK	N/A		5/13/2025	-	-	-	Sign
2001-2	Classroom 101 - Bathroom	SK	N/A		5/13/2025	-	-	-	Sign
2002-1	Classroom 103	SK	N/A		5/13/2025	-	-	-	Sign
2003-1	Classroom 105	SK	N/A		5/13/2025	-	-	-	Sign
2004-1	Classroom 104	SK	N/A		5/13/2025	-	-	-	Sign

Space #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
2004-2	Classroom 104	WF	N/A		5/13/2025	-	-	-	Turned Off; Sign
2004-3	Classroom 104 - Bathroom	SK	N/A		5/13/2025	-	-	-	Sign
2005-1	Hallway @ Classroom 104	WF	App	<1.0	5/13/2025	-	-	-	-
2005-2	Hallway @ Classroom 104	BF	App	<1.0	5/13/2025	-	-	-	-
2006-1	Boy's Bathrooms	SK	N/A		5/13/2025	-	-	-	Sign
2006-2	Boy's Bathrooms	SK	N/A		5/13/2025	-	-	-	Sign
2006-3	Boy's Bathrooms	SK	N/A		5/13/2025	-	-	-	Sign
2006-4	Boy's Bathrooms	HB	N/A		5/13/2025	-	-	-	Sign
2007-1	Janitor's Closet	SS	N/A		5/13/2025	-	-	-	Sign
2008-1	Faculty Restroom	SK	N/A		5/13/2025	-	-	-	Sign
2009-1	Principal's Office Restroom	SK	N/A		5/13/2025	-	-	-	Sign
2010-1	Classroom 106	SK	N/A		5/13/2025	-	-	-	Sign
2010-2	Classroom 106 - Bathroom	SK	N/A		5/13/2025	-	-	-	Sign
2010-3	Classroom 106 - Bathroom	HB	N/A		5/13/2025	-	-	-	Sign
2011-1	Librarian Office	SK	App	<1.0	5/13/2025	-	-	-	-
2012-1	Classroom 107	SK	N/A		5/13/2025	-	-	-	Sign
2012-2	Classroom 107 - Bathroom	SK	N/A		5/13/2025	-	-	-	Sign
2012-3	Classroom 107 - Bathroom	HB	N/A		5/13/2025	-	-	-	Sign

Space #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
2013-1	Faculty Restroom	SK	N/A		5/13/2025	-	-	-	Sign
2014-1	Girl's Bathrooms	SK	N/A		5/13/2025	-	-	-	Sign
2014-2	Girl's Bathrooms	SK	N/A		5/13/2025	-	-	-	Sign
2014-3	Girl's Bathrooms	SK	N/A		5/13/2025	-	-	-	Sign
2014-4	Girl's Bathrooms	HB	N/A		5/13/2025	-	-	-	Sign
2015-1	Classroom 109	SK	N/A		5/13/2025	-	-	-	Sign
2016-1	Hallway @ Classroom 110	WF	App	<1.0	5/13/2025	-	-	-	-
2016-2	Hallway @ Classroom 110	BF	App	<1.0	5/13/2025	-	-	-	-
2017-1	Nurse's Office	SK	N/A		5/13/2025	-	-	-	Bottled Water Provided Mixed Valve; Sign
2017-2	Nurse's Office	HW	N/A		5/13/2025	-	-	-	Bottled Water Provided Mixed Valve; Sign
2017-3	Nurse's Office - Bathroom	SK	N/A		5/13/2025	-	-	-	Bottled Water Provided Mixed Valve; Sign
2018-1	Janitor's Closet	SS	N/A		5/13/2025	-	-	-	Sign
2019-1	Classroom 113 - Office/Storage	SK	N/A		5/13/2025	-	-	-	Sign
2020-1	Hallway @ Classroom 113	WF	App	<1.0	5/13/2025	-	-	-	-
2020-2	Hallway @ Classroom 113	BF	App	<1.0	5/13/2025	-	-	-	-
2021-1	Janitor's Closet	SS	N/A		5/13/2025	-	-	-	Sign
3001-1	Hallway @ Classroom 204	WF	App	<1.0	5/13/2025	-	-	-	-
3001-2	Hallway @ Classroom 204	BF	App	<1.0	5/13/2025	-	-	-	-

Space #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
3002-1	Boy's Bathrooms	SK	N/A		5/13/2025	-	-	-	Sign
3002-2	Boy's Bathrooms	SK	N/A		5/13/2025	-	-	-	Sign
3002-3	Boy's Bathrooms	SK	N/A		5/13/2025	-	-	-	Sign
3002-4	Boy's Bathrooms	HB	N/A		5/13/2025	-	-	-	Sign
3003-1	Faculty Restroom	SK	N/A		5/13/2025	-	-	-	Sign
3004-1	Girl's Bathrooms	SK	N/A		5/13/2025	-	-	-	Sign
3004-2	Girl's Bathrooms	SK	N/A		5/13/2025	-	-	-	Sign
3004-3	Girl's Bathrooms	SK	N/A		5/13/2025	-	-	-	Sign
3004-4	Girl's Bathrooms	HB	N/A		5/13/2025	-	-	-	Sign
3005-1	Janitor's Closet	SS	N/A		5/13/2025	-	-	-	Sign
3006-1	Faculty Room 215	SK	App	<1.0	5/13/2025	-	-	-	-
3006-2	Faculty Room 215	SPY	N/A		5/13/2025	-	-	-	Removed From Service
3007-1	Faculty Restroom	SK	N/A		5/13/2025	-	-	-	Sign
3007-2	Faculty Restroom	HB	N/A		5/13/2025	-	-	-	Sign

Laboratory Report

NYE Report #: 2502210-33349

May 15, 2025

Project Manager
Enviroscience Consultants, Inc.
2150 Smithtown Avenue
Ronkonkoma, NY 11779

Project: Edgemont UFSD; Seely Place School

Dear Project Manager,


Enclosed is the Laboratory Analytical Report for potable water sample(s) received on May 14, 2025. New York Environmental analyzed the samples on May 15, 2025 for Lead (Pb) by EPA Method 200.9 Rev. 2.2.

If there are any questions regarding the analyses, please feel free to contact us at your convenience. New York Environmental is a NELAP accredited laboratory. Attached reported results meet the requirements of the NELAP standards unless otherwise noted.

Samples' analytical results relate only to the samples tested, in the condition received by the laboratory. This report shall not be reproduced except in its entirety without written approval of the laboratory.

We sincerely thank you for your business, and look forward to being of service for your future environmental testing needs.

Sincerely,



Li Tsang, Laboratory Director

Date Collected:	13 May 2025
Date Received:	14 May 2025
Date Analyzed:	15 May 2025

Analytical Method:	EPA 200.9 Rev. 2.2
Analyte, Matrix:	Lead, Potable Water

Lab ID	CID	Sample Location/Description	LOQ	Result	Units	Flag
250514J001	1	Hallway @ Classroom 204 - BF, Initial	0.001	<0.001	mg/L	
250514J002	2	Hallway @ Classroom 204 - wF, Initial	0.001	<0.001	mg/L	
250514J003	3	Faculty Room 215 - SK, Initial	0.001	<0.001	mg/L	
250514J004	4	Cafeteria - BF, Initial	0.001	<0.001	mg/L	
250514J005	5	Cafeteria - WF, Initial	0.001	<0.001	mg/L	
250514J006	6	Hallway @ Classroom 006 - BF, Initial	0.001	<0.001	mg/L	
250514J007	7	Hallway @ Classroom 006 - WF, Initial	0.001	<0.001	mg/L	
250514J008	8	Hallway @ Classroom 113 - BF, Initial	0.001	<0.001	mg/L	
250514J009	9	Hallway @ Classroom 113 - WF, Initial	0.001	<0.001	mg/L	
250514J010	10	Hallway @ Classroom 110 - BF, Initial	0.001	<0.001	mg/L	
250514J011	11	Hallway @ Classroom 110 - WF, Initial	0.001	<0.001	mg/L	
250514J012	12	Hallway @ Classroom 104 - BF, Initial	0.001	<0.001	mg/L	
250514J013	13	Hallway @ Classroom 104 - WF, Initial	0.001	<0.001	mg/L	
250514J014	14	Librarian Office - SK, Initial	0.001	<0.001	mg/L	

Comment:

CID: Client ID LOQ: Limit of Quantitation

Appendix C

Edgemont Jr./Sr. High School

Space #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
Maintenance Building									
1001-1	Main Garage/Storage Room	SK	N/A		5/15/2025	-	-	-	Sign
1001-2	Main Garage/Storage Room	HB	N/A		5/15/2025	-	-	-	Sign
Gymnasium									
1001-1	DOF Office	SK	App	5.0	5/15/2025	-	-	-	
1002-1	Boy's Locker Room - Janitor's Closet	SS	N/A		5/15/2025	-	-	-	Sign
1003-1	Boy's Locker Room - Bathroom	SK	N/A		5/15/2025	-	-	-	Mixed Valve; Sign
1003-2	Boy's Locker Room - Bathroom	SK	N/A		5/15/2025	-	-	-	Mixed Valve; Sign
1004-1	Boy's P.E. Office - Bathroom	SK	N/A		5/15/2025	-	-	-	Sign
1005-1	Boy's Locker Room - Janitor's Closet	SS	N/A		5/15/2025	-	-	-	Sign
1006-1	Boy's Locker Room	WF	App	<1.0	5/20/2025	-	-	-	
1007-1	Men's Bathroom	SK	N/A		5/15/2025	-	-	-	Mixed Valve; Sign
1007-2	Men's Bathroom	SK	N/A		5/15/2025	-	-	-	Mixed Valve; Sign
1007-3	Men's Bathroom	HB	N/A		5/15/2025	-	-	-	Sign
1008-1	Hallway @ Boy's Locker Room	WF	App	2.0	5/15/2025	-	-	-	
1008-2	Hallway @ Boy's Locker Room	BF	App	<1.0	5/15/2025	-	-	-	
1009-1	Girl's Locker Room - Bathroom	SK	N/A		5/15/2025	-	-	-	Mixed Valve; Sign
1009-2	Girl's Locker Room - Bathroom	SK	N/A		5/15/2025	-	-	-	Mixed Valve; Sign

Space #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
1009-3	Girl's Locker Room - Bathroom	HB	N/A		5/15/2025	-	-	-	Sign
1010-1	Hallway @ Visitor's Room	WF	App	<1.0	5/15/2025	-	-	-	
1011-1	Boy's Locker Room - Bathroom	SK	N/A		5/15/2025	-	-	-	Sign
1011-2	Boy's Locker Room - Bathroom	SK	N/A		5/15/2025	-	-	-	Sign
1012-1	Janitor's Closet	SS	N/A		5/15/2025	-	-	-	Sign
1013-1	Fitness Center	WF	App	<1.0	5/15/2025	-	-	-	
1013-2	Fitness Center	BF	App	<1.0	5/15/2025	-	-	-	
1014-1	Concession Stand	SK	App	1.0	5/15/2025	-	-	-	
1014-2	Concession Stand	IM	App	<1.0	5/15/2025	-	-	-	
1015-1	Hallway @ Girl's Locker Room	WF	App	<1.0	5/15/2025	-	-	-	
1015-2	Hallway @ Girl's Locker Room	BF	App	<1.0	5/15/2025	-	-	-	
1016-1	Girl's Locker Room	WF	App	<1.0	5/15/2025	-	-	-	
1017-1	Women's Bathroom	SK	N/A		5/15/2025	-	-	-	Sign
1017-2	Women's Bathroom	SK	N/A		5/15/2025	-	-	-	Sign
1017-3	Women's Bathroom	HB	N/A		5/15/2025	-	-	-	Sign
1018-1	Girl's Locker Room - Janitor's Closet	SS	N/A		5/15/2025	-	-	-	Sign
1019-1	Girl's P.E. Office - Bathroom	SK	N/A		5/15/2025	-	-	-	Sign
1020-1	Girl's Locker Room - Janitor's Closet	SS	N/A		5/15/2025	-	-	-	Sign

Space #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
1021-1	Girl's Locker Room - Bathroom	SK	N/A		5/15/2025	-	-	-	Mixed Valve; Sign
1021-2	Girl's Locker Room - Bathroom	SK	N/A		5/15/2025	-	-	-	Mixed Valve; Sign
1021-3	Girl's Locker Room - Bathroom	SK	N/A		5/15/2025	-	-	-	Mixed Valve; Sign
1021-4	Girl's Locker Room - Bathroom	HB	N/A		5/15/2025	-	-	-	
Art Building									
1001-1	Business Office	SK	App	<1.0	5/15/2025	-	-	-	
1002-1	Men's Bathroom	SK	N/A		5/15/2025	-	-	-	Mixed Valve; Sign
1002-2	Men's Bathroom	HB	N/A		5/15/2025	-	-	-	Sign
1003-1	Fan Room	SS	N/A		5/15/2025	-	-	-	Sign
1004-1	Women's Bathroom	SK	N/A		5/15/2025	-	-	-	Mixed Valve; Sign
1004-2	Women's Bathroom	HB	N/A		5/15/2025	-	-	-	Sign
1005-1	Art Room	SK	N/A		5/15/2025	-	-	-	Sign
1005-2	Art Room	SK	N/A		5/15/2025	-	-	-	Sign
1005-3	Art Room	SK	N/A		5/15/2025	-	-	-	Sign
1006-1	Lobby	WF	App	<1.0	5/15/2025	-	-	-	
1006-2	Lobby	BF	App	<1.0	5/15/2025	-	-	-	
Administration Building									
1001-1	Faculty Restroom	SK	N/A		5/15/2025	-	-	-	Sign

Space #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
1002-1	Kitchen 2-Bay (Left)	SK	App	3.0	5/15/2025	-	-	-	
1002-2	Kitchen 2-Bay (Right)	SK	App	<1.0	5/15/2025	-	-	-	
1002-3	Kitchen	SK	N/A		5/15/2025	-	-	-	Sign
1002-4	Kitchen	SK	N/A		5/15/2025	-	-	-	Sign
1002-5	Kitchen	SPY	N/A		5/15/2025	-	-	-	Sign
1002-6	Kitchen	Kettle	App	<1.0	5/15/2025	-	-	-	
1002-7	Kitchen	HC	N/A		5/15/2025	-	-	-	Hot Chocolate Maker (Has direct water line from "Space #1002-1" source)
1002A-1	Kitchen Serving Area	IM	App	<1.0	5/15/2025	-	-	-	
1003-1	Cafeteria	WF	App	<1.0	5/15/2025	-	-	-	
1003-2	Cafeteria	BF	App	<1.0	5/15/2025	-	-	-	
1004-1	Faculty Lunch/Break Room	SK	App	<1.0	5/15/2025	-	-	-	Mixed Valve
1005-1	Staff Restroom	SK	N/A		5/15/2025	-	-	-	Sign
1005-2	Staff Restroom	HB	N/A		5/15/2025	-	-	-	Sign
1006-1	Staff Restroom	SK	N/A		5/15/2025	-	-	-	Sign
1006-2	Staff Restroom	HB	N/A		5/15/2025	-	-	-	Sign
1007-1	Custodian's Break Room	SK	N/A	<1.0	5/15/2025	-	-	-	
1008-1	Faculty Restroom	SK	N/A		5/15/2025	-	-	-	Mixed Valve; Sign
2001-1	Faculty Restroom	SK	N/A		5/15/2025	-	-	-	Sign

Space #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
2001-2	Faculty Restroom	HB	N/A		5/15/2025	-	-	-	Sign
2002-1	Faculty Restroom	SK	N/A		5/15/2025	-	-	-	Sign
2002-2	Faculty Restroom	HB	N/A		5/15/2025	-	-	-	Sign
2003-1	Hallway @ Guidance Office	WF	App	<1.0	5/15/2025	-	-	-	
2003-2	Hallway @ Guidance Office	BF	App	<1.0	5/15/2025	-	-	-	
2004-1	Boy's Bathroom	SK	N/A		5/15/2025	-	-	-	Sign
2004-2	Boy's Bathroom	SK	N/A		5/15/2025	-	-	-	Sign
2004-3	Boy's Bathroom	HB	N/A		5/15/2025	-	-	-	Sign
2005-1	Janitor's Closet	SS	N/A		5/15/2025	-	-	-	Sign
2006-1	Girl's Bathroom	SK	N/A		5/15/2025	-	-	-	Sign
2006-2	Girl's Bathroom	SK	N/A		5/15/2025	-	-	-	Sign
2007-1	Nurse's Office	SK	N/A		5/15/2025	-	-	-	Mixed Valve; Sign
2007-2	Nurse's Office - Bathroom	SK	N/A		5/15/2025	-	-	-	Mixed Valve; Sign
2008-1	Principal's Office - Bathroom	SK	N/A		5/15/2025	-	-	-	Sign
2009-1	Music Room	SK	N/A		5/15/2025	-	-	-	Sign
2009-2	Music Room	SK	N/A		5/15/2025	-	-	-	Sign
Building A									
1001-1	Hallway @ Mechanical Room - Left	WF	App	<1.0	5/15/2025	-	-	-	

Space #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
1001-2	Hallway @ Mechanical Room - Left	BF	App	<1.0	5/20/2025	-	-	-	
1001-3	Hallway @ Mechanical Room - Right	WF	App	<1.0	5/15/2025	-	-	-	
1001-4	Hallway @ Mechanical Room - Right	BF	App	<1.0	5/15/2025	-	-	-	
1002-1	Hallway @ Girl's Bathroom	WF	N/A		5/15/2025	-	-	-	Turned Off; Sign
1002-2	Hallway @ Girl's Bathroom	WF	N/A		5/15/2025	-	-	-	Turned Off; Sign
1003-1	Janitor's Closet	SS	N/A		5/15/2025	-	-	-	Sign
1004-1	Girl's Bathroom	SK	N/A		5/15/2025	-	-	-	Sign
1004-2	Girl's Bathroom	SK	N/A		5/15/2025	-	-	-	Sign
1004-3	Girl's Bathroom	SK	N/A		5/15/2025	-	-	-	Sign
1004-4	Girl's Bathroom	HB	N/A		5/15/2025	-	-	-	Sign
1005-1	Boy's Bathroom	SK	N/A		5/15/2025	-	-	-	Sign
1005-2	Boy's Bathroom	SK	N/A		5/15/2025	-	-	-	Sign
1005-3	Boy's Bathroom	SK	N/A		5/15/2025	-	-	-	Sign
1005-4	Boy's Bathroom	HB	N/A		5/15/2025	-	-	-	Sign
Building B									
1001-1	Mechanical Room Vestibule	SS	N/A		5/15/2025	-	-	-	Sign
1002-1	Girl's Bathroom	SK	N/A		5/15/2025	-	-	-	Sign
1002-2	Girl's Bathroom	SK	N/A		5/15/2025	-	-	-	Sign

Space #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
1002-3	Girl's Bathroom	HB	N/A		5/15/2025	-	-	-	Sign
1003-1	Classroom B-1	SK	N/A		5/15/2025	-	-	-	Sign
1003-2	Classroom B-1	SK	N/A		5/15/2025	-	-	-	Sign
1003-3	Classroom B-1	SK	N/A		5/15/2025	-	-	-	Sign
1003-4	Classroom B-1	SK	N/A		5/15/2025	-	-	-	Sign
1003-5	Classroom B-1	SK	N/A		5/15/2025	-	-	-	Sign
1003-6	Classroom B-1	SK	N/A		5/15/2025	-	-	-	Sign
1003-7	Classroom B-1	SK	N/A		5/15/2025	-	-	-	Sign
1003-8	Classroom B-1	SK	N/A		5/15/2025	-	-	-	Sign
1003-9	Classroom B-1	EWS	N/A		5/15/2025	-	-	-	Sign
1004-1	Prep Room B-1A	SK	N/A		5/15/2025	-	-	-	Sign
1005-1	Classroom B-2	SK	N/A		5/15/2025	-	-	-	Sign
1005-2	Classroom B-2	SK	N/A		5/15/2025	-	-	-	Sign
1005-3	Classroom B-2	SK	N/A		5/15/2025	-	-	-	Sign
1005-4	Classroom B-2	SK	N/A		5/15/2025	-	-	-	Sign
1005-5	Classroom B-2	SK	N/A		5/15/2025	-	-	-	Sign
1005-6	Classroom B-2	EWS	N/A		5/15/2025	-	-	-	Sign
1006-1	Classroom B-3	SK	N/A		5/15/2025	-	-	-	Sign

Space #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
1006-2	Classroom B-3	SK	N/A		5/15/2025	-	-	-	Sign
1006-3	Classroom B-3	SK	N/A		5/15/2025	-	-	-	Sign
1006-4	Classroom B-3	SK	N/A		5/15/2025	-	-	-	Sign
1006-5	Classroom B-3	SK	N/A		5/15/2025	-	-	-	Sign
1006-6	Classroom B-3	SK	N/A		5/15/2025	-	-	-	Sign
1006-7	Classroom B-3	SK	N/A		5/15/2025	-	-	-	Sign
1006-8	Classroom B-3	SK	N/A		5/15/2025	-	-	-	Sign
1006-9	Classroom B-3	SK	N/A		5/15/2025	-	-	-	Sign
1006-10	Classroom B-3	SK	N/A		5/15/2025	-	-	-	Sign
1006-11	Classroom B-3	EWS	N/A		5/15/2025	-	-	-	Sign
1007-1	Prep Room B-5A	SK	N/A		5/15/2025	-	-	-	Sign
1008-1	Classroom B-5	SK	N/A		5/15/2025	-	-	-	Sign
1008-2	Classroom B-5	SK	N/A		5/15/2025	-	-	-	Sign
1008-3	Classroom B-5	SK	N/A		5/15/2025	-	-	-	Sign
1008-4	Classroom B-5	SK	N/A		5/15/2025	-	-	-	Sign
1008-5	Classroom B-5	SK	N/A		5/15/2025	-	-	-	Sign
1008-6	Classroom B-5	SK	N/A		5/15/2025	-	-	-	Sign
1008-7	Classroom B-5	SK	N/A		5/15/2025	-	-	-	Sign

Space #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
1008-8	Classroom B-5	SK	N/A		5/15/2025	-	-	-	Sign
1008-9	Classroom B-5	SK	N/A		5/15/2025	-	-	-	Sign
1008-10	Classroom B-5	SK	N/A		5/15/2025	-	-	-	Sign
1008-11	Classroom B-5	SK	N/A		5/15/2025	-	-	-	Sign
1008-12	Classroom B-5	EWS	N/A		5/15/2025	-	-	-	Sign
1009-1	Prep Room B-3A	SK	N/A		5/15/2025	-	-	-	Sign
1010-1	Classroom B-6	SK	N/A		5/15/2025	-	-	-	Sign
1010-2	Classroom B-6	SK	N/A		5/15/2025	-	-	-	Sign
1010-3	Classroom B-6	SK	N/A		5/15/2025	-	-	-	Sign
1010-4	Classroom B-6	SK	N/A		5/15/2025	-	-	-	Sign
1010-5	Classroom B-6	SK	N/A		5/15/2025	-	-	-	Sign
1010-6	Classroom B-6	SK	N/A		5/15/2025	-	-	-	Sign
1010-7	Classroom B-6	SK	N/A		5/15/2025	-	-	-	Sign
1010-8	Classroom B-6	SK	N/A		5/15/2025	-	-	-	Sign
1010-9	Classroom B-6	SK	N/A		5/15/2025	-	-	-	Sign
1010-10	Classroom B-6	SK	N/A		5/15/2025	-	-	-	Sign
1010-11	Classroom B-6	SK	N/A		5/15/2025	-	-	-	Sign
1010-12	Classroom B-6	EWS	N/A		5/15/2025	-	-	-	Sign

Space #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
1011-1	Prep Room B-6A	SK	N/A		5/15/2025	-	-	-	Sign
1011-2	Prep Room B-6A	SK	N/A		5/15/2025	-	-	-	Sign
1012-1	Classroom B-4	SK	N/A		5/15/2025	-	-	-	Sign
1012-2	Classroom B-4	SK	N/A		5/15/2025	-	-	-	Sign
1012-3	Classroom B-4	SK	N/A		5/15/2025	-	-	-	Sign
1012-4	Classroom B-4	SK	N/A		5/15/2025	-	-	-	Sign
1012-5	Classroom B-4	SK	N/A		5/15/2025	-	-	-	Sign
1012-6	Classroom B-4	SK	N/A		5/15/2025	-	-	-	Sign
1012-7	Classroom B-4	SK	N/A		5/15/2025	-	-	-	Sign
1012-8	Classroom B-4	SK	N/A		5/15/2025	-	-	-	Sign
1012-9	Classroom B-4	SK	N/A		5/15/2025	-	-	-	Sign
1012-10	Classroom B-4	SK	N/A		5/15/2025	-	-	-	Sign
1013-1	Prep Room B-4A	SK	N/A		5/15/2025	-	-	-	Sign
1013-2	Prep Room B-4A	SK	N/A		5/15/2025	-	-	-	Sign
1013-3	Prep Room B-4A	EWS	N/A		5/15/2025	-	-	-	Sign
1014-1	Boy's Bathroom	SK	N/A		5/15/2025	-	-	-	Sign
1014-2	Boy's Bathroom	SK	N/A		5/15/2025	-	-	-	Sign
1014-3	Boy's Bathroom	HB	N/A		5/15/2025	-	-	-	Sign

Space #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
1015-1	Hallway @ Main Entry	WF	App	<1.0	5/15/2025	-	-	-	
1015-2	Hallway @ Main Entry	BF	App	<1.0	5/15/2025	-	-	-	
Building C									
1001-1	Girl's Bathroom	SK	N/A		5/15/2025	-	-	-	Sign
1001-2	Girl's Bathroom	SK	N/A		5/15/2025	-	-	-	Sign
1001-3	Girl's Bathroom	HB	N/A		5/15/2025	-	-	-	Sign
1002-1	Janitor's Closet	SS	N/A		5/15/2025	-	-	-	Sign
1003-1	Boy's Bathroom	SK	N/A		5/15/2025	-	-	-	Sign
1003-2	Boy's Bathroom	SK	N/A		5/15/2025	-	-	-	Sign
1003-3	Boy's Bathroom	HB	N/A		5/15/2025	-	-	-	Sign
1004-1	Hallway	WF	App	<1.0	5/15/2025	-	-	-	
1004-2	Hallway	BF	App	<1.0	5/15/2025	-	-	-	
1005-1	Room C1 - Math Office	SK	App	<1.0	5/15/2025	-	-	-	
Building D									
1001-1	Bathroom	SK	N/A		5/15/2025	-	-	-	Mixed Valve; Sign
1001-2	Bathroom	HB	N/A		5/15/2025	-	-	-	Sign
1002-1	Janitor's Closet	SS	N/A		5/15/2025	-	-	-	Sign
1003-1	Bathroom	SS	N/A		5/15/2025	-	-	-	Mixed Valve; Sign

Space #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
1003-2	Bathroom	HB	N/A		5/15/2025	-	-	-	Sign
1004-1	Hallway	WF	App	<1.0	5/15/2025	-	-	-	
1004-2	Hallway	BF	App	<1.0	5/15/2025	-	-	-	
2001-1	Bathroom	SK	N/A		5/15/2025	-	-	-	Sign
2001-2	Bathroom	HB	N/A		5/15/2025	-	-	-	Sign
2002-1	Janitor's Closet	SS	N/A		5/15/2025	-	-	-	Sign
2003-1	Bathroom	SS	N/A		5/15/2025	-	-	-	Mixed Valve; Sign
2003-2	Bathroom	HB	N/A		5/15/2025	-	-	-	Sign
2004-1	Hallway	WF	App	<1.0	5/15/2025	-	-	-	
2004-2	Hallway	BF	App	<1.0	5/15/2025	-	-	-	
2005-1	Classroom D8	SK	N/A	<1.0	5/15/2025	-	-	-	
2006-1	Classroom D10	SK	N/A		5/15/2025	-	-	-	Sign
2006-2	Classroom D10	SK	N/A		5/15/2025	-	-	-	Sign
2006-3	Classroom D10	SK	N/A		5/15/2025	-	-	-	Sign
2006-4	Classroom D10	SK	N/A		5/15/2025	-	-	-	Sign
2006-5	Classroom D10	SK	N/A		5/15/2025	-	-	-	Sign
2006-6	Classroom D10	SK	N/A		5/15/2025	-	-	-	Sign
2006-7	Classroom D10	SK	N/A		5/15/2025	-	-	-	Sign

Space #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
2006-8	Classroom D10	SK	N/A		5/15/2025	-	-	-	Sign
2006-9	Classroom D10	SK	N/A		5/15/2025	-	-	-	Sign
2006-10	Classroom D10	SK	N/A		5/15/2025	-	-	-	Sign
2006-11	Classroom D10	SK	N/A		5/15/2025	-	-	-	Sign
2006-12	Classroom D10	SK	N/A		5/15/2025	-	-	-	Sign
2006-13	Classroom D10	SK	N/A		5/15/2025	-	-	-	Sign
2006-14	Classroom D10	SK	N/A		5/15/2025	-	-	-	Sign
2006-15	Classroom D10	SK	N/A		5/15/2025	-	-	-	Sign
2006-16	Classroom D10	SK	N/A		5/15/2025	-	-	-	Sign
2006-17	Classroom D10	SK	N/A		5/15/2025	-	-	-	Sign
2007-1	Classroom D10 - Prep Area	SK	N/A		5/15/2025	-	-	-	Sign
2008-1	Classroom D10 - Storage	SK	N/A		5/15/2025	-	-	-	Sign
2009-1	Classroom D7	SK	N/A		5/15/2025	-	-	-	Sign
2009-2	Classroom D7	SK	N/A		5/15/2025	-	-	-	Sign
2009-3	Classroom D7	SK	N/A		5/15/2025	-	-	-	Sign
2009-4	Classroom D7	SK	N/A		5/15/2025	-	-	-	Sign
2009-5	Classroom D7	SK	N/A		5/15/2025	-	-	-	Sign
2009-6	Classroom D7	SK	N/A		5/15/2025	-	-	-	Sign

Space #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
2009-7	Classroom D7	SK	N/A		5/15/2025	-	-	-	Sign
2009-8	Classroom D7	SK	N/A		5/15/2025	-	-	-	Sign
Resources Building									
1001-1	Main Corridor	WF	App	<1.0	5/15/2025	-	-	-	
1001-2	Main Corridor	BF	App	<1.0	5/15/2025	-	-	-	
1002-1	Boy's Bathroom	SK	N/A		5/15/2025	-	-	-	Sign
1002-2	Boy's Bathroom	SK	N/A		5/15/2025	-	-	-	Sign
1002-3	Boy's Bathroom	SK	N/A		5/15/2025	-	-	-	Sign
1002-4	Boy's Bathroom	HB	N/A		5/15/2025	-	-	-	Sign
1003-1	Girl's Bathroom	SK	N/A		5/15/2025	-	-	-	Sign
1003-2	Girl's Bathroom	SK	N/A		5/15/2025	-	-	-	Sign
1003-3	Girl's Bathroom	SK	N/A		5/15/2025	-	-	-	Sign
1003-4	Girl's Bathroom	HB	N/A		5/15/2025	-	-	-	Sign
1004-1	Janitor's Closet	SS	N/A		5/15/2025	-	-	-	Sign
1005-1	Classroom 006	SK	N/A		5/15/2025	-	-	-	Sign
1005-2	Classroom 006	SK	N/A		5/15/2025	-	-	-	Sign
1005-3	Classroom 006	SK	N/A		5/15/2025	-	-	-	Sign
1005-4	Classroom 006	SK	N/A		5/15/2025	-	-	-	Sign

Space #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
1005-5	Classroom 006	SK	N/A		5/15/2025	-	-	-	Sign
1005-6	Classroom 006	SK	N/A		5/15/2025	-	-	-	Sign
1006-1	Classroom 006 - Dark Room	SK	N/A		5/15/2025	-	-	-	Sign
1006-2	Classroom 006 - Dark Room	SK	N/A		5/15/2025	-	-	-	Sign
1006-3	Classroom 006 - Dark Room	EWS	N/A		5/15/2025	-	-	-	Sign
1007-1	Vestibule Outside E1	WF	App	<1.0	5/15/2025	-	-	-	
1007-2	Vestibule Outside E1	BF	App	<1.0	5/15/2025	-	-	-	
1008-1	Vestibule R6 - Janitor's Closet	SS	N/A		5/15/2025	-	-	-	Sign
1009-1	Vestibule R6 - Restroom	SK	N/A		5/15/2025	-	-	-	Sign
1010-1	Vestibule R6 - Restroom	SK	N/A		5/15/2025	-	-	-	Sign
1011-1	AV Room	SK	App	<1.0	5/15/2025	-	-	-	
1011-2	AV Room - Bathroom	SK	N/A		5/15/2025	-	-	-	Sign
1012-1	Passage R23 - Bathroom	SK	N/A		5/15/2025	-	-	-	Sign
2001-1	Main Corridor	WF	App	<1.0	5/15/2025	-	-	-	
2001-2	Main Corridor	BF	App	<1.0	5/15/2025	-	-	-	
2002-1	Classroom E-7	SK	N/A		5/15/2025	-	-	-	Sign
2002-2	Classroom E-7	SK	N/A		5/15/2025	-	-	-	Sign
2002-3	Classroom E-7	SK	N/A		5/15/2025	-	-	-	Sign

Space #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
2002-4	Classroom E-7	SK	N/A		5/15/2025	-	-	-	Sign
2002-5	Classroom E-7	SK	N/A		5/15/2025	-	-	-	Sign
2002-6	Classroom E-7	SK	N/A		5/15/2025	-	-	-	Sign
2002-7	Classroom E-7	SK	N/A		5/15/2025	-	-	-	Sign
2002-8	Classroom E-7	SK	N/A		5/15/2025	-	-	-	Sign
2003-1	Lab Prep 103	SK	N/A		5/15/2025	-	-	-	Sign
2004-1	Classroom E-8	SK	N/A		5/15/2025	-	-	-	Sign
2004-2	Classroom E-8	SK	N/A		5/15/2025	-	-	-	Sign
2004-3	Classroom E-8	SK	N/A		5/15/2025	-	-	-	Sign
2004-4	Classroom E-8	SK	N/A		5/15/2025	-	-	-	Sign
2004-5	Classroom E-8	SK	N/A		5/15/2025	-	-	-	Sign
2004-6	Classroom E-8	SK	N/A		5/15/2025	-	-	-	Sign
2004-7	Classroom E-8	SK	N/A		5/15/2025	-	-	-	Sign
2004-8	Classroom E-8	SK	N/A		5/15/2025	-	-	-	Sign
2004-9	Classroom E-8	EWS	N/A		5/15/2025	-	-	-	Sign
2005-1	Classroom E-9	SK	N/A		5/15/2025	-	-	-	Sign
2005-2	Classroom E-9	SK	N/A		5/15/2025	-	-	-	Sign
2005-3	Classroom E-9	SK	N/A		5/15/2025	-	-	-	Sign

Space #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
2005-4	Classroom E-9	SK	N/A		5/15/2025	-	-	-	Sign
2005-5	Classroom E-9	SK	N/A		5/15/2025	-	-	-	Sign
2006-1	Bathroom	SK	N/A		5/15/2025	-	-	-	Sign
2007-1	Bathroom	SK	N/A		5/15/2025	-	-	-	Sign
2008-1	Library Kitchen	SK	App	<1.0	5/15/2025	-	-	-	
2010-1	Vestibule R13 - Restroom	SK	N/A		5/15/2025	-	-	-	Mixed Valve; Sign
2011-2	Vestibule R13 - Restroom	SK	N/A		5/15/2025	-	-	-	Mixed Valve; Sign
2012-1	Library	WF	App	<1.0	5/15/2025	-	-	-	
2012-2	Library	BF	App	<1.0	5/15/2025	-	-	-	
Field House									
1001-1	Field House - Sidewalk Approach	WF	App	<1.0	5/20/2025	-	-	-	
1001-2	Field House - Sidewalk Approach	BF	App	<1.0	5/20/2025	-	-	-	
1002-1	Field House - Garage	SS	N/A		5/15/2025	-	-	-	Sign
1003-1	Field House - Boy's Bathroom	SK	N/A		5/15/2025	-	-	-	Sign
1003-2	Field House - Boy's Bathroom	SK	N/A		5/15/2025	-	-	-	Sign
1003-3	Field House - Boy's Bathroom	SK	N/A		5/15/2025	-	-	-	Sign
1003-4	Field House - Boy's Bathroom	HB	N/A		5/15/2025	-	-	-	Sign
1004-1	Field House - Girl's Bathroom	SK	N/A		5/15/2025	-	-	-	Sign

Space #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
1004-2	Field House - Girl's Bathroom	SK	N/A		5/15/2025	-	-	-	Sign
1004-3	Field House - Girl's Bathroom	SK	N/A		5/15/2025	-	-	-	Sign
1004-4	Field House - Girl's Bathroom	HB	N/A		5/15/2025	-	-	-	Sign
1005-1	Field House - Concessions	SK	App	1.0	5/15/2025	-	-	-	
1006-1	Football Field - Field Box #1	HB	N/A		5/15/2025	-	-	-	Sign
1006-2	Football Field - Field Box #2	HB	N/A		5/15/2025	-	-	-	Sign
1006-3	Football Field - Field Box #3	HB	N/A		5/15/2025	-	-	-	Sign
1006-4	Football Field - Field Box #4	HB	N/A		5/15/2025	-	-	-	Sign
1007-1	Tennis Courts	WF	N/A		5/15/2025	-	-	-	Removed From Service
1007-2	Tennis Courts	HB	N/A		5/15/2025	-	-	-	Sign
1008-1	Path to Field House	WF	App	<1.0	5/15/2025	-	-	-	

Laboratory Report

NYE Report #: 2502300-33365

May 16, 2025

Project Manager
Enviroscience Consultants, Inc.
2150 Smithtown Avenue
Ronkonkoma, NY 11779

Project: Ms/hs Administration Building

Dear Project Manager,

Enclosed is the Laboratory Analytical Report for potable water sample(s) received on May 15, 2025. New York Environmental analyzed the samples on May 16, 2025 for Lead (Pb) by EPA Method 200.9 Rev. 2.2.

If there are any questions regarding the analyses, please feel free to contact us at your convenience. New York Environmental is a NELAP accredited laboratory. Attached reported results meet the requirements of the NELAP standards unless otherwise noted.

Samples' analytical results relate only to the samples tested, in the condition received by the laboratory. This report shall not be reproduced except in its entirety without written approval of the laboratory.

We sincerely thank you for your business, and look forward to being of service for your future environmental testing needs.

Sincerely,



Li Tsang, Laboratory Director

Date Collected:	15 May 2025
Date Received:	15 May 2025
Date Analyzed:	16 May 2025

Analytical Method:	EPA 200.9 Rev. 2.2
Analyte, Matrix:	Lead, Potable Water

Lab ID	CID	Sample Location/Description	LOQ	Result	Units	Flag
250515K040	1	Kitchen - 2 Bay - Left - SK, Initial	0.001	0.003	mg/L	
250515K041	2	Kitchen - 2 Bay - Right - SK, Initial	0.001	<0.001	mg/L	
250515K042	3	Kitchen - Kettle - Kettle, Initial	0.001	<0.001	mg/L	
250515K043	4	Kitchen Serving Area - IM, Initial	0.001	<0.001	mg/L	
250515K044	5	Custodial Breakroom - SK, initial	0.001	<0.001	mg/L	
250515K045	6	Faculty Luch/Break Room- Sk, Initial	0.001	<0.001	mg/L	
250515K046	7	Cafeteria - BF, Initial	0.001	<0.001	mg/L	
250515K047	8	Cafeteria - WF, Initial	0.001	<0.001	mg/L	
250515K048	9	Hallway @ Guidance Office - BF, initial	0.001	<0.001	mg/L	
250515K049	10	Hallway @ Guidance Office - WF, initial	0.001	<0.001	mg/L	

Comment:

CID: Client ID LOQ: Limit of Quantitation

Laboratory Report

NYE Report #: 2502294-33359

May 16, 2025

Project Manager
Enviroscience Consultants, Inc.
2150 Smithtown Avenue
Ronkonkoma, NY 11779

Project: Ms/hs Art Building

Dear Project Manager,

Enclosed is the Laboratory Analytical Report for potable water sample(s) received on May 15, 2025. New York Environmental analyzed the samples on May 16, 2025 for Lead (Pb) by EPA Method 200.9 Rev. 2.2.

If there are any questions regarding the analyses, please feel free to contact us at your convenience. New York Environmental is a NELAP accredited laboratory. Attached reported results meet the requirements of the NELAP standards unless otherwise noted.

Samples' analytical results relate only to the samples tested, in the condition received by the laboratory. This report shall not be reproduced except in its entirety without written approval of the laboratory.

We sincerely thank you for your business, and look forward to being of service for your future environmental testing needs.

Sincerely,



Li Tsang, Laboratory Director

Date Collected:	15 May 2025
Date Received:	15 May 2025
Date Analyzed:	16 May 2025

Analytical Method:	EPA 200.9 Rev. 2.2
Analyte, Matrix:	Lead, Potable Water

Lab ID	CID	Sample Location/Description	LOQ	Result	Units	Flag
250515K015	1	Lobby - BF, Initial	0.001	<0.001	mg/L	
250515K016	2	Lobby - WF, Initial	0.001	<0.001	mg/L	
250515K017	3	Buisness Office - SK, Initial	0.001	<0.001	mg/L	

Comment:

CID: Client ID LOQ: Limit of Quantitation

Laboratory Report

NYE Report #: 2502293-33358

May 16, 2025

Project Manager
Enviroscience Consultants, Inc.
2150 Smithtown Avenue
Ronkonkoma, NY 11779

Project: Ms/hs Building A

Dear Project Manager,

Enclosed is the Laboratory Analytical Report for potable water sample(s) received on May 15, 2025. New York Environmental analyzed the samples on May 16, 2025 for Lead (Pb) by EPA Method 200.9 Rev. 2.2.

If there are any questions regarding the analyses, please feel free to contact us at your convenience. New York Environmental is a NELAP accredited laboratory. Attached reported results meet the requirements of the NELAP standards unless otherwise noted.

Samples' analytical results relate only to the samples tested, in the condition received by the laboratory. This report shall not be reproduced except in its entirety without written approval of the laboratory.

We sincerely thank you for your business, and look forward to being of service for your future environmental testing needs.

Sincerely,



Li Tsang, Laboratory Director

Date Collected:	15 May 2025
Date Received:	15 May 2025
Date Analyzed:	16 May 2025

Analytical Method:	EPA 200.9 Rev. 2.2
Analyte, Matrix:	Lead, Potable Water

Lab ID	CID	Sample Location/Description	LOQ	Result	Units	Flag
250515K012	1	Hallway @ Mechanical Rm - Left - WF, Initial	0.001	<0.001	mg/L	
250515K013	2	Hallway @ Mechanical Rm - Right - BF, Initial	0.001	<0.001	mg/L	
250515K014	3	Hallway @ Mechanical Rm - Right - WF, Initial	0.001	<0.001	mg/L	

Comment:

CID: Client ID LOQ: Limit of Quantitation

Laboratory Report

NYE Report #: 2502296-33361

May 16, 2025

Project Manager
Enviroscience Consultants, Inc.
2150 Smithtown Avenue
Ronkonkoma, NY 11779

Project: Ms/hs Building B

Dear Project Manager,

Enclosed is the Laboratory Analytical Report for potable water sample(s) received on May 15, 2025. New York Environmental analyzed the samples on May 16, 2025 for Lead (Pb) by EPA Method 200.9 Rev. 2.2.

If there are any questions regarding the analyses, please feel free to contact us at your convenience. New York Environmental is a NELAP accredited laboratory. Attached reported results meet the requirements of the NELAP standards unless otherwise noted.

Samples' analytical results relate only to the samples tested, in the condition received by the laboratory. This report shall not be reproduced except in its entirety without written approval of the laboratory.

We sincerely thank you for your business, and look forward to being of service for your future environmental testing needs.

Sincerely,



Li Tsang, Laboratory Director

Date Collected:	15 May 2025
Date Received:	15 May 2025
Date Analyzed:	16 May 2025

Analytical Method:	EPA 200.9 Rev. 2.2
Analyte, Matrix:	Lead, Potable Water

Lab ID	CID	Sample Location/Description	LOQ	Result	Units	Flag
250515K020	1	Hallway @ Main Entry - BF, Initial	0.001	<0.001	mg/L	
250515K021	2	Hallway @ Main Entry - WF, Initial	0.001	<0.001	mg/L	

Comment:

CID: Client ID LOQ: Limit of Quantitation

Laboratory Report

NYE Report #: 2502298-33363

May 16, 2025

Project Manager
Enviroscience Consultants, Inc.
2150 Smithtown Avenue
Ronkonkoma, NY 11779

Project: Ms/hs Building C

Dear Project Manager,

Enclosed is the Laboratory Analytical Report for potable water sample(s) received on May 15, 2025. New York Environmental analyzed the samples on May 16, 2025 for Lead (Pb) by EPA Method 200.9 Rev. 2.2.

If there are any questions regarding the analyses, please feel free to contact us at your convenience. New York Environmental is a NELAP accredited laboratory. Attached reported results meet the requirements of the NELAP standards unless otherwise noted.

Samples' analytical results relate only to the samples tested, in the condition received by the laboratory. This report shall not be reproduced except in its entirety without written approval of the laboratory.

We sincerely thank you for your business, and look forward to being of service for your future environmental testing needs.

Sincerely,



Li Tsang, Laboratory Director

Date Collected:	15 May 2025
Date Received:	15 May 2025
Date Analyzed:	16 May 2025

Analytical Method:	EPA 200.9 Rev. 2.2
Analyte, Matrix:	Lead, Potable Water

Lab ID	CID	Sample Location/Description	LOQ	Result	Units	Flag
250515K032	1	Hallway - BF, Initial	0.001	<0.001	mg/L	
250515K033	2	Hallway - WF, Initial	0.001	<0.001	mg/L	
250515K034	3	Room C1-Math Office - SK, Initial	0.001	<0.001	mg/L	

Comment:

CID: Client ID LOQ: Limit of Quantitation

Laboratory Report

NYE Report #: 2502299-33364

May 16, 2025

Project Manager
Enviroscience Consultants, Inc.
2150 Smithtown Avenue
Ronkonkoma, NY 11779

Project: Ms/hs Building D

Dear Project Manager,

Enclosed is the Laboratory Analytical Report for potable water sample(s) received on May 15, 2025. New York Environmental analyzed the samples on May 16, 2025 for Lead (Pb) by EPA Method 200.9 Rev. 2.2.

If there are any questions regarding the analyses, please feel free to contact us at your convenience. New York Environmental is a NELAP accredited laboratory. Attached reported results meet the requirements of the NELAP standards unless otherwise noted.

Samples' analytical results relate only to the samples tested, in the condition received by the laboratory. This report shall not be reproduced except in its entirety without written approval of the laboratory.

We sincerely thank you for your business, and look forward to being of service for your future environmental testing needs.

Sincerely,



Li Tsang, Laboratory Director

Date Collected:	15 May 2025
Date Received:	15 May 2025
Date Analyzed:	16 May 2025

Analytical Method:	EPA 200.9 Rev. 2.2
Analyte, Matrix:	Lead, Potable Water

Lab ID	CID	Sample Location/Description	LOQ	Result	Units	Flag
250515K035	1	Hallway (#1004-1) - BF, Initial	0.001	<0.001	mg/L	
250515K036	2	Hallway (#1004-1) - WF, Initial	0.001	<0.001	mg/L	
250515K037	3	Classroom D8 - SK, Initial	0.001	<0.001	mg/L	
250515K038	4	Hallway (#21004-1) - BF, Initial	0.001	<0.001	mg/L	
250515K039	5	Hallway (#21004-1) - WF, Initial	0.001	<0.001	mg/L	

Comment:

CID: Client ID LOQ: Limit of Quantitation

Laboratory Report

NYE Report #: 2502297-33362

May 16, 2025

Project Manager
Enviroscience Consultants, Inc.
2150 Smithtown Avenue
Ronkonkoma, NY 11779

Project: Ms/hs Building E / Resource Building

Dear Project Manager,

Enclosed is the Laboratory Analytical Report for potable water sample(s) received on May 15, 2025. New York Environmental analyzed the samples on May 16, 2025 for Lead (Pb) by EPA Method 200.9 Rev. 2.2.

If there are any questions regarding the analyses, please feel free to contact us at your convenience. New York Environmental is a NELAP accredited laboratory. Attached reported results meet the requirements of the NELAP standards unless otherwise noted.

Samples' analytical results relate only to the samples tested, in the condition received by the laboratory. This report shall not be reproduced except in its entirety without written approval of the laboratory.

We sincerely thank you for your business, and look forward to being of service for your future environmental testing needs.

Sincerely,



Li Tsang, Laboratory Director

Date Collected:	15 May 2025
Date Received:	15 May 2025
Date Analyzed:	16 May 2025

Analytical Method:	EPA 200.9 Rev. 2.2
Analyte, Matrix:	Lead, Potable Water

Lab ID	CID	Sample Location/Description	LOQ	Result	Units	Flag
250515K022	1	Vestible Outside E1 - BF, Initial	0.001	<0.001	mg/L	
250515K023	2	Vestible Outside E1 - WF, Initial	0.001	<0.001	mg/L	
250515K024	3	AV Room - SK, Initial	0.001	<0.001	mg/L	
250515K025	4	Main Corridor - BF, Initial	0.001	<0.001	mg/L	
250515K026	5	Main Corridor - WF, Initial	0.001	<0.001	mg/L	
250515K027	6	Library Kitchen - SK, Initial	0.001	<0.001	mg/L	
250515K028	7	Library - BF, Initial	0.001	<0.001	mg/L	
250515K029	8	Library - WF, Initial	0.001	<0.001	mg/L	
250515K030	9	Main Corridor - BF, initial	0.001	<0.001	mg/L	
250515K031	10	Main Corridor - WF, initial	0.001	<0.001	mg/L	

Laboratory Report

NYE Report #: 2502295-33360

May 16, 2025

Project Manager
Enviroscience Consultants, Inc.
2150 Smithtown Avenue
Ronkonkoma, NY 11779

Project: Ms/hs Field House Ext. Sources

Dear Project Manager,

Enclosed is the Laboratory Analytical Report for potable water sample(s) received on May 15, 2025. New York Environmental analyzed the samples on May 16, 2025 for Lead (Pb) by EPA Method 200.9 Rev. 2.2.

If there are any questions regarding the analyses, please feel free to contact us at your convenience. New York Environmental is a NELAP accredited laboratory. Attached reported results meet the requirements of the NELAP standards unless otherwise noted.

Samples' analytical results relate only to the samples tested, in the condition received by the laboratory. This report shall not be reproduced except in its entirety without written approval of the laboratory.

We sincerely thank you for your business, and look forward to being of service for your future environmental testing needs.

Sincerely,



Li Tsang, Laboratory Director

Date Collected:	15 May 2025
Date Received:	15 May 2025
Date Analyzed:	16 May 2025

Analytical Method:	EPA 200.9 Rev. 2.2
Analyte, Matrix:	Lead, Potable Water

Lab ID	CID	Sample Location/Description	LOQ	Result	Units	Flag
250515K018	1	Path to Field House - WF, Initial	0.001	<0.001	mg/L	
250515K019	2	Field House - Concessions - SK, Initial	0.001	0.001	mg/L	

Comment:

CID: Client ID LOQ: Limit of Quantitation

Laboratory Report

NYE Report #: 2502292-33357

May 16, 2025

Project Manager
Enviroscience Consultants, Inc.
2150 Smithtown Avenue
Ronkonkoma, NY 11779

Project: Ms/hs Gymnasium Building

Dear Project Manager,


Enclosed is the Laboratory Analytical Report for potable water sample(s) received on May 15, 2025. New York Environmental analyzed the samples on May 16, 2025 for Lead (Pb) by EPA Method 200.9 Rev. 2.2.

If there are any questions regarding the analyses, please feel free to contact us at your convenience. New York Environmental is a NELAP accredited laboratory. Attached reported results meet the requirements of the NELAP standards unless otherwise noted.

Samples' analytical results relate only to the samples tested, in the condition received by the laboratory. This report shall not be reproduced except in its entirety without written approval of the laboratory.

We sincerely thank you for your business, and look forward to being of service for your future environmental testing needs.

Sincerely,



Li Tsang, Laboratory Director

Date Collected:	15 May 2025
Date Received:	15 May 2025
Date Analyzed:	16 May 2025

Analytical Method:	EPA 200.9 Rev. 2.2
Analyte, Matrix:	Lead, Potable Water

Lab ID	CID	Sample Location/Description	LOQ	Result	Units	Flag
250515K001	1	Hallway @ Bays Locker Room - BF, Initial	0.001	<0.001	mg/L	
250515K002	2	Hallway @ Bays Locker Room - WF, Initial	0.001	0.002	mg/L	
250515K003	3	Hallway @ Girls Locker Room - BF, Initial	0.001	<0.001	mg/L	
250515K004	4	Hallway @ Girls Locker Room - WF, Initial	0.001	<0.001	mg/L	
250515K005	5	Concession Stand - SK, Initial	0.001	0.001	mg/L	
250515K006	6	Concession Stand - IM, Initial	0.001	<0.001	mg/L	
250515K007	7	Fitness Center - BF, Initial	0.001	<0.001	mg/L	
250515K008	8	Fitness Center - WF, Initial	0.001	<0.001	mg/L	
250515K009	9	Hallway @ Visitors Room - WF, Initial	0.001	<0.001	mg/L	
250515K010	10	Girls Locker Room - WF, Initial	0.001	<0.001	mg/L	
250515K011	11	DOF Office - SK, Initial	0.001	0.005	mg/L	

Comment:

CID: Client ID LOQ: Limit of Quantitation

Laboratory Report

NYE Report #: 2502400-33419

May 21, 2025

Project Manager
Enviroscience Consultants, Inc.
2150 Smithtown Avenue
Ronkonkoma, NY 11779

Project: Edgemont Ufsd; Ms/hs Building A

Dear Project Manager,


Enclosed is the Laboratory Analytical Report for potable water sample(s) received on May 20, 2025. New York Environmental analyzed the samples on May 21, 2025 for Lead (Pb) by EPA Method 200.9 Rev. 2.2.

If there are any questions regarding the analyses, please feel free to contact us at your convenience. New York Environmental is a NELAP accredited laboratory. Attached reported results meet the requirements of the NELAP standards unless otherwise noted.

Samples' analytical results relate only to the samples tested, in the condition received by the laboratory. This report shall not be reproduced except in its entirety without written approval of the laboratory.

We sincerely thank you for your business, and look forward to being of service for your future environmental testing needs.

Sincerely,



Li Tsang, Laboratory Director

Date Collected:	20 May 2025
Date Received:	20 May 2025
Date Analyzed:	21 May 2025

Analytical Method:	EPA 200.9 Rev. 2.2
Analyte, Matrix:	Lead, Potable Water

<u>Lab ID</u>	<u>CID</u>	<u>Sample Location/Description</u>	<u>LOQ</u>	<u>Result</u>	<u>Units</u>	<u>Flag</u>
250520K014	1	Hallway @ Mechanical Room - BF, Initial	0.001	<0.001	mg/L	

Comment:

CID: Client ID LOQ: Limit of Quantitation

Laboratory Report

NYE Report #: 2502399-33418

May 21, 2025

Project Manager
Enviroscience Consultants, Inc.
2150 Smithtown Avenue
Ronkonkoma, NY 11779

Project: Edgemont Ufsd; Ms/hs Gymnasium Building

Dear Project Manager,


Enclosed is the Laboratory Analytical Report for potable water sample(s) received on May 20, 2025. New York Environmental analyzed the samples on May 21, 2025 for Lead (Pb) by EPA Method 200.9 Rev. 2.2.

If there are any questions regarding the analyses, please feel free to contact us at your convenience. New York Environmental is a NELAP accredited laboratory. Attached reported results meet the requirements of the NELAP standards unless otherwise noted.

Samples' analytical results relate only to the samples tested, in the condition received by the laboratory. This report shall not be reproduced except in its entirety without written approval of the laboratory.

We sincerely thank you for your business, and look forward to being of service for your future environmental testing needs.

Sincerely,



Li Tsang, Laboratory Director

Date Collected:	20 May 2025
Date Received:	20 May 2025
Date Analyzed:	21 May 2025

Analytical Method:	EPA 200.9 Rev. 2.2
Analyte, Matrix:	Lead, Potable Water

Lab ID	CID	Sample Location/Description	LOQ	Result	Units	Flag
250520K013	1	Boys Locker Room - WF, Initial	0.001	<0.001	mg/L	

Comment:
CID: Client ID LOQ: Limit of Quantitation



Laboratory Report

NYE Report #: 2502398-33417

May 21, 2025

Project Manager
Enviroscience Consultants, Inc.
2150 Smithtown Avenue
Ronkonkoma, NY 11779

Project: Edgemont Ufsd; Ms/hs Field House Exterior Sources

Dear Project Manager,

Enclosed is the Laboratory Analytical Report for potable water sample(s) received on May 20, 2025. New York Environmental analyzed the samples on May 21, 2025 for Lead (Pb) by EPA Method 200.9 Rev. 2.2.

If there are any questions regarding the analyses, please feel free to contact us at your convenience. New York Environmental is a NELAP accredited laboratory. Attached reported results meet the requirements of the NELAP standards unless otherwise noted.

Samples' analytical results relate only to the samples tested, in the condition received by the laboratory. This report shall not be reproduced except in its entirety without written approval of the laboratory.

We sincerely thank you for your business, and look forward to being of service for your future environmental testing needs.

Sincerely,



Li Tsang, Laboratory Director

Date Collected:	20 May 2025
Date Received:	20 May 2025
Date Analyzed:	21 May 2025

Analytical Method:	EPA 200.9 Rev. 2.2
Analyte, Matrix:	Lead, Potable Water

Lab ID	CID	Sample Location/Description	LOQ	Result	Units	Flag
250520K011	1	Field House- Sidewalk Approach - BF, Initial	0.001	<0.001	mg/L	
250520K012	2	Field House- Sidewalk Approach - WF, Initial	0.001	<0.001	mg/L	

Comment:

CID: Client ID LOQ: Limit of Quantitation