

May 16, 2025

Northfield Community Schools
2000 New Road
Northfield, NJ 08225

Dear NCS Community,

Our school system is committed to protecting student, teacher, and staff health. To protect our community and be in compliance with the Department of Education regulations, Northfield Community Schools tested our schools' drinking water for lead.

In accordance with the Department of Education regulations, NCS had all drinking water faucets, fountains and ice machine tested. The final water lead test results were received by Vineland Environmental Laboratories L.L.C. today, May 16, 2025. Vineland laboratory was pleased to share that all water test samples were below the acceptable lead action level of 15 µg/l (parts per billion [ppb]).

For The Test Results or More Information

A copy of the test results for the Northfield Schools are available in the Northfield Board of Education office for the public, including students, teachers, other school personnel, and parents, and can be viewed between the hours of 9:00 a.m. and 3:00 p.m. We are also publishing the results on our website at <https://www.ncs-nj.org/>.

If you would like more information on reducing lead exposure, or the health effects of lead, visit EPA's Web site at www.epa.gov/lead, call the National Lead Information Center at 800-424-LEAD, or contact your health care provider.

Sincerely,



Pedro Bretones
Superintendent of Schools



Northfield BOE
2000 New Road
Northfield, NJ 08225

5/14/2002 15:00
Sample # Y2698
Sample Received: 4/21/25 16:30
Sampled by: Client

Northfield Board Of Education
2000 New Road, Northfield, NJ 08225
CERTIFICATE OF ANALYSIS
N.J.D.E.P. CERTIFICATION # 06003

Results in mg/l(ppm) unless otherwise noted

Sample #	Sample Location	Date Sampled	Time Sampled	FD / FL	Lead ug/L	Date Analyzed	Time Analyzed
Y2698-1	78NCS-DW-903-1FL-Room	4/21/2025	8:02	FD	<2	4/28/2025	12:04
Y2698-2	80NCS-BO-920-1FL-Room	4/21/2025	8:04	FD	<2	4/28/2025	12:09
Y2698-3	82NCS-WC-1FL-4th Hall	4/21/2025	8:06	FD	<2	4/28/2025	12:14
Y2698-4	84NCS-DW-401-1FL-Room	4/21/2025	8:08	FD	<2	4/28/2025	12:19
Y2698-5	86NCS-DW-402-1FL-Room	4/21/2025	8:10	FD	<2	4/28/2025	12:24
Y2698-6	88NCS-DW-406-1FL-Room	4/21/2025	8:12	FD	<2	4/28/2025	12:29
Y2698-7	90NCS-DW-405-1FL-Room	4/21/2025	8:16	FD	<2	4/28/2025	12:34
Y2698-8	92NCS-DW-403-1FL-Room	4/21/2025	8:18	FD	<2	4/28/2025	12:39
Y2698-9	94NCS-TS-409-1FL-Lavatory	4/21/2025	8:20	FD	<2	4/28/2025	12:54
Y2698-10	96NCS-DW-906-1FL-Room	4/21/2025	8:22	FD	<2	4/28/2025	13:10
Y2698-11	98NCS-DW-907-1FL-Room	4/21/2025	8:24	FD	<2	4/28/2025	13:15
Y2698-12	100NCS-TS-309-1FL-Lavatory	4/21/2025	8:26	FD	<2	4/28/2025	13:20
Y2698-13	102NCS-WC-1FL-3rd Hall	4/21/2025	8:28	FD	<2	4/28/2025	13:25
Y2698-14	104NCS-DW-301-1FL-Room	4/21/2025	8:30	FD	<2	4/28/2025	13:30
Y2698-15	106NCS-DW-302-1FL-Room	4/21/2025	8:32	FD	<2	4/28/2025	13:35
Y2698-16	108NCS-DW-306-1FL-Room	4/21/2025	8:34	FD	<2	4/28/2025	13:50
Y2698-17	110NCS-DW-305-1FL-Room	4/21/2025	8:36	FD	<2	4/28/2025	13:55
Y2698-18	112NCS-DW-303-1FL-Room	4/21/2025	8:38	FD	<2	4/28/2025	14:00
Y2698-19	114NCS-NS1-909-1FL-Room	4/21/2025	8:40	FD	<2	4/28/2025	14:05
Y2698-20	116NCS-NS2-1FL-Room	4/21/2025	8:42	FD	<2	4/28/2025	14:20
Y2698-21	118NCS-WC-2FL-7th Hall	4/21/2025	9:00	FD	<2	4/30/2025	11:59
Y2698-22	120NCS-WC-2FL-MCHall	4/21/2025	9:02	FD	<2	4/30/2025	12:04
Y2698-23	122NCS-TS-709-2FL-Lavatory	4/21/2025	9:04	FD	<2	4/30/2025	12:09
Y2698-24	124NCS-TS-609-2FL-Lavatory	4/21/2025	9:06	FD	<2	4/30/2025	12:14
Y2698-25	126NCS-WC-2FL-6th Hall	4/21/2025	9:08	FD	<2	4/30/2025	12:19
Y2698-26	128NCS-5LS1-968-2FL-Room	4/21/2025	9:10	FD	<2	4/30/2025	12:24
Y2698-27	130NCS-SL2-968-2FL-Room	4/21/2025	9:12	FD	<2	4/30/2025	12:29
Y2698-28	132NCS-SL1-969-2FL-Room	4/21/2025	9:14	FD	<2	4/30/2025	12:34
Y2698-29	134NCS-SL2-969-2FL-Room	4/21/2025	9:16	FD	<2	4/30/2025	12:39
Y2698-30	136NCS-WC-2FL-5th Hall	4/21/2025	9:18	FD	<2	4/30/2025	12:54
Y2698-31	138NCS-WC-2FL-CRHall	4/21/2025	9:20	FD	<2	4/30/2025	12:59
Y2698-32	140NCS-TS-509-2FL-Lavatory	4/21/2025	9:22	FD	<2	4/30/2025	13:10
Y2698-33	142NCS-TS-809-2FL-Lavatory	4/21/2025	9:24	FD	<2	4/30/2025	13:15
Y2698-34	144NCS-WC-2FL-8th Hall	4/21/2025	9:26	FD	<2	4/30/2025	13:20
Y2698-35	146NCS-SE1-972-2FL-Room	4/21/2025	9:28	FD	<2	4/30/2025	13:25
Y2698-36	148NS-SE2-972-2FL-Room	4/21/2025	9:30	FD	<2	4/30/2025	13:30
Y2698-37	150NCS-SE3-972-2FL-Room	4/21/2025	9:32	FD	<2	4/30/2025	13:35

Note: FD represents First Draw and FL represents Flushed sample

Office: (856) 692-6800 • Fax: (856) 692-3700 • Email: vinelandlab@comcast.net • Website: www.vinelandlab.com

Latish Menghani
Latish Menghani
Laboratory Director



VINELAND ENVIRONMENTAL LABORATORIES

782 S. Brewster Road, Suite B1 • Vineland, NJ 08361

Northfield BOE
2000 New Road
Northfield, NJ 08225

5/14/2025 15:33

Sample # Y2698

Sample Received: 4/21/25

Sampled by: Client

Northfield Board Of Education
2000 New Road, Northfield, NJ 08225
CERTIFICATE OF ANALYSIS
N.J.D.E.P. CERTIFICATION # 06003

Results in mg/l(ppm) unless otherwise noted

Sample #	Sample Location	Date Sampled	Time Sampled	FD / FL	Lead ug/L	Date Analyzed	Time Analyzed
Y2698-38	01NCS-WC-208-1FL-GYM	4/21/2025	9:45	FD	<2	4/30/2025	13:55
Y2698-39	03NCS-GS-208-1FL-GYM	4/21/2025	9:47	FD	<2	4/30/2025	14:00
Y2698-40	05NCS-SS-935-1FL-Room	4/21/2025	9:50	FD	<2	4/30/2025	14:05
Y2698-41	07NCS-WC-938-1FL-GYM	4/21/2025	9:52	FD	<2	5/1/2025	11:36
Y2698-42	09NCS-WC-939-1FL-GYM	4/21/2025	9:54	FD	<2	5/1/2025	11:41
Y2698-43	11NCS-WC-229-1FL-outside	4/21/2025	9:56	FD	<2	5/1/2025	11:46
Y2698-44	13NCS-GS-229-1FL-GYM	4/21/2025	9:58	FD	<2	5/1/2025	11:51
Y2698-45	15NCS-IM-1FL-Kitchen	4/21/2025	10:10	FD	<2	5/1/2025	11:56
Y2698-46	16NCS-FP1-1FL-Kitchen	4/21/2025	10:12	FD	<2	5/1/2025	12:01
Y2698-47	18NCS-FP2-1FL-Kitchen	4/21/2025	10:14	FD	<2	5/1/2025	12:06
Y2698-48	20NCS-FP3-1FL-Kitchen	4/21/2025	10:16	FD	<2	5/1/2025	12:11
Y2698-49	22NCS-FP4-1FL-Kitchen	4/21/2025	10:18	FD	<2	5/1/2025	12:26
Y2698-50	24NCS-TL-1FL-Lounge	4/21/2025	10:20	FD	<2	5/1/2025	12:41
Y2698-51	26NCS-TS-932-1FL-Lavatory	4/21/2025	10:22	FD	<2	5/1/2025	12:46
Y2698-52	28NCS-AS-931-1FL-Room	4/21/2025	10:24	FD	<2	5/1/2025	12:51
Y2698-53	30NCS-MS-930-1FL-Room	4/21/2025	10:26	FD	<2	5/1/2025	12:56
Y2698-54	32NCS-WC-1FL-2nd Hall	4/21/2025	10:30	FD	<2	5/1/2025	13:01
Y2698-55	34NCS-DW-201-1FL-Room	4/21/2025	10:32	FD	<2	5/1/2025	13:06
Y2698-56	36NCS-DW-202-1FL-Room	4/21/2025	10:34	FD	<2	5/1/2025	13:21
Y2698-57	38NCS-DW-206-1FL-Room	4/21/2025	10:36	FD	<2	5/1/2025	13:26
Y2698-58	40NCS-DW-205-1FL-Room	4/21/2025	10:38	FD	<2	5/1/2025	13:31
Y2698-59	42NCS-DW-203-1FL-Room	4/21/2025	10:40	FD	<2	5/1/2025	13:36
Y2698-60	44NCS-DW-001-1FL-Room	4/21/2025	10:42	FD	<2	5/1/2025	13:51
Y2698-61	46NCS-DW-002-1FL-Room	4/21/2025	10:44	FD	<2	5/2/2025	11:25
Y2698-62	48NCS-DW-0003-1FL-Room	4/21/2025	10:46	FD	<2	5/2/2025	11:30
Y2698-63	50NCS-DW-004-1FL-Room	4/21/2025	10:48	FD	<2	5/2/2025	11:35
Y2698-64	52NCS-DW-005-1FL-Room	4/21/2025	10:50	FD	<2	5/2/2025	11:40
Y2698-65	54NCS-DW-006-1FL-Room	4/21/2025	10:52	FD	<2	5/2/2025	11:45
Y2698-66	56NCS-TS-209-1FL-Lavatory	4/21/2025	10:54	FD	<2	5/2/2025	11:50
Y2698-67	58NCS-DW-912-1FL-Room	4/21/2025	10:56	FD	<2	5/2/2025	11:55
Y2698-68	60NCS-DW-913-1FL-Room	4/21/2025	10:58	FD	<2	5/2/2025	12:00
Y2698-69	62NCS-TS-109-1FL-Lavatory	4/21/2025	11:00	FD	<2	5/2/2025	12:05
Y2698-70	64NCS-WC-1FL-1st Hall	4/21/2025	11:02	FD	<2	5/2/2025	12:20
Y2698-71	66NCS-DW-101-1FL-Room	4/21/2025	11:04	FD	<2	5/2/2025	12:51
Y2698-72	68NCS-DW-102-1FL-Room	4/21/2025	11:06	FD	<2	5/2/2025	12:56
Y2698-73	70NCS-DW-106-1FL-Room	4/21/2025	11:08	FD	<2	5/2/2025	13:01
Y2698-74	72NCS-DW-105-1FL-Room	4/21/2025	11:10	FD	<2	5/2/2025	13:06
Y2698-75	74NCS-DW-103-1FL-Room	4/21/2025	11:12	FD	<2	5/2/2025	13:11
Y2698-76	76NCS-DW-902-1FL-Room	4/21/2025	11:14	FD	<2	5/2/2025	13:16

Note: FD represents First Draw and FL represents Flushed sample

Latish Menghani
Latish Menghani
Laboratory Director