



part of
ALS Limited

Specialists in Drinking Water Testing Technologies ■ Residential ■ Industrial ■ Municipal

York Analytical Laboratory A Division of ALS Limited

2161 WHITESVILLE ROAD TOMS RIVER, NJ 08755 PHONE 732-914-1515 FAX 732-914-1616

NJ Lab Cert. # 15001

CERTIFICATE OF ANALYSIS

Customer : Garden State Environmental
555 South Broad Street, Suite K
Glen Rock, NJ 07452

Project ID : Stafford BOE (Primary Learning Center) (9001), 1000 McKinley Ave., Stafford, NJ

PAS Project ID : P25-03528

Matrix : Drinking Water

Report Date : 5/19/2025

PAS Sample ID	Client ID	Analysis	Results	Units	DF	PQL	MDL	MCL	Method	Date Sampled	Date Analyzed
P25-03528-01	SPLC-1-S01A	Lead	8.53	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/23/25 08:00	5/7/25 13:46
P25-03528-02	SPLC-1-WC01A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/23/25 08:00	5/7/25 13:50
P25-03528-03	SPLC-1-BF01A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/23/25 08:00	5/7/25 13:54
P25-03528-04	SPLC-1-S02A	Lead	0.950 J	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/23/25 08:02	5/7/25 13:57
P25-03528-05	SPLC-1-B01A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/23/25 08:03	5/7/25 14:01
P25-03528-06	SPLC-1-B02A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/23/25 08:04	5/7/25 14:05
P25-03528-07	SPLC-1-B03A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/23/25 08:04	5/7/25 14:09
P25-03528-08	SPLC-1-B04A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/23/25 08:05	5/7/25 14:13
P25-03528-09	SPLC-1-B05A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/23/25 08:05	5/7/25 14:25
P25-03528-10	SPLC-1-B06A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/23/25 08:06	5/7/25 14:29
P25-03528-11	SPLC-1-B07A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/23/25 08:06	5/7/25 14:33
P25-03528-12	SPLC-1-B09A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/23/25 08:07	5/7/25 14:37
P25-03528-13	SPLC-1-B10A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/23/25 08:07	5/7/25 14:41
P25-03528-14	SPLC-1-S03A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/23/25 08:10	5/7/25 14:45
P25-03528-15	SPLC-1-S04A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/23/25 08:11	5/7/25 15:10
P25-03528-16	SPLC-1-S05A	Lead	5.44	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/23/25 08:11	5/7/25 15:14
P25-03528-17	SPLC-1-S06A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/23/25 08:12	5/7/25 15:18
P25-03528-18	SPLC-1-B11A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/23/25 08:13	5/7/25 15:22
P25-03528-19	SPLC-1-B12A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/23/25 08:13	5/7/25 15:27
P25-03528-20	SPLC-1-B13A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/23/25 08:16	5/7/25 15:31
P25-03528-21	SPLC-1-B14A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/23/25 08:16	5/7/25 15:35
P25-03528-22	SPLC-1-B15A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/23/25 08:17	5/7/25 15:39
P25-03528-23	SPLC-1-B16A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/23/25 08:17	5/7/25 15:43
P25-03528-24	SPLC-1-B17A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/23/25 08:18	5/7/25 15:55
P25-03528-25	SPLC-1-B18A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/23/25 08:19	5/7/25 15:59
P25-03528-26	SPLC-1-B19A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/23/25 08:20	5/7/25 16:03
P25-03528-27	SPLC-1-B20A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/23/25 08:20	5/7/25 16:06
P25-03528-28	SPLC-4-23-FBA	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/23/25 08:21	5/7/25 16:10

Except for the parameters tested, York Analytical makes no representation as to the fitness or quality of the water sample taken.

PQL = Practical Quantitation Limit

MDL = Minimum Detection Limit

MCL = Maximum Contaminant Level

DF = Dilution Factor

ND = Analyzed for but not detected

J = Estimated result

* NJ Dept of Education & Dept of Children & Families Action Level

All samples are analyzed in accordance with
New Jersey Department of Environmental
Protection Protocol

Kelly Hogan - Quality Assurance Officer