



CERTIFICATE OF ANALYSIS

Customer : Garden State Environmental
555 South Broad Street, Suite K
Glen Rock, NJ 07452

Project ID : Stafford BOE (Stafford Township Arts Center) (9001), 1000 Mckinley Avenue, Stafford NJ

Matrix : Drinking Water

PAS Project ID : P25-03531

Report Date : 5/19/2025

PAS Sample ID	Client ID	Analysis	Results	Units	DF	PQL	MDL	MCL	Method	Date Sampled	Date Analyzed
P25-03531-01	STAC-1-S01A	Lead	5.95	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/23/25 10:00	5/7/25 16:46
P25-03531-02	STAC-1-S02A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/23/25 10:01	5/7/25 16:51
P25-03531-03	STAC-1-WC01A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/23/25 10:02	5/7/25 16:55
P25-03531-04	STAC-1-WC02A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/23/25 10:03	5/7/25 17:00
P25-03531-05	STAC-4-23-FBA	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/23/25 10:04	5/7/25 17:23

Except for the parameters tested, York Analytical makes no representation as to the fitness or quality of the water sample taken.

PQL = Practical Quantitation Limit

MDL = Minimum Detection Limit

MCL = Maximum Contaminant Level

DF = Dilution Factor

ND = Analyzed for but not detected

J = Estimated result

* NJ Dept of Education & Dept of Children & Families Action Level

All samples are analyzed in accordance with
New Jersey Department of Environmental
Protection Protocol

Kelly Hogan - Quality Assurance Officer