



**Annual Drinking Water Quality Report**  
**Sandshore School**  
**PWSID# NJ1427302**  
**For the Year 2025, Results from the Year 2024**

Sandshore School is pleased to present to you this year's Annual Drinking Water Quality Report. Our drinking water is pumped from 1 active well on site in Morris County.

*Landlords must distribute this information to every tenant as soon as practicable, but no later than three business days after receipt. Delivery must be done by hand, mail, or email, and by posting the information in a prominent location at the entrance of each rental premises, pursuant to section 3 of P.L. 2021, c. 82 (C.58:12A-12.4 et seq.).*

Sandshore School routinely monitors for contaminants in your drinking water according to Federal and State laws. This table shows the test results of our monitoring for the period of January 1<sup>st</sup> to December 31<sup>st</sup>, 2024. The state allows us to monitor for some contaminants less than once per year because the concentrations of these contaminants do not change frequently. Some of our test results, though representative, are more than one year old and are the most recent results available.

We have prepared a Lead Service Line Inventory for our water system. Please call us at (973)691-4003 if you would like more information or to review the inventory.

**Vulnerable Populations:** Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and other microbiological contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

| TABLE OF DETECTED CONTAMINANTS           |                      |  |                             |          |        |   |
|--|----------------------|--|-----------------------------|----------|--------|---|
| Contaminant                              | Violati<br>on<br>Y/N | Level<br>Detected  | Units of<br>Measure<br>ment | MC<br>LG | MCL    | Likely Source of<br>Contamination   |
| <b>Inorganic Contaminants</b>            |                      |  |                             |          |        |   |
| Barium<br>Test Results Yr.: 2022         | N                    | 0.0124   | ppm                         | 2        | 2      | Discharge of drilling wastes;<br>discharge from metal refineries;<br>erosion of natural deposits                                      |
| Copper<br>Result at 90th Percentile      | N                    | 0.196<br>Range:<br>0.0501 to 0.678<br>0 samples exceed AL<br>0.565<br>Range: 0.139 to 0.604<br>0 samples exceed AL | ppm                         | 1.3      | AL=1.3 | Corrosion of household<br>plumbing systems, erosion of<br>natural deposits  |
| Fluoride<br>Test Results Yr.: 2022       | N                    | 0.05   | ppm                         | 4        | 4      | Erosion of natural deposits;<br>water additive which promotes<br>strong teeth; discharge from<br>fertilizer and aluminum<br>factories |
| Lead<br>Result at 90th Percentile        | N                    | 2.73<br>Range: ND to 3.95<br>0 samples exceed AL<br>4.06<br>Range: ND to 10.5<br>0 samples exceed AL               | ppb                         | 0        | AL=15  | Corrosion of household<br>plumbing systems, erosion of<br>natural deposits  |
| Nickel<br>Test Results Yr.: 2022         | N                    | 2.02   | ppb                         | n/a      | n/a    | Erosion of natural deposits   |
| Nitrate-Nitrite                          | N                    | 3.97   | ppm                         | 10       | 10     | Runoff from fertilizer use;<br>leaching from septic tanks,<br>sewage; erosion of natural<br>deposits                                  |
| <b>Radioactive Contaminants</b>          |                      |  |                             |          |        |   |
| Alpha emitters<br>Test Results Yr.: 2021 | N                    | Range: ND to 4.6<br>Avg. = 2.73  | pCi/l                       | 0        | 15     | Erosion of natural deposits   |

| TABLE OF DETECTED CONTAMINANTS         |               |                                |                      |       |     |                                |
|--|---------------|--------------------------------|----------------------|-------|-----|--------------------------------|
| Contaminant                            | Violation Y/N | Level Detected                 | Units of Measurement | MC LG | MCL | Likely Source of Contamination |
| Combined Radium Test Results Yr.: 2021 | N             | Range: ND to 1.5<br>Avg. = 0.5 | pCi/l                | 0     | 5   | Erosion of natural deposits    |

| TABLE OF DETECTED UNREGULATED CONTAMINANTS*  |               |                |                      |       |     |  |
|--|---------------|----------------|----------------------|-------|-----|--|
| Contaminant  | Violation Y/N | Level Detected | Units of Measurement | MC LG | MCL | Likely Source of Contamination             |
| <b>PFAS Per- and Polyfluoroalkyl Substances</b>  |               |                |                      |       |     |  |
| Perfluorobutanoic Acid (PFBA)  | N             | 2.5            | ppt                  | n/a   | n/a | Used in the manufacture of fluoropolymers. |
| * Unregulated contaminant monitoring helps EPA to determine where certain contaminants occur and whether the Agency should consider regulating those contaminants in the future. |               |                |                      |       |     |  |

| TABLE OF SECONDARY CONTAMINANTS     |                |                      |     |
|-------------------------------------|----------------|----------------------|-----|
| Secondary Contaminant               | Level Detected | Units of Measurement | RUL |
| Iron<br>Test results Yr.: 2020      | 118            | ppb                  | 300 |
| Manganese<br>Test results Yr.: 2020 | 11.4           | ppb                  | 50  |
| Sodium<br>Test Results Yr.: 2022    | 151            | ppm                  | 50  |
| Sulfate<br>Test results Yr.: 2020   | 8.8            | ppm                  | 250 |

**Sodium Health Effects:** For healthy individuals, the sodium intake from water is not important, because a much greater intake of sodium takes place from salt in the diet. However, sodium levels above the Recommended Upper Limit (RUL) may be of concern to individuals on a sodium restricted diet.

**Potential Sources of Contamination:** The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water include:

- Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- Inorganic contaminants, such as salts and metals, which can be naturally-occurring or result from urban storm water runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- Pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm water runoff, and residential uses.
- Organic chemical contaminants, including synthetic and volatile organic chemicals, which are byproducts of industrial processes and petroleum production, and can, also come from gas stations, urban storm water runoff, and septic systems.
- Radioactive contaminants which can be naturally occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of certain contaminants in water provided by public water systems. Food and Drug Administration regulations establish limits for contaminants in bottled water, which must provide the same protection for public health.

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1-800-426-4791.

Lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Sandshore School is responsible for providing high quality drinking water and removing lead pipes, but cannot control the variety of materials used in plumbing components in your home. You share the responsibility for protecting yourself and your family from the lead in your home plumbing. You can take responsibility by identifying and removing lead materials within your home plumbing and taking steps to reduce your family's risk. Before drinking tap water, flush your pipes for several minutes by running your tap, taking a shower, doing laundry or a load of dishes. You can also use a filter certified by an American National Standards Institute accredited certifier to reduce lead in drinking water. If you are concerned about lead in your water and wish to have your water tested, contact Sandshore School at (973)691-4003. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available at <http://www.epa.gov/safewater/lead>.

**DEFINITIONS**

In the “TABLE OF DETECTED CONTAMINANTS” you will find many terms and abbreviations you might not be familiar with. To help you better understand these terms we've provided the following definitions:

**Non-Detects (ND)** - laboratory analysis indicates that the constituent is not present.

**Parts per million (ppm) or Milligrams per liter (mg/l)** - one part per million corresponds to one minute in two years or a single penny in \$10,000.

**Parts per billion (ppb) or Micrograms per liter** - one part per billion corresponds to one minute in 2,000 years, or a single penny in \$10,000,000.

**Parts per trillion (ppt) or Nanograms per liter (nanograms/l)** - one part per trillion corresponds to one minute in 2,000,000 years, or a single penny in \$10,000,000,000

**Picocuries per liter (pCi/L)** - Picocuries per liter is a measure of the radioactivity in water.

**Treatment Technique (TT)** - A required process intended to reduce the level of a contaminant in drinking water.

**Action Level (AL)** - the concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

**Maximum Contaminant Level** - The "Maximum Allowed" (MCL) is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

**Maximum Contaminant Level Goal** -The "Goal"(MCLG) is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

**Secondary Contaminant** - Substances that do not have an impact on health. Secondary Contaminants affect aesthetic qualities such as odor, taste or appearance. Secondary standards are recommendations, not mandates.

**Recommended Upper Limit (RUL)** – Recommended maximum concentration of secondary contaminants. These reflect aesthetic qualities such as odor, taste or appearance. RULs are recommendations, not mandates.

**Waivers:** The Safe Drinking Water Act regulations allow monitoring waivers to reduce or eliminate the monitoring requirements for asbestos, volatile organic chemicals and synthetic organic chemicals. Our system received a monitoring waiver for asbestos and received a waiver for synthetic organic chemicals (SOC) for the previous waiver period. We have applied for and expect to receive a SOC waiver for the current waiver period upon NJDEP approval.

**For Additional Information:** If you have any questions about this report or concerning your water quality, please contact Sandshore School at (973)691-4003 or attend one of our regular Board of Education meetings as posted on our website, [www.motsd.org/about/boe](http://www.motsd.org/about/boe). We want our valued customers to be informed about their water quality.

**Source Water Assessment:** The New Jersey Department of Environmental Protection (NJDEP) has completed and issued the Source Water Assessment Report and Summary for this public water system, which is available at <http://www.nj.gov/dep/watersupply/swap/index.html>, or by contacting the NJDEP, Bureau of Safe Drinking Water at 609-292-5550 or [watersupply@dep.nj.gov](mailto:watersupply@dep.nj.gov).

**Susceptibility Ratings for Sandshore School Sources**

The table below illustrates the susceptibility ratings for the seven contaminant categories (and radon) for each source in the system. The table provides the number of wells and intakes that rated high (H), medium (M), or low (L) for each contaminant category. For susceptibility ratings of purchased water, refer to the specific water system’s source water assessment report.

The seven contaminant categories are defined at the bottom of this page. DEP considered all surface water highly susceptible to pathogens, therefore all intakes received a high rating for the pathogen category. For the purpose of Source Water Assessment Program, radionuclides are more of a concern for ground water than surface water. As a result, surface water intakes’ susceptibility to radionuclides was not determined and they all received a low rating.

**If a system is rated highly susceptible for a contaminant category, it does not mean a customer is or will be consuming contaminated drinking water.** The rating reflects the potential for contamination of source water, not the existence of contamination. Public water systems are required to monitor for regulated contaminants and to install treatment if any contaminants are detected at frequencies and concentrations above allowable levels. As a result of the assessments, DEP may customize (change existing) monitoring schedules based on the susceptibility ratings.

| Sources   | Pathogens |   |   | Nutrients |   |   | Pesticides |   |   | Volatile Organic Compounds |   |   | Inorganics |   |   | Radio-nuclides |   |   | Radon |   |   | Disinfection Byproduct Precursors |   |   |  |
|-----------|-----------|---|---|-----------|---|---|------------|---|---|----------------------------|---|---|------------|---|---|----------------|---|---|-------|---|---|-----------------------------------|---|---|--|
|           | H         | M | L | H         | M | L | H          | M | L | H                          | M | L | H          | M | L | H              | M | L | H     | M | L | H                                 | M | L |  |
| Wells - 1 |           |   | 1 |           | 1 |   |            | 1 |   | 1                          |   |   |            |   | 1 | 1              |   |   | 1     |   |   |                                   |   | 1 |  |

**Pathogens:** Disease-causing organisms such as bacteria and viruses. Common sources are animal and human fecal wastes.  
**Nutrients:** Compounds, minerals and elements that aid growth, that are both naturally occurring and man-made. Examples include nitrogen and phosphorus.

**Volatile Organic Compounds:** Man-made chemicals used as solvents, degreasers, and gasoline components. Examples include benzene, methyl tertiary butyl ether (MTBE), and vinyl chloride.

**Pesticides:** Man-made chemicals used to control pests, weeds and fungus. Common sources include land application and manufacturing centers of pesticides. Examples include herbicides such as atrazine, and insecticides such as chlordane.

**Inorganics:** Mineral-based compounds that are both naturally occurring and man-made. Examples include arsenic, asbestos, copper, lead, and nitrate.

**Radionuclides:** Radioactive substances that are both naturally occurring and man-made. Examples include radium and uranium.

**Radon:** Colorless, odorless, cancer-causing gas that occurs naturally in the environment. For more information go to <http://www.nj.gov/dep/rpp/radon/index.htm> or call (800) 648-0394.

**Disinfection Byproduct Precursors:** A common source is naturally occurring organic matter in surface water. Disinfection byproducts are formed when the disinfectants (usually chlorine) used to kill pathogens react with dissolved organic material (for example leaves) present in surface water.