

AECC water test Results compiled

Building Name/ICOS Name	Sample Barcode	Location description	 Type	Sample Order Number	Lead ppb	Copper ppb
Bldg B	104506	Classroom 4	Sink faucet	39	41	83
Bldg B	104502	flex rm - bldg B	Sink faucet	37	39	550
Bldg C	104542	Health room	Sink faucet	3	26	98
Bldg B	104504	flex rm - bldg B	Bubbler	38	24	92
Bldg C	104540	Lib office	Sink faucet	2	18	80
Bldg B	104508	Classroom 4	Bubbler	40	17	170
Bldg C	104544	Health room	Bubbler	4	15	96
Bldg A	104562	Classroom 16	Bubbler	13	12	89
Bldg A	104553	Classroom 20	Bubbler	25	11	110
Bldg B	104494	Classroom 7	Sink faucet	33	9.4	76
Bldg A	104539	Classroom 14	Sink faucet	18	8.6	110
Bldg B	104500	Classroom 5	Sink faucet	36	8.5	110
Bldg A	104543	Classroom 13	Sink faucet	20	8	66
Bldg A	104558	Classroom 17	Sink faucet	11	7.8	100
Bldg A	104547	Classroom 12	Sink faucet	22	7.7	170
Bldg B	104518	Classroom 10	Bubbler	45	7.4	110
Bldg B	104496	Classroom 6	Sink faucet	34	7.3	130
Bldg A	104552	Classroom 19	Sink faucet	8	6.9	81
Bldg B	104561	Classroom 8	Bubbler	29	6.6	100
Bldg A	104554	Classroom 19	Bubbler	9	4.9	88
Bldg A	104541	Classroom 14	Bubbler	19	4.8	120
Bldg A	104537	flex rm - bldg A	Bubbler	17	4.5	92
Bldg B	104514	Hall right of Rm	Water fountain	43	4.3	240
Bldg B	104512	Classroom 2	Sink faucet	42	4.2	54
Bldg A	104550	Classroom 18	Sink faucet	7	3.9	85
Bldg C	104538	Staff lounge	Sink faucet	1	3.8	34
Bldg B	104520	Classroom 1	Sink faucet	46	3.6	76
Bldg A	104549	Hall right of Rm	Water fountain	23	3.7	240
Bldg A	104551	Classroom 20	Sink faucet	24	3.5	97

AECC water test Results compiled

Building Name/ICOS Name	Sample Barcode	Location description	 Type	Sample Order Number	Lead ppb	Copper ppb
Bldg A	104535	flex rm - bldg A	Sink faucet	16	3.5	77
Bldg A	104531	Classroom 15	Sink faucet	14	3.4	74
Bldg B	104546	Kitchen	Sink faucet	5	3.3	120
Bldg B	104498	Classroom 6	Bubbler	35	3.3	91
Bldg B	104555	Classroom 11	Sink faucet	26	3.1	99
Bldg B	104557	Classroom 11	Bubbler	27	3	120
Bldg A	104545	Classroom 13	Bubbler	21	3	95
Bldg B	104559	Classroom 8	Sink faucet	28	2.6	57
Bldg B	104516	Classroom 10	Sink faucet	44	2.6	48
Bldg A	104533	Classroom 15	Bubbler	15	<2.5	92
Bldg B	104565	Classroom 9	Bubbler	31	<2.5	76
Bldg A	104556	Hall left of Rm 1	Water fountain	10	<2.5	64
Bldg B	104548	Kitchen hall	Water fountain	6	<2.5	49
Bldg B	104492	hall left of Rm 9	Water fountain	32	<2.5	47
Bldg B	104510	Classroom 3	Sink faucet	41	<2.5	44
Bldg A	104560	Classroom 16	Sink faucet	12	<2.5	38
Bldg B	104563	Classroom 9	Sink faucet	30	<2.5	29
Bldg B	--	Classroom 19	Sink faucet	Off	--	--
Bldg B	--	Classroom 19	Sink faucet	off	--	--