


Attendees:

Mike Kubert, Superintendent Buildings & Grounds Foundation (BPS)
Erwin Smieszek, EPA New Jersey Office – Sampling Lead
Sarah Peterson, EPA New Jersey Office – Assistant

Building Photo and Description:



Horace Mann School #6 is a K-8 grade school built in 1914. An addition was added in 1924. To the left is a photo of the front entrance (38th Street) taken by EPA.

BPS Sampling/Analytical Results/Remediation:

BPS staff had conducted sampling of Horace Mann School on December 9, 2013. Sampling began on the 3rd floor, then 2nd floor, then 1st floor, and then the basement, where BPS collected 500mL first draw samples for a total of 22 sampled outlets. BPS sampling included bathroom/art room faucets and if 2 or more outlets are next to each other, BPS would sample all outlets. Analytical results were compared to the EPA Lead and Copper Rule (LCR) action limit of 15ppb. Four (4) results exceeded the 15ppb action limit, the bubbler in Room 102 (18 ppb) which as of the EPA walk-thru not been removed, hallway bubbler (left) next to Gym (16ppb) and has been replaced, both Lunch Room bubblers (22ppb and 16ppb) which have been replaced.

EPA Objective and Observations:

Although BPS had conducted sampling, analysis and remediation of some outlets within BPS, the approach used did not follow the Region 2 Children's Health Initiative - EPA 3T's Lead in Drinking Water program. The objective of the pre-sampling walk-thru is to locate the cold water (CW) potable outlets and determine if these outlets require repair (see underlined outlets below) by BPS prior to EPA sampling. EPA also noted whether the outlets were remediated (i.e. removed, replaced).

The attached floor diagram displays the approximate locations of the building's water main entry, water meter and potable water outlets. The water main (39th Street) enters near Room B4 (PTA room) where the water meter is located, and continues to the remainder of the building. There is no in-line water filter or central chiller (to pre-chill the water) prior to water distribution. Plumbing diagrams are not available, therefore, EPA/BPS made an educated guess as to the water piping layout and water distribution through-out the building (see floor diagram).

All CW outlets were observed for leaks, drips, spray pattern, color, temperature (warm/cold), tempered water devices, screens, point of use (POU) filters. There are no outside drinking fountains, water features or lawn sprinkler system.

Note: EPA only samples one outlet of a group of outlets (i.e. if faucet and bubbler, bubbler takes precedence).
Note: Bathrooms/Custodial/Science/Art outlets are not sampled and are only noted if repair is required.

	ement	by Room B4	Water Main (enters 39 th street) and Meter (Brass)
		Room B4 (PTA)	Faucet (screen on).
		Hallway	Two (2) bubbler by elevator. Right bubbler replaced.
		Room B11	Two (2) faucets and bubbler. <u>Bubbler low flow</u> . Left Faucet screen off. <u>BPS did not sample. Should be sampled</u>
		Lunch Room	Two (2) bubblers. Both bubblers replaced.
1 st Floor		Room 102	Bubbler and Faucet. BPS stated in 2.26.15 email that bubbler was removed. As of 4.9.2015 bubbler had not been removed.
		Hallway	Bubbler by Room 101.
		Room 101	Bubbler and Faucet.
		Hallway	Bubbler by office.
		Room 114	Chiller/Faucet combination in Teachers Cafe. Faucet gooseneck to fill coffee. Faucet (on other side of wall) <u>irregular flow</u> (screen on).
		Nurse	Faucet in Bathroom (screen off).
		Hallway	Bubbler (<u>low flow</u>) by Room 111. <u>BPS did not sample. Should be sampled</u>
		Room 109	Faucet.
2 nd Floor		Hallway	Bubbler by Room 204.
		Hallway	Bubbler by Room 217. <u>Bubbler low flow</u> .
		Hallway	Bubbler by Room 213.
3 rd Floor		Hallway	Bubbler by Room 303.
		Hallway	Bubbler by Room 317.

Note: EPA only samples one outlet of a group of outlets (i.e. if faucet and bubbler, bubbler takes precedence).
Note: Bathrooms/Custodial/Science/Art outlets are not sampled and are only noted if repair is required.

Basement by Room B4 Water Main (enters 39th street) and Meter (Brass)
Room B4 (PTA) Faucet (screen on).
Hallway Two (2) bubbler by elevator. Right bubbler replaced.
Room B11 Two (2) faucets and bubbler. Bubbler low flow. Left Faucet screen off.
BPS did not sample. Should be sampled.

1st Floor Lunch Room Two (2) bubblers. Both bubblers replaced.
Room 102 Bubbler and Faucet. BPS stated in 2.26.15 email that bubbler was removed.
As of 4.9.2015 bubbler had not been removed.
Hallway Bubbler by Room 101.
Room 101 Bubbler and Faucet.
Hallway Bubbler by office.
Room 114 Chiller/Faucet combination in Teachers Cafe. Faucet gooseneck to fill coffee.
Faucet (on other side of wall) irregular flow (screen on).
Nurse Faucet in Bathroom (screen off).
Hallway Bubbler (low flow) by Room 111. BPS did not sample. Should be sampled.
Room 109 Faucet.

2nd Floor Hallway Bubbler by Room 204.
Hallway Bubbler by Room 217. Bubbler low flow.
Hallway Bubbler by Room 213.

3rd Floor Hallway Bubbler by Room 303.
Hallway Bubbler by Room 317.

OK
MR & BK

Attendees:

Mike Kubert, BPS Superintendent Buildings & Grounds Foundation
Scott Nolan, BPS BOE Code Compliance Supervisor
Erwin Smieszek, EPA New Jersey Office – Sampling Lead
Robert Morrell, EPA New Jersey Office – Sampler

Building Photo and Description:



Horace Mann School #6 is a K-8 grade school built in 1914. An addition was added in 1924. To the left is a photo of the front entrance (38th Street) taken by EPA on April 9, 2015.

Pre-Sampling Walk-thru:

On Thursday, April 9, 2015, Erwin Smieszek (Lead) and Sarah Peterson conducted a Lead in Drinking Water pre-sampling walk-thru of #6 Horace Mann School. See April 30, 2015 modified pre-sampling report for objectives and observations.

Sampling Day Introductions/General Conditions

Prior to the sampling event, it was determined that the BPS would not be flushing the outlets.

On Thursday, April 7, 2016, EPA Inspectors Erwin Smieszek (Inspection Lead) and Robert Morrell conducted a Lead in Drinking Water sampling event at the BPS #6 Horace Mann School. EPA met and presented credentials to BPS Mike Kubert and Scott Nolan. Mr. Kubert and Mr. Nolan accompanied EPA during the sampling event. Barbara McGuire (engineer) arrived at 5:15am and was aware that no water is to be used. Ms. McGuire and Mr. Kubert stated that no water was used from the building since 7:30pm April 6, 2016 and the building was locked at 7:30pm on April 6, 2016. There were no do not use water signs posted at the 38th Street (by Room 115) entrance/exit area where EPA/BPS entered to indicate that water sampling was to be conducted.

Sampling Design/Process and Observations:

The water main is located in the Basement. Water sampling would begin with the outlet closest to the water main and continue downstream (see Chain of Custody and Floor Diagrams).

A field reagent blank (FRB) was collected in the Basement PTA room (near sample 01/02) and then water samples were collected. For each outlet sampled, initial and follow-up (30 second) cold-water samples were collected in separate pre-cleaned certified HDPE 250mL wide mouth containers.

Sample codes were either written with permanent marker or labels were placed under each (or next) sampled outlet. Mr. Smieszek provided sampling observations to Mr. Kubert as sampling progressed. Additional sampling information can be found on the attached Floor Diagram and Chain of Custody (COC) form.

	<u>Sample Number</u>	<u>Location</u>	<u>Comments (also see Floor Diagrams/Chain of Custody)</u>
Basement	00	PTA Room	Field Reagent Blank.
Basement	1/2	PTA Room Faucet	Delta Aerator. No POU filter.
Basement	3/4	Lunch Room 2 bubblers	Sampled lower left bubbler Elkay No POU filter.
Basement	5/6	Room B11- Art Room 2 Faucets	Sampled left faucet. Screen off. No POU filter. "Not Drinking Water" sign above sink Note: 4.30.15 report was Lunch Room with 2 faucets/ 1bubbler. BPS did not sample in 2013.
Basement	7/8	Hallway 2 Bubblers by Boys Bathroom.	Sampled lower left bubbler. Halsey Taylor m/n HRFSB s/n131112631 No POU filter.
1 st Floor	9/10	Classroom 109 faucet	Metered. Aerator. No POU filter.
1 st Floor	11/12	Hallway bubbler by Classroom 111	Halsey Taylor m/n HRFSB s/n130810324 No POU filter. Note: BPS did not sample in 2013.
1 st Floor	13/14	Nurse Office faucet	Delta. Screen off. No POU filter.
1 st Floor	15/16	Teacher Café Faucet	Delta – single sink. Aerator. No POU filter.
1 st Floor	17/18	Teacher Café Chiller.	Stand-alone chiller appears old. Could not see make, m/n, s/n Bubbler and goose neck mounted on chiller. Sampled bubbler.
1 st Floor	19/20	Hallway bubbler by Teacher Cafe	No POU filter.
1 st Floor	21/22	Hallway bubbler by Classroom 102	No POU filter.
1 st Floor	23/24	Classroom 101 2 Faucets	Sampled Right Faucet. Both faucets attached to CW line. Delta. Metered. Aerator. No POU filter. Note: 4.30.15 report had bubbler and faucet.
1 st Floor	25/26	Classroom 102 2 Faucets	Sampled Right Faucet. Both faucets attached to CW line. Delta. Metered. Aerator. No POU filter. Note: 4.30.15 report had bubbler and faucet.
Note: Custodial Closet (Room 106) had continuous Cold Water drip.			
2 nd Floor	27/28	Hallway bubbler by Classroom 213	No POU filter.

2 nd Floor	29/30	Hallway bubbler by Classroom 214	No POU filter.
2 nd Floor	31/32	Hallway bubbler by Classroom 204	No POU filter.
3 rd Floor	33/34	Hallway bubbler by Classroom 318	No POU filter.
3 rd Floor	35/36	Hallway bubbler by Classroom 309	Elkay m/n EDFP210C s/n 141226580 No POU filter.

No sampling deviations were made from the EPA Quality Assurance Project Plan (QAPP). No photos were taken.

After sampling complete, bubblers not sampled in banks of 2 were turned on (see notes above). Mr. Kubert stated on March 23, 2016 that BPS has for the past few weeks begun a daily flushing routine at all schools. School custodians will flush all outlets (except bathrooms/slop sinks) prior to student arrival for approximately 60 seconds.

Eighteen (18) potable water outlets, for a total of thirty-six (36) (initial and follow-up) plus one (1) Field Reagent Blank were collected. All samples were preserved with nitric acid (HNO₃) to a pH < 2 at the EPA Laboratory.

Attachments

- Chain of Custody's (4 pages)
- Building Floor Diagrams (4 pages)

Table 1.
OUTLET/ PLUMBING/ SAMPLE CODE

CODE	TYPE OF OUTLET OR PLUMBING	INITIAL SCREENING (1 ST DRAW) SAMPLE	FOLLOW-UP SAMPLES
S	Service Connection to Distribution Main	1S	1M
A	Bubblers Without Central Chiller	1A	2A
B	Bubblers with Central Chiller	1B	2B
-	Central Chiller Unit	-	3B, 4B
C	Water Cooler	1C	2C, 3C, 4C
D	Bottled Water Dispensers	1D	2D
E	Ice Making Machines	1E	2E
F	Water Faucets (Tap)	1F	2F
Interior Plumbing			
G	Laterals	-	1G
H	Headers	-	1H
I	Loops	-	1I
J	Risers	-	1J

Table 2.
FUNCTIONAL SPACE

COD E	FUNCTIONAL SPACE
KI	Kitchen
GY	Gymnasium
CF	Cafeteria
TC	Teachers' Cafeteria
BC	Boys' Cafeteria
GC	Girls' Cafeteria
CR	Classroom
HA	Hallway
BR	Bathroom
GB	Girls' Bathroom
BB	Boys' Bathroom
RM	Room
OF	Office
LB	Laboratory
LI	Library
MO	Medical Office
BO	Boiler Room
LR	Locker Room
NM	Natatorium
WP	Water Meter/Pump Room
SS	Slop Sink

Table 3.
FLOOR CODE

CODE	FLOOR
SB	Sub Basement
BS	Basement
MZ	Mezzanine
01	1 st Floor
02	2 nd Floor
03	3 rd Floor
04	4 th Floor etc.

Table 4.
CONSTRUCTION DATE CODE

CODE	CONSTRUCTION
0	Original Construction
1	1 st Addition
2	2 nd Addition
3	1 st Modernization
4	2 nd Modernization

NOTE: EPA typically samples the highlighted outlets in Table 1.



UNITED STATES ENVIRONMENTAL PROTECTION AGENCY

**Region 2 Laboratory
2890 Woodbridge Avenue
Edison , New Jersey 08837
732-906-6886 Phone
732-906-6165 Fax**

April 20, 2016

John Kushwara
Monitoring & Assessment Branch
DESA/MAB
Edison, NJ 08837

RE: BPS-#6 Horace Mann School-1604018

Enclosed are the results of analyses for samples received by the laboratory on 04/07/2016. The signature below reflects the laboratory's approval of the reported results. If you have any questions concerning this report, please refer to Project Number 1603046 and contact the laboratory.

Sincerely,

A handwritten signature in cursive script, appearing to read "John R. Bourbon".

John R. Bourbon
Chief, DESA/LB

<---Please click here to complete the EPA Region 2 Lab Project Survey---->



UNITED STATES ENVIRONMENTAL PROTECTION AGENCY
Region 2 Laboratory

Final Report

Project: BPS-#6 Horace Mann School-1604018

Project Number: 1603046

Project Narrative:

The National Environmental Laboratory Accreditation Conference Institute (TNI) is a voluntary environmental laboratory accreditation association of State and Federal agencies. TNI established and promoted a National Environmental Laboratory Accreditation Program (NELAP) that provides a uniform set of standards for the generation of environmental data that are of known and defensible quality. The EPA Region 2 Laboratory is NELAP accredited. The Laboratory tests that are accredited have met all the requirements established under the TNI Standards.

Condition Comments

None

Comment(s):

The "Sample Analysis Date and Time" is included in the results section for any analyte with a prescribed holding time of 72 hours or less.

Data Qualifier(s):

- U- The analyte was not detected at or above the Reporting Limit.
- J- The identification of the analyte is acceptable; the reported value is an estimate.
- K- The identification of the analyte is acceptable; the reported value may be biased high.
- L- The identification of the analyte is acceptable; the reported value may be biased low.
- NJ- There is presumptive evidence that the analyte is present; the analyte is reported as a tentative identification. The reported value is an estimate.

Reporting Limit(s):

The Laboratory was able to achieve the appropriate limits for each analyte requested.



UNITED STATES ENVIRONMENTAL PROTECTION AGENCY
Region 2 Laboratory

Final Report

Project:BPS-#6 Horace Mann School-1604018

Project Number: 1603046

SUMMARY REPORT FOR SAMPLES

Field ID	Laboratory ID	Matrix	Date Sampled	Date Received
00 - HM- FRBLANK	1604018-01	Aqueous	04/07/2016 04:44	04/07/2016 08:25
01BSRMINPTA101F	1604018-02	Aqueous	04/07/2016 04:45	04/07/2016 08:25
02BSRMINPTA102F	1604018-03	Aqueous	04/07/2016 04:45	04/07/2016 08:25
03BSRMINLUNC11A	1604018-04	Aqueous	04/07/2016 04:50	04/07/2016 08:25
04BSRMINLUNC12A	1604018-05	Aqueous	04/07/2016 04:50	04/07/2016 08:25
05BSRMINB11-11F	1604018-06	Aqueous	04/07/2016 04:54	04/07/2016 08:25
06BSRMINB11-12F	1604018-07	Aqueous	04/07/2016 04:54	04/07/2016 08:25
07BSHABYBOYS01A	1604018-08	Aqueous	04/07/2016 04:58	04/07/2016 08:25
08BSHABYBOYS02A	1604018-09	Aqueous	04/07/2016 04:58	04/07/2016 08:25
0901CRINC10911F	1604018-10	Aqueous	04/07/2016 05:03	04/07/2016 08:25
1001CRINC10912F	1604018-11	Aqueous	04/07/2016 05:03	04/07/2016 08:25
1101HABYC11111A	1604018-12	Aqueous	04/07/2016 05:07	04/07/2016 08:25
1201HABYC11112A	1604018-13	Aqueous	04/07/2016 05:07	04/07/2016 08:25
1301MOINNURS11F	1604018-14	Aqueous	04/07/2016 05:10	04/07/2016 08:25
1401MOINNURS12F	1604018-15	Aqueous	04/07/2016 05:10	04/07/2016 08:25
1501CFINTEA111F	1604018-16	Aqueous	04/07/2016 05:15	04/07/2016 08:25
1601CFINTEA112F	1604018-17	Aqueous	04/07/2016 05:15	04/07/2016 08:25
1701CFINTEA211B	1604018-18	Aqueous	04/07/2016 05:19	04/07/2016 08:25
1801CFINTEA212B	1604018-19	Aqueous	04/07/2016 05:19	04/07/2016 08:25
1901HABYTEAC01A	1604018-20	Aqueous	04/07/2016 05:23	04/07/2016 08:25
2001HABYTEAC02A	1604018-21	Aqueous	04/07/2016 05:23	04/07/2016 08:25
2101HABYC10201A	1604018-22	Aqueous	04/07/2016 05:26	04/07/2016 08:25
2201HABYC10202A	1604018-23	Aqueous	04/07/2016 05:26	04/07/2016 08:25
2301CRINC10101F	1604018-24	Aqueous	04/07/2016 05:31	04/07/2016 08:25
2401CRINC10102F	1604018-25	Aqueous	04/07/2016 05:31	04/07/2016 08:25
2501CRINC10201F	1604018-26	Aqueous	04/07/2016 05:35	04/07/2016 08:25
2601CRINC10202F	1604018-27	Aqueous	04/07/2016 05:35	04/07/2016 08:25
2702HABYC21301A	1604018-28	Aqueous	04/07/2016 05:40	04/07/2016 08:25
2802HABYC21302A	1604018-29	Aqueous	04/07/2016 05:40	04/07/2016 08:25



UNITED STATES ENVIRONMENTAL PROTECTION AGENCY
Region 2 Laboratory

Final Report

Project: BPS-#6 Horace Mann School-1604018

Project Number: 1603046

SUMMARY REPORT FOR SAMPLES

Field ID	Laboratory ID	Matrix	Date Sampled	Date Received
2902HABYC21401A	1604018-30	Aqueous	04/07/2016 05:43	04/07/2016 08:25
3002HABYC21402A	1604018-31	Aqueous	04/07/2016 05:43	04/07/2016 08:25
3102HABYC20401A	1604018-32	Aqueous	04/07/2016 05:46	04/07/2016 08:25
3202HABYC20402A	1604018-33	Aqueous	04/07/2016 05:46	04/07/2016 08:25
3303HABYC31801A	1604018-34	Aqueous	04/07/2016 05:52	04/07/2016 08:25
3403HABYC31802A	1604018-35	Aqueous	04/07/2016 05:52	04/07/2016 08:25
3503HABYC30901A	1604018-36	Aqueous	04/07/2016 05:57	04/07/2016 08:25
3603HABYC30902A	1604018-37	Aqueous	04/07/2016 05:57	04/07/2016 08:25



UNITED STATES ENVIRONMENTAL PROTECTION AGENCY
Region 2 Laboratory

Final Report

Project: BPS-#6 Horace Mann School-1604018

Project Number: 1603046

SUMMARY REPORT FOR METHODS

Analysis	Method	Certification	Matrix
Lead	EPA 200.8 SOP C-112 Rev 3.3	NELAP	Aqueous



UNITED STATES ENVIRONMENTAL PROTECTION AGENCY

Region 2 Laboratory

Final Report

Project: BPS-#6 Horace Mann School-1604018

Project Number: 1603046

Analyte	Result	Qualifier	Reporting Limit	Units	
Field ID: 00 - HM- FRBLANK		Sample ID: 1604018-01			
Metals ICPMS					
Lead	---	U	1.0	ug/L	
Field ID: 01BSRMINPTA101F		Sample ID: 1604018-02			
Metals ICPMS	Faucet PTA Room				
	1st draw				
Lead	5.1		1.0	ug/L	
Field ID: 02BSRMINPTA102F		Sample ID: 1604018-03			
Metals ICPMS	Faucet PTA Room				
	2nd draw				
Lead	---	U	1.0	ug/L	
Field ID: 03BSRMINLUNC11A		Sample ID: 1604018-04			
Metals ICPMS	Left bubbler in				
	Lunch Room				
Lead	1st draw	---	U	1.0	ug/L
Field ID: 04BSRMINLUNC12A		Sample ID: 1604018-05			
Metals ICPMS	Left bubbler in				
	Lunch Room				
Lead	2nd draw	---	U	1.0	ug/L
Field ID: 05BSRMINB11-11F		Sample ID: 1604018-06			
Metals ICPMS	Faucet in Art Room				
	1st draw				
Lead	130		10	ug/L	
Field ID: 06BSRMINB11-12F		Sample ID: 1604018-07			
Metals ICPMS	Faucet in Art Room				
	2nd draw				



UNITED STATES ENVIRONMENTAL PROTECTION AGENCY
Region 2 Laboratory

Final Report

Project: BPS-#6 Horace Mann School-1604018

Project Number: 1603046

Analyte	Result	Qualifier	Reporting Limit	Units
Field ID: 06BSRMINB11-12F		Sample ID: 1604018-07		
Metals ICPMS				
Lead	2.4		1.0	ug/L
Field ID: 07BSHABYBOYS01A		Sample ID: 1604018-08		
Metals ICPMS	Hallway bubbler by boys lavatory			
Lead	1st draw	-- U	1.0	ug/L
Field ID: 08BSHABYBOYS02A		Sample ID: 1604018-09		
Metals ICPMS	Hallway bubbler by boys lavatory			
Lead	2nd draw	-- U	1.0	ug/L
Field ID: 0901CRINC10911F		Sample ID: 1604018-10		
Metals ICPMS	Faucet in Room 109			
Lead	1st draw		1.0	ug/L
Field ID: 1001CRINC10912F		Sample ID: 1604018-11		
Metals ICPMS	Faucet in Room 109			
Lead	2nd draw	-- U	1.0	ug/L
Field ID: 1101HABYCI1111A		Sample ID: 1604018-12		
Metals ICPMS	Hallway bubbler by Room 111			
Lead	1st draw		1.0	ug/L
Field ID: 1201HABYCI1112A		Sample ID: 1604018-13		
Metals ICPMS	Hallway bubbler by Room 111			
	2nd draw			



UNITED STATES ENVIRONMENTAL PROTECTION AGENCY
Region 2 Laboratory

Final Report

Project: BPS-#6 Horace Mann School-1604018

Project Number: 1603046

Analyte	Result	Qualifier	Reporting Limit	Units
Field ID: 1201HABYC1112A		Sample ID: 1604018-13		
Metals ICPMS				
Lead	2.8		1.0	ug/L
Field ID: 1301MOINNURS11F		Sample ID: 1604018-14		
Metals ICPMS	Faucet in Nurses Office			
Lead	1st draw	1.5	1.0	ug/L
Field ID: 1401MOINNURS12F		Sample ID: 1604018-15		
Metals ICPMS	Faucet in Nurses Office			
Lead	2nd draw	--	U	1.0 ug/L
Field ID: 1501CFINTEA111F		Sample ID: 1604018-16		
Metals ICPMS	Faucet in Teachers Lounge			
Lead	1st draw	--	U	1.0 ug/L
Field ID: 1601CFINTEA112F		Sample ID: 1604018-17		
Metals ICPMS	Faucet in Teachers Lounge			
Lead	2nd draw	--	U	1.0 ug/L
Field ID: 1701CFINTEA211B		Sample ID: 1604018-18		
Metals ICPMS	Chiller in Teachers lounge			
Lead	1st draw	--	U	1.0 ug/L
Field ID: 1801CFINTEA212B		Sample ID: 1604018-19		
Metals ICPMS	Chiller in Teachers Lounge			
	2nd draw			



UNITED STATES ENVIRONMENTAL PROTECTION AGENCY
Region 2 Laboratory

Final Report

Project: BPS-#6 Horace Mann School-1604018

Project Number: 1603046

Analyte	Result	Qualifier	Reporting Limit	Units
Field ID: 1801CFINTEA212B		Sample ID: 1604018-19		
Metals ICPMS				
Lead	1.2		1.0	ug/L
Field ID: 1901HABYTEAC01A		Sample ID: 1604018-20		
Metals ICPMS	Hallway bubbler by Teachers Lounge			
Lead	5.9		1.0	ug/L
Field ID: 2001HABYTEAC02A		Sample ID: 1604018-21		
Metals ICPMS	Hallway bubbler by Teachers Lounge			
Lead	1.1		1.0	ug/L
Field ID: 2101HABYC10201A		Sample ID: 1604018-22		
Metals ICPMS	Hallway bubbler by Room 102			
Lead	3.4		1.0	ug/L
Field ID: 2201HABYC10202A		Sample ID: 1604018-23		
Metals ICPMS	Hallway bubbler by Room 102			
Lead	--	U	1.0	ug/L
Field ID: 2301CRINC10101F		Sample ID: 1604018-24		
Metals ICPMS	Faucet Room 101			
Lead	1.5		1.0	ug/L
Field ID: 2401CRINC10102F		Sample ID: 1604018-25		
Metals ICPMS	Faucet Room 101			
Lead	--	U	1.0	ug/L



UNITED STATES ENVIRONMENTAL PROTECTION AGENCY
Region 2 Laboratory

Final Report

Project: BPS-#6 Horace Mann School-1604018

Project Number: 1603046

Analyte	Result	Qualifier	Reporting Limit	Units
Field ID: 2501CRINC10201F		Sample ID: 1604018-26		
Metals ICPMS Faucet Room 102 Lead 1st draw	4.6		1.0	ug/L
Field ID: 2601CRINC10202F		Sample ID: 1604018-27		
Metals ICPMS Faucet Room 102 Lead 2nd draw	--	U	1.0	ug/L
Field ID: 2702HABYC21301A		Sample ID: 1604018-28		
Metals ICPMS Hallway bubbler by Room 213 Lead 1st draw	3.2		1.0	ug/L
Field ID: 2802HABYC21302A		Sample ID: 1604018-29		
Metals ICPMS Hallway bubbler by Room 213 Lead 2nd draw	2.2		1.0	ug/L
Field ID: 2902HABYC21401A		Sample ID: 1604018-30		
Metals ICPMS Hallway bubbler by Room 214 Lead 1st draw	8.6		1.0	ug/L
Field ID: 3002HABYC21402A		Sample ID: 1604018-31		
Metals ICPMS Hallway bubbler by Room 214 Lead 2nd draw	1.8		1.0	ug/L
Field ID: 3102HABYC20401A		Sample ID: 1604018-32		
Metals ICPMS Hallway bubbler by Room 204 Lead 1st draw	2.6		1.0	ug/L



UNITED STATES ENVIRONMENTAL PROTECTION AGENCY
Region 2 Laboratory

Final Report

Project: BPS-#6 Horace Mann School-1604018

Project Number: 1603046

Analyte	Result	Qualifier	Reporting Limit	Units
Field ID: 3202HABYC20402A				
Sample ID: 1604018-33				
Metals ICPMS	Hallway bubbler by Room 204			
Lead	2nd draw	--	U	1.0 ug/L
Field ID: 3303HABYC31801A				
Sample ID: 1604018-34				
Metals ICPMS	Hallway bubbler by Room 318			
Lead	1st draw	11	1.0	ug/L
Field ID: 3403HABYC31802A				
Sample ID: 1604018-35				
Metals ICPMS	Hallway bubbler by Room 318			
Lead	2nd draw	4.8	1.0	ug/L
Field ID: 3503HABYC30901A				
Sample ID: 1604018-36				
Metals ICPMS	Hallway bubbler by Room 309			
Lead	1st draw	4.5	1.0	ug/L
Field ID: 3603HABYC30902A				
Sample ID: 1604018-37				
Metals ICPMS	Hallway bubbler by Room 309			
Lead	2nd draw	--	U	1.0 ug/L

IDENT INFORMATION

Name:	Bayonne Public Schools
Address:	669 Avenue A, Bayonne, NJ 07002
Contact Rep:	Dr. Patricia McGeehan Superintendent of Schools

EPA INFORMATION

Name:	US Environmental Protection Agency - Region 2
Address:	2890 Woodbridge Ave., Edison, NJ 08837
Proj.Mgr:	John Kushwara

SCHOOL/PROJECT INFORMATION

DG ID:				
DG No./Name:	#6 Horace Mann School			
DG Address:	25 West 38th Street, Bayonne NJ 07002			
Contact Name & Numbers:	Mike Kubert 201.858.5582		mkubert@bboed.org	
Yr. Built:	(1) Yr. 1st Add.:	(2) Yr. 2nd Add.:	(3) Yr. 1st Mod.:	(4) Yr. 2nd Mod.:
	1914	1924		

SPECTOR(S): Erwin Smieszek (Lead) & Bob Morrell

SAMPLING DATE: Thursday, April 7, 2016

SAMPLE DATA

Sample #	Sample Description ID (ID must match container label)						Outlet Information				
	Floor	Functional Space Code	IN/BY	Room Number	Construc. Code	Sample/Outlet Code	Sampled Outlet Location/Coordinates number and Serial number	Model	0 Seconds	30 Seconds	Time of collection (24hr)
1											
2											
3											
4											
5											
6											
7											
8											
9											
10											

1 containers are pre-cleaned/pre-certified 250mL wide-mouth HDPE bottles.

CHAIN OF CUSTODY

Relinquished By:	Received By:	Date/Time:
Erwin J. Smieszek 4/7/2016 4:55		4/7/16 6:25

All samples are Lab Preserved by W. Rickert @ 8:45 on 4/7/16.

Method of shipment/delivery:

Fed-Ex Hand Delivery US Mail UPS Courier Other:

INSTRUCTIONS TO THE LABORATORY

<input type="checkbox"/> Analyze all samples. <input type="checkbox"/> Follow QAPP instructions <input type="checkbox"/> to preserve with HNO ₃ at pH<2 Other:	Lab: US EPA - Region 2 2890 Woodbridge Ave. Edison, NJ 08837 Contact: Ness Tirol	Report Results to: Phone (732) 321-6686 Email: kushwara.john@epa.gov
Comments: Provide Laboratory Data Report (LDR)		

AGENT INFORMATION

Name: Bayonne Public Schools
Address: 669 Avenue A, Bayonne, NJ 07002
Contact Rep: Dr. Patricia McGeehan Superintendent of Schools

EPA INFORMATION

Name: US Environmental Protection Agency - Region 2
Address: 2890 Woodbridge Ave., Edison, NJ 08837
Proj.Mgr: John Kushwara

SCHOOL/PROJECT INFORMATION

DG ID: _____
DG No./Name: #6 Horace Mann School
DG Address: 25 West 38th Street, Bayonne NJ 07002
Contact Name & Numbers: Mike Kubert 201.858.5582 mkubert@bboed.org
Yr. Built: 1914 **(1) Yr. 1st Add.:** 1924 **(2) Yr. 2nd Add.:** _____ **(3) Yr. 1st Mod.:** _____ **(4) Yr. 2nd Mod.:** _____

SPECTOR(S): Erwin Smieszek (Lead) & Bob Morrell

SAMPLING DATE: Thursday, April 7, 2016

SAMPLE DATA

Sample Description ID (ID must match container label)							Outlet Information				
Sample #	Floor	Functional Space Code	IN/BY	Room Number	Construc. Code	Sample/Outlet Code	Sampled Outlet Location/Coordinates number and Serial number	Model	0 Seconds	30 Seconds	Time of collection (24hr)
1	01	HABY	C11111	11A		11A	Handing Bubbler by Classroom C111 Handley Taylor Infl. 4KPS B s/n 130510324		/	/	0507
2	01	HABY	C11112	2A		2A	no filter		/	/	
3	01	MOIN	URS11	1F		1F	Nurse Office Delta - screen off		/	/	0510
4	01	MOIN	URS12	2F		2F	no filter		/	/	
5	01	CFIN	TEA11	1F		1F	Teachers Cafe Delta - single sink		/	/	0515
6	01	CFIN	TEA12	2F		2F	AERATOR - no filter		/	/	
7	01	CFIN	TEA21	1B		1B	Teachers Cafe w/iter has goose neck (off top) and bubbler		/	/	0519
8	01	CFIN	TEA22	2B		2B	sampled bubbler filter appears to be clear model		/	/	
9	01	HABY	TEAC01	1A		1A	Handing Bubbler by Teachers Cafe		/	/	0523
10	01	HABY	TEAC02	2A		2A	no filter		/	/	
11	01	HABY	C10201	1A		1A	Handing Bubbler by Classroom #2		/	/	0526
12	01	HABY	C10202	2A		2A	no filter		/	/	

containers are pre-cleaned/pre-certified 250mL wide-mouth HDPE bottles.

CHAIN OF CUSTODY

Relinquished By:	Received By:	Date/Time:
Erwin Smieszek 4/7/16 0522		4/7/16 0521

Method of shipment/delivery: Fed-Ex Hand Delivery US Mail UPS Courier Other: _____

INSTRUCTIONS TO THE LABORATORY

<input type="checkbox"/> Analyze all samples. <input type="checkbox"/> Follow QAPP instructions <input type="checkbox"/> to preserve with HNO ₃ at pH<2 Other: _____	Lab: US EPA - Region 2 2890 Woodbridge Ave. Edison, NJ 08837 Contact: Ness Tirol	Report Results to: Phone (732) 321-6686 Email: kushwara.john@epa.gov
--	---	---

Comments: Provide Laboratory Data Report (LDR)

ENT INFORMATION

me: Bayonne Public Schools
 dress: 669 Avenue A, Bayonne, NJ 07002
 e Rep: Dr. Patricia McGeehan Superintendent of Schools

EPA INFORMATION

Name: US Environmental Protection Agency - Region 2
 Address: 2890 Woodbridge Ave., Edison, NJ 08837
 Proj.Mgr: John Kushwara

SCHOOL/PROJECT INFORMATION

DG ID:
 DG No./Name: #6 Horace Mann School
 DG Address: 25 West 38th Street, Bayonne NJ 07002
 Contact Name & Numbers: Mike Kubert 201.858.5582 mkubert@bboed.org
 Yr. Built: 1914 (1) Yr. 1st Add.: 1924 (2) Yr. 2nd Add.: (3) Yr. 1st Mod.: (4) Yr. 2nd Mod.:

SPECTOR(S): Erwin Smieszek (Lead) & Bob Morrell

SAMPLING DATE: Thursday, April 7, 2016

SAMPLE DATA

Sample Description ID (ID must match container label)							Outlet Information				
Sample #	Floor	Functional Space Code	IN/BY	Room Number	Construc. Code	Sample/Outlet Code	Sampled Outlet Location/Coordinates number and Serial number	Model	0 Seconds	30 Seconds	Time of collection (24hr)
3	01	CRINC1	01	01	F	DELTA Metered	2 Faucets line split sampled right				0531
4	01	CRINC1	01	02	F	Aerator	No POU filter				
5	01	CRINC1	02	01	F	DELTA Metered	2 Faucets/line split/sampled by ht.				0535
6	01	CRINC1	02	02	F	Aerator	No POU filter				
7	02	HABYC2	13	01	A		Hallway bubbler by Classroom 213				0540
8	02	HABYC2	13	02	A		No POU filter				
9	02	HABYC2	14	01	A		Hallway B-bubbler by Classroom 214				0543
10	02	HABYC2	14	02	A		No POU filter				
11	02	HABYC2	14	04	1	A	Hallway B-bubbler by classroom 207				0546
12	02	HABYC2	14	04	2	A	No POU filter				
13	03	HABYC3	18	01	A		Hallway bubbler by classroom 318				0552
14	03	HABYC3	18	02	A		No POU filter				

containers are pre-cleaned/pre-certified 250mL wide-mouth HDPE bottles.

CHAIN OF CUSTODY

Relinquished By:	Received By:	Date/Time:
Erwin J. Smieszek 4/7/16 05:22		04/07/16 08:25

Method of shipment/delivery: Fed-Ex Hand Delivery US Mail UPS Courier Other:

INSTRUCTIONS TO THE LABORATORY

Analyze all samples.
 Follow QAPP instructions
 to preserve with HNO₃ at pH<2
 Other:

Lab: US EPA - Region 2
 2890 Woodbridge Ave.
 Edison, NJ 08837
 Contact: Ness Tirol

Report Results to:
 Phone (732) 321-6686
 Email: kushwara.john@epa.gov

Comments: Provide Laboratory Data Report (LDR)

ENT INFORMATION

Agency:	Bayonne Public Schools
Address:	669 Avenue A, Bayonne, NJ 07002
Contact Rep:	Dr. Patricia McGeehan Superintendent of Schools

EPA INFORMATION

Name:	US Environmental Protection Agency - Region 2
Address:	2890 Woodbridge Ave., Edison, NJ 08837
Proj.Mgr:	John Kushwara

SCHOOL/PROJECT INFORMATION

DG ID:				
DG No./Name:	#6 Horace Mann School			
DG Address:	25 West 38th Street, Bayonne NJ 07002			
Contact Name & Numbers:	Mike Kubert 201.858.5582 mkubert@bboed.org			
Yr. Built:	(1) Yr. 1st Add.:	(2) Yr. 2nd Add.:	(3) Yr. 1st Mod.:	(4) Yr. 2nd Mod.:
1914	1924			

SPECTOR(S): Erwin Smieszek (Lead) & Bob Morrell

SAMPLING DATE: Thursday, April 7, 2016

SAMPLE DATA

Sample Description ID (ID must match container label)						Outlet Information					
Sample #	Floor	Functional Space Code	IN/BY	Room Number	Construc. Code	Sample/Outlet Code	Sampled Outlet Location/Coordinates number and Serial number	Model	0 Seconds	30 Seconds	Time of collection (24hr)
5	03	H A B Y C 3 0 9 0 1 A					ELKAY m/n EDFA210C s/n 1141226530 followed by classroom 309				5557
6	03	H A B Y C 3 0 9 0 2 A					no PVC filter				

All containers are pre-cleaned/pre-certified 250mL wide-mouth HDPE bottles.

CHAIN OF CUSTODY

Relinquished By:	Received By:	Date/Time:
Erwin J. Smieszek 4/7/16 09:20		4/7/16 08:21

Method of shipment/delivery: Fed-Ex Hand Delivery US Mail UPS Courier Other

INSTRUCTIONS TO THE LABORATORY

<input type="checkbox"/> Analyze all samples. <input type="checkbox"/> Follow QAPP instructions <input type="checkbox"/> to preserve with HNO ₃ at pH<2 Other:	Lab: US EPA - Region 2 2890 Woodbridge Ave. Edison, NJ 08837 Contact: Ness Tirol	Report Results to: Phone (732) 321-6686 Email: kushwara.john@epa.gov
--	---	--

Comments: Provide Laboratory Data Report (LDR)



UNITED STATES ENVIRONMENTAL PROTECTION AGENCY

**Region 2 Laboratory
2890 Woodbridge Avenue
Edison , New Jersey 08837
732-906-6886 Phone
732-906-6165 Fax**

June 30, 2016

John Kushwara
Monitoring & Assessment Branch
DESA/MAB
Edison, NJ 08837

E: BPS-#6 Horace Mann School-1606042

Enclosed are the results of analyses for samples received by the laboratory on 06/16/2016. The signature below reflects the laboratory's approval of the reported results. If you have any questions concerning this report, please refer to Project Number 1606038 and contact the laboratory.

Sincerely,

A handwritten signature in cursive script, appearing to read "John R. Bourbon".

John R. Bourbon
Chief, DESA/LB



UNITED STATES ENVIRONMENTAL PROTECTION AGENCY
Region 2 Laboratory

Final Report

Project: BPS-#6 Horace Mann School-1606042

Project Number: 1606038

Project Narrative:

The National Environmental Laboratory Accreditation Conference Institute (TNI) is a voluntary environmental laboratory accreditation association of State and Federal agencies. TNI established and promoted a National Environmental Laboratory Accreditation Program (NELAP) that provides a uniform set of standards for the generation of environmental data that are of known and defensible quality. The EPA Region 2 Laboratory is NELAP accredited. The Laboratory tests that are accredited have met all the requirements established under the TNI Standards.

Condition Comments

None

Comment(s):

The "Sample Analysis Date and Time" is included in the results section for any analyte with a prescribed holding time of 72 hours or less.

Data Qualifier(s):

- U- The analyte was not detected at or above the Reporting Limit.
- J- The identification of the analyte is acceptable; the reported value is an estimate.
- K- The identification of the analyte is acceptable; the reported value may be biased high.
- L- The identification of the analyte is acceptable; the reported value may be biased low.
- NJ- There is presumptive evidence that the analyte is present; the analyte is reported as a tentative identification. The reported value is an estimate.

Reporting Limit(s):

The Laboratory was able to achieve the appropriate limits for each analyte requested.



UNITED STATES ENVIRONMENTAL PROTECTION AGENCY
Region 2 Laboratory

Final Report

Project: BPS-#6 Horace Mann School-1606042

Project Number: 1606038

SUMMARY REPORT FOR SAMPLES

Field ID	Laboratory ID	Matrix	Date Sampled	Date Received
00 - HM- FRBLANK	1606042-01	Aqueous	06/16/2016 04:08	06/16/2016 08:30
05BSRMNB11-11F	1606042-02	Aqueous	06/16/2016 04:10	06/16/2016 08:30
06BSRMNB11-12F	1606042-03	Aqueous	06/16/2016 04:10	06/16/2016 08:30



UNITED STATES ENVIRONMENTAL PROTECTION AGENCY
Region 2 Laboratory

Final Report

Project: BPS-#6 Horace Mann School-1606042

Project Number: 1606038

SUMMARY REPORT FOR METHODS

Analysis	Method	Certification	Matrix
Lead	EPA 200.8 SOP C-112 Rev 3.4	NELAP	Aqueous



UNITED STATES ENVIRONMENTAL PROTECTION AGENCY
Region 2 Laboratory

Final Report

Project: BPS-#6 Horace Mann School-1606042

Project Number: 1606038

Analyte	Result	Qualifier	Reporting Limit	Units	Date and Time of Analysis*
Field ID: 00 - HM- FRBLANK			Sample ID: 1606042-01		
Metals ICPMS Lead	---	U	1.0	ug/L	
Field ID: 05BSRMINB11-11F			Sample ID: 1606042-02		
Metals ICPMS Lead	Faucet in Art Room 1st draw		120	5.0 ug/L	
Field ID: 06BSRMINB11-12F			Sample ID: 1606042-03		
Metals ICPMS Lead	Faucet in Art Room 2nd draw		3.8	1.0 ug/L	

Horace Mann School - #6

On 4/7/2016 the EPA sampled for lead at eighteen (18) potable water outlets, for a total of thirty-six (36) samples. Results indicate that there were two (2) results greater than 15ug/l (ppb)

Location (1) – First floor hallway bubbler by Room 11 – Results 130ug/l (ppb)

Location (2) – Basement sink in Art Room – Results 40ug/l (ppb)

Remedial action taken-

Location (1) – Disconnected and removed hallway bubbler from outside Room 11. Bubbler was not replaced.

Location (2) – Disconnected and removed sink from Art room. Installed new sink and faucet. Ran new Copper pipe using pro press fittings. Installed a new aqua pure water filter model 3MFF100

Retesting by the EPA was done on 9/1/2016. Results were below the action limit of 15ug/l (ppb)



UNITED STATES ENVIRONMENTAL PROTECTION AGENCY

**Region 2 Laboratory
2890 Woodbridge Avenue
Edison , New Jersey 08837
732-906-6886 Phone
732-906-6165 Fax**

October 04, 2016

John Kushwara
Monitoring & Assessment Branch
DESA/MAB
Edison, NJ 08837

RE: BPS-#6 Horace Mann School-1609008

Enclosed are the results of analyses for samples received by the laboratory on 09/01/2016. The signature below reflects the laboratory's approval of the reported results. If you have any questions concerning this report, please refer to Project Number 1609008 and contact the laboratory.

Sincerely,

A handwritten signature in cursive script, appearing to read "John R. Bourbon".

John R. Bourbon
Chief, DESA/LB



UNITED STATES ENVIRONMENTAL PROTECTION AGENCY
Region 2 Laboratory

Final Report

Project: BPS-#6 Horace Mann School-1609008

Project Number: 1609008

Project Narrative:

The National Environmental Laboratory Accreditation Conference Institute (TNI) is a voluntary environmental laboratory accreditation association of State and Federal agencies. TNI established and promoted a National Environmental Laboratory Accreditation Program (NELAP) that provides a uniform set of standards for the generation of environmental data that are of known and defensible quality. The EPA Region 2 Laboratory is NELAP accredited. The Laboratory tests that are accredited have met all the requirements established under the TNI Standards.

Condition Comments

None

Comment(s):

The "Sample Analysis Date and Time" is included in the results section for any analyte with a prescribed holding time of 72 hours or less.

Data Qualifier(s):

- U- The analyte was not detected at or above the Reporting Limit.
- J- The identification of the analyte is acceptable; the reported value is an estimate.
- K- The identification of the analyte is acceptable; the reported value may be biased high.
- L- The identification of the analyte is acceptable; the reported value may be biased low.
- NJ- There is presumptive evidence that the analyte is present; the analyte is reported as a tentative identification. The reported value is an estimate.

Reporting Limit(s):

The Laboratory was able to achieve the appropriate limits for each analyte requested.



UNITED STATES ENVIRONMENTAL PROTECTION AGENCY
Region 2 Laboratory

Final Report

Project: BPS-#6 Horace Mann School-1609008

Project Number: 1609008

SUMMARY REPORT FOR SAMPLES

Field ID	Laboratory ID	Matrix	Date Sampled	Date Received
00-HM-FRBLANK	1609008-01	Aqueous	09/01/2016 05:09	09/01/2016 09:00
05BSRMINB11-11F	1609008-02	Aqueous	09/01/2016 05:12	09/01/2016 09:00
06BSRMINB11-12F	1609008-03	Aqueous	09/01/2016 05:12	09/01/2016 09:00



UNITED STATES ENVIRONMENTAL PROTECTION AGENCY
Region 2 Laboratory

Final Report

Project: BPS-#6 Horace Mann School-1609008

Project Number: 1609008

SUMMARY REPORT FOR METHODS

Analysis	Method	Certification	Matrix
Lead	EPA 200.8 SOP C-112 Rev 3.4	NELAP	Aqueous

E.P.A Region 2 Laboratory

NOTE: The results recorded in this report relate only to the samples as received on the date and at the time noted
Reported: 10/4/2016



UNITED STATES ENVIRONMENTAL PROTECTION AGENCY
Region 2 Laboratory

Final Report

Project: BPS-#6 Horace Mann School-1609008

Project Number: 1609008

Analyte	Result	Qualifier	Reporting Limit	Units	Date and Time of Analysis*
Field ID: 00-HM-FR-BLANK			Sample ID: 1609008-01		
Metals ICPMS Lead	---	U	1.0	ug/L	
Field ID: 05BSRMINB11-11			Sample ID: 1609008-02		
Metals ICPMS Lead	Faucet in Art Room 1st draw	---	U	1.0	ug/L
Field ID: 06BSRMINB11-12			Sample ID: 1609008-03		
Metals ICPMS Lead	Faucet in Art Room 2nd draw	---	U	1.0	ug/L

CLIENT INFORMATION

Name:	Bayonne Public Schools
Address:	669 Avenue A, Bayonne, NJ 07002
Contact Rep:	Dr. Patricia McGeehan Superintendent of Schools

EPA INFORMATION

Name:	US Environmental Protection Agency - Region 2
Address:	2890 Woodbridge Ave., Edison, NJ 08837
Proj.Mgr:	John Kushwara

SCHOOL/PROJECT INFORMATION

BLDG ID:				
BLDG No./Name:	#6 Horace Mann School			
BLDG Address:	25 West 38th Street, Bayonne NJ 07002			
Contact Name & Numbers:	Mike Kubert 201.858.5582		mkubert@bboed.org	
Yr. Built:	(1) Yr. 1st Add.:	(2) Yr. 2nd Add.:	(3) Yr. 1st Mod.:	(4) Yr. 2nd Mod.:
1914	1924			

INSPECTOR(S): Erwin Smieszek (Lead) & Bob Morrell

SAMPLING DATE: Thursday, September 1, 2016

SAMPLE DATA

Sample Description ID (ID must match container label)							Outlet Information				
Sample #	Floor	Functional Space Code	IN/BY	Room Number	Construct. Code	Sample/Outlet Code	Sampled Outlet Location/Coordinates number and Serial number	Model	0 Seconds	30 Seconds	Time of collection (24hr)
<i>EGS</i>											
00		HM		FIRBLANK			Room B-11 (ART)				0509
05		BSRM		B11-11F			Room B-11 (ART) DELTA Aerator	VALUE OFF NEEDED TO BE Turned On			0512
06		BSRM		B11-12F			COPPER PIPE (PROBESS CONNECTORS) UNFILTERED SHFF101 with timer	Installed 7/21/16			
<i>EGS</i>											

All containers are pre-cleaned/pre-certified 250mL wide-mouth HDPE bottles.

CHAIN OF CUSTODY

Relinquished By:	Received By:	Date/Time
Erwin J. Smieszek	<i>[Signature]</i>	09/01/16 9:00 AM
<i>[Signature]</i>	<i>[Signature]</i>	9/1/16 9:30

Preserved at 0914 on 9/1/16 *ur*

Method of shipment/delivery: Fed-Ex Hand Delivery US Mail UPS Courier Other:

INSTRUCTIONS TO THE LABORATORY

<input checked="" type="checkbox"/> Analyze all samples.	Lab: US EPA - Region 2 2890 Woodbridge Ave. Edison, NJ 08837 Contact: Ness Tirol	Report Results to:
<input checked="" type="checkbox"/> Follow QAPP instructions		Phone (732) 321-6686
<input type="checkbox"/> Lab to preserve with HNO ₃ at pH<2		Email: kushwara.john@epa.gov
Other:		

Comments: Provide Laboratory Data Report (LDR)

Aqua-Pure®

Spec # _____

Quantity _____

Applications:

- Chlorine Taste & Odor (CTO)
- Particulate
- Lead & *Cryptosporidium parvum* Cysts
- Select VOCs*



3MFF100

Models:

3MFF100

Full Flow Drinking Water System

At a Glance:

- Easy to install
- Easy to replace cartridge
- 6,000 Gallon/22,712 liter Capacity
- 2.5 gpm/9.5 lpm Flow Rate
- 0.2 Nominal Micron Rating
- NSF Certified for NSF/ANSI Standard 42, Standard 53, and CSA B483.1
- WQA Certified for NSF/ANSI 372 to meet low lead compliance for CA AB1953
- Certified for use in California per California Department of Public Health Certification Number: 09-2017
- Registered for use in Los Angeles County by the Department of Building and Safety. File Number: M-080152

Product Benefits:

- 2.5 GPM allows filter system to be used on existing kitchen and /or bathroom faucets
- 3/8" NPT connections on filter head makes installation easy
- Shut off valve in head eliminates the need to turn off water supply
- Sanitary quick change cartridge design eliminates the need to handle filter media
- Easy filter change-outs, just a 1/4 turn to remove and insert
- Designed to connect to your existing primary kitchen or bathroom faucet for full flow filtration
- *This system reduces CTO, particulate, and a number of select VOCs (Benzene, p-Dichlorobenzene & Toxaphene), as well as lead and 99.95% of filterable *Cryptosporidium parvum* cysts

Physical Specifications:

Model No. (Part No.)	Inlet/ Outlet Size	Dimensions		Approximate Weight	Flow Rate	Capacity	Max. Water Temp.	Max. Water Pressure	Std. Replacement Ctg. No.
		Height	Diameter						
3MFF100 (56163-18)	3/8" NPT	16" (40.6 cm)	4-1/2" (11.4 cm)	4 lbs (1.8 kg)	2.5 gpm (9.5 lpm)	6,000 gallons (22,712 liters)	100 °F (37.8 °C)	125 psi (862 kPa)	56134-32
3MFF101 (56134-32)	N/A	14.5" (36.8 cm)		3.5 lbs (1.6kg)	N/A				N/A

3M



BAYONNE PUBLIC SCHOOLS
Administration Building
669 Avenue A
Bayonne, New Jersey 07002

Patricia L. McGeehan, Ed.D.,
Superintendent of Schools

Tel: (201) 858-5815

October 31, 2016

Dear Horace Mann School Community,

Our school system is committed to protecting student, teacher and staff health. In an effort to protect our community, the Bayonne School District tested our Elementary schools' drinking water for lead.

Why Test School Drinking Water for Lead?

High levels of lead in drinking water can cause health problems. Lead is most dangerous for pregnant women, infants, and children under 6 years old. Exposure to high levels of lead during pregnancy contributes to low birth weight and developmental delays in infants. In young children, lead exposure can lower IQ levels, affect hearing, reduce attention span and hurt school performance. In very high levels, lead can even cause brain damage.

In an effort to protect public health, the U.S. Environmental Protection Agency (EPA) suggests that schools and day care facilities test their drinking water for lead. If lead is found at any water outlet at levels above 20 parts per billion (ppb), the EPA recommends taking action to reduce the lead. The level utilized by the NJDEP is 15 parts per billion (ppb).

Is Our School's Drinking Water Safe?

Yes, our schools' water is safe. The Bayonne School District tested our drinking water for lead. There were 36 water samples taken at Horace Mann Community School and only two (2) of them showed lead levels above the ppb mark. In other words 94.44 % of the water outlets tested did not have any lead problems.


The first outlet with high lead levels was a bubbler outside Room 11. We identified the source of the lead so we could fix the problem. The old bubbler in the hallway outside Room 11 was disconnected and removed. The bubbler was not replaced as it was not needed.

The second outlet with high lead levels was a sink in the basement Art Room. We identified the source of the lead so we could fix the problem. The old sink was disconnected and removed. A new sink and faucet were installed along with new copper piping using pro press fittings. A new aqua pure filter was also installed. The outlet was tested again which confirmed that the problem was fixed.

How Can I Learn More?

You can see a copy of all of our water testing results at the District's Central Office, which is open Monday to Friday from 9:00 am to 4:00 pm and on our Web site at www.bboed.org. If you have any questions regarding the water quality in our schools, please contact our Risk Manager, Christopher L. Patella at 201-858-5936. Information about water quality and sampling for lead at home can be obtained from your local water supplier or state drinking water agency.

Sincerely,


Patricia L. McGeehan Ed.D.
Superintendent of Schools