



20-21 Wagaraw Road – Bldg. 35E, Fair Lawn, NJ 07410
(973) 636-9145/Email:info@envirovisionconsultants.com

CLIENT: Park Ridge School District

PROJECT: Lead (Pb) in Drinking Water

ADDRESS: 2 Park Avenue, Park Ridge, NJ 07656

FIELD TECHNICIAN: Steven Audenried

REPORT DATE: March 11, 2025

Project Number 25-036

Park Ridge Jr./Sr. High School

As per your request, EnviroVision Consultants, Inc. was contracted by Park Ridge School District to conduct Lead (Pb) in water sampling at the Park Ridge Jr./Sr. High School on February 21, 2025. The sample locations, in addition to a unique sample location code was determined/assigned by school district personnel. The school district performed the proper flushing of outlets prior to sampling and EnviroVision was instructed to collect only first draw samples for this sampling event. The school district's corresponding flushing logs should be attached to this report.

The facility was closed at the time of sampling in order to prevent occupants from utilizing any water outlets. After flushing, the water in the facility must remain motionless in the plumbing fixtures for a minimum of 8 hours, but no more than 48 hours. Cold water samples were collected in pre-cleaned high-density polyethylene (HDPE) 250mL wide mouth bottles.

The samples were analyzed at EMSL Analytical, Inc. in Cinnaminson, New Jersey (NJDEP#03036), accredited in accordance with NELAC (National Environmental Laboratory Accreditation Conference). The analytical method utilized was inductively coupled plasma mass spectrometry ICP-MS (EPA 200.8).

Results: Thirty-two samples were collected and analyzed from Park Ridge Jr./Sr. High School. A blank sample was also analyzed, as required, for Quality Assurance Purposes.

Results: All of the samples analyzed were either "None Detected" or less than the US EPA established threshold for lead in drinking water of 15 parts per billion (ppb).

Should you have any questions, or if we could be of any further assistance, please feel free to contact our office. EnviroVision looks forward to providing you with the service and attention to detail you have come to expect from us.

Sincerely,
EnviroVision Consultants, Inc.

Cathy DiNardo

Cathy DiNardo, Project Manager

Attached: Lab results, Associated data sheets

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax:cs@emsl.com
EMSL-CIN-01

EMSL Order ID: 012510749**LIMS Reference ID:** AD10749**EMSL Customer ID:** RAMA51**Attention:** Info

EnviroVision Consultants, Inc [RAMA51]
20-21 Wagaraw Rd, Bldg 35E
Fair Lawn, NJ 07410
(973) 636-9145
info@envirovisionconsultants.com

Project Name:

Park Ridge Jr& Sr High School - 25-036

Customer PO:**EMSL Sales Rep:**

Sheryl Steinmetz

Received:

02/24/2025 12:00

Reported:

03/10/2025 14:14

Analytical Results

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: HS WC BFG1/Hallway by Classroom 13									
				Lims Reference ID:	AD10749-01	Matrix: Drinking Water		Sampled: 02/21/25 09:15:00	
Metals									
Lead	ND	1		1.00	µg/L	03/03/25 14:01	03/05/25 21:11	JW1	EPA 200.8 (DA)/EPA 200.8
Sample: HS WC WFG1/Hallway by Classroom 13									
				Lims Reference ID:	AD10749-02	Matrix: Drinking Water		Sampled: 02/21/25 09:17:00	
Metals									
Lead	ND	1		1.00	µg/L	03/05/25 09:54	03/06/25 15:34	JW1	EPA 200.8 (Dig)/EPA 200.8
Sample: HS PF KTI/Kitchen									
				Lims Reference ID:	AD10749-03	Matrix: Drinking Water		Sampled: 02/21/25 09:19:00	
Metals									
Lead	1.87	1		1.00	µg/L	03/03/25 14:01	03/05/25 21:18	JW1	EPA 200.8 (DA)/EPA 200.8
Sample: HS FP - 01/Kitchen									
				Lims Reference ID:	AD10749-04	Matrix: Drinking Water		Sampled: 02/21/25 09:21:00	
Metals									
Lead	1.59	1		1.00	µg/L	03/03/25 14:01	03/05/25 21:20	JW1	EPA 200.8 (DA)/EPA 200.8
Sample: HS FP - 02/Kitchen									
				Lims Reference ID:	AD10749-05	Matrix: Drinking Water		Sampled: 02/21/25 09:23:00	
Metals									
Lead	2.24	1		1.00	µg/L	03/03/25 14:01	03/05/25 21:23	JW1	EPA 200.8 (DA)/EPA 200.8
Sample: HS FP-03/Kitchen									
				Lims Reference ID:	AD10749-06	Matrix: Drinking Water		Sampled: 02/21/25 09:29:00	
Metals									
Lead	1.33	1		1.00	µg/L	03/03/25 14:01	03/05/25 21:25	JW1	EPA 200.8 (DA)/EPA 200.8
Sample: HS FP-04/Kitchen									
				Lims Reference ID:	AD10749-07	Matrix: Drinking Water		Sampled: 02/21/25 09:31:00	
Metals									
Lead	2.89	1		1.00	µg/L	03/03/25 14:01	03/05/25 21:27	JW1	EPA 200.8 (DA)/EPA 200.8
Sample: HS WC BF G2/Hallway by Classroom 11									
				Lims Reference ID:	AD10749-08	Matrix: Drinking Water		Sampled: 02/21/25 09:32:00	
Metals									
Lead	ND	1		1.00	µg/L	03/03/25 14:01	03/05/25 21:30	JW1	EPA 200.8 (DA)/EPA 200.8
Sample: HS WC WF G2/Hallway by Classroom 11									
				Lims Reference ID:	AD10749-09	Matrix: Drinking Water		Sampled: 02/21/25 09:34:00	
Metals									
Lead	ND	1		1.00	µg/L	03/03/25 14:01	03/05/25 21:32	JW1	EPA 200.8 (DA)/EPA 200.8

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077
 Telephone: 856-858-4800 Fax:cs@emsl.com
 EMSL-CIN-01

EMSL Order ID: 012510749**LIMS Reference ID:** AD10749**EMSL Customer ID:** RAMA51**Attention:** Info

EnviroVision Consultants, Inc [RAMA51]
 20-21 Wagaraw Rd, Bldg 35E
 Fair Lawn, NJ 07410
 (973) 636-9145
 info@envirovisionconsultants.com

Project Name:

Park Ridge Jr& Sr High School - 25-036

Customer PO:**EMSL Sales Rep:**

Sheryl Steinmetz

Received:

02/24/2025 12:00

Reported:

03/10/2025 14:14

Analytical Results

(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: HS WC BF 11/Hallway by Guidance Office Lims Reference ID: AD10749-10 Matrix: Drinking Water Sampled: 02/21/25 09:36:00									
Metals									
Lead	ND	1		1.00	µg/L	03/03/25 14:06	03/05/25 15:34	JW1	EPA 200.8 (DA)/EPA 200.8
Sample: HS WC WF11/Hallway by Guidance Office Lims Reference ID: AD10749-11 Matrix: Drinking Water Sampled: 02/21/25 09:40:00									
Metals									
Lead	ND	1		1.00	µg/L	03/03/25 14:06	03/05/25 15:40	JW1	EPA 200.8 (DA)/EPA 200.8
Sample: HS WC BF 12/Hallway by Rm 104 Lims Reference ID: AD10749-12 Matrix: Drinking Water Sampled: 02/21/25 09:42:00									
Metals									
Lead	ND	1		1.00	µg/L	03/03/25 14:06	03/05/25 15:42	JW1	EPA 200.8 (DA)/EPA 200.8
Sample: HS WC WF12/By Classroom 106 Lims Reference ID: AD10749-13 Matrix: Drinking Water Sampled: 02/21/25 09:44:00									
Metals									
Lead	ND	1		1.00	µg/L	03/03/25 14:06	03/05/25 15:44	JW1	EPA 200.8 (DA)/EPA 200.8
Sample: HS TL 103/Teacher Lounge Lims Reference ID: AD10749-14 Matrix: Drinking Water Sampled: 02/21/25 09:46:00									
Metals									
Lead	1.02	1		1.00	µg/L	03/03/25 14:06	03/05/25 15:46	JW1	EPA 200.8 (DA)/EPA 200.8
Sample: HS WC BF21/By Classroom 204 Lims Reference ID: AD10749-15 Matrix: Drinking Water Sampled: 02/21/25 09:47:00									
Metals									
Lead	ND	1		1.00	µg/L	03/03/25 14:06	03/05/25 15:52	JW1	EPA 200.8 (DA)/EPA 200.8
Sample: HS WC WF21/By Classroom 204 Lims Reference ID: AD10749-16 Matrix: Drinking Water Sampled: 02/21/25 09:48:00									
Metals									
Lead	ND	1		1.00	µg/L	03/03/25 14:06	03/05/25 15:54	JW1	EPA 200.8 (DA)/EPA 200.8
Sample: HS NS N01/Nurse Lims Reference ID: AD10749-17 Matrix: Drinking Water Sampled: 02/21/25 09:52:00									
Metals									
Lead	ND	1		1.00	µg/L	03/03/25 14:06	03/05/25 15:56	JW1	EPA 200.8 (DA)/EPA 200.8
Sample: HS WC BF L1/Classroom 21 Lims Reference ID: AD10749-18 Matrix: Drinking Water Sampled: 02/21/25 09:55:00									
Metals									
Lead	ND	1		1.00	µg/L	03/03/25 14:06	03/05/25 15:58	JW1	EPA 200.8 (DA)/EPA 200.8

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077
 Telephone: 856-858-4800 Fax:cs@emsl.com
 EMSL-CIN-01

EMSL Order ID: 012510749**LIMS Reference ID:** AD10749**EMSL Customer ID:** RAMA51**Attention:** Info

EnviroVision Consultants, Inc [RAMA51]
 20-21 Wagaraw Rd, Bldg 35E
 Fair Lawn, NJ 07410
 (973) 636-9145
 info@envirovisionconsultants.com

Project Name:

Park Ridge Jr& Sr High School - 25-036

Customer PO:**EMSL Sales Rep:**

Sheryl Steinmetz

Received:

02/24/2025 12:00

Reported:

03/10/2025 14:14

Analytical Results

(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: HS WC WF L1/Classroom 21									
		Lims Reference ID:		AD10749-19		Matrix: Drinking Water		Sampled: 02/21/25 09:56:00	
Metals									
Lead	ND	1	1.00	µg/L	03/03/25 14:06	03/05/25 15:59	JW1	EPA 200.8 (DA)/EPA 200.8	
Sample: HS WC BFG3/By Library									
		Lims Reference ID:		AD10749-20		Matrix: Drinking Water		Sampled: 02/21/25 09:59:00	
Metals									
Lead	ND	1	1.00	µg/L	03/03/25 14:06	03/05/25 16:01	JW1	EPA 200.8 (DA)/EPA 200.8	
Sample: HS WC WFG3/By Library									
		Lims Reference ID:		AD10749-21		Matrix: Drinking Water		Sampled: 02/21/25 10:01:00	
Metals									
Lead	ND	1	1.00	µg/L	03/03/25 14:06	03/05/25 16:07	JW1	EPA 200.8 (DA)/EPA 200.8	
Sample: HS WC BF31/By Tech Room									
		Lims Reference ID:		AD10749-22		Matrix: Drinking Water		Sampled: 02/21/25 10:05:00	
Metals									
Lead	ND	1	1.00	µg/L	03/03/25 14:06	03/05/25 16:09	JW1	EPA 200.8 (DA)/EPA 200.8	
Sample: HS WC WF31/By Tech Room									
		Lims Reference ID:		AD10749-23		Matrix: Drinking Water		Sampled: 02/21/25 10:05:00	
Metals									
Lead	ND	1	1.00	µg/L	03/03/25 14:06	03/05/25 16:39	JW1	EPA 200.8 (DA)/EPA 200.8	
Sample: HS HS TS T1/Trainer Office									
		Lims Reference ID:		AD10749-24		Matrix: Drinking Water		Sampled: 02/21/25 10:09:00	
Metals									
Lead	ND	1	1.00	µg/L	03/03/25 14:06	03/05/25 16:54	JW1	EPA 200.8 (DA)/EPA 200.8	
Sample: HS-1M-TRM/Trainers Room									
		Lims Reference ID:		AD10749-25		Matrix: Drinking Water		Sampled: 02/21/25 10:13:00	
Metals									
Lead	ND	1	1.00	µg/L	03/03/25 14:06	03/05/25 16:43	JW1	EPA 200.8 (DA)/EPA 200.8	
Sample: HS-1M-CLM/Trainers Room									
		Lims Reference ID:		AD10749-26		Matrix: Drinking Water		Sampled: 02/21/25 10:17:00	
Metals									
Lead	ND	1	1.00	µg/L	03/03/25 14:06	03/05/25 16:45	JW1	EPA 200.8 (DA)/EPA 200.8	
Sample: HS-WC-BF-T1/Trainers Entrance									
		Lims Reference ID:		AD10749-27		Matrix: Drinking Water		Sampled: 02/21/25 10:20:00	
Metals									
Lead	ND	1	1.00	µg/L	03/03/25 14:06	03/05/25 16:47	JW1	EPA 200.8 (DA)/EPA 200.8	

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax:cs@emsl.com
EMSL-CIN-01

EMSL Order ID: 012510749**LIMS Reference ID:** AD10749**EMSL Customer ID:** RAMA51**Attention:** Info

EnviroVision Consultants, Inc [RAMA51]
20-21 Wagaraw Rd, Bldg 35E
Fair Lawn, NJ 07410
(973) 636-9145
info@envirovisionconsultants.com

Project Name:

Park Ridge Jr& Sr High School - 25-036

Customer PO:**EMSL Sales Rep:**

Sheryl Steinmetz

Received:

02/24/2025 12:00

Reported:

03/10/2025 14:14

Analytical Results**(Continued)**

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: HS WC WF-T1/Trainers Entrance Lims Reference ID: AD10749-28 Matrix: Drinking Water Sampled: 02/21/25 10:22:00									
Metals									
Lead	ND	1		1.00	µg/L	03/03/25 14:06	03/05/25 16:49	JW1	EPA 200.8 (DA)/EPA 200.8
Sample: HS WC BF-T2/Trainers Entrance Lims Reference ID: AD10749-29 Matrix: Drinking Water Sampled: 02/21/25 10:25:00									
Metals									
Lead	ND	1		1.00	µg/L	03/03/25 14:06	03/05/25 16:51	JW1	EPA 200.8 (DA)/EPA 200.8
Sample: HS WC WF-T2/Trainers Entrance Lims Reference ID: AD10749-30 Matrix: Drinking Water Sampled: 02/21/25 10:27:00									
Metals									
Lead	ND	1		1.00	µg/L	03/03/25 16:04	03/05/25 18:33	JW1	EPA 200.8 (DA)/EPA 200.8
Sample: HS-WC-BF-MG/By Mini Gym Lims Reference ID: AD10749-31 Matrix: Drinking Water Sampled: 02/21/25 10:29:00									
Metals									
Lead	ND	1		1.00	µg/L	03/03/25 16:04	03/05/25 18:39	JW1	EPA 200.8 (DA)/EPA 200.8
Sample: HS WC WF-MG/By Mini Gym Lims Reference ID: AD10749-32 Matrix: Drinking Water Sampled: 02/21/25 10:30:00									
Metals									
Lead	ND	1		1.00	µg/L	03/03/25 16:04	03/05/25 18:41	JW1	EPA 200.8 (DA)/EPA 200.8
Sample: HS Blank/Blank Lims Reference ID: AD10749-33 Matrix: Drinking Water Sampled: 02/21/25 10:35:00									
Metals									
Lead	ND	1		1.00	µg/L	03/03/25 16:04	03/05/25 18:43	JW1	EPA 200.8 (DA)/EPA 200.8

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax:cs@emsl.com
EMSL-CIN-01

EMSL Order ID: 012510749**LIMS Reference ID:** AD10749**EMSL Customer ID:** RAMA51**Attention:** Info

EnviroVision Consultants, Inc [RAMA51]
20-21 Wagaraw Rd, Bldg 35E
Fair Lawn, NJ 07410
(973) 636-9145
info@envirovisionconsultants.com

Project Name:

Park Ridge Jr& Sr High School - 25-036

Customer PO:**EMSL Sales Rep:**

Sheryl Steinmetz

Received:

02/24/2025 12:00

Reported:

03/10/2025 14:14

Certified Analyses included in this Report**Analyte** **Certifications*****EPA 200.8 in Drinking Water***

Lead NJDEP

List of Certifications

Code	Description	Number	Expires
PADEP	Pennsylvania Department of Environmental Protection	68-00367	11/30/2025
NYSDOH	New York State Department of Health	10872	04/01/2025
NJDEP	New Jersey Department of Environmental Protection	03036	06/30/2025
MADEP	Massachusetts Department of Environmental Protection	M-NJ337	06/30/2025
CTDPH	Connecticut Department of Public Health	PH-0270	06/23/2026
California ELAP	California Water Boards	1877	06/30/2025
AIHA LAP	EMSL Analytical, Inc. Cinnaminson, NJ AIHA-LAP, LLC-ELLAP Accredited	100194	03/01/2025
A2LA	A2LA Environmental Certificate	2845.01	07/31/2026

Please see the specific Field of Testing (FOT) on www.emsl.com <<http://www.emsl.com>> for a complete listing of parameters for which EMSL is certified.

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax: cs@emsl.com
EMSL-CIN-01

EMSL Order ID: 012510749**LIMS Reference ID:** AD10749**EMSL Customer ID:** RAMA51**Attention:** Info

EnviroVision Consultants, Inc [RAMA51]
20-21 Wagaraw Rd, Bldg 35E
Fair Lawn, NJ 07410
(973) 636-9145
info@envirovisionconsultants.com

Project Name:

Park Ridge Jr& Sr High School - 25-036

Customer PO:**EMSL Sales Rep:**

Sheryl Steinmetz

Received:

02/24/2025 12:00

Reported:

03/10/2025 14:14


Notes and Definitions

Item	Definition
(Dig)	For metals analysis, sample was digested.
[2C]	Reported from the second channel in dual column analysis.
DA	Direct Analysis
DF	Dilution Factor
MDL	Method Detection Limit.
ND	Analyte was NOT DETECTED at or above the detection limit.
NR	Spike/Surrogate showed no recovery.
Q	Qualifier
RL	Reporting Limit
Wet	Sample is not dry weight corrected.

Measurement of uncertainty and any applicable definitions of method modifications are available upon request. Per EPA NLLAP policy, sample results are not blank corrected.

Owen McKenna Laboratory Manager or other approved signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted.



AD10749
20-21 Wagaraw Road - Bldg. 35E, Fair Lawn, NJ 07410
(973) 636-9145 / info@envirovisionconsultants.com
NJDOH IHEA Lic #: 1097

CLIENT Park Ridge School District
PROJECT Park Ridge Jr & Sr High School
TECH Steven Audenried

ADDRESS 85 Pasack Road, Park Ridge, NJ 07656
ADDRESS 2 Park Avenue, Park Ridge, NJ 07656
SAMPLING DATE 2/21/2025 PROJ # 25-036

LEAD IN DRINKING WATER DATA SHEET

Sample ID #	Date/Time Collected	Sample Location	Observations
1 HS WC BFG-1	12/21/25	915 Hallway by Classroom 13	BF
2 HS WC WFG-1		917 Hallway by Classroom 13	WF
3 HS PF K-1		919 Kitchen	Pat Siller
4 HS FP-01		921 Kitchen	Food sink
5 HS FP-02		923 Kitchen	Food sink
6 HS FP-03		929 Kitchen	Food sink
7 HS FP-04		931 Kitchen	Food sink
8 HS WC BFG-2		932 Hallway by Classroom 11	BF
9 HS WC WFG-2		934 Hallway by Classroom 11	WF
10 HS WC BFG-11		936 Hallway by Guidance Office	BF
11 HS WC WFG-11		940 Hallway by Guidance Office	WF
12 HS WC BFG-12		942 Hallway by Classroom 12 Rm 124	BF

CHAIN OF CUSTODY See Photos.

Relinquished By:	Received By:	Date & Time
		2/24/25 12pm

ANALYSIS:

Unpreserved, via EPA 200.8 ICP-MS (0.001 mg/L (ppm))
☒ Preserved with HNO₃, via EPA 200.8 ICP-MS (0.001 mg/L (ppm))

Matrix: Drinking Water, Sample Type: Grab

Sample(s) Temperature Upon Receipt (Lab Only):

Bottle Size: 250 mL, wide mouth

TURNAROUND TIME 2 WEEKS


EMAIL RESULTS TO info@envirovisionconsultants.com

RECEIVED

FEB 24 2025

By SP 9:10am
EMSL PISCATAWAY
W.I.

PAGE 1 OF 3



AD10749
20-21 Wagaw Road - Bldg. 35E, Fair Lawn, NJ 07410
(973) 636-9145 / info@envirovisionconsultants.com
NJDOH IHEA Lic #: 1097


CLIENT Park Ridge School District
PROJECT Park Ridge Jr & Sr High School
TECH Steven Audenried

ADDRESS 85 Pascack Road, Park Ridge, NJ 07656
ADDRESS 2 Park Avenue, Park Ridge, NJ 07656
SAMPLING DATE 2/21/2025 PROJ # 25-036

LEAD IN DRINKING WATER DATA SHEET

Sample ID #	Date/Time Collected	Sample Location	Observations
13 HS WC WF17	2/21/25	944 by Classroom 104	WF
14 HS TL 103		946 Teachers lounge	Sink
15 HS WC BF21		947 by Classroom 204	BF
16 HS WC WF21		948 by Classroom 204	WF
17 HS NS NO1		952 Nurse	Sink
18 HS WC BF41		955 Classroom 21	BF
19 HS WC WF11		956 Classroom 21	WF
20 HS WC BF23		959 by library	BF
21 HS WC WF23		1001 by library	WF
22 HS WC BF21		1005 by Tech room	BF
23 HS WC WF21		1005 by Tech room	WF
24 HS TS T1	✓	1009 Trainer office	Sink

CHAIN OF CUSTODY

Relinquished By:	Received By:	Date & Time
		2/24/25 12pm

ANALYSIS:

Unpreserved, via EPA 200.8 ICP-MS (0.001 mg/L (ppm))
☒ Preserved with HNO₃, via EPA 200.8 ICP-MS (0.001 mg/L (ppm))

Matrix: Drinking Water, Sample Type: Grab

Sample(s) Temperature Upon Receipt (Lab Only): _____

Bottle Size: 250 mL, wide mouth

TURNAROUND TIME 2 WEEKS

EMAIL RESULTS TO info@envirovisionconsultants.com

LABORATORY SUBMITTED TO:	RECEIVED
LAB ORDER #	FEB 24 2025

PAGE 23 OF 3

By EMSL PISCATAWAY



20-21 Wagaraw Road - Bldg. 35E, Fair Lawn, NJ 07410
(973) 636-9145 / info@envirovisionconsultants.com
NJDOH IHEA Lic #: 1097

AD16749

CLIENT Park Ridge School District
PROJECT Park Ridge Jr & Sr High School
TECH Steven Audenried

ADDRESS 85 Pascack Road, Park Ridge, NJ 07656
ADDRESS 2 Park Avenue, Park Ridge, NJ 07656
SAMPLING DATE 2/21/2025 PROJ # 25-036

LEAD IN DRINKING WATER DATA SHEET

Sample ID #	Date/Time Collected	Sample Location	Observations
25 HS-1m-TRM	2/1/25	Trainers Room	IM
26 HS-1m-CLM	10/17	Trainers Room	BS IM
27 HS-WC-BF-T1	10/20	Trainers entrance	BS
28 HS-WC-WF-T1	10/22	Trainers entrance	WF
29 HS-WC-BF-T2	10/25	Trainers entrance	BS
30 HS-WC-WF-T2	10/27	Trainers entrance	WF
31 HS-WC-BF-MG	10/29	bag mini Gym	BS
32 HS-WC-WF-MG	10/30	bag mini Gym	WF
33 HS Blank	12/2/25		

CHAIN OF CUSTODY

Received By: *Horneley*

Relinquished By:	Received By:	Date & Time
<i>[Signature]</i>	<i>Horneley</i>	2/24/25 10pm

ANALYSIS:

Unpreserved, via EPA 200.8 ICP-MS (0.001 mg/L (ppm))

☒ Preserved with HNO₃, via EPA 200.8 ICP-MS (0.001 mg/L (ppm))

Matrix: Drinking Water, Sample Type: Grab

Sample(s) Temperature Upon Receipt (Lab Only):

Bottle Size: 250 mL, wide mouth

TURNAROUND TIME 2 WEEKS

EMAIL RESULTS TO info@envirovisionconsultants.com

LABORATORY SUBMITTED TO:	RECEIVED
LAB ORDER #	FEB 24 2025

By EMSL PISCATAWAY