



20-21 Wagaraw Road – Bldg. 35E, Fair Lawn, NJ 07410
(973) 636-9145/Email:info@envirovisionconsultants.com

CLIENT: Park Ridge School District

Project Number 25-036

PROJECT: Lead (Pb) in Drinking Water

West Ridge Elementary School

ADDRESS: 167 Sibbald Drive, Park Ridge, NJ 07656

FIELD TECHNICIAN: Steven Audenried

REPORT DATE: March 11, 2025

As per your request, EnviroVision Consultants, Inc. was contracted by Park Ridge School District to conduct Lead (Pb) in water sampling at the West Ridge Elementary School on February 21, 2025. The sample locations, in addition to a unique sample location code was determined/assigned by school district personnel. The school district performed the proper flushing of outlets prior to sampling and EnviroVision was instructed to collect only first draw samples for this sampling event. The school district's corresponding flushing logs should be attached to this report.

The facility was closed at the time of sampling in order to prevent occupants from utilizing any water outlets. After flushing, the water in the facility must remain motionless in the plumbing fixtures for a minimum of 8 hours, but no more than 48 hours. Cold water samples were collected in pre-cleaned high-density polyethylene (HDPE) 250mL wide mouth bottles.

The samples were analyzed at EMSL Analytical, Inc. in Cinnaminson, New Jersey (NJDEP#03036), accredited in accordance with NELAC (National Environmental Laboratory Accreditation Conference). The analytical method utilized was inductively coupled plasma mass spectrometry ICP-MS (EPA 200.8).

Twenty-four samples were collected and analyzed from Drinking Water outlets at West Ridge Elementary School. A blank sample was also analyzed, as required, for Quality Assurance Purposes. Note: four outlets were inadvertently sampled that are for handwashing only. These outlets are not for consumption and therefore testing was not required.

Results: All of the samples analyzed from drinking water outlets were either "None Detected" or less than the US EPA established threshold for lead in drinking water of 15 parts per billion (ppb or ug/L).

Should you have any questions, or if we could be of any further assistance, please feel free to contact our office. EnviroVision looks forward to providing you with the service and attention to detail you have come to expect from us.

Sincerely,
EnviroVision Consultants, Inc.

Cathy DiNardo

Cathy DiNardo, Project Manager



WEST RIDGE ELEMENTARY SCHOOL - LEAD (Pb) in Water Results of Concern

Outlet ID/Sample Number	Location	Results
WR-DW-16	Classroom 16	16.4 ppb
WR-DW-20	Classroom 20	192 ppb
WR-DW-03	Classroom 3	19.2 ppb
WR-DW-09	Classroom 9	309 ppb

Due to the elevated levels in the above outlets, we recommend that some or all of the following steps be taken at this time;

- Closure of the affected water outlet(s) until the system can be further evaluated and proper remedial action is achieved.
- Removal and replacement with non-lead containing fixtures.
- Installation of filtration systems.
- Development of a Flushing Program for those taps high in lead and turbidity (this may include automatic flushing systems).
- Contact the local water utility company to obtain information about their corrosion control procedures and how it might affect the District's control plans.
- Permanent closure of outlet(s).

Once the remedial action(s) are complete, follow up testing is required to ensure alterations/replacement to plumbing fixtures has lowered the amount of lead to acceptable levels.

I have also enclosed documents with detailed steps from the New Jersey Department of Environmental Protection regarding notifications that must be made, posting of results, and initial and long-term remedial requirements.

Should you have any questions, or if we could be of any further assistance, please feel free to contact our office. EnviroVision looks forward to providing you with the service and attention to detail you have come to expect from us.

Sincerely,
EnviroVision Consultants, Inc.

Cathy DiNardo

Cathy DiNardo, Project Manager
Attached: Lab results, Associated data sheets

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax:cs@emsl.com
EMSL-CIN-01

EMSL Order ID: 012510762**LIMS Reference ID:** AD10762**EMSL Customer ID:** RAMA51**Attention:** Info

EnviroVision Consultants, Inc [RAMA51]
20-21 Wagawag Rd, Bldg 35E
Fair Lawn, NJ 07410
(973) 636-9145
info@envirovisionconsultants.com

Project Name:

West Ridge Elementary School - 25-036

Customer PO:**EMSL Sales Rep:**

Sheryl Steinmetz

Received:

02/24/2025 12:00

Reported:

03/10/2025 14:16

Analytical Results

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: WR WC BF 1/By Stage Lims Reference ID: AD10762-01 Matrix: Drinking Water Sampled: 02/21/25 11:10:00									
Metals									
Lead	ND	1	1.00		µg/L	03/04/25 13:18	03/07/25 11:38	PL	EPA 200.8 (DA)/EPA 200.8
Sample: WR WC WF 1/By Stage Lims Reference ID: AD10762-02 Matrix: Drinking Water Sampled: 02/21/25 11:12:00									
Metals									
Lead	ND	1	1.00		µg/L	03/04/25 13:18	03/07/25 11:39	PL	EPA 200.8 (DA)/EPA 200.8
Sample: WR DW-11/Classroom 11 Lims Reference ID: AD10762-03 Matrix: Drinking Water Sampled: 02/21/25 11:13:00									
Metals									
Lead	5.35	1	1.00		µg/L	03/04/25 13:18	03/07/25 11:41	PL	EPA 200.8 (DA)/EPA 200.8
Sample: WR DW-16/Classroom 16 Lims Reference ID: AD10762-04 Matrix: Drinking Water Sampled: 02/21/25 11:15:00									
Metals									
Lead	16.4	1	1.00		µg/L	03/04/25 13:18	03/07/25 11:43	PL	EPA 200.8 (DA)/EPA 200.8
Sample: WR DW-12/Classroom 12 Lims Reference ID: AD10762-05 Matrix: Drinking Water Sampled: 02/21/25 11:16:00									
Metals									
Lead	8.15	1	1.00		µg/L	03/04/25 17:40	03/07/25 13:03	PL	EPA 200.8 (DA)/EPA 200.8
Sample: WR DW-17/Classroom 17 Lims Reference ID: AD10762-06 Matrix: Drinking Water Sampled: 02/21/25 11:19:00									
Metals									
Lead	5.84	1	1.00		µg/L	03/04/25 17:40	03/07/25 13:09	PL	EPA 200.8 (DA)/EPA 200.8
Sample: WR DW-13/Classroom 13 Lims Reference ID: AD10762-07 Matrix: Drinking Water Sampled: 02/21/25 11:21:00									
Metals									
Lead	3.97	1	1.00		µg/L	03/04/25 17:40	03/07/25 13:11	PL	EPA 200.8 (DA)/EPA 200.8
Sample: WR DW-18/Classroom 18 Lims Reference ID: AD10762-08 Matrix: Drinking Water Sampled: 02/21/25 11:23:00									
Metals									
Lead	12.0	1	1.00		µg/L	03/04/25 17:40	03/07/25 13:13	PL	EPA 200.8 (DA)/EPA 200.8
Sample: WR DW-14/Classroom 14 Lims Reference ID: AD10762-09 Matrix: Drinking Water Sampled: 02/21/25 11:27:00									
Metals									
Lead	9.09	1	1.00		µg/L	03/04/25 17:40	03/07/25 13:15	PL	EPA 200.8 (DA)/EPA 200.8

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077
 Telephone: 856-858-4800 Fax:cs@emsl.com
 EMSL-CIN-01

EMSL Order ID: 012510762**LIMS Reference ID:** AD10762**EMSL Customer ID:** RAMA51**Attention:** Info

EnviroVision Consultants, Inc [RAMA51]
 20-21 Wagaraw Rd, Bldg 35E
 Fair Lawn, NJ 07410
 (973) 636-9145
 info@envirovisionconsultants.com

Project Name:

West Ridge Elementary School - 25-036

Customer PO:**EMSL Sales Rep:**

Sheryl Steinmetz

Received:

02/24/2025 12:00

Reported:

03/10/2025 14:16

Analytical Results

(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: WR DW-19/Classroom 19 Lims Reference ID: AD10762-10 Matrix: Drinking Water Sampled: 02/21/25 11:29:00									
Metals									
Lead	5.15		1	1.00	µg/L	03/04/25 17:40	03/07/25 13:43	PL	EPA 200.8 (DA)/EPA 200.8
Sample: WR DW-15/Classroom 15 Lims Reference ID: AD10762-11 Matrix: Drinking Water Sampled: 02/21/25 11:32:00									
Metals									
Lead	1.86		1	1.00	µg/L	03/04/25 17:40	03/07/25 13:45	PL	EPA 200.8 (DA)/EPA 200.8
Sample: WR DW-20/Classroom 20 Lims Reference ID: AD10762-12 Matrix: Drinking Water Sampled: 02/21/25 11:33:00									
Metals									
Lead	192	D	5	5.00	µg/L	03/04/25 17:40	03/07/25 14:07	PL	EPA 200.8 (DA)/EPA 200.8
Sample: WR WC BF 2/By Nurse Lims Reference ID: AD10762-13 Matrix: Drinking Water Sampled: 02/21/25 11:36:00									
Metals									
Lead	ND		1	1.00	µg/L	03/04/25 17:40	03/07/25 13:49	PL	EPA 200.8 (DA)/EPA 200.8
Sample: WR WC WF 2/By Nurse Lims Reference ID: AD10762-14 Matrix: Drinking Water Sampled: 02/21/25 11:38:00									
Metals									
Lead	ND		1	1.00	µg/L	03/04/25 17:40	03/07/25 13:51	PL	EPA 200.8 (DA)/EPA 200.8
Sample: WR NS N01/Nurse Lims Reference ID: AD10762-15 Matrix: Drinking Water Sampled: 02/21/25 11:40:00									
Metals									
Lead	2.67		1	1.00	µg/L	03/04/25 17:40	03/07/25 13:53	PL	EPA 200.8 (DA)/EPA 200.8
Sample: WR NS N02/Nurse Lims Reference ID: AD10762-16 Matrix: Drinking Water Sampled: 02/21/25 11:41:00									
Metals									
Lead	2.18		1	1.00	µg/L	03/04/25 17:40	03/07/25 13:59	PL	EPA 200.8 (DA)/EPA 200.8
Sample: WR DW-02/Classroom 2 Lims Reference ID: AD10762-17 Matrix: Drinking Water Sampled: 02/21/25 11:43:00									
Metals									
Lead	1.61		1	1.00	µg/L	03/04/25 17:40	03/07/25 14:01	PL	EPA 200.8 (DA)/EPA 200.8
Sample: WR TL - 01/Teachers Lounge Lims Reference ID: AD10762-18 Matrix: Drinking Water Sampled: 02/21/25 11:50:00									
Metals									
Lead	2.78		1	1.00	µg/L	03/04/25 17:40	03/07/25 14:09	PL	EPA 200.8 (DA)/EPA 200.8

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077
 Telephone: 856-858-4800 Fax:cs@emsl.com
 EMSL-CIN-01

EMSL Order ID: 012510762
LIMS Reference ID: AD10762
EMSL Customer ID: RAMA51

Attention: Info

EnviroVision Consultants, Inc [RAMA51]
 20-21 Wagaraw Rd, Bldg 35E
 Fair Lawn, NJ 07410
 (973) 636-9145
 info@envirovisionconsultants.com

Project Name:

West Ridge Elementary School - 25-036

Customer PO:**EMSL Sales Rep:**

Sheryl Steinmetz

Received:

02/24/2025 12:00

Reported:

03/10/2025 14:16

Analytical Results

(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: WR DW-03/Classroom 3 Lims Reference ID: AD10762-19 Matrix: Drinking Water Sampled: 02/21/25 11:52:00									
Metals									
Lead	19.2	1		1.00	µg/L	03/04/25 17:40	03/07/25 14:11	PL	EPA 200.8 (DA)/EPA 200.8
Sample: WR DW-07/Classroom 7 Lims Reference ID: AD10762-20 Matrix: Drinking Water Sampled: 02/21/25 11:53:00									
Metals									
Lead	9.68	1		1.00	µg/L	03/04/25 17:40	03/07/25 14:12	PL	EPA 200.8 (DA)/EPA 200.8
Sample: WR DW-04/Classroom 4 Lims Reference ID: AD10762-21 Matrix: Drinking Water Sampled: 02/21/25 12:00:00									
Metals									
Lead	3.58	1		1.00	µg/L	03/04/25 17:40	03/07/25 14:14	PL	EPA 200.8 (DA)/EPA 200.8
Sample: WR DW-08/Classroom 8 Lims Reference ID: AD10762-22 Matrix: Drinking Water Sampled: 02/21/25 12:09:00									
Metals									
Lead	5.41	1		1.00	µg/L	03/04/25 17:40	03/07/25 14:16	PL	EPA 200.8 (DA)/EPA 200.8
Sample: WR DW-05/Classroom 5 Lims Reference ID: AD10762-23 Matrix: Drinking Water Sampled: 02/21/25 12:11:00									
Metals									
Lead	9.99	1		1.00	µg/L	03/04/25 17:40	03/07/25 14:18	PL	EPA 200.8 (DA)/EPA 200.8
Sample: WR WC-BF 3/By Classroom 10 Lims Reference ID: AD10762-24 Matrix: Drinking Water Sampled: 02/21/25 12:13:00									
Metals									
Lead	ND	1		1.00	µg/L	03/04/25 17:40	03/07/25 14:20	PL	EPA 200.8 (DA)/EPA 200.8
Sample: WR WC WF 3/By Classroom 10 Lims Reference ID: AD10762-25 Matrix: Drinking Water Sampled: 02/21/25 12:15:00									
Metals									
Lead	ND	1		1.00	µg/L	03/04/25 13:30	03/07/25 11:30	PL	EPA 200.8 (DA)/EPA 200.8
Sample: WR DW-06/Classroom 6 Lims Reference ID: AD10762-26 Matrix: Drinking Water Sampled: 02/21/25 12:16:00									
Metals									
Lead	5.21	1		1.00	µg/L	03/04/25 13:30	03/07/25 11:36	PL	EPA 200.8 (DA)/EPA 200.8
Sample: WR DW-10/Classroom 10 Lims Reference ID: AD10762-27 Matrix: Drinking Water Sampled: 02/21/25 12:18:00									
Metals									
Lead	4.78	1		1.00	µg/L	03/04/25 13:30	03/07/25 11:38	PL	EPA 200.8 (DA)/EPA 200.8

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax:cs@emsl.com
EMSL-CIN-01

EMSL Order ID: 012510762**LIMS Reference ID:** AD10762**EMSL Customer ID:** RAMA51**Attention:** Info

EnviroVision Consultants, Inc [RAMA51]
20-21 Wagaraw Rd, Bldg 35E
Fair Lawn, NJ 07410
(973) 636-9145
info@envirovisionconsultants.com

Project Name:

West Ridge Elementary School - 25-036

Customer PO:**EMSL Sales Rep:**

Sheryl Steinmetz

Received:

02/24/2025 12:00

Reported:

03/10/2025 14:16

Analytical Results

(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: WR DW-09/Classroom 9									
Lims Reference ID:				AD10762-28				Matrix: Drinking Water	
				Sampled: 02/21/25 12:20:00					
Metals									
Lead	309	D	5	5.00	µg/L	03/04/25 13:30	03/07/25 12:25	PL	EPA 200.8 (DA)/EPA 200.8
Sample: WR Blank/Blank									
Lims Reference ID:				AD10762-29				Matrix: Drinking Water	
				Sampled: 02/21/25 12:30:00					
Metals									
Lead	ND		1	1.00	µg/L	03/04/25 13:30	03/07/25 11:42	PL	EPA 200.8 (DA)/EPA 200.8

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax: cs@emsl.com
EMSL-CIN-01

EMSL Order ID: 012510762**LIMS Reference ID:** AD10762**EMSL Customer ID:** RAMA51**Attention:** Info

EnviroVision Consultants, Inc [RAMA51]
20-21 Wagaraw Rd, Bldg 35E
Fair Lawn, NJ 07410
(973) 636-9145
info@envirovisionconsultants.com

Project Name:

West Ridge Elementary School - 25-036

Customer PO:**EMSL Sales Rep:**

Sheryl Steinmetz

Received:

02/24/2025 12:00

Reported:

03/10/2025 14:16

Certified Analyses included in this Report

Analyte	Certifications
<i>EPA 200.8 in Drinking Water</i>	
Lead	NJDEP

List of Certifications

Code	Description	Number	Expires
PADEP	Pennsylvania Department of Environmental Protection	68-00367	11/30/2025
NYSDOH	New York State Department of Health	10872	04/01/2025
NJDEP	New Jersey Department of Environmental Protection	03036	06/30/2025
MADEP	Massachusetts Department of Environmental Protection	M-NJ337	06/30/2025
CTDPH	Connecticut Department of Public Health	PH-0270	06/23/2026
California ELAP	California Water Boards	1877	06/30/2025
AIHA LAP	EMSL Analytical, Inc. Cinnaminson, NJ AIHA-LAP, LLC-ELLAP Accredited	100194	03/01/2025
A2LA	A2LA Environmental Certificate	2845.01	07/31/2026

Please see the specific Field of Testing (FOT) on www.emsl.com <<http://www.emsl.com>> for a complete listing of parameters for which EMSL is certified.

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax: cs@emsl.com
EMSL-CIN-01

EMSL Order ID: 012510762**LIMS Reference ID:** AD10762**EMSL Customer ID:** RAMA51**Attention:** Info

EnviroVision Consultants, Inc [RAMA51]
20-21 Wagaraw Rd, Bldg 35E
Fair Lawn, NJ 07410
(973) 636-9145
info@envirovisionconsultants.com

Project Name:

West Ridge Elementary School - 25-036

Customer PO:**EMSL Sales Rep:**

Sheryl Steinmetz

Received:

02/24/2025 12:00

Reported:

03/10/2025 14:16


Notes and Definitions

Item	Definition
D	Analyte was reported from a dilution run.
(Dig)	For metals analysis, sample was digested.
[2C]	Reported from the second channel in dual column analysis.
DA	Direct Analysis
DF	Dilution Factor
MDL	Method Detection Limit.
ND	Analyte was NOT DETECTED at or above the detection limit.
NR	Spike/Surrogate showed no recovery.
Q	Qualifier
RL	Reporting Limit
Wet	Sample is not dry weight corrected.

Measurement of uncertainty and any applicable definitions of method modifications are available upon request. Per EPA NLLAP policy, sample results are not blank corrected.

Owen McKenna Laboratory Manager or other approved signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted.



20-21 Wagaraw Road - Bldg. 35E, Fair Lawn, NJ 07410
(973) 636-9145 / info@envirovisionconsultants.com
NJDOH IHEA Lic #: 1097

AD10762



CLIENT	Park Ridge School District	ADDRESS	85 Pascack Road, Park Ridge, NJ 07656
PROJECT	West Ridge Elementary School	ADDRESS	18 South First St, Park Ridge, NJ 07656
TECH	Steven Audenried	SAMPLING DATE	2/21/2025
		PROJ #	25-036

LEAD IN DRINKING WATER DATA SHEET

Sample ID #	Date/Time Collected	Sample Location	Observations
1 WRWC BF1	2/21/25 11:00 AM	by Stage	BF
2 WRWC WF1	11:12	by Stage	WF
3 WRDW-11	11:13	Classroom 11	Sink
4 WRDW-16	11:15	Classroom 16	Sink
5 WRDW-12	11:16	Classroom 12	Sink
6 WRDW-17	11:19	Classroom 17	Sink
7 WRDW-13	11:21	Classroom 13	Sink
8 WRDW-18	11:23	Classroom 18	Sink
9 WRDW-14	11:27	Classroom 14	Sink
10 WRDW-19	11:29	Classroom 19	Sink
11 WRDW-15	11:32	Classroom 15	Sink
12 WRDW-20	11:33	Classroom 20	Sink

CHAIN OF CUSTODY

Reed Ples.

Relinquished By:	Received By:	Date & Time
		2/24/25 12pm

ANALYSIS:

Unpreserved, via EPA 200.8 ICP-MS (0.001 mg/L (ppm))
☒ Preserved with HNO₃, via EPA 200.8 ICP-MS (0.001 mg/L (ppm))

Matrix: Drinking Water, Sample Type: Grab

Sample(s) Temperature Upon Receipt (Lab Only): _____

Bottle Size: 250 mL, wide mouth


TURNAROUND TIME 2 WEEKS

EMAIL RESULTS TO info@envirovisionconsultants.com

LABORATORY SUBMITTED TO:	RECEIVED
LAB ORDER #	FEB 24 2025

By SL 9:10am
EMSL PISCATAWAY
N.J.

PAGE 1 OF 3



AD10762

20-21 Wagaraw Road - Bldg. 35E, Fair Lawn, NJ 07410
(973) 636-9145 / info@envirovisionconsultants.com
NJDOH IHEA Lic #: 1097

CLIENT	Park Ridge School District	ADDRESS	85 Pascack Road, Park Ridge, NJ 07656
PROJECT	West Ridge Elementary School	ADDRESS	18 South First St, Park Ridge, NJ 07656
TECH	Steven Audenried	SAMPLING DATE	2/21/2025
		PROJ #	25-036

LEAD IN DRINKING WATER DATA SHEET

Sample ID #	Date/Time Collected	Sample Location	Observations
13 WR WC BF2	2/21/25	by Nurse	BF
14 WR WC WF2		by Nurse	WF
15 WR NS N01		Nurse	Sink
16 WR NS N02		Nurse	Sink
17 WR DW-02		Classroom 2	Sink
18 WR TL-01		Teachers lounge	Sink
19 WR DW-03		Classroom 3	Sink
20 WR DW-07		Classroom 7	Sink
21 WR DW-04		Classroom 4	Sink
22 WR DW-08		Classroom 8	Sink
23 WR DW-05		Classroom 5	Sink
24 WR WC-BF3		by Classroom 10	BF

Rec'd Plus.

CHAIN OF CUSTODY

Relinquished By:	Received By:	Date & Time
	<i>Annely</i>	2/24/25 10pm

ANALYSIS:

___ Unpreserved, via EPA 200.8 ICP-MS (0.001 mg/L (ppm))
☒ Preserved with HNO₃, via EPA 200.8 ICP-MS (0.001 mg/L (ppm))

Matrix: Drinking Water, Sample Type: Grab

Sample(s) Temperature Upon Receipt (Lab Only):

Bottle Size: 250 mL, wide mouth

TURNAROUND TIME 2 WEEKS

EMAIL RESULTS TO info@envirovisionconsultants.com

LABORATORY SUBMITTED TO:	RECEIVED
LAB ORDER #	FEB 24 2025

By
EMSL PISCATAWAY



AD10762

20-21 Wagaraw Road - Bldg. 35E, Fair Lawn, NJ 07410
(973) 636-9145 / info@envirovisionconsultants.com
NJDOH IHEA Lic #: 1097



CLIENT Park Ridge School District
PROJECT West Ridge Elementary School
TECH Steven Audenried

ADDRESS 85 Pascack Road, Park Ridge, NJ 07656
ADDRESS 18 South First St, Park Ridge, NJ 07656
SAMPLING DATE 2/21/2025 PROJ # 25-036

LEAD IN DRINKING WATER DATA SHEET

Sample ID #	Date/Time Collected	Sample Location	Observations
25 WR WC WF-3	2/21/25	1215 by Classroom 10	WF
26 WR DW 06	↓	1218 Classroom 6	Sink
27 WR DW 10	↓	1218 Classroom 10	Sink
28 WR DW 09	↓	1220 Classroom 9	Sink
29 WR Blank	2/21/25	1230pm	Blank sample

CHAIN OF CUSTODY Rec'd POS.

Relinquished By:	Received By:	Date & Time
 2/21/25	 2/24/25 6pm	

ANALYSIS:

Unpreserved, via EPA 200.8 ICP-MS (0.001 mg/L (ppm))
☒ Preserved with HNO₃, via EPA 200.8 ICP-MS (0.001 mg/L (ppm))

Matrix: Drinking Water, Sample Type: Grab

Sample(s) Temperature Upon Receipt (Lab Only):

Bottle Size: 250 mL, wide mouth

TURNAROUND TIME 2 WEEKS

EMAIL RESULTS TO info@envirovisionconsultants.com

LABORATORY SUBMITTED TO:	REC'D
LAB ORDER #	FEB 24 2025

By
EMSL PISCATAWAY