



May 27, 2025

Zach Nannestad
Douglas County School District
2812 N. Highway 85
Castle Rock, CO 80109

**Re: DCSD Cresthill Middle School
9195 Cresthill Lane in Highlands Ranch, Colorado
Radon Sampling Assessment**

Dear Mr. Nannestad:

Quality Environmental Services & Technologies Inc. (QUEST) is pleased to assist Douglas County School District with the ongoing radon survey of its schools. At your request, QUEST conducted radon testing at Cresthill Middle School, located at 9195 Cresthill Lane in Highlands Ranch, Colorado.

Sixty five (65) AirChek radon test kits were placed on October 20, 2025, and sixty five (65) were retrieved on October 22, 2025. The attached laboratory results specify radon concentrations to be all within the EPA guideline of 4 pCi/L for acceptable radon concentrations.

If you have any questions, or if we may be of additional assistance, please contact QUEST, Inc. at 303-935-1573. We look forward to our continued association.

Sincerely,

A handwritten signature in black ink, appearing to read "Robert A. Woellner".

Robert A. Woellner
President/Industrial Hygienist
NEHA: NRPP Certification #105324RT

Attachment: Laboratory Report

Radon test result report for:
CRESTHILL MS
MAIN

Kit #	Room Id	Started	Ended	pCi/L	Analyzed
12073998	1100	2025-05-20 @ 11:00 am	2025-05-22 @ 1:00 pm	< 0.3	2025-05-23
12073996	1101	2025-05-20 @ 11:00 am	2025-05-22 @ 1:00 pm	0.5	2025-05-23
12073997	1102	2025-05-20 @ 11:00 am	2025-05-22 @ 1:00 pm	< 0.3	2025-05-23
12073995	1106	2025-05-20 @ 11:00 am	2025-05-22 @ 1:00 pm	< 0.3	2025-05-23
12073994	1107	2025-05-20 @ 11:00 am	2025-05-22 @ 1:00 pm	< 0.3	2025-05-23
12073993	1108	2025-05-20 @ 11:00 am	2025-05-22 @ 1:00 pm	< 0.3	2025-05-23
12073992	1109	2025-05-20 @ 11:00 am	2025-05-22 @ 1:00 pm	< 0.3	2025-05-23
12073991	1112	2025-05-20 @ 11:00 am	2025-05-22 @ 1:00 pm	< 0.3	2025-05-23
12073990	1113	2025-05-20 @ 11:00 am	2025-05-22 @ 1:00 pm	< 0.3	2025-05-23
12073980	1119	2025-05-20 @ 11:00 am	2025-05-22 @ 1:00 pm	< 0.3	2025-05-23
12073979	1120	2025-05-20 @ 11:00 am	2025-05-22 @ 1:00 pm	< 0.3	2025-05-23
12073978	1121	2025-05-20 @ 11:00 am	2025-05-22 @ 1:00 pm	< 0.3	2025-05-23
12073976	1121 (B)	2025-05-20 @ 11:00 am	2025-05-22 @ 1:00 pm	< 0.3	2025-05-23
12073977	1121 (D)	2025-05-20 @ 11:00 am	2025-05-22 @ 1:00 pm	1.0	2025-05-23
12073975	1122	2025-05-20 @ 11:00 am	2025-05-22 @ 1:00 pm	< 0.3	2025-05-23
12073974	1123	2025-05-20 @ 11:00 am	2025-05-22 @ 1:00 pm	< 0.3	2025-05-23
12073970	1126	2025-05-20 @ 11:00 am	2025-05-22 @ 1:00 pm	< 0.3	2025-05-23
12073971	1127	2025-05-20 @ 11:00 am	2025-05-22 @ 1:00 pm	0.7	2025-05-23
12073969	1128	2025-05-20 @ 11:00 am	2025-05-22 @ 1:00 pm	< 0.3	2025-05-23
12073968	1129	2025-05-20 @ 11:00 am	2025-05-22 @ 1:00 pm	< 0.3	2025-05-23
12073967	1130	2025-05-20 @ 11:00 am	2025-05-22 @ 1:00 pm	< 0.3	2025-05-23
12073963	1133	2025-05-20 @ 11:00 am	2025-05-22 @ 1:00 pm	< 0.3	2025-05-23
12073964	1134	2025-05-20 @ 11:00 am	2025-05-22 @ 1:00 pm	< 0.3	2025-05-23
12073962	1135	2025-05-20 @ 11:00 am	2025-05-22 @ 1:00 pm	< 0.3	2025-05-23
12073961	1136	2025-05-20 @ 12:00 pm	2025-05-22 @ 1:00 pm	< 0.3	2025-05-23
12073956	1140	2025-05-20 @ 12:00 pm	2025-05-22 @ 1:00 pm	< 0.3	2025-05-23
12073955	1141	2025-05-20 @ 12:00 pm	2025-05-22 @ 1:00 pm	< 0.3	2025-05-23
12073954	1141 (D)	2025-05-20 @ 12:00 pm	2025-05-22 @ 1:00 pm	< 0.3	2025-05-23
12073953	1142	2025-05-20 @ 12:00 pm	2025-05-22 @ 1:00 pm	< 0.3	2025-05-23
12073952	1143	2025-05-20 @ 12:00 pm	2025-05-22 @ 1:00 pm	< 0.3	2025-05-23
12073959	1146 N	2025-05-20 @ 12:00 pm	2025-05-22 @ 1:00 pm	< 0.3	2025-05-23
12073958	1146 S	2025-05-20 @ 12:00 pm	2025-05-22 @ 1:00 pm	< 0.3	2025-05-23
12073957	1147	2025-05-20 @ 12:00 pm	2025-05-22 @ 1:00 pm	< 0.3	2025-05-23
12073960	1155	2025-05-20 @ 12:00 pm	2025-05-22 @ 1:00 pm	< 0.3	2025-05-23
12073966	1158	2025-05-20 @ 11:00 am	2025-05-22 @ 1:00 pm	< 0.3	2025-05-23
12073965	1158 (D)	2025-05-20 @ 11:00 am	2025-05-22 @ 1:00 pm	< 0.3	2025-05-23
12073972	1159	2025-05-20 @ 11:00 am	2025-05-22 @ 1:00 pm	0.6	2025-05-23

Radon test result report for:
CRESTHILL MS
MAIN

Kit #	Room Id	Started	Ended	pCi/L	Analyzed
12073973	1161	2025-05-20 @ 11:00 am	2025-05-22 @ 1:00 pm	< 0.3	2025-05-23
12073981	1165	2025-05-20 @ 11:00 am	2025-05-22 @ 1:00 pm	< 0.3	2025-05-23
12073982	1167	2025-05-20 @ 11:00 am	2025-05-22 @ 1:00 pm	0.6	2025-05-23
12073983	1168	2025-05-20 @ 11:00 am	2025-05-22 @ 1:00 pm	< 0.3	2025-05-23
12073984	1169	2025-05-20 @ 11:00 am	2025-05-22 @ 1:00 pm	< 0.3	2025-05-23
12073986	1170	2025-05-20 @ 11:00 am	2025-05-22 @ 1:00 pm	< 0.3	2025-05-23
12073987	1171	2025-05-20 @ 11:00 am	2025-05-22 @ 1:00 pm	< 0.3	2025-05-23
12073989	1172	2025-05-20 @ 11:00 am	2025-05-22 @ 1:00 pm	< 0.3	2025-05-23
12073988	1172 (D)	2025-05-20 @ 11:00 am	2025-05-22 @ 1:00 pm	< 0.3	2025-05-23
12073985	1174	2025-05-20 @ 11:00 am	2025-05-22 @ 1:00 pm	< 0.3	2025-05-23
12073938	1178	2025-05-20 @ 12:00 pm	2025-05-22 @ 1:00 pm	< 0.3	2025-05-23
12073939	1183	2025-05-20 @ 12:00 pm	2025-05-22 @ 1:00 pm	< 0.3	2025-05-23
12073937	1184	2025-05-20 @ 12:00 pm	2025-05-22 @ 1:00 pm	< 0.3	2025-05-23
12073936	1187	2025-05-20 @ 12:00 pm	2025-05-22 @ 1:00 pm	< 0.3	2025-05-23
12073935	1189	2025-05-20 @ 12:00 pm	2025-05-22 @ 1:00 pm	< 0.3	2025-05-23
12073934	1190	2025-05-20 @ 12:00 pm	2025-05-22 @ 1:00 pm	< 0.3	2025-05-23
12073940	1197 N	2025-05-20 @ 12:00 pm	2025-05-22 @ 1:00 pm	< 0.3	2025-05-23
12073941	1197 S	2025-05-20 @ 12:00 pm	2025-05-22 @ 1:00 pm	< 0.3	2025-05-23
12073942	1197 S (B)	2025-05-20 @ 12:00 pm	2025-05-22 @ 1:00 pm	< 0.3	2025-05-23
12073943	1197 S (D)	2025-05-20 @ 12:00 pm	2025-05-22 @ 1:00 pm	< 0.3	2025-05-23
12073951	1213	2025-05-20 @ 12:00 pm	2025-05-22 @ 1:00 pm	< 0.3	2025-05-23
12073950	1217	2025-05-20 @ 12:00 pm	2025-05-22 @ 1:00 pm	< 0.3	2025-05-23
12073944	1219 N	2025-05-20 @ 12:00 pm	2025-05-22 @ 1:00 pm	< 0.3	2025-05-23
12073945	1219 S	2025-05-20 @ 12:00 pm	2025-05-22 @ 1:00 pm	< 0.3	2025-05-23
12073946	1221 N	2025-05-20 @ 12:00 pm	2025-05-22 @ 1:00 pm	< 0.3	2025-05-23
12073947	1221 S	2025-05-20 @ 12:00 pm	2025-05-22 @ 1:00 pm	< 0.3	2025-05-23
12073948	1229	2025-05-20 @ 12:00 pm	2025-05-22 @ 1:00 pm	< 0.3	2025-05-23
12073949	1230	2025-05-20 @ 12:00 pm	2025-05-22 @ 1:00 pm	< 0.3	2025-05-23