

Arts and Academics Academy									Old Building ID#	Main Campus Building #
ODE Building # 44401700									44401700	Old Bank Building #
Fixture ID #	Fixture Description per Location	Initial Test Date	Initial Test Result (ppb)	Initial Level	Final Retest Date	Final Test Result (ppb)	Final Level	Notes	Order No.:	
44401700-001NS	Nurse office sink (Main Building)	3/9/23	ND	Non-Detect					2303346	
44401700-002CF	Studio 4 Classroom Faucet 1	3/9/23	ND	Non-Detect					2303346	
44401700-003CF	Studio 4 Classroom Faucet 2	3/9/23	2.34	Low					2303346	
44401700-004CF	Studio 4 Classroom Faucet 3	3/9/23	4.05	Low					2303346	
44401700-005CF	Studio 4 Classroom Faucet 4	3/9/23	3.34	Low					2303346	
44401700-006CF	Studio 4 Classroom Faucet (Closet) 5	3/9/23	10.00	High					2303346	
44401700-007BF	Bottle fill Station	3/9/23	ND	Non-Detect					2303346	
44401700-008DW	Drinking Water fountain	3/9/23	ND	Non-Detect					2303346	
44401700-009DW	Single Drinking water fountain	3/9/23	ND	Non-Detect					2303346	
44401700-010BF	Mens restroom bathroom faucet 1	3/9/23	ND	Non-Detect					2303346	
44401700-011BF	Mens restroom bathroom faucet 2	3/9/23	ND	Non-Detect					2303346	
44401700-012BF	Mens restroom bathroom faucet 3	3/9/23	3.66	Low					2303346	
44401700-013BF	Mens restroom bathroom faucet 4	3/9/23	5.85	Moderate					2303346	
44401700-014BF	Womens restroom faucet 1	3/9/23	ND	Non-Detect					2303346	
44401700-015BF	Womens restroom faucet 2	3/9/23	ND	Non-Detect					2303346	
44401700-016BF	Womens restroom faucet 3	3/9/23	ND	Non-Detect					2303346	
44401700-017BF	Womens restroom faucet 4	3/9/23	ND	Non-Detect					2303346	
44401700-018SF	Studio B Staff faucet	3/9/23	ND	Non-Detect					2303346	
44401700-019BF	Bathroom faucet (ANNEX3)	3/9/23	ND	Non-Detect					2303346	
44401700-020CF	Wash out sink classroom faucet	3/9/23	ND	Non-Detect					2303346	
44401700-021BF	Bathroom faucet (old coin shop)	3/9/23	42.00	Action Req					2303350	
44401700-022BF	Bathroom Faucet (ANNEX 1)	3/9/23	ND	Non-Detect					2303350	
44401700-023BF	Bathroom Faucet	3/9/23	3.51	Low					2303350	
44401700-024SF	Staff room sink	3/9/23	ND	Non-Detect					2303350	
44401700-025DW	Drinking water fountain @entrance (OLD BANK BUILDING)1ST FLOOR	3/9/23	ND	Non-Detect					2303350	
44401700-026CF	Classroom 108 classroom faucet	3/9/23	2.15	Low					2303350	
44401700-027BF	Mens restroom bathroom faucet	3/9/23	ND	Non-Detect					2303350	
44401700-028BF	Womens bathroom faucet	3/9/23	ND	Non-Detect					2303350	
44401700-029DW	Drinking water fountain	3/9/23	2.21	Low					2303350	
44401700-030SF	2nd Floor staff room sink	3/9/23	2.26	Low					2303350	
44401700-031BF	Staffroom mens bathroom faucet	3/9/23	3.96	Low					2303350	
44401700-032BF	Staffroom womens bathroom faucet	3/9/23	14.60	High					2303350	