

Agnes Stewart Middle School							Old Building ID#		
ODE Building # 20831700							13531300		
Fixture ID #	Fixture Description per Location	Initial Test Date	Initial Test Result (ppb)	Initial Level	Final Retest Date	Final Test Result (ppb)	Final Level	Notes	Order No.:
20831700-001BF	Kitchen Bathroom Faucet	4/4/2025	ND	Non-Detect					2504213
20831700-002KF	Kitchen Faucet (Next To Restroom) #1	4/4/2025	6.18	Moderate				See Map For All Locations	2504213
20831700-003KF	Kitchen Faucet #2	4/4/2025	ND	Non-Detect				See Map For All Locations	2504213
20831700-004KF	Kitchen Faucet #3 (Next to Ice Machine)	4/4/2025	3.15	Low				See Map For All Locations	2504213
20831700-005KF	Kitchen Faucet #4 (Steam Kettle)	4/4/2025	2.41	Low				See Map For All Locations	2504213
20831700-006KF	Kitchen Faucet #5 (Left Of Dishwasher)	4/4/2025	2.45	Low				See Map For All Locations	2504213
20831700-007KF	Kitchen Faucet #6 (Right Of Dishwasher)	4/4/2025	ND	Non-Detect				See Map For All Locations	2504213
20831700-008KF	Kitchen Faucet #7 (Behind Dishwasher Left)	4/4/2025	ND	Non-Detect				See Map For All Locations	2504213
20831700-009KF	Kitchen Faucet #8 (Right)	4/4/2025	3.9	Low				See Map For All Locations	2504213
20831700-010KF	Kitchen Faucet #9 (Outside Dishwasher Area)	4/4/2025	2.15	Low				See Map For All Locations	2504213
20831700-011KF	Kitchen Faucet #10	4/4/2025	2.67	Low				See Map For All Locations	2504213
20831700-012KF	Kitchen Faucet #11	4/4/2025	3.3	Low				See Map For All Locations	2504213
20831700-013CF	Classroom 114 Band Room Faucet	4/4/2025	ND	Non-Detect					2504213
20831700-014DW	Classroom 114 Band Room Drinking Fountain	4/4/2025	ND	Non-Detect					2504213
20831700-015BF	Girls Bradley Bathroom Faucet #1 (Far Left)	4/4/2025	ND	Non-Detect					2504213
20831700-016BF	Girls Bradley Bathroom Faucet #2	4/4/2025	ND	Non-Detect					2504213
20831700-017BF	Girls Bradley Bathroom Faucet #3	4/4/2025	ND	Non-Detect					2504213
20831700-018BF	Girls Bradley Bathroom Faucet #4 (Far Right)							NOT IN USE	
20831700-019BF	Boys Bradley Bathroom Faucet #1 (Far Left)	4/4/2025	4.9	Low					2504217
20831700-020BF	Boys Bradley Bathroom Faucet #2	4/4/2025	3.09	Low					2504217
20831700-021BF	Boys Bradley Bathroom Faucet #3	4/4/2025	ND	Non-Detect					2504217
20831700-022BF	Boys Bradley Bathroom Faucet #4 (Far Right)	4/4/2025	2.15	Low					2504217
20831700-023DW	Drinking Fountain (Next To Boys Bathroom Left)	4/4/2025	ND	Non-Detect					2504217
20831700-024DW	Drinking Fountain (Next To Boys Bathroom Right)	4/4/2025	ND	Non-Detect					2504217
20831700-025CF	Classroom 113 Faucet STEM Hallway	4/4/2025	ND	Non-Detect					2504217
20831700-026CF	Classroom 117 Faucet #1	4/4/2025	ND	Non-Detect					2504217
20831700-027CF	Classroom 117 Faucet #2	4/4/2025	ND	Non-Detect					2504217
20831700-028CF	Classroom 117 Faucet #3	4/4/2025	ND	Non-Detect					2504217
20831700-029SF	Staff Lounge Faucet	4/4/2025	ND	Non-Detect					2504217
20831700-030SF	Staff Lounge Insta Hot Faucet	4/4/2025	ND	Non-Detect					2504217
20831700-031BF	W Staff Bathroom Faucet	4/4/2025	ND	Non-Detect					2504217
20831700-032BF	M Staff Bathroom Faucet	4/4/2025	ND	Non-Detect					2504217
20831700-033CF	Art Classroom 111 Facuet #1 (By Entrance)	4/4/2025	ND	Non-Detect					2504217
20831700-034CF	Art Classroom 111 Facuet #2	4/4/2025	ND	Non-Detect					2504217
20831700-035CF	Art Classroom 111 Facuet #3 (By Window)	4/4/2025	ND	Non-Detect					2504217
20831700-036SF	Office Faucet	4/4/2025	ND	Non-Detect					2504217
20831700-037SF	Office Instant Hot Water Faucet	4/4/2025	ND	Non-Detect					2504221
20831700-038BF	Staff Bathroom Faucet (Next for RM 107)	4/4/2025	ND	Non-Detect					2504221
20831700-039NS	Nurse Office Sink (RM 106)	4/4/2025	ND	Non-Detect					2504221
20831700-040DW	Nurse Office Drinking Fountain (RM 106)	4/4/2025	ND	Non-Detect					2504221
20831700-041BF	Nurse Office Bathroom Faucet (RM 106)	4/4/2025	ND	Non-Detect					2504221
20831700-042BF	Staff Bathroom Faucet (RM 105)	4/4/2025	ND	Non-Detect					2504221
20831700-043SF	Library Staff Faucet (1)	4/4/2025	ND	Non-Detect					2504221
20831700-044DW	Drinking Fountain (Next To Elevator Left)	4/4/2025	ND	Non-Detect					2504221
20831700-045DW	Drinking Fountain (Next To Elevator Right)	4/4/2025	ND	Non-Detect					2504221

Agnes Stewart Middle School							Old Building ID#		
ODE Building # 20831700							13531300		
Fixture ID #	Fixture Description per Location	Initial Test Date	Initial Test Result (ppb)	Initial Level	Final Retest Date	Final Test Result (ppb)	Final Level	Notes	Order No.:
20831700-046CF	Classroom A110 Faucet	4/4/2025	ND	Non-Detect					2504221
20831700-047DW	Classroom A110 Drinking Fountain	4/4/2025	ND	Non-Detect					2504221
20831700-048BF	Classroom A110 Bathroom Faucet	4/4/2025	3.69	low					2504221
20831700-049BF	Girls Bradley Bathroom Faucet #1 (Far Left)	4/4/2025	2.45	low					2504221
20831700-050BF	Girls Bradley Bathroom Faucet #2							NOT IN USE	
20831700-051BF	Girls Bradley Bathroom Faucet #3	4/4/2025	ND	Non-Detect					2504221
20831700-052BF	Girls Bradley Bathroom Faucet #4 (Far Right)	4/4/2025	2.12	low					2504221
20831700-053BF	Staff Bathroom Faucet (Next To Girls RR)	4/4/2025	ND	Non-Detect					2504221
20831700-054BF	Boys Bradley Bathroom Faucet #1 (Far Left)	4/4/2025	3.16	low					2504221
20831700-055BF	Boys Bradley Bathroom Faucet #2	4/4/2025	ND	Non-Detect					2504220
20831700-056BF	Boys Bradley Bathroom Faucet #3	4/4/2025	ND	Non-Detect					2504220
20831700-057BF	Boys Bradley Bathroom Faucet #4 (Far Right)	4/4/2025	4.63	low					2504220
20831700-058CF	Classroom A109 Faucet #1 (Front Of Classroom)	4/4/2025	3.93	low				See Map for Location	2504220
20831700-059CF	Classroom A109 Faucet #2 (Far Left)	4/4/2025	ND	Non-Detect				See Map for Location	2504220
20831700-060CF	Classroom A109 Faucet #3	4/4/2025	ND	Non-Detect				See Map for Location	2504220
20831700-061CF	Classroom A109 Faucet #4	4/4/2025	ND	Non-Detect				See Map for Location	2504220
20831700-062CF	Classroom A109 Faucet #5	4/4/2025	11.5	low				See Map for Location	2504220
20831700-063CF	Classroom A109 Faucet #6 (Far Right)	4/4/2025	2.09	low				See Map for Location	2504220
20831700-064CF	Classroom A108 Faucet	4/4/2025	ND	Non-Detect					2504220
20831700-065DW	Classroom A108 Drinking Fountain	4/4/2025	ND	Non-Detect					2504220
20831700-066CF	Classroom A107 Faucet	4/4/2025	ND	Non-Detect					2504220
20831700-067DW	Classroom A107 Drinking Fountain	4/4/2025	ND	Non-Detect					2504220
20831700-068CF	Classroom A106 Faucet	4/4/2025	ND	Non-Detect					2504220
20831700-069DW	Classroom A106 Drinking Fountain	4/4/2025	ND	Non-Detect					2504220
20831700-070CF	Classroom A105 Faucet	4/4/2025	ND	Non-Detect					2504220
20831700-071DW	Classroom A105 Drinking Fountain	4/4/2025	ND	Non-Detect					2504228
20831700-072CF	Classroom A104 Faucet	4/4/2025	ND	Non-Detect					2504228
20831700-073DW	Classroom A104 Drinking Fountain	4/4/2025	ND	Non-Detect					2504228
20831700-074CF	Classroom A102 Faucet	4/4/2025	ND	Non-Detect					2504228
20831700-075DW	Classroom A102 Drinking Fountain	4/4/2025	ND	Non-Detect					2504228
20831700-076CF	Classroom A101 Faucet	4/4/2025	5.49	low					2504228
20831700-077DW	Classroom A101 Drinking Fountain	4/4/2025	ND	Non-Detect					2504228
20831700-078DW	Drinking Fountain (Next To Elevator 2nd Floor Left)	4/4/2025	ND	Non-Detect					2504228
20831700-079DW	Drinking Fountain (Next To Elevator 2nd Floor Right)	4/4/2025	ND	Non-Detect					2504228
20831700-080CF	Classroom B110 Faucet	4/4/2025	ND	Non-Detect					2504228
20831700-081DW	Classroom B110 Drinking Fountain	4/4/2025	ND	Non-Detect					2504228
20831700-082BF	Girls Bradley Bathroom Faucet #1 (Far Left)	4/4/2025	ND	Non-Detect					2504228
20831700-083BF	Girls Bradley Bathroom Faucet #2							NOT IN USE	
20831700-084BF	Girls Bradley Bathroom Faucet #3	4/4/2025	ND	Non-Detect					2504228
20831700-085BF	Girls Bradley Bathroom Faucet #4 (Far Right)	4/4/2025	ND	Non-Detect					2504228
20831700-086BF	Staff Bathroom Faucet (Next To Girls RR)	4/4/2025	ND	Non-Detect					2504228
20831700-087BF	Boys Bradley Bathroom Faucet #1 (Far Left)							NOT IN USE	
20831700-088BF	Boys Bradley Bathroom Faucet #2	4/4/2025	ND	Non-Detect					2504228
20831700-089BF	Boys Bradley Bathroom Faucet #3							NOT IN USE	
20831700-090BF	Boys Bradley Bathroom Faucet #4 (Far Right)	4/4/2025	ND	Non-Detect					2504228

Agnes Stewart Middle School							Old Building ID#		
ODE Building # 20831700							13531300		
Fixture ID #	Fixture Description per Location	Initial Test Date	Initial Test Result (ppb)	Initial Level	Final Retest Date	Final Test Result (ppb)	Final Level	Notes	Order No.:
20831700-091CF	Classroom B109 Faucet #1 (Front Of Classroom)	4/4/2025	ND	Non-Detect				See Map for location	2504226
20831700-092CF	Classroom B109 Faucet #2 (Far Left)	4/4/2025	ND	Non-Detect				See Map for location	2504226
20831700-093CF	Classroom B109 Faucet #3	4/4/2025	ND	Non-Detect				See Map for location	2504226
20831700-094CF	Classroom B109 Faucet #4	4/4/2025	2.11	low				See Map for location	2504226
20831700-095CF	Classroom B109 Faucet #5	4/4/2025	ND	Non-Detect				See Map for location	2504226
20831700-096CF	Classroom B109 Faucet #6 (Far Right)	4/4/2025	ND	Non-Detect				See Map for location	2504226
20831700-097CF	Classroom B108 Faucet	4/4/2025	ND	Non-Detect					2504226
20831700-098DW	Classroom B108 Drinking Fountain	4/4/2025	ND	Non-Detect					2504226
20831700-099CF	Classroom B107 Faucet	4/4/2025	ND	Non-Detect					2504226
20831700-100DW	Classroom B107 Drinking Fountain	4/4/2025	ND	Non-Detect					2504226
20831700-101CF	Classroom B106 Faucet	4/4/2025	ND	Non-Detect					2504226
20831700-102DW	Classroom B106 Drinking Fountain	4/4/2025	ND	Non-Detect					2504226
20831700-103CF	Classroom B105 Faucet	4/4/2025	ND	Non-Detect					2504226
20831700-104DW	Classroom B105 Drinking Fountain	4/7/2025	ND	Non-Detect					2504253
20831700-105CF	Classroom B104 Faucet	4/7/2025	ND	Non-Detect					2504253
20831700-106DW	Classroom B104 Drinking Fountain	4/7/2025	ND	Non-Detect					2504253
20831700-107CF	Classroom B102 Faucet	4/7/2025	ND	Non-Detect					2504253
20831700-108DW	Classroom B102 Drinking Fountain	4/7/2025	ND	Non-Detect					2504253
20831700-109CF	Classroom B101 Faucet	4/7/2025	ND	Non-Detect					2504253
20831700-110DW	Classroom B101 Drinking Fountain	4/7/2025	ND	Non-Detect					2504253
20831700-111CF	Classroom C110 Faucet - C-Wing	4/7/2025	ND	Non-Detect					2504253
20831700-112DW	Classroom C110 Drinking Fountain	4/7/2025	ND	Non-Detect					2504253
20831700-113BF	Girls Bradley Bathroom Faucet #1 (Far Left)	4/7/2025	ND	Non-Detect					2504253
20831700-114BF	Girls Bradley Bathroom Faucet #2							NOT IN USE	
20831700-115BF	Girls Bradley Bathroom Faucet #3							NOT IN USE	
20831700-116BF	Girls Bradley Bathroom Faucet #4 (Far Right)	4/7/2025	ND	Non-Detect					2504253
20831700-117BF	Staff Bathroom Faucet (Next To Girls RR)	4/7/2025	ND	Non-Detect					2504253
20831700-118BF	Boys Bradley Bathroom Faucet #1 (Far Left)	4/7/2025	ND	Non-Detect					2504253
20831700-119BF	Boys Bradley Bathroom Faucet #2	4/7/2025	ND	Non-Detect					2504253
20831700-120BF	Boys Bradley Bathroom Faucet #3							NOT IN USE	
20831700-121BF	Boys Bradley Bathroom Faucet #4 (Far Right)	4/7/2025	2.31	low					2504253
20831700-122CF	Classroom C109 Faucet #1(Front of classroom)	4/7/2025	ND	Non-Detect				See Map for location	2504253
20831700-123CF	Classroom C109 Faucet #2 (Far Left)	4/7/2025	2.67	low				See Map for location	2504253
20831700-124CF	Classroom C109 Faucet #3	4/7/2025	ND	Non-Detect				See Map for location	2504253
20831700-125CF	Classroom C109 Faucet #4	4/7/2025	2.36	low				See Map for location	2504253
20831700-126CF	Classroom C109 Faucet #5	4/7/2025	5.54	moderate				See Map for location	2504253
20831700-127CF	Classroom C109 Faucet #6 (Far Right)	4/7/2025	ND	Non-Detect				See Map for location	2504254
20831700-128CF	Classroom C108 Faucet	4/7/2025	ND	Non-Detect					2504254
20831700-129DW	Classroom C108 Drinking Fountain	4/7/2025	ND	Non-Detect					2504254
20831700-130CF	Classroom C107 Faucet	4/7/2025	ND	Non-Detect					2504254
20831700-131DW	Classroom C107 Drinking Fountain	4/7/2025	ND	Non-Detect					2504254
20831700-132CF	Classroom C106 Faucet	4/7/2025	ND	Non-Detect					2504254
20831700-133DW	Classroom C106 Drinking Fountain	4/7/2025	ND	Non-Detect					2504254
20831700-134CF	Classroom C105 Faucet	4/7/2025	3.3	low					2504254
20831700-135DW	Classroom C105 Drinking Fountain	4/7/2025	ND	Non-Detect					2504254

Agnes Stewart Middle School							Old Building ID#		
ODE Building # 20831700							13531300		
Fixture ID #	Fixture Description per Location	Initial Test Date	Initial Test Result (ppb)	Initial Level	Final Retest Date	Final Test Result (ppb)	Final Level	Notes	Order No.:
20831700-136CF	Classroom C104 Faucet	4/7/2025	ND	Non-Detect					2504254
20831700-137DW	Classroom C104 Drinking Fountain	4/7/2025	ND	Non-Detect					2504254
20831700-138CF	Classroom C102 Faucet	4/7/2025	ND	Non-Detect					2504254
20831700-139DW	Classroom C102 Drinking Fountain	4/7/2025	ND	Non-Detect					2504254
20831700-140CF	Classroom C101 Faucet	4/7/2025	ND	Non-Detect					2504254
20831700-141DW	Classroom C101 Drinking Fountain	4/7/2025	ND	Non-Detect					2504254
20831700-142DW	Dinking Fountain (Outside Boy's Locker Room) GYM (Left)	4/7/2025	ND	Non-Detect					2504254
20831700-143DW	Dinking Fountain (Outside Boy's Locker Room) GYM (Right)	4/7/2025	ND	Non-Detect					2504254
20831700-144BF	Boy's Locker Room Teacher Bathrom Faucet	4/7/2025	ND	Non-Detect					2504254
20831700-145BF	Boy's Locker Room Bradley Bathrom Faucet #1 (Far Left)	4/7/2025	5.71	moderate					2504252
20831700-146BF	Boy's Locker Room Bradley Bathrom Faucet #2	4/7/2025	3.08	low					2504252
20831700-147BF	Boy's Locker Room Bradley Bathrom Faucet #3	4/7/2025	3.22	low					2504252
20831700-148BF	Boy's Locker Room Bradley Bathrom Faucet #4 (Far Right)	4/7/2025	4.62	low					2504252
20831700-149BF	Boys Bradley Bathroom Faucet #1 (Far Left)	4/7/2025	2.75	low					2504252
20831700-150BF	Boys Bradley Bathroom Faucet #2	4/7/2025	ND	Non-Detect					2504252
20831700-151BF	Boys Bradley Bathroom Faucet #3	4/7/2025	ND	Non-Detect					2504252
20831700-152BF	Boys Bradley Bathroom Faucet #4 (Far Right)	4/7/2025	ND	Non-Detect					2504252
20831700-153BF	Girl's Bradley Bathroom Faucet #1 (Far Left)	4/7/2025	2.05	low					2504252
20831700-154BF	Girl's Bradley Bathroom Faucet #2	4/7/2025	ND	Non-Detect					2504252
20831700-155BF	Girl's Bradley Bathroom Faucet #3	4/7/2025	ND	Non-Detect					2504252
20831700-156BF	Girl's Bradley Bathroom Faucet #4 (Far Right)	4/7/2025	ND	Non-Detect					2504252
20831700-157BF	Girl's Locker Room Teacher Bathroom Faucet	4/7/2025	ND	Non-Detect					2504252
20831700-158BF	Girl's Locker Room Bradlet Bathroom Faucet #1	4/7/2025	2.9	low					2504252
20831700-159BF	Girl's Locker Room Bradlet Bathroom Faucet #2	4/7/2025	ND	Non-Detect					2504252
20831700-160BF	Girl's Locker Room Bradlet Bathroom Faucet #3	4/7/2025	ND	Non-Detect					2504252
20831700-161BF	Girl's Locker Room Bradlet Bathroom Faucet #4	4/7/2025	2.25	low					2504252