

Brattain Campus High School (Gateways)									
ODE Building # 13541800									
Fixture ID #	Fixture Description per Location	Initial Test Date	Initial Test Result (ppb)	Initial Level	Final Retest Date	Final Test Result (ppb)	Final Level	Notes	Order No.:
13541800-001SF	Staff faucet breakroom	3/14/2023	2.51	Low					2303520
13541800-002BF	Bathroom Faucet nurse office	3/14/2023	5.08	Moderate					2303520
13541800-003BF	Bathroom Faucet Breakroom	3/14/2023	3.16	Low					2303520
13541800-004SF	Nursing room staff faucet	3/14/2023	8.19	Moderate					2303520
13541800-005BF	Boys bathroom faucet across from room 12 (north)	3/14/2023	23.90	Action Req	5/21/2025	3.15	Low		2303520
13541800-006BF	Boys bathroom faucet	3/14/2023	10.90	High					2303520
13541800-007BF	Boys bathroom faucet	3/14/2023	5.75	Moderate					2303520
13541800-008BF	Girls bathroom faucet	3/14/2023	11.60	High					2303520
13541800-009BF	Girls bathroom faucet	3/14/2023	5.65	Moderate					2303520
13541800-010BF	Girls bathroom faucet	3/14/2023	26.90	Action Req	5/21/2025	3.88	Low		2303520
13541800-011DW	Drinking Fountain between room 13 and 14	3/14/2023	ND	Non-Detect					2303520
13541800-012WB	Water bottle filler	3/14/2023	ND	Non-Detect					2303520
13541800-013BF	Boys bathroom faucet across from room 5 (south)	3/14/2023	ND	Non-Detect					2303520
13541800-014BF	Boys bathroom faucet	3/14/2023	ND	Non-Detect					2303520
13541800-015BF	Girls bathroom faucet	3/14/2023	5.30	Moderate					2303520
13541800-016BF	Girls bathroom faucet	3/14/2023	5.36	Moderate					2303520
13541800-017BF	Girls bathroom faucet	3/14/2023	7.33	Moderate					2303520
13541800-018DW	Drinking Fountain between room 2 and 3	3/14/2023	ND	Non-Detect					2303520
13541800-019WB	Water bottle filler	3/14/2023	ND	Non-Detect					2303520
13541800-020DW	Drinking Fountain in cafeteria	3/14/2023	ND	Non-Detect					2303520
13541800-021WB	Water bottle filler	3/14/2023	ND	Non-Detect					2303520
13541800-022WB	Kitchen Faucet 1	3/14/2023	37.50	Action Req	5/21/2025	3.79	Low		2505703
13541800-023KF	Kitchen Faucet 2	3/14/2023	42.70	Action Req	5/21/2025	7.74	Moderate		2505703
13541800-024KF	Kitchen Faucet 3	3/14/2023	65.50	Action Req	5/21/2025	2.88	Low		2505703
13541800-025BF	Kitchen bathroom faucet	3/14/2023	145.00	Action Req	5/21/2025	43.4	Action Req	Water shut off	2505703