

Briggs Middle School
 ODE Building # 05421400

Fixture ID #	Fixture Description per Location	Initial Test Date	Initial Test Result (ppb)	Initial Level	Final Retest Date	Final Test Result (ppb)	Final Level	Notes	Order No:
05421400-001SF	Front office Staff bathroom faucet 1	2/13/2024	ND	Non-Detect					2402462
05421400-002BF	Staff bathroom faucet 1	2/13/2024	2.22	Low					2402462
05421400-003BF	Nurse office bathroom faucet 1	2/13/2024	3.05	Low					2402462
05421400-004NS	Nurse office sink	2/13/2024	3.75	Low					2402462
05421400-005BF	T.A.B room bathroom faucet	2/13/2024	ND	Non-Detect					2402462
05421400-006SF	Library staff room sink	2/13/2024	ND	Non-Detect					2402462
05421400-007CF	Classroom 2 classroom faucet	2/13/2024	4.68	Low					2402462
05421400-008BF	Boys bathroom faucet	2/13/2024	ND	Non-Detect					2402462
05421400-009BF	Boys bathroom faucet	2/13/2024	ND	Non-Detect					2402462
05421400-010DW	Drinking fountain	2/13/2024	ND	Non-Detect					2402462
05421400-011WB	Water fill station	2/13/2024	ND	Non-Detect					2402462
05421400-012BF	Girls bathroom faucet	2/13/2024	ND	Non-Detect					2402462
05421400-013BF	Girls bathroom faucet	2/13/2024	ND	Non-Detect					2402462
05421400-014SF	Staff room between class room 6 & 7 faucet	2/13/2024	ND	Non-Detect					2402462
05421400-015CF	Classroom 3 faucet	2/13/2024	6.41	Moderate					2402462
05421400-016CF	Classroom 4 faucet	2/13/2024	7.65	Moderate					2402462
05421400-017DW	Classroom 4 drinking fountain	2/13/2024	6.31	Moderate					2402462
05421400-018SF	Staff room faucet	2/13/2024	4.93	Low					2402462
05421400-019SF	Staff room between class room 10 & 11 faucet	2/13/2024	63.90	Action Req	5/29/2025			Results Pending	2402462
05421400-020CF	Speech language room classroom faucet	2/13/2024	ND	Non-Detect					2402462
05421400-021DW	Drinking fountain	2/13/2024	ND	Non-Detect					2402463
05421400-022WB	Water fill station	2/13/2024	ND	Non-Detect					2402463
05421400-023CF	Classroom 13 faucet	2/13/2024	6.98	Moderate					2402463
05421400-024CF	Classroom 14 faucet	2/13/2024	4.80	Low					2402463
05421400-025SF	Staff room between class room 16 & 11 faucet	2/13/2024	13.60	High					2402463
05421400-026BF	Girls bathroom faucet	2/13/2024	ND	Non-Detect					2402463
05421400-027BF	Girls bathroom faucet	2/13/2024	ND	Non-Detect					2402463
05421400-028DW	Drinking fountain	2/13/2024	ND	Non-Detect					2402463
05421400-029BF	Boys bathroom faucet	2/13/2024	2.11	Low					2402463
05421400-030BF	Boys bathroom faucet	2/13/2024	ND	Non-Detect					2402463
05421400-031CF	Classroom 25 classroom faucet 1	2/13/2024	4.69	Low					2402463
05421400-032CF	Classroom faucet 2	2/13/2024	22.50	Action Req	NOT IN USE			Water is turned off	2402463
05421400-033CF	Classroom faucet 3	2/13/2024	23.30	Action Req	NOT IN USE			Water is turned off	2402463
05421400-034CF	Classroom faucet 4	2/13/2024	34.50	Action Req	NOT IN USE			Water is turned off	2402463
05421400-035CF	Classroom faucet 5	2/13/2024	33.80	Action Req	NOT IN USE			Water is turned off	2402463
05421400-036CF	Classroom faucet 6	2/13/2024	25.40	Action Req	5/29/2025			Results Pending	2402463
05421400-037CF	Classroom 21 classroom faucet	2/13/2024	5.00	Low					2402463
05421400-038CF	Classroom 26 classroom faucet 1	2/13/2024	ND	Non-Detect					2402463
05421400-039SF	Staff room faucet	2/13/2024	7.01	Moderate					2402463

Briggs Middle School									
ODE Building # 05421400									
Fixture ID #	Fixture Description per Location	Initial Test Date	Initial Test Result (ppb)	Initial Level	Final Retest Date	Final Test Result (ppb)	Final Level	Notes	Order No:
05421400-040SF	Staff bathroom faucet 1	2/13/2024	ND	Non-Detect					2402463
05421400-041SF	Staff bathroom faucet 2	2/13/2024	2.38	Low					2402465
05421400-042BF	Kitchen bathroom faucet	2/13/2024	ND	Non-Detect					2402465
05421400-043KF	Kitchen faucet 1	2/13/2024	2.85	Low					2402465
05421400-044KF	Kitchen faucet 2	2/13/2024	5.64	Moderate					2402465
05421400-045KF	Kitchen faucet 3	2/13/2024	11.00	High					2402465
05421400-046DW	Drinking fountain near boiler rm	2/13/2024	ND	Non-Detect					2402465
05421400-047BF	Girls bathroom faucet	2/13/2024	ND	Non-Detect					2402465
05421400-048BF	Girls bathroom faucet	2/13/2024	ND	Non-Detect					2402465
05421400-049BF	Boys bathroom faucet	2/13/2024	ND	Non-Detect					2402465
05421400-050BF	Boys bathroom faucet	2/13/2024	ND	Non-Detect					2402465
05421400-051DW	Commons Drinking fountain	2/13/2024	ND	Non-Detect					2402465
05421400-052WB	Water Bottle fill station	2/13/2024	ND	Non-Detect					2402465
05421400-053BF	CTE hallway bathroom faucet	2/13/2024	3.58	Low					2402465
05421400-054CF	Classroom 28 faucet 1	2/13/2024	5.20	Moderate					2402465
05421400-055CF	Classroom faucet 2	2/13/2024	ND	Non-Detect					2402465
05421400-056CF	Classroom faucet 3	2/13/2024	26.20	Action Req	5/29/2025			Results Pending	2402465
05421400-057CF	Classroom faucet 4	2/13/2024	ND	Non-Detect					2402465
05421400-074CF	Classroom faucet 5							NOT IN USE	
05421400-058CF	Classroom 30 faucet 1	2/13/2024	ND	Non-Detect					2402465
05421400-059CF	Classroom faucet 2	2/13/2024	ND	Non-Detect					2402465
05421400-060CF	Classroom faucet 3	2/13/2024	2.36	Low					2402465
05421400-061DW	Drinking fountain hallway	2/13/2024	ND	Non-Detect					2402467
05421400-062BF	Girls locker Bathroom faucet 1	2/13/2024	ND	Non-Detect					2402467
05421400-063BF	Bathroom faucet 2	2/13/2024	ND	Non-Detect					2402467
05421400-064DW	Drinking fountain	2/13/2024	ND	Non-Detect					2402467
05421400-065BF	CoAches bathroom faucet	2/13/2024	5.38	Moderate					2402467
05421400-066BF	Boys locker Bathroom faucet 1	2/13/2024	2.25	Low					2402467
05421400-067BF	Bathroom faucet 2	2/13/2024	ND	Non-Detect					2402467
05421400-068DW	Drinking fountain	2/13/2024	ND	Non-Detect					2402467
05421400-069BF	CoAches bathroom faucet	2/13/2024	3.49	Low					2402467
05421400-070DW	Classroom 35 drinking fountain	2/13/2024	ND	Non-Detect					2402467
05421400-071CF	Practice Room A classroom faucet 1	2/13/2024	12.60	High					2402467
05421400-072CF	Practice Room A classroom faucet 2	2/13/2024	18.50	Action Req	5/29/2025			Results Pending	2402467
05421400-073DW	Classroom 34 drinking fountain	2/13/2024	6.03	Moderate					2402467