

Centennial Elementary								Building # 0544	
ODE Building # 05440100								Campus # 01	
								Fixture # -000	
								Building location # 00	
Fixture ID #	Fixture Description per Location	Initial Test Date	Initial Test Result (ppb)	Initial Level	Final Retest Date	Final Test Result (ppb)	Final Level	Notes	Order No.:
05440100-001DW	Classroom 1 Drinking water fountain	3/1/23	4.10	Low				Bottle # 1	2303014
05440100-002CF	Classroom 1 Classroom faucet	3/1/23	4.44	Low				Bottle # 2	2303014
05440100-003DW	Classroom 2 Drinking water fountain	3/1/23	2.18	Low				Bottle # 3	2303014
05440100-004CF	Classroom 2 Classroom Faucet	3/1/23	ND	Non-Detect				Bottle # 4	2303014
05440100-005DW	Drinking water fountain hallway	3/1/23	ND	Non-Detect				Bottle # 5	2303014
05440100-006WB	Water bottle filter	3/1/23	ND	Non-Detect				Bottle # 6	2303014
05440100-007BF	Boys restroom bathroom faucet (004)	3/1/23	ND	Non-Detect				Bottle # 7	2303014
05440100-008BF	Girls restroom bathroom faucet (004)	3/1/23	ND	Non-Detect				Bottle # 8	2303014
05440100-009DW	Classroom 3 Drinking water fountain	3/1/23	ND	Non-Detect				Bottle # 9	2303014
05440100-010CF	Classroom 3 Classroom Faucet	3/1/23	ND	Non-Detect				Bottle # 10	2303014
05440100-011DW	Classroom 4 Drinking water fountain	3/1/23	2.20	Low				Bottle # 11	2303014
05440100-012CF	Classroom 4 Classroom Faucet	3/1/23	ND	Non-Detect				Bottle # 12	2303014
05440100-013DW	Classroom 5 Drinking water fountain	3/1/23	ND	Non-Detect				Bottle # 13	2303014
05440100-014CF	Classroom 5 Classroom Faucet	3/1/23	ND	Non-Detect				Bottle # 14	2303014
05440100-015DW	Classroom 6 Drinking water fountain	3/1/23	ND	Non-Detect				Bottle # 15	2303014
05440100-016CF	Classroom 6 Classroom Faucet	3/1/23	ND	Non-Detect				Bottle # 16	2303014
05440100-017DW	Classroom 7 Drinking water fountain	3/1/23	ND	Non-Detect				Bottle # 17	2303014
05440100-018CF	Classroom 7 Classroom Faucet	3/1/23	ND	Non-Detect				Bottle # 18	2303014
05440100-019DW	Classroom 8 Drinking water fountain	3/1/23	ND	Non-Detect				Bottle # 19	2303014
05440100-020CF	Classroom 8 Classroom Faucet	3/1/23	ND	Non-Detect				Bottle # 20	2303014
05440100-021BF	Boys restroom bathroom faucet (3)	3/1/23	ND	Non-Detect				Bottle # 21	2303014
05440100-022BF	Girls restroom bathroom faucet (3)	3/1/23	ND	Non-Detect				Bottle # 22	2303014
05440100-023DW	Classroom 9 Drinking water fountain	3/1/23	ND	Non-Detect				Bottle # 23	2303014
05440100-024CF	Classroom 9 Classroom Faucet	3/1/23	ND	Non-Detect				Bottle # 24	2303014
05440100-025DW	Drinking water fountain hallway	3/1/23	ND	Non-Detect				Bottle # 25	2303014
05440100-026DW	Classroom 10 Drinking water fountain	3/1/23	ND	Non-Detect				Bottle # 26	2303014
05440100-027CF	Classroom 10 Classroom Faucet	3/1/23	ND	Non-Detect				Bottle # 27	2303014
05440100-028BF	Boys restroom bathroom faucet (2)	3/1/23	ND	Non-Detect				Bottle # 28	2303014
05440100-029BF	Girls restroom bathroom faucet (2)	3/1/23	ND	Non-Detect				Bottle # 29	2303014
05440100-030DW	Classroom 11 Drinking water fountain	3/1/23	3.81	Low				Bottle # 30	2303014
05440100-031CF	Classroom 11 Classroom Faucet	3/1/23	ND	Non-Detect				Bottle # 31	2303014
05440100-032DW	Classroom 12 Drinking water fountain	3/1/23	3.00	Low				Bottle # 32	2303014
05440100-033CF	Classroom 12 Classroom Faucet	3/1/23	ND	Non-Detect				Bottle # 33	2303014
05440100-034DW	Classroom 14 Drinking water fountain	3/1/23	4.25	Low				Bottle # 34	2303014
05440100-035CF	Classroom 14 Classroom Faucet	3/1/23	ND	Non-Detect				Bottle # 35	2303014
05440100-036DW	Classroom 15 Drinking water fountain	3/1/23	ND	Non-Detect				Bottle # 36	2303014
05440100-037CF	Classroom 15 Classroom Faucet	3/1/23	ND	Non-Detect				Bottle # 37	2303014
05440100-038DW	Classroom 16 Drinking water fountain	3/1/23	2.19	Low				Bottle # 38	2303014
05440100-039CF	Classroom 16 Classroom Faucet	3/1/23	ND	Non-Detect				Bottle # 39	2303014
05440100-040DW	Classroom 17 Drinking water fountain	3/1/23	4.17	Low				Bottle # 40	2303014
05440100-041CF	Classroom 17 Classroom Faucet	3/1/23	ND	Non-Detect				Bottle # 41	2303014
05440100-042DW	Classroom 18 Drinking water fountain	3/1/23	ND	Non-Detect				Bottle # 42	2303014
05440100-043CF	Classroom 18 Classroom Faucet	3/1/23	ND	Non-Detect				Bottle # 43	2303014
05440100-044DW	Classroom 19 Drinking water fountain	3/1/23	ND	Non-Detect				Bottle # 44	2303014

Centennial Elementary								Building # 0544	
ODE Building # 05440100								Campus # 01	
								Fixture # -000	
								Building location # 00	
Fixture ID #	Fixture Description per Location	Initial Test Date	Initial Test Result (ppb)	Initial Level	Final Retest Date	Final Test Result (ppb)	Final Level	Notes	Order No.:
05440100-045CF	Classroom 19 Classroom Faucet	3/1/23	ND	Non-Detect				Bottle # 45	2303014
05440100-046DW	Drinking water fountain hallway	3/1/23	ND	Non-Detect				Bottle # 46	2303014
05440100-047WB	Water bottle filter	3/1/23	ND	Non-Detect				Bottle # 47	2303014
05440100-048BF	Girls restroom bathroom faucet (001)	3/1/23	ND	Non-Detect				Bottle # 48	2303014
05440100-049BF	Boys restroom bathroom faucet (001)	3/1/23	ND	Non-Detect				Bottle # 49	2303014
05440100-050CF	Lobby area room 21 Classroom Faucet (south)	3/1/23	ND	Non-Detect				Bottle # 50	2303014
05440100-051DW	Classroom 21 Drinking water fountain	3/1/23	ND	Non-Detect				Bottle # 51	2303016
05440100-052CF	Classroom 21 Classroom Faucet	3/1/23	ND	Non-Detect				Bottle # 52	2303016
05440100-053CF	Lobby area room 22 Classroom Faucet	3/1/23	4.75	Low				Bottle # 53	2303016
05440100-054DW	Lobby area room 22 Drinking water fountain (north)	3/1/23	6.22	Moderate				Bottle # 54	2303016
05440100-055DW	Classroom 22 Drinking water fountain	3/1/23	ND	Non-Detect				Bottle # 55	2303016
05440100-056CF	Classroom 22 Classroom Faucet	3/1/23	ND	Non-Detect				Bottle # 56	2303016
05440100-057DW	Classroom 23 Drinking water fountain	3/1/23	62.80	Action Req	9/6/2024	8.28	Moderate	Bottle # 57	2409218
05440100-058CF	Classroom 23 Classroom Faucet	3/1/23	2.26	Low				Bottle # 58	2303016
05440100-059BF	Girls restroom bathroom faucet	3/1/23	ND	Non-Detect				Bottle # 59	2303016
05440100-060BF	Girls restroom bathroom faucet backroom door on back wall of girls restroom	3/1/23	ND	Non-Detect				Bottle # 60	2303016
05440100-061BF	Boys restroom bathroom faucet	3/1/23	ND	Non-Detect				Bottle # 61	2303016
05440100-062DW	Classroom 24 Drinking water fountain	3/1/23	16.50	Action Req	9/6/2024	3.64	Low	Bottle # 62	2409218
05440100-063CF	Classroom 24 Classroom Faucet	3/1/23	ND	Non-Detect				Bottle # 63	2303016
05440100-064DW	Gym Drinking water fountain	3/1/23	ND	Non-Detect				Bottle # 64	2303016
05440100-065BF	Courtyard Grils restroom bathroom faucet (clockwise)	3/1/23	ND	Non-Detect				Bottle # 65 (clockwise)	2303016
05440100-066BF	Girls restroom bathroom faucet (clockwise)	3/1/23	ND	Non-Detect				Bottle # 66 (clockwise)	2303016
05440100-067BF	Girls restroom bathroom faucet (clockwise)	3/1/23	ND	Non-Detect				Bottle # 67 (clockwise)	2303016
05440100-068BF	Courtyard Boys restroom bathroom faucet (clockwise)	3/1/23	ND	Non-Detect				Bottle # 68 (clockwise)	2303016
05440100-069BF	Boys restroom bathroom faucet (clockwise)	3/1/23	ND	Non-Detect				Bottle # 69 (clockwise)	2303016
05440100-070BF	Boys restroom bathroom faucet (clockwise)	3/1/23	ND	Non-Detect				Bottle # 70 (clockwise)	2303016
05440100-071DW	Courtyard Drinking water fountain	3/1/23	ND	Non-Detect				Bottle # 71	2303016
05440100-072SF	Front Office staff Faucet	3/1/23	ND	Non-Detect				Bottle # 72	2303016
05440100-073NS	Nurses room faucet	3/1/23	ND	Non-Detect				Bottle # 73	2303016
05440100-074CF	Music room classroom faucet	3/1/23	ND	Non-Detect				Bottle # 74	2303016
05440100-075BF	Staff restroom 2 Bathroom faucet	3/1/23	ND	Non-Detect				Bottle # 75	2303016
05440100-076BF	Staff restroom 1 Bathroom faucet	3/1/23	ND	Non-Detect				Bottle # 76	2303016
05440100-077SF	Staff room faucet	3/1/23	ND	Non-Detect				Bottle # 77	2303016
05440100-078KF	Kitchen faucet (west)	3/1/23	10.10	High				Bottle # 78	2303016
05440100-079KF	Kitchen faucet (north)	3/1/23	ND	Non-Detect				Bottle # 79	2303016
05440100-080KF	Kitchen faucet (east)	3/1/23	ND	Non-Detect				Bottle # 80	2303016