

Admin Building									
ODE Building #20830002									
Fixture ID #	Fixture Description per Location	Initial Test Date	Initial Test Result (ppb)	Initial Level	Final Retest Date	Final Test Result (ppb)	Final Level	Notes	Order No.:
20830002-001BF	Woman's Bathroom Faucet #1 First Floor (By Room 148)	3/27/2025	2.54	Low					2503886
20830002-002BF	Woman's Bathroom Faucet #2		ND	Non-Detect					2503886
20830002-003BF	Men's Bathroom Faucet #1		ND	Non-Detect					2503886
20830002-004BF	Men's Bathroom Faucet #2		ND	Non-Detect					2503886
20830002-005SF	Office Faucet		ND	Non-Detect					2503886
20830002-006SF	Instant Hot Water Faucet (By Room 148)		ND	Non-Detect					2503886
20830002-007WB	Water Bottle Fill (By Room 142)		ND	Non-Detect					2503886
20830002-008BF	Bathroom Faucet (By Room 130)		ND	Non-Detect					2503886
20830002-009SF	Office Faucet		ND	Non-Detect					2503886
20830002-010SF	Instant Hot Water Faucet (By Room 130)		ND	Non-Detect					2503886
20830002-011BF	Men's Bathroom Faucet (By Room 119)		ND	Non-Detect					2503886
20830002-012BF	Woman's Bathroom Faucet		ND	Non-Detect					2503886
20830002-013WB	Water Bottle Fill Second Floor (Next To Room 206)		ND	Non-Detect					2503886
20830002-014DW	Drinking Fountain (With Bottle Fill)		ND	Non-Detect					2503886
20830002-015DW	Drinking Fountain (Without Bottle Fill)		ND	Non-Detect					2503886
20830002-016BF	Men's Bathroom Faucet (By Board Room)		ND	Non-Detect					2503886
20830002-017BF	Woman's Bathroom Faucet #1		ND	Non-Detect					2503886
20830002-018BF	Woman's Bathroom Faucet #2		ND	Non-Detect					2503886
20830002-019BF	Bathroom Faucet (Next to Room 217)		ND	Non-Detect					2503886
20830002-020BF	Bathroom Faucet (By Stairs)		ND	Non-Detect					2503886
20830002-021SF	Staff Room Faucet		ND	Non-Detect					2503887
20830002-022SF	Staff Room Instant Hot Water Faucet		ND	Non-Detect					2503887
20830002-023WB	Bottle Fill (Outside Staff Room)		ND	Non-Detect					2503887