

Douglas Garden Elementary									Main Office Building # 05450200	Red	Green
ODE Building # 05450200									Purple Pod building # 05450201	Yellow	Gym
											Music
Fixture ID #	Fixture Description per Location	Initial Test Date	Initial Test Result (ppb)	Initial Level	Final Retest Date	Final Test Result (ppb)	Final Level	Notes	Order No:		
05450200-001NS	Nurses sink front office (FRONT OFFICE)	3/7/23	ND	Non-Detect				Bottle # 1	2303195		
05450200-002BF	Nurses Bathroom Faucet	3/7/23	ND	Non-Detect				Bottle # 2	2303195		
05450200-003BF	Womens Restroom Bathroom Faucet	3/7/23	ND	Non-Detect				Bottle # 3	2303195		
05450200-004BF	Mens Restroom Bathroom Faucet	3/7/23	ND	Non-Detect				Bottle # 4	2303195		
05450200-005SF	Staff faucet north	3/7/23	ND	Non-Detect				Bottle # 5	2303195		
05450200-006SF	Staff Faucet south	3/7/23	2.08	Low				Bottle # 6	2303195		
05450200-007DW	Classroom 1 Drinking Water Fountain (POD A PURPLE)	3/7/23	ND	Non-Detect				Bottle # 7	2303195		
05450200-008CF	Classroom 1 Classroom Faucet	3/7/23	ND	Non-Detect				Bottle # 8	2303195		
05450200-009DW	Classroom 2 Drinking Water Fountain	3/7/23	ND	Non-Detect				Bottle # 9	2303195		
05450200-010CF	Classroom 2 Classroom Faucet	3/7/23	ND	Non-Detect				Bottle # 10	2303195		
05450200-011DW	Classroom 3 Drinking Water Fountain	3/7/23	ND	Non-Detect				Bottle # 11	2303195		
05450200-012CF	Classroom 3 Classroom Faucet	3/7/23	ND	Non-Detect				Bottle # 12	2303195		
05450200-013BF	Bathroom Faucet	3/7/23	ND	Non-Detect				Bottle # 13	2303195		
05450200-014BF	Bathroom Faucet	3/7/23	ND	Non-Detect				Bottle # 14	2303195		
05450200-015DW	Classroom 4 Drinking Water Fountain	3/7/23	ND	Non-Detect				Bottle # 15	2303195		
05450200-016CF	Classroom 4 Classroom Faucet	3/7/23	ND	Non-Detect				Bottle # 16	2303195		
05450200-017DW	Classroom 5 Drinking Water Fountain	3/7/23	ND	Non-Detect				Bottle # 17	2303195		
05450200-018CF	Classroom 5 Classroom Faucet	3/7/23	ND	Non-Detect				Bottle # 18	2303195		
05450200-019DW	Classroom 6 Drinking Water Fountain	3/7/23	ND	Non-Detect				Bottle # 19	2303195		
05450200-020CF	Classroom 6 Classroom Faucet	3/7/23	ND	Non-Detect				Bottle # 20	2303195		
05450200-021DW	Classroom 7 Drinking Water Fountain (POD E GREEN)	3/7/23	2.74	Low				Bottle # 21	2303196		
05450200-022CF	Classroom 7 Classroom Faucet	3/7/23	ND	Non-Detect				Bottle # 22	2303196		
05450200-023DW	Classroom 8 Drinking Water Fountain	3/7/23	ND	Non-Detect				Bottle # 23	2303196		
05450200-024CF	Classroom 8 Classroom Faucet	3/7/23	ND	Non-Detect				Bottle # 24	2303196		
05450200-025DW	Classroom 9 Drinking Water Fountain	3/7/23	ND	Non-Detect				Bottle # 25	2303196		
05450200-026CF	Classroom 9 Classroom Faucet	3/7/23	ND	Non-Detect				Bottle # 26	2303196		
05450200-027DW	Classroom 10 Drinking Water Fountain	3/7/23	ND	Non-Detect				Bottle # 27	2303196		
05450200-028CF	Classroom 10 Classroom Faucet	3/7/23	ND	Non-Detect				Bottle # 28	2303196		
05450200-029DW	Classroom 11 Drinking Water Fountain	3/7/23	ND	Non-Detect				Bottle # 29	2303196		
05450200-030CF	Classroom 11 Classroom Faucet	3/7/23	ND	Non-Detect				Bottle # 30	2303196		
05450200-031DW	Classroom 12 Drinking Water Fountain	3/7/23	ND	Non-Detect				Bottle # 31	2303196		
05450200-032CF	Classroom 13 Classroom Faucet (PODF YELLOW)	3/7/23	ND	Non-Detect				Bottle # 32	2303196		
05450200-033DW	Classroom 13 Drinking Water Fountain	3/7/23	18.20	Action Req	9/6/2024	14	High	Bottle # 33	2409219		
05450200-034CF	Classroom 14 Classroom Faucet	3/7/23	9.29	Moderate				Bottle # 34	2303196		
05450200-035DW	Classroom 14 Drinking Water Fountain	3/7/23	6.71	Moderate				Bottle # 35	2303196		
05450200-036CF	Classroom 15 Classroom Faucet	3/7/23	2.69	Low				Bottle # 36	2303196		
05450200-037DW	Classroom 15 Drinking Water Fountain	3/7/23	20.40	Action Req	9/6/2024	8.11	Moderate	Bottle # 37	2409219		
05450200-038CF	Classroom 16 Classroom Faucet	3/7/23	4.96	Low				Bottle # 38	2303196		
05450200-039DW	Classroom 16 Drinking Water Fountain	3/7/23	7.14	Moderate				Bottle # 39	2303196		
05450200-040CF	Classroom 17 Classroom Faucet	3/7/23	9.39	Moderate				Bottle # 40	2303196		
05450200-041DW	Classroom 17 Drinking Water Fountain	3/7/23	4.68	Low				Bottle # 41	2303197		
05450200-042CF	Classroom 18 Classroom Faucet	3/7/23	ND	Non-Detect				Bottle # 42	2303197		
05450200-043DW	Classroom 18 Drinking Water Fountain	3/7/23	7.29	Moderate				Bottle # 43	2303197		
05450200-044DW	GYM Drinking Water Fountain (GYM)	3/7/23	4.65	Low				Bottle # 44	2303197		
05450200-045WB	Gym Water Bottle Filler	3/7/23	ND	Non-Detect				Bottle # 45	2303197		
05450200-046BF	Boys bathroom Faucet	3/7/23	ND	Non-Detect				Bottle # 46	2303197		
05450200-047BF	Staff Bathroom faucet	3/7/23	ND	Non-Detect				Bottle # 47	2303197		
05450200-048BF	Girls bathroom faucet	3/7/23	2.52	Low				Bottle # 48	2303197		
05450200-049KF	Kitchen Faucet near dishwasher (KITCHEN)	3/7/23	ND	Non-Detect				Bottle # 49	2303197		
05450200-050SF	Staff Faucet hand wash	3/7/23	2.00	Low				Bottle # 50	2303197		
05450200-051KF	Kitchen Faucet	3/7/23	9.21	Moderate				Bottle # 51	2303197		

Douglas Garden Elementary								Main Office Building # 05450200	Red	Green
ODE Building # 05450200								Purple Pod building # 05450201	Yellow	Gym
										Music
Fixture ID #	Fixture Description per Location	Initial Test Date	Initial Test Result (ppb)	Initial Level	Final Retest Date	Final Test Result (ppb)	Final Level	Notes	Order No:	
05450200-052BF	Kitchen Bathroom Faucet	3/7/23	ND	Non-Detect				Bottle # 52	2303197	
05450200-053DW	Cafeteria entrance Drinking Water Fountain (CAFETERIA)	3/7/23	ND	Non-Detect				Bottle # 53	2303197	
05450200-054DW	Classroom 19 Drinking Water Fountain (POD D RED)	3/7/23	10.70	High				Bottle # 54	2303197	
05450200-055CF	Classroom 19 Classroom Faucet	3/7/23	2.82	Low				Bottle # 55	2303197	
05450200-056DW	Classroom 20 Drinking Water Fountain	3/7/23	8.02	Moderate				Bottle # 56	2303197	
05450200-057CF	Classroom 20 Classroom Faucet	3/7/23	4.91	Low				Bottle # 57	2303197	
05450200-058DW	Classroom 21 Drinking Water Fountain	3/7/23	2.53	Low				Bottle # 58	2303197	
05450200-059CF	Classroom 21 Classroom Faucet	3/7/23	9.38	Moderate				Bottle # 59	2303197	
05450200-060CF	Classroom 22 Classroom Faucet	3/7/23	15.30	Action Req				Bottle # 60	2303197	
05450200-061BF	Bathroom Faucet between boys and girls bathroom	3/7/23	ND	Non-Detect				Bottle # 61	2303197	
05450200-062SF	Open area at entrance staff faucet	3/7/23	9.42	Moderate				Bottle # 62	2303197	