

Guy Lee Elementary
 ODE Building # 05480300

Redo or double check Map in comparison to fixture ID coding for future testing

Incorrect Missing Jody UPDATED

Fixture ID #	Fixture Description per Location	Initial Test Date	Initial Test Result (ppb)	Initial Level	Final Retest Date	Final Test Result (ppb)	Final Level	Notes	Order No.:
05480300-001NS	Nurses office nurses sink in front office area	3/1/23	ND	Non-Detect					2303012
05480300-002BF	Nurses office bathroom faucet in front office area	3/1/23	ND	Non-Detect					2303012
05480300-003BF	Staff restroom Bathroom Faucet (east)in front office area	3/1/23	ND	Non-Detect					2303012
05480300-004BF	Staff restroom Bathroom Faucet (west)in front office area	3/1/23	ND	Non-Detect					2303012
05480300-005CF	Counseling office Classroom Faucet in front office area	3/1/23	2.30	Low					2303012
05480300-006CF	Classroom # 01 Classroom Faucet	3/1/23	ND	Non-Detect					2303012
05480300-007DW	Classroom # 01 Drinking Fountain	3/1/23	ND	Non-Detect					2303012
05480300-008CF	Classroom # 03 Classroom Faucet	3/1/23	4.56	Low					2303012
05480300-009DW	Classroom # 03 Drinking Fountain	3/1/23	7.02	Moderate					2303012
05480300-010CF	Classroom # 02 Classroom Faucet	3/1/23	2.38	Low					2303012
05480300-011DW	Classroom # 02 Drinking Fountain	3/1/23	ND	Non-Detect					2303012
05480300-012CF	Classroom # 04 Classroom Faucet	3/1/23	2.34	Low					2303012
05480300-013DW	Classroom # 04 Drinking Fountain	3/1/23	ND	Non-Detect					2303012
05480300-014CF	Classroom # 06 Classroom Faucet	3/1/23	ND	Non-Detect					2303012
05480300-015DW	Classroom # 06 Drinking Fountain	3/1/23	ND	Non-Detect					2303012
05480300-016CF	Classroom # 08 Classroom Faucet	3/1/23	4.87	Low					2303012
05480300-017DW	Classroom # 08 Drinking Fountain	3/1/23	ND	Non-Detect					2303012
05480300-018CF	Classroom # 10 Classroom Faucet	3/1/23	3.69	Low					2303012
05480300-019DW	Classroom # 10 Drinking Fountain	3/1/23	ND	Non-Detect					2303012
05480300-020CF	Classroom # 12 Classroom Faucet	3/1/23	5.38	Moderate					2303012
05480300-021DW	Classroom # 12 Drinking Fountain	3/1/23	16.20	Action Req	9/6/2024	4.04	Low		2409217
05480300-022BF	Girls restroom Bradley Bathroom	3/1/23	ND	Non-Detect					2303012
05480300-023BF	Girls restroom Bradley Bathroom	3/1/23	ND	Non-Detect					2303012
05480300-024BF	Girls restroom Bradley Bathroom	3/1/23	ND	Non-Detect					2303012
05480300-028BF	Boys restroom Bradley Bathroom	3/1/23	ND	Non-Detect					2303012
05480300-029BF	Boys restroom Bradley Bathroom	3/1/23	ND	Non-Detect					2303012
05480300-030DW	Drinking water fountain	3/1/23	3.11	Low					2303012
05480300-034CF	Music Room Classroom Faucet	3/1/23	3.62	Low					2303012
05480300-035CF	Classroom # 13 Classroom Faucet	3/1/23	2.31	Low					2303012
05480300-036DW	Classroom # 13 Drinking Fountain	3/1/23	ND	Non-Detect					2303012
05480300-037CF	Classroom # 11 Classroom Faucet	3/1/23	6.34	Moderate					2303012
05480300-038DW	Classroom # 11 Drinking Fountain	3/1/23	10.10	High					2303012
05480300-039CF	Classroom # 09 Classroom Faucet	3/1/23	3.40	Low					2303012
05480300-040DW	Classroom # 09 Drinking Fountain	3/1/23	2.26	Low					2303012
05480300-041CF	Classroom # 07 Classroom Faucet	3/1/23	4.46	Low					2303012
05480300-042DW	Classroom # 07 Drinking Fountain	3/1/23	36.60	Action Req	9/6/2024	ND	Non-Detect		2409217
05480300-043CF	PSY Room Classroom Faucet	3/1/23	3.12	Low					2303012
05480300-044CF	Speech Room Classroom Faucet	3/1/23	7.25	Moderate					2303012
05480300-045CF	Classroom # 5 Classroom Faucet	3/1/23	3.59	Low					2303012
05480300-046CF	Staff Room Staff Faucet	3/1/23	2.97	Low					2303012
05480300-047BF	Staff Room Bathroom Faucet	3/1/23	ND	Non-Detect					2303012
05480300-048CF	Classroom # 20 Drinking Fountain	3/1/23	ND	Non-Detect					2303012

Guy Lee Elementary		Redo or double check Map in comparison to fixture ID coding for future testing							
ODE Building # 05480300									
		Incorrect	Missing	Jody UPDATED					
Fixture ID #	Fixture Description per Location	Initial Test Date	Initial Test Result (ppb)	Initial Level	Final Retest Date	Final Test Result (ppb)	Final Level	Notes	Order No.:
05480300-049DW	Classroom # 20 Classroom faucet	3/1/23	ND	Non-Detect					2303012
05480300-050CF	Classroom # 22 Classroom Faucet	3/1/23	5.73	Moderate					2303012
05480300-051DW	Classroom # 22 Drinking Fountain	3/1/23	7.53	Moderate					2303012
05480300-052CF	Classroom # 24 Classroom Faucet	3/1/23	ND	Non-Detect					2303012
05480300-053DW	Classroom # 24 Drinking Fountain	3/1/23	ND	Non-Detect					2303012
05480300-061BF	Boys restroom Bradley Bradley	3/1/23	ND	Non-Detect					2303015
05480300-062BF	Boys restroom Bradley Bradley	3/1/23	3.07	Low					2303015
05480300-063BF	Boys restroom Bradley Bradley	3/1/23	ND	Non-Detect					2303015
05480300-069DW	Drinking water fountain	3/1/23	ND	Non-Detect					2303015
05480300-070BF	Girls restroom Bradley	3/1/23	ND	Non-Detect					2303015
05480300-071BF	Girls restroom Bradley	3/1/23	ND	Non-Detect					2303015
05480300-072BF	Girls restroom Bradley	3/1/23	3.10	Low					2303015
05480300-073CF	Classroom # 25 Classroom Faucet	3/1/23	3.17	Low					2303015
05480300-074DW	Classroom # 25 Drinking Fountain	3/1/23	ND	Non-Detect					2303015
05480300-075CF	Classroom # 23 Classroom Faucet	3/1/23	ND	Non-Detect					2303015
05480300-076DW	Classroom # 23 Drinking Fountain	3/1/23	ND	Non-Detect					2303015
05480300-077CF	Classroom # 21 Classroom Faucet	3/1/23	ND	Non-Detect					2303015
05480300-078DW	Classroom # 21 Drinking Fountain	3/1/23	ND	Non-Detect					2303015
05480300-079CF	Classroom # 19 Classroom Faucet	3/1/23	2.22	Low					2303015
05480300-080DW	Classroom # 19 Drinking Fountain	3/1/23	3.94	Low					2303015
05480300-081CF	Classroom # 17 Classroom Faucet	3/1/23	4.21	Low					2303015
05480300-082DW	Classroom # 17 Drinking Fountain	3/1/23	ND	Non-Detect					2303015
05480300-083CF	Classroom # 15 Classroom Faucet	3/1/23	8.22	Moderate					2303015
05480300-084DW	Classroom # 15 Drinking Fountain	3/1/23	ND	Non-Detect					2303015
05480300-085BF	Boys restroom Bradley Bathroom Faucet # 1 (behind cafeteria)	3/1/23	7.98	Moderate					2303015
05480300-086BF	Boys restroom Bradley Bathroom Faucet # 2 (behind cafeteria)	3/1/23	4.99	Low					2303015
05480300-087BF	Boys restroom Bradley Bathroom Faucet # 3(behind cafeteria)	3/1/23	3.97	Low					2303015
05480300-088BF	Boys restroom Bradley Bathroom Faucet # 1 (behind cafeteria)	3/1/23	3.10	Low					2303015
05480300-089BF	Boys restroom Bradley Bathroom Faucet # 2 (behind cafeteria)	3/1/23	ND	Non-Detect					2303015
05480300-090BF	Boys restroom Bradley Bathroom Faucet # 3 (behind cafeteria)	3/1/23	ND	Non-Detect					2303015
05480300-091BF	Girls restroom Bradley Bathroom Faucet # 1 (behind cafeteria)	3/1/23	9.78	Moderate					2303015
05480300-092BF	Girls restroom Bradley Bathroom Faucet # 2 (behind cafeteria)	3/1/23	4.24	Low					2303015
05480300-093BF	Girls restroom Bradley Bathroom Faucet # 3 (behind cafeteria)	3/1/23	3.69	Low					2303015
05480300-094BF	Girls restroom Bradley Bathroom Faucet # 1 (behind cafeteria)	3/1/23	3.15	Low					2303015
05480300-095BF	Girls restroom Bradley Bathroom Faucet # 2 (behind cafeteria)	3/1/23	3.78	Low					2303015
05480300-096BF	Girls restroom Bradley Bathroom Faucet # 3 (behind cafeteria)	3/1/23	ND	Non-Detect					2303015
05480300-097DW	Cafeteria east wall Drinking Fountain	3/1/23	ND	Non-Detect					2303015
05480300-098KF	Kitchen (south east wall) Kitchen /food prep	3/1/23	ND	Non-Detect					2303015
05480300-099KF	Kitchen (south west wall) Kitchen /food prep	3/1/23	ND	Non-Detect					2303015
05480300-100KF	Kitchen (north east wall) Kitchen /food prep	3/1/23	ND	Non-Detect					2303015
05480300-101BF	Kitchen staff women restroom Bathroom Faucet	3/1/23	ND	Non-Detect					2303015
05480300-102BF	Restroom Staff mens boiler room Bathroom Faucet	3/1/23	ND	Non-Detect					2303015

Guy Lee Elementary						Redo or double check Map in comparison to fixture ID coding for future testing				
ODE Building # 05480300										
		Incorrect	Missing	Jody UPDATED						
Fixture ID #	Fixture Description per Location	Initial Test Date	Initial Test Result (ppb)	Initial Level	Final Retest Date	Final Test Result (ppb)	Final Level	Notes	Order No.:	
05480300-103DW	Drinking fountain in between restrooms (behind cafeteria)	3/1/23	ND	Non-Detect					2303015	
05480300-104BF	Water bottle filler (behind cafeteria)	3/1/23	ND	Non-Detect					2303015	
05480300-105DW	Classroom 16 Drinking water fountain	3/1/23	ND	Non-Detect					2303015	
05480300-107DW	Classroom 16 Classroom faucet	3/1/23	6.89	Moderate					2303015	
05480300-108CF	Classroom 14 Drinking water fountain	3/1/23	2.11	Low					2303015	
05480300-106CF	Classroom 14 classroom faucet	3/1/23	2.48	Low					2303015	