

Mt. Vernon									
ODE Building # 05540500									
Fixture ID #	Fixture Description per Location	Initial Test Date	Initial Test Result (ppb)	Initial Level	Final Retest Date	Final Test Result (ppb)	Final Level	Notes	Order No.:
1911763-001A	Kitchen Bathroom	11/19/2019	2.69	Low					1911763
1911763-002A	Kitchen Prewash	11/19/2019	ND	Non-Detect					1911763
1911763-003A	Office Health Restroom	11/19/2019	2.77	Low					1911763
1911763-004A	Office Staff Restroom North	11/19/2019	ND	Non-Detect					1911763
1911763-005A	Office Staff Restroom South	11/19/2019	ND	Non-Detect					1911763
1911763-006A	Office Work Room	11/19/2019	2.57	Low					1911763
1911763-007A	Cafeteria RR Girls Wash Station #1	11/19/2019	3.20	Low					1911763
1911763-008A	Cafeteria RR Girls Wash Station #2	11/19/2019	ND	Non-Detect					1911763
1911763-009A	Cafeteria RR Girls Wash Station #3	11/19/2019	ND	Non-Detect					1911763
1911763-010A	Cafeteria RR Girls Wash Station #4	11/19/2019	2.97	Low					1911763
1911763-011A	Cafeteria Drinking Fountain Bottle Filler	11/19/2019	ND	Non-Detect					1911763
1911763-012A	Cafeteria Drinking Fountain W	11/19/2019	ND	Non-Detect					1911763
1911763-013A	A Wing RR Girls Wash Station #2	11/19/2019	6.73	Moderate					1911763
1911763-014A	A Wing RR Girls Wash Station #3	11/19/2019	4.49	Low					1911763
1911763-015A	A Wing RR Girls Wash Station #4	11/19/2019	2.17	Low					1911763
1911763-016A	A Wing Staff Restroom	11/19/2019	ND	Non-Detect					1911763
1911763-017A	A Wing Commons Bubbler	11/19/2019	ND	Non-Detect					1911763
1911763-018A	A Wing Commons Faucet	11/19/2019	ND	Non-Detect					1911763
1911763-019A	A Wing Rm A101 Faucet	11/19/2019	ND	Non-Detect					1911763
1911763-020A	A Wing Rm A101 Bubbler	11/19/2019	ND	Non-Detect					1911763
1911763-021A	A Wing Rm A102 Faucet	11/19/2019	ND	Non-Detect					1911763
1911763-022A	A Wing Rm A102 Bubbler	11/19/2019	ND	Non-Detect					1911763
1911763-023A	A Wing Rm A103 Faucet	11/19/2019	ND	Non-Detect					1911763
1911763-024A	A Wing Rm A103 Bubbler	11/19/2019	ND	Non-Detect					1911763
1911763-025A	A Wing Rm A104 Faucet	11/19/2019	ND	Non-Detect					1911763
1911763-026A	A Wing Rm A104 Bubbler	11/19/2019	ND	Non-Detect					1911763
1911763-027A	B Wing Rm 220 Faucet	11/19/2019	ND	Non-Detect					1911763
1911763-028A	B Wing RR Girls Wash Station #1	11/19/2019	6.92	Moderate					1911763
1911763-029A	B Wing RR Girls Wash Station #2	11/19/2019	ND	Non-Detect					1911763
1911763-030A	B Wing RR Girls Wash Station #3	11/19/2019	2.93	Low					1911763
1911763-031A	B Wing RR Girls Wash Station #4	11/19/2019	2.38	Low					1911763
1911763-032A	B Wing Rm B101 Faucet	11/19/2019	ND	Non-Detect					1911763
1911763-033A	B Wing Rm B101 Bubbler	11/19/2019	ND	Non-Detect					1911763
1911763-034A	B Wing Rm B102 Faucet	11/19/2019	ND	Non-Detect					1911763
1911763-035A	B Wing Rm B102 Bubbler	11/19/2019	ND	Non-Detect					1911763
1911763-036A	B Wing Rm B103 Faucet	11/19/2019	ND	Non-Detect					1911763

Mt. Vernon									
ODE Building # 05540500									
Fixture ID #	Fixture Description per Location	Initial Test Date	Initial Test Result (ppb)	Initial Level	Final Retest Date	Final Test Result (ppb)	Final Level	Notes	Order No.:
1911763-037A	B Wing Rm B103 Bubblers	11/19/2019	ND	Non-Detect					1911763
1911763-038A	C Wing Drinking Fountain	11/19/2019	ND	Non-Detect					1911763
1911763-039A	C Wing RR Girls Wash Station #1	11/19/2019	4.34	Low					1911763
1911763-040A	C Wing RR Girls Wash Station #2	11/19/2019	2.88	Low					1911763
1911763-041A	C Wing RR Girls Wash Station #3	11/19/2019	2.55	Low					1911763
1911763-042A	C Wing RR Girls Wash Station #4	11/19/2019	3.27	Low					1911763
1911763-043A	C Wing Rm C101 Faucet	11/19/2019	16.50	Action Req	12/4/2019	ND	Non-Detect		1912191
1911763-044A	C Wing Rm C101 Bubblers	11/19/2019	ND	Non-Detect					1911763
1911763-045A	C Wing Rm C102 Faucet	11/19/2019	ND	Non-Detect					1911763
1911763-046A	C Wing Rm C102 Bubblers	11/19/2019	ND	Non-Detect					1911763
1911763-047A	C Wing Rm C103 Faucet	11/19/2019	ND	Non-Detect					1911763
1911763-048A	C Wing Rm C103 Bubblers	11/19/2019	ND	Non-Detect					1911763
1911763-049A	C Wing Rm C104 Faucet	11/19/2019	ND	Non-Detect					1911763
1911763-050A	C Wing Rm C104 Bubblers	11/19/2019	ND	Non-Detect					1911763
1911795-001A	Library	11/19/2019	ND	Non-Detect					1911795
1911795-002A	Office Breakroom	11/19/2019	ND	Non-Detect					1911795
1911795-003A	Office Health Room	11/19/2019	ND	Non-Detect					1911795
1911795-004A	A Wing RR Boys Wash Station #1	11/19/2019	3.24	Low					1911795
1911795-005A	A Wing RR Boys Wash Station #2	11/19/2019	2.84	Low					1911795
1911795-006A	A Wing RR Boys Wash Station #3	11/19/2019	2.90	Low					1911795
1911795-007A	A Wing RR Boys Wash Station #4	11/19/2019	2.48	Low					1911795
1911795-008A	A Wing Rm A105 Faucet	11/19/2019	ND	Non-Detect					1911795
1911795-009A	A Wing Rm A105 Bubblers	11/19/2019	ND	Non-Detect					1911795
1911795-010A	A Wing Rm A106 Faucet	11/19/2019	ND	Non-Detect					1911795
1911795-011A	A Wing Rm A106 Bubblers	11/19/2019	ND	Non-Detect					1911795
1911795-012A	A Wing Rm A107 Faucet	11/19/2019	ND	Non-Detect					1911795
1911795-013A	A Wing Rm A107 Bubblers	11/19/2019	ND	Non-Detect					1911795
1911795-014A	A Wing Rm A108 Faucet	11/19/2019	ND	Non-Detect					1911795
1911795-015A	A Wing Rm A108 Bubblers	11/19/2019	ND	Non-Detect					1911795
1911795-016A	B Wing Commons Faucet	11/19/2019	ND	Non-Detect					1911795
1911795-017A	B Wing Commons Bubblers	11/19/2019	ND	Non-Detect					1911795
1911795-018A	B Wing Rm 215 Basin	11/19/2019	ND	Non-Detect					1911795
1911795-019A	B Wing Rm 215 Faucet	11/19/2019	ND	Non-Detect					1911795
1911795-020A	B Wing Rm 215 Bubblers	11/19/2019	ND	Non-Detect					1911795
1911795-021A	B Wing RR Boys Wash Station #1	11/19/2019	8.29	Moderate					1911795
1911795-022A	B Wing RR Boys Wash Station #2	11/19/2019	2.65	Low					1911795

Mt. Vernon									
ODE Building # 05540500									
Fixture ID #	Fixture Description per Location	Initial Test Date	Initial Test Result (ppb)	Initial Level	Final Retest Date	Final Test Result (ppb)	Final Level	Notes	Order No.:
1911795-023A	B Wing RR Boys Wash Station #3	11/19/2019	4.32	Low					1911795
1911795-024A	B Wing RR Boys Wash Station #4	11/19/2019	3.18	Low					1911795
1911795-025A	B Wing Rm B106 Faucet	11/19/2019	ND	Non-Detect					1911795
1911795-026A	B Wing Rm B106 Bubbler	11/19/2019	ND	Non-Detect					1911795
1911795-027A	B Wing Rm B107 Faucet	11/19/2019	ND	Non-Detect					1911795
1911795-028A	B Wing Rm B107 Bubbler	11/19/2019	ND	Non-Detect					1911795
1911795-029A	B Wing Rm B108 Faucet	11/19/2019	ND	Non-Detect					1911795
1911795-030A	B Wing Rm B108 Bubbler	11/19/2019	ND	Non-Detect					1911795
1911795-031A	C Wing Staff Restroom	11/19/2019	ND	Non-Detect					1911795
1911795-032A	C Wing Rm 225 Faucet	11/19/2019	ND	Non-Detect					1911795
1911795-033A	C Wing RR Boys Wash Station #1	11/19/2019	ND	Non-Detect					1911795
1911795-034A	C Wing RR Boys Wash Station #2	11/19/2019	ND	Non-Detect					1911795
1911795-035A	C Wing RR Boys Wash Station #3	11/19/2019	ND	Non-Detect					1911795
1911795-036A	C Wing RR Boys Wash Station #4	11/19/2019	3.62	Low					1911795
1911795-037A	C Wing Commons Faucet	11/19/2019	ND	Non-Detect					1911795
1911795-038A	C Wing Commons Bubbler	11/19/2019	ND	Non-Detect					1911795
1911795-039A	C Wing Rm C105 Faucet	11/19/2019	ND	Non-Detect					1911795
1911795-040A	C Wing Rm C105 Bubbler	11/19/2019	ND	Non-Detect					1911795
1911795-041A	C Wing Rm C106 Faucet	11/19/2019	2.11	Low					1911795
1911795-042A	C Wing Rm C106 Bubbler	11/19/2019	ND	Non-Detect					1911795
1911795-043A	C Wing Rm C107 Faucet	11/19/2019	ND	Non-Detect					1911795
1911795-044A	C Wing Rm C107 Bubbler	11/19/2019	ND	Non-Detect					1911795
1911795-045A	C Wing Rm C108 Faucet	11/19/2019	ND	Non-Detect					1911795
1911795-046A	C Wing Rm C108 Bubbler	11/19/2019	ND	Non-Detect					1911795
1911795-047A	Cafeteria RR Boys Wash Station #1	11/19/2019	ND	Non-Detect					1911795
1911795-048A	Cafeteria RR Boys Wash Station #2	11/19/2019	ND	Non-Detect					1911795
1911795-049A	Cafeteria RR Boys Wash Station #3	11/19/2019	ND	Non-Detect					1911795
1911795-050A	Cafeteria RR Boys Wash Station #4	11/19/2019	2.08	Low					1911795
1911795-051A	Cafeteria RR Drinking Fountain E	11/19/2019	ND	Non-Detect					1911795
1911795-052A	Kitchen Dishwasher	11/19/2019	ND	Non-Detect					1911795
1911795-053A	Kitchen Hand Wash	11/19/2019	2.03	Low					1911795