

Ridgeview Elementary									
ODE Building # 05530700									
Fixture ID #	Fixture Description per Location	Initial Test Date	Initial Test Result (ppb)	Initial Level	Final Retest Date	Final Test Result (ppb)	Final Level	Notes	Order No.:
05530700-001DW	Entrance Drinking Fountain	02/27/2023	ND	Non-Detect					2302878
05530700-002CF	Room # 1 Classroom Faucet	02/27/2023	3.48	Low					2302878
05530700-003DW	Room # 1 Drinking Fountain	02/27/2023	ND	Non-Detect					2302878
05530700-004CF	Room # 2 Classroom Faucet	02/27/2023	ND	Non-Detect					2302878
05530700-005DW	Room # 2 Drinking Fountain	02/27/2023	ND	Non-Detect					2302878
05530700-006CF	Room # 3 Classroom Faucet	02/27/2023	5.31	Moderate					2302878
05530700-007DW	Room # 3 Drinking Fountain	02/27/2023	2.97	Low					2302878
05530700-008CF	Room # 4 Classroom Faucet	02/27/2023	2.73	Low					2302878
05530700-009DW	Room # 4 Drinking Fountain	02/27/2023	2.29	Low					2302878
05530700-010DW	Room # 5 Classroom Faucet	02/27/2023	3.66	Low					2302878
05530700-010.5CF	Room # 5 Classroom Faucet	02/27/2023	ND	Non-Detect					2302878
05530700-011DW	Room # 6 Drinking Fountain	02/27/2023	4.45	Low					2302878
05530700-012CF	Room # 6 Classroom Faucet	02/27/2023	ND	Non-Detect					2302878
05530700-013DW	Room # 7 Drinking Fountain	02/27/2023	3.28	Low					2302878
05530700-014CF	Room # 7 Classroom Faucet	02/27/2023	3.22	Low					2302878
05530700-015DW	Room # 8 Drinking Fountain	02/27/2023	2.67	Low					2302878
05530700-016CF	Room # 8 Classroom Faucet	02/27/2023	ND	Non-Detect					2302878
05530700-017DW	Room # 9 Drinking Fountain	02/27/2023	4.52	Low					2302878
05530700-018CF	Room # 9 Classroom Faucet	02/27/2023	ND	Non-Detect					2302878
05530700-019DW	Room # 10 Drinking Fountain	02/27/2023	ND	Non-Detect					2302878
05530700-020CF	Room # 10 Classroom Faucet	02/27/2023	ND	Non-Detect					2302878
05530700-021DW	Room # 11 Drinking Fountain	02/27/2023	3.37	Low					2302878
05530700-022CF	Room # 11 Classroom Faucet	02/27/2023	ND	Non-Detect					2302878
05530700-023DW	Room # 12 Drinking Fountain	02/27/2023	ND	Non-Detect					2302878
05530700-024CF	Room # 12 Classroom Faucet	02/27/2023	ND	Non-Detect					2302878
05530700-025DW	Room # 13 Drinking Fountain	02/27/2023	ND	Non-Detect					2302878
05530700-026CF	Room # 13 Classroom Faucet	02/27/2023	ND	Non-Detect					2302878
05530700-027DW	Room # 14 Drinking Fountain	02/27/2023	ND	Non-Detect					2302878
05530700-028CF	Room # 14 Classroom Faucet	02/27/2023	ND	Non-Detect					2302878
05530700-029DW	Room # 15 Drinking Fountain	02/27/2023	ND	Non-Detect					2302878
05530700-030CF	Room # 15 Classroom Faucet	02/27/2023	ND	Non-Detect					2302878
05530700-031DW	Room # 16 Drinking Fountain	02/27/2023	ND	Non-Detect					2302878
05530700-032CF	Room # 16 Classroom Faucet	02/27/2023	ND	Non-Detect					2302878
05530700-033DW	Room # 17 Drinking Fountain	02/27/2023	ND	Non-Detect					2302878
05530700-034CF	Room # 17 Classroom Faucet	02/27/2023	ND	Non-Detect					2302878
05530700-035DW	Room # 18 Drinking Fountain	02/27/2023	ND	Non-Detect					2302878
05530700-036CF	Room # 18 Classroom Faucet	02/27/2023	ND	Non-Detect					2302878
05530700-037DW	Room # 19 Drinking Fountain	02/27/2023	ND	Non-Detect					2302878
05530700-038CF	Room # 19 Classroom Faucet	02/27/2023	ND	Non-Detect					2302878
05530700-039DW	Room # 20 Drinking Fountain	02/27/2023	ND	Non-Detect					2302878
05530700-040CF	Room # 20 Classroom Faucet	02/27/2023	ND	Non-Detect					2302878

Ridgeview Elementary									
ODE Building # 05530700									
Fixture ID #	Fixture Description per Location	Initial Test Date	Initial Test Result (ppb)	Initial Level	Final Retest Date	Final Test Result (ppb)	Final Level	Notes	Order No.:
05530700-041DW	Drinking fountain	02/27/2023	3.42	Low					2302878
05530700-042BF	West Girls bathroom faucet (north) across from room 20	02/27/2023	ND	Non-Detect					2302878
05530700-043BF	West Girls bathroom faucet (middle)	02/27/2023	2.75	Low					2302878
05530700-044BF	West Girls bathroom faucet (south)	02/27/2023	2.57	Low					2302878
05530700-045BF	West Boys bathroom faucet (north)	02/27/2023	2.15	Low					2302878
05530700-046BF	West Boys bathroom faucet (middle)	02/27/2023	ND	Non-Detect					2302878
05530700-047BF	West Boys bathroom faucet (south)	02/27/2023	ND	Non-Detect					2302878
05530700-048BF	Single Restroom	02/27/2023	ND	Non-Detect					2302878
05530700-049BF	North West Girls Bathroom Faucet (north) across from room 17	02/27/2023	ND	Non-Detect					2302878
05530700-050BF	North West Girls Bathroom Faucet (middle)	02/27/2023	2.36	Low					2302881
05530700-051BF	North West Girls Bathroom Faucet (south)	02/27/2023	ND	Non-Detect					2302881
05530700-052BF	North West Boys Bathroom Faucet (north)	02/27/2023	ND	Non-Detect					2302881
05530700-053BF	North West Boys Bathroom Faucet (middle)	02/27/2023	ND	Non-Detect					2302881
05530700-054BF	North West Boys Bathroom Faucet (south)	02/27/2023	ND	Non-Detect					2302881
05530700-055CF	South room in Library	02/27/2023	44.30	Action Req	5/29/2025			Results Pending	2302881
05530700-056CF	North room in Library	02/27/2023	33.50	Action Req	5/29/2025			Results Pending	2302881
05530700-057DW	Drinking water fountain outside custodial room	02/27/2023	ND	Non-Detect					2302881
05530700-058WB	Water Bottle filler on drinking fountain	02/27/2023	ND	Non-Detect					2302881
05530700-059BF	North Girls Bathroom Faucet (north) across from room 9	02/27/2023	7.49	Moderate					2302881
05530700-060BF	North Girls Bathroom Faucet (south)	02/27/2023	6.20	Moderate					2302881
05530700-061BF	North Boys Bathroom Faucet (north)	02/27/2023	8.63	Moderate					2302881
05530700-062BF	North Boys Bathroom Faucet (south)	02/27/2023	8.87	Moderate					2302881
05530700-063DW	Gym Drinking Water Fountain	02/27/2023	8.41	Moderate					2302881
05530700-064DW	Music room Drinking water fountain (south)	02/27/2023	ND	Non-Detect					2302881
05530700-065CF	Music room Classroom Faucet (south)	02/27/2023	2.17	Low					2302881
05530700-066DW	Music room Drinking water fountain (north)	02/27/2023	ND	Non-Detect					2302881
05530700-067CF	Music room Classroom Faucet (north)	02/27/2023	ND	Non-Detect					2302881
05530700-068DW	Drinking water fountain across from room 6	02/27/2023	6.65	Moderate					2302881
05530700-069BF	North Girls Bathroom Faucet (north) across from room 6	02/27/2023	5.24	Moderate					2302881
05530700-070BF	North Girls Bathroom Faucet (south)	02/27/2023	4.57	Low					2302881
05530700-071BF	North Boys Bathroom Faucet (north)	02/27/2023	5.06	Moderate					2302881
05530700-072BF	North Boys Bathroom Faucet (south)	02/27/2023	6.52	Moderate					2302881
05530700-075KF	Kitchen Food Prep area (Kitchen /Food Prep Faucet)	02/27/2023	2.46	Low					2302881
05530700-076KF	Kitchen Kettle Fill (Kitchen /Food Prep Faucet)	02/27/2023	3.01	Low					2302881
05530700-077SF	Kitchen Hand Wash Station	02/27/2023	3.32	Low					2302881
05530700-078BF	Kitchen staff Restroom bathroom faucet	02/27/2023	5.73	Moderate					2302881
05530700-079KF	Dump station (North)(Kitchen /Food Prep Faucet)	02/27/2023	ND	Non-Detect					2302881
05530700-080KF	Dump Station (west) south(Kitchen /Food Prep Faucet)	02/27/2023	2.38	Low					2302881
05530700-081KF	Dump Station (east) south(Kitchen /Food Prep Faucet)	02/27/2023	ND	Non-Detect					2302881
05530700-082SF	Staff room (front office) Staff faucet	02/27/2023	ND	Non-Detect					2302881
05530700-083BF	Adult unisex restroom Bathroom faucet (front office)	02/27/2023	10.90	High					2302881

Ridgeview Elementary									
ODE Building # 05530700									
Fixture ID #	Fixture Description per Location	Initial Test Date	Initial Test Result (ppb)	Initial Level	Final Retest Date	Final Test Result (ppb)	Final Level	Notes	Order No.:
05530700-084BF	Adult women restroom Bathroom faucet (front office)	02/27/2023	4.76	Low					2302881
05530700-085BF	Nurses room restroom Bathroom Faucet	02/27/2023	22.20	Action Req	9/6/2024	2.13	Low		2409216
05530700-086NS	Nurses office Faucet	02/27/2023	23.60	Action Req	9/6/2024	2.29	Low		2409216
05530700-087BF	Bottle Fill station at main entrance	02/27/2023	ND	Non-Detect					2302881