

Riverbend Elementary									
ODE Building # 13520800									
Fixture ID #	Fixture Description per Location	Initial Test Date	Initial Test Result (ppb)	Initial Level	Final Retest Date	Final Test Result (ppb)	Final Level	Notes	Order No.:
13520800-001	Kitchen Staff Restroom	1/31/2020	ND	Non-Detect					2002016
13520800-002	Cafeteria Drinking Fountain (East)	1/31/2020	ND	Non-Detect					2002016
13520800-003	Cafeteria Drinking Fountain (West)	1/31/2020	ND	Non-Detect					2002016
13520800-004	Cafeteria, Boys Restroom, Wash Station #1	1/31/2020	2.3	Low					2002016
13520800-005	Cafeteria, Boys Restroom, Wash Station #2	1/31/2020	2.14	Low					2002016
13520800-006	Cafeteria, Boys Restroom, Wash Station #3	1/31/2020	2.56	Low					2002016
13520800-007	Cafeteria, Boys Restroom, Wash Station #4	1/31/2020	5.86	Moderate					2002016
13520800-008	Cafeteria, Girls Restroom, Wash Station #1	1/31/2020	2.58	Low					2002016
13520800-009	Cafeteria, Girls Restroom, Wash Station #2	1/31/2020	ND	Non-Detect					2002016
13520800-010	Cafeteria, Girls Restroom, Wash Station #3	1/31/2020	ND	Non-Detect					2002016
13520800-011	Cafeteria, Girls Restroom, Wash Station #4	1/31/2020	ND	Non-Detect					2002016
13520800-012	Library, Faucet	1/31/2020	7.28	Moderate					2002016
13520800-013	Main Office Health Room, Faucet	1/31/2020	3.23	Low					2002016
13520800-014	Main Office Health Room, Restroom Faucet	1/31/2020	ND	Non-Detect					2002016
13520800-015	Main Office, East Staff Restroom	1/31/2020	ND	Non-Detect					2002016
13520800-016	Main Office, West Staff Restroom	1/31/2020	ND	Non-Detect					2002016
13520800-017	Main Office Breakroom, Faucet	1/31/2020	4.57	Low					2002016
13520800-018	Main Office, Staff Workroom Faucet	1/31/2020	4.35	Low					2002016
13520800-019	A Wing, Staff Restroom	1/31/2020	ND	Non-Detect					2002016
13520800-020	A Wing, Boys Restroom, Wash Station #1	1/31/2020	4.92	Low					2002016
13520800-021	A Wing, Boys Restroom, Wash Station #2	1/31/2020	2.07	Low					2002016
13520800-022	A Wing, Boys Restroom, Wash Station #3	1/31/2020	2.04	Low					2002016
13520800-023	A Wing, Boys Restroom, Wash Station #4	1/31/2020	ND	Non-Detect					2002016
13520800-024	A Wing, Girls Restroom, Wash Station #1	1/31/2020	2.57	Low					2002016
13520800-025	A Wing, Girls Restroom, Wash Station #2	1/31/2020	2.2	Low					2002016
13520800-026	A Wing, Girls Restroom, Wash Station #3	1/31/2020	2.38	Low					2002016
13520800-027	A Wing, Girls Restroom, Wash Station #4	1/31/2020	3.57	Low					2002016
13520800-028	A Wing, Common Area, Faucet	1/31/2020	2.48	Low					2002016
13520800-029	A Wing, Common Area, Bubbler	1/31/2020	ND	Non-Detect					2002016
13520800-030	A Wing, Room A101, Faucet	1/31/2020	2.23	Low					2002016
13520800-031	A Wing, Room A101, Bubbler	1/31/2020	ND	Non-Detect					2002016
13520800-032	A Wing, Room A102, Faucet	1/31/2020	7.89	Moderate					2002016
13520800-033	A Wing, Room A102, Bubbler	1/31/2020	ND	Non-Detect					2002016
13520800-034	A Wing, Room A103, Faucet	1/31/2020	4.33	Low					2002016
13520800-035	A Wing, Room A103, Bubbler	1/31/2020	ND	Non-Detect					2002016
13520800-036	A Wing, Room A104, Faucet	1/31/2020	ND	Non-Detect					2002016
13520800-037	A Wing, Room A104, Bubbler	1/31/2020	ND	Non-Detect					2002016
13520800-038	A Wing, Room A105, Faucet	1/31/2020	ND	Non-Detect					2002016

Riverbend Elementary									
ODE Building # 13520800									
Fixture ID #	Fixture Description per Location	Initial Test Date	Initial Test Result (ppb)	Initial Level	Final Retest Date	Final Test Result (ppb)	Final Level	Notes	Order No.:
13520800-039	A Wing, Room A105, Bubbler	1/31/2020	ND	Non-Detect					2002016
13520800-040	A Wing, Room A106, Faucet	1/31/2020	ND	Non-Detect					2002016
13520800-041	A Wing, Room A106, Bubbler	1/31/2020	ND	Non-Detect					2002016
13520800-042	A Wing, Room A107, Faucet	1/31/2020	ND	Non-Detect					2002016
13520800-043	A Wing, Room A107, Bubbler	1/31/2020	ND	Non-Detect					2002016
13520800-044	A Wing, Room A108, Faucet	1/31/2020	ND	Non-Detect					2002016
13520800-045	A Wing, Room A108, Bubbler	1/31/2020	ND	Non-Detect					2002016
13520800-046	B Wing, Room 215, Faucet	1/31/2020	3.92	Low					2002016
13520800-047	B Wing, Room 215, Bubbler	1/31/2020	ND	Non-Detect					2002016
13520800-048	B Wing, Room 215, Restroom Faucet	1/31/2020	ND	Non-Detect					2002016
13520800-049	B Wing, Room 220, Faucet	1/31/2020	2.23	Low					2002016
13520800-050	B Wing, Boys Restroom, Wash Station #1	1/31/2020	5.99	Moderate					2002016
13520800-051	B Wing, Boys Restroom, Wash Station #3	1/31/2020	3.04	Low					2002016
13520800-052	B Wing, Girls Restroom, Wash Station #1	1/31/2020	2.23	Low					2002016
13520800-053	B Wing, Girls Restroom, Wash Station #2	1/31/2020	2.75	Low					2002016
13520800-054	B Wing, Girls Restroom, Wash Station #3	1/31/2020	ND	Non-Detect					2002016
13520800-055	B Wing, Girls Restroom, Wash Station #4	1/31/2020	4.37	Low					2002051
13520800-056	B Wing, Common Area, Faucet	1/31/2020	ND	Non-Detect					2002051
13520800-057	B Wing, Common Area, Bubbler	1/31/2020	ND	Non-Detect					2002051
13520800-058	B Wing, Room B101, Faucet	1/31/2020	3.6	Low					2002051
13520800-059	B Wing, Room B101, Bubbler	1/31/2020	ND	Non-Detect					2002051
13520800-060	B Wing, Room B102, Faucet	1/31/2020	ND	Non-Detect					2002051
13520800-061	B Wing, Room B102, Bubbler	1/31/2020	ND	Non-Detect					2002051
13520800-062	B Wing, Room B103, Faucet	1/31/2020	ND	Non-Detect					2002051
13520800-063	B Wing, Room B103, Bubbler	1/31/2020	ND	Non-Detect					2002051
13520800-064	B Wing, Room B106, Faucet	1/31/2020	ND	Non-Detect					2002051
13520800-065	B Wing, Room B106, Bubbler	1/31/2020	ND	Non-Detect					2002051
13520800-066	B Wing, Room B107, Faucet	1/31/2020	ND	Non-Detect					2002051
13520800-067	B Wing, Room B107, Bubbler	1/31/2020	ND	Non-Detect					2002051
13520800-068	B Wing, Room B108, Faucet	1/31/2020	ND	Non-Detect					2002051
13520800-069	B Wing, Room B108, Bubbler	1/31/2020	ND	Non-Detect					2002051
13520800-070	C Wing, Drinking Fountain	1/31/2020	ND	Non-Detect					2002051
13520800-071	C Wing, Staff Restroom, Faucet	1/31/2020	ND	Non-Detect					2002051
13520800-072	C Wing, Boys Restroom Wash Station #1	1/31/2020	4.65	Low					2002051
13520800-073	C Wing, Boys Restroom Wash Station #2	1/31/2020	ND	Non-Detect					2002051
13520800-074	C Wing, Boys Restroom Wash Station #3	1/31/2020	ND	Non-Detect					2002051
13520800-075	C Wing, Boys Restroom Wash Station #4	1/31/2020	2.23	Low					2002051
13520800-076	C Wing, Girls Restroom Wash Station #1	1/31/2020	6.54	Moderate					2002051

Riverbend Elementary									
ODE Building # 13520800									
Fixture ID #	Fixture Description per Location	Initial Test Date	Initial Test Result (ppb)	Initial Level	Final Retest Date	Final Test Result (ppb)	Final Level	Notes	Order No.:
13520800-077	C Wing, Girls Restroom Wash Station #2	1/31/2020	2.67	Low					2002051
13520800-078	C Wing, Girls Restroom Wash Station #3	1/31/2020	2.18	Low					2002051
13520800-079	C Wing, Girls Restroom Wash Station #4	1/31/2020	ND	Non-Detect					2002051
13520800-080	C Wing, Common Area, Faucet	1/31/2020	ND	Non-Detect					2002051
13520800-081	C Wing, Common Area, Bubbler	1/31/2020	ND	Non-Detect					2002051
13520800-082	C Wing, Room C101 Faucet	1/31/2020	ND	Non-Detect					2002051
13520800-083	C Wing, Room C101 Bubbler	1/31/2020	ND	Non-Detect					2002051
13520800-084	C Wing, Room C102 Faucet	1/31/2020	ND	Non-Detect					2002051
13520800-085	C Wing, Room C102 Bubbler	1/31/2020	ND	Non-Detect					2002051
13520800-086	C Wing, Room C103 Faucet	1/31/2020	4.74	Low					2002051
13520800-087	C Wing, Room C103 Bubbler	1/31/2020	ND	Non-Detect					2002051
13520800-088	C Wing, Room C104 Faucet	1/31/2020	3.09	Low					2002051
13520800-089	C Wing, Room C104 Bubbler	1/31/2020	ND	Non-Detect					2002051
13520800-090	C Wing, Room C105, Faucet	1/31/2020	3.44	Low					2002051
13520800-091	C Wing, Room C105, Bubbler	1/31/2020	ND	Non-Detect					2002051
13520800-092	C Wing, Room C106, Faucet	1/31/2020	2.46	Low					2002051
13520800-093	C Wing, Room C106, Bubbler	1/31/2020	ND	Non-Detect					2002051
13520800-094	C Wing, Room C107, Faucet	1/31/2020	ND	Non-Detect					2002051
13520800-095	C Wing, Room C107, Bubbler	1/31/2020	ND	Non-Detect					2002051
13520800-096	C Wing, Room C108, Faucet	1/31/2020	2.56	Low					2002051
13520800-097	C Wing, Room C108, Bubbler	1/31/2020	ND	Non-Detect					2002051