

Springfield High School									
ODE Building # 05602000									
Fixture ID #	Fixture Description per Location	Initial Test Date	Initial Test Result (ppb)	Initial Level	Final Retest Date	Final Test Result (ppb)	Final Level	Notes	Order No.:
5602000-001BF	CDC Health center entrance bathroom faucet	2/1/2024	ND	Non-Detect				Bottle # 1	2402009
5602000-002NS	Nurse exam room 1	2/1/2024	13.60	High				Bottle # 2	2402009
5602000-003SF	Nurse Staff faucet	2/1/2024	4.52	Low				Bottle # 3	2402009
5602000-004NS	Nurse exam room 2	2/1/2024	4.86	Low				Bottle # 4	2402009
5602000-005BF	Nurse Bathroom Faucet	2/1/2024	ND	Non-Detect				Bottle # 5	2402009
5602000-006DW	Drinking fountain Hallway near attic stairs	2/1/2024	6.15	Moderate				Bottle # 6	2402009
5602000-007BF	Staff bathroom Single	2/1/2024	2.48	Low				Bottle # 7	2402009
5602000-008BF	Bathroom faucet (student)	2/1/2024	ND	Non-Detect				Bottle # 8	2402009
5602000-009BF	Bathroom faucet (student)	2/1/2024	ND	Non-Detect				Bottle # 9	2402009
5602000-010SF	Nursery staff faucet	2/1/2024	ND	Non-Detect				Bottle # 10	2402009
5602000-011SF	Nursery staff faucet	2/1/2024	2.19	Low				Bottle # 11	2402009
5602000-012KF	Nursery kitchen faucet 1	2/1/2024	ND	Non-Detect				Bottle # 12	2402009
5602000-013KF	Nursery kitchen faucet 2	2/1/0204	4.34	Low				Bottle # 13	2402009
5602000-014KF	Nursery kitchen faucet 3	2/1/2024	22.10	Action Req	5/30/2025	Results Pending		Bottle # 14	2402009
5602000-015SF	Nursery kitchen faucet 4	2/1/2024	12.10	High				Bottle # 15	2402009
5602000-017BF	GYM mens bathroom faucet Rm 809 single bradley	2/1/2024	9.42	Moderate				Bottle # 17	2402015
5602000-018BF	mens bathroom faucet 3 Faucet Bradley (left)	2/1/2024	ND	Non-Detect				Bottle # 18	2402015
5602000-019BF	mens bathroom faucet (middle)	2/1/2024	ND	Non-Detect				Bottle # 19	2402015
5602000-020BF	mens bathroom faucet (right)	2/1/2024	ND	Non-Detect				Bottle # 20	2402015
5602000-021SF	Training room 818 staff faucet	2/1/2024	ND	Non-Detect				Bottle # 21	2402015
5602000-022DW	Boys Locker Drinking fountain							Bottle # 22	
5602000-023DW	Boys Locker Drinking fountain	2/1/2024	4.22	Low				Bottle # 23	2402015
5602000-024BF	Coaches Rm 819 bathroom faucet	2/1/2024	ND	Non-Detect				Bottle # 24	2402015
5602000-025BF	Boys bathroom faucet	2/1/2024	6.45	Moderate				Bottle # 25	2402015
5602000-026BF	Boys bathroom faucet	2/1/2024	ND	Non-Detect				Bottle # 26	2402015
5602000-027BF	Boys bathroom faucet	2/1/2024	ND	Non-Detect				Bottle # 27	2402015
5602000-028BF	Single bathroom faucet near back exit boys locker room BETWEEN 815 & 816	2/1/2024	ND	Non-Detect				Bottle # 28	2402015
5602000-029DW	Lobby drinking fountain	2/1/2024	2.63	Low				Bottle # 29	2402015
5602000-030DW	Drinking fountain	2/1/2024	ND	Non-Detect				Bottle # 30	2402015
5602000-031SF	Concessions staff faucet RM 824	2/1/2024	3.39	Low				Bottle # 31	2402015
5602000-032DW	Lobby drinking fountain	2/1/2024	ND	Non-Detect				Bottle # 32	2402015
5602000-033WB	Water bottle fill station	2/1/2024	ND	Non-Detect				Bottle # 33	2402015
5602000-034BF	Women bathroom faucet Rm 827 single bradley	2/1/2024	ND	Non-Detect				Bottle # 34	2402015
5602000-035BF	Women bathroom faucet 3 Faucet Bradley (left)	2/1/2024	11.30	High				Bottle # 35	2402015
5602000-036BF	Women bathroom faucet (middle)	2/1/2024	4.59	Low				Bottle # 36	2402015
5602000-037BF	Women bathroom faucet (right)							Bottle # 37	
5602000-038BF	Girls Locker room bathroom faucet	2/1/2024	11.60	High				Bottle # 38	2402015
5602000-039BF	Girls Locker room bathroom faucet	2/1/2024	4.49	Low				Bottle # 39	2402015
5602000-040BF	Girls Locker room bathroom faucet	2/1/2024	4.28	Low				Bottle # 40	2402015
5602000-041BF	Coaches Rm 829 bathroom faucet	2/2/2024	33.40	Action Req	5/30/2025	Results Pending		Bottle # 41	2402076
5602000-042DW	Girls Locker Drinking fountain	2/1/2024	ND	Non-Detect				Bottle # 42	2402015
5602000-043DW	Girls Locker Drinking fountain	2/1/2024	2.11	Low				Bottle # 43	2402015
5602000-044CF	Wood shop RM 930 Bradley	2/1/2024	8.74	Moderate				Bottle # 44	2402015
5602000-045DW	Rm 930 drinking Fountain	2/1/2024	ND	Non-Detect				Bottle # 45	2402015
5602000-046BF	Bathroom faucet RM 938	2/1/2024	ND	Non-Detect				Bottle # 46	2402015
5602000-047BF	Bathroom faucet Rm 937	2/1/2024	ND	Non-Detect				Bottle # 47	2402015
5602000-048CF	Small engine classroom faucet Bradley	2/1/2024	4.55	Low				Bottle # 48	2402015
5602000-049DW	Drinking fountain	2/1/2024	4.69	Low				Bottle # 49	2402015
5602000-050DW	Auto shop main bay drinking fountain	2/1/2024	ND	Non-Detect				Bottle # 50	2402015
5602000-051WB	Water bottle fill station	2/1/2024	ND	Non-Detect				Bottle # 51	2402015

Springfield High School									
ODE Building # 05602000									
Fixture ID #	Fixture Description per Location	Initial Test Date	Initial Test Result (ppb)	Initial Level	Final Retest Date	Final Test Result (ppb)	Final Level	Notes	Order No.:
5602000-052BF	Bathroom faucet G Rm 926	2/1/2024	ND	Non-Detect				Bottle # 52	2402015
5602000-053BF	Bathroom faucet B Rm 925	2/1/2024	2.67	Low				Bottle # 53	2402015
5602000-054CF	Classroom faucet (Hand wash)	2/1/2024	ND	Non-Detect				Bottle # 54	2402015
5602000-055CF	Industrial arts Rm 940 Classroom faucet	2/1/2024	6.95	Moderate				Bottle # 55	2402015
5602000-056CF	Rm 934 Classroom Faucet	2/1/2024	26.30	Action Req	5/30/2025	Results Pending		Bottle # 56	2402015
5602000-057DW	RM 935 Drinking fountain	2/1/2024	10.40	High				Bottle # 57	2402015
5602000-058CF	Rm 935 Classroom Faucet	2/1/2024	3.87	Low				Bottle # 58	2402015
5602000-059CF	Rm 935 Classroom Faucet	2/1/2024	ND	Non-Detect				Bottle # 59	2402015
5602000-060DW	Rm 936 Drinking fountain							Bottle # 60	Chain of Custody "CF"
5602000-061CF	Rm 936 Classroom Faucet	2/1/2024	ND	Non-Detect				Bottle # 61	2402015
5602000-062BF	Rm 960 Bathroom Faucet	2/1/2024	8.94	Moderate				Bottle # 62	2402015
5602000-063CF	Rm 960 Classroom Faucet	2/1/2024	ND	Non-Detect				Bottle # 63	2402015
5602000-156DW	Metals Shop Drinking fountain	2/1/2024	ND	Non-Detect				Bottle # 156	2402022
5602000-157WB	Water bottle fill station	2/1/2024	ND	Non-Detect				Bottle # 157	2402022
5602000-158CF	Classroom Faucet in shop hand wash station	2/1/2024	ND	Non-Detect				Bottle # 158	2402022
5602000-159BF	Portable metals shop bathroom faucet	2/1/2024	ND	Non-Detect				Bottle # 159	2402022
5602000-064BF	Music Hall RM 761 Men's bathroom faucet	2/1/2024	2.46	Low				Bottle # 64	2402022
5602000-065BF	mens bathroom faucet							Bottle # 65	
5602000-066BF	mens bathroom faucet	2/1/2024	ND	Non-Detect				Bottle # 66	2402022
5602000-067DW	Drinking fountain	2/1/2024	ND	Non-Detect				Bottle # 67	2402022
5602000-068DW	Drinking fountain	2/1/2024	ND	Non-Detect				Bottle # 68	2402022
5602000-069BF	RM 754 Women bathroom faucet	2/1/2024	ND	Non-Detect				Bottle # 69	2402022
5602000-070BF	Women bathroom faucet	2/1/2024	ND	Non-Detect				Bottle # 70	2402022
5602000-071BF	Women bathroom faucet	2/1/2024	ND	Non-Detect				Bottle # 71	2402022
5602000-072BF	Auditorium back hallway Womens bathroom faucet RM 745	2/1/2024	8.04	Moderate				Bottle # 72	2402022
5602000-073BF	mens bathroom faucet RM 747	2/1/2024	8.90	Moderate				Bottle # 73	2402022
5602000-074CF	Stage Classroom Faucet - NOT IN USE	2/1/2024	43.40	Action Req		NOT IN USE			2402022
5602000-075BF	Commons Mens bathroom faucet	2/1/2024	3.19	Low				Bottle # 75	2402022
5602000-076BF	Womens Bathroom faucet	2/1/2024	ND	Non-Detect				Bottle # 76	2402022
5602000-077DW	Drinking fountain	2/1/2024	ND	Non-Detect				Bottle # 77	2402022
5602000-078WB	Water bottle fill station	2/1/2024	ND	Non-Detect				Bottle # 78	2402022
5602000-079SF	Custodial room 737 Staff faucet	2/1/2024	ND	Non-Detect				Bottle # 79	2402022
5602000-080BF	Custodial room 738 bathroom faucet	2/1/2024	10.80	High				Bottle # 80	2402022
5602000-081KF	Kitchen Dishwasher area Kitchen faucet	2/2/2024	9.04	Moderate				Bottle # 81	2402071
5602000-082KF	Dishwasher area Kitchen faucet	2/2/2024	8.29	Moderate				Bottle # 82	2402071
5602000-083KF	Dishwasher area Kitchen faucet	2/2/2024	14.10	High				Bottle # 83	2402071
5602000-083KF	Kitchen faucet Sprayer on dishwasher							Bottle # 83.5	
5602000-084KF	Kitchen faucet near ice machine	2/2/2024	9.73	Moderate				Bottle # 84	2402071
5602000-085KF	Kitchen faucet near back exit door	2/2/2024	5.08	Moderate				Bottle # 85	2402071
5602000-086KF	Kitchen faucet near office	2/2/2024	2.74	Low				Bottle # 86	2402071
5602000-087BF	Breakroom bathroom faucet rm 705	2/2/2024	4.18	Low				Bottle # 87	2402071
5602000-088BF	1st floor main building Male staff bathroom faucet (RM113)	2/2/2024	3.21	Low				Bottle # 88	2402071
5602000-089BF	Women bathroom faucet (RM 115)	2/2/2024	3.12	Low				Bottle # 89	2402071
5602000-090SF	Staff room 116 staff faucet	2/2/2024	2.38	Low				Bottle # 90	2402071
5602000-091BF	Student women's bathroom faucet Rm 130	2/2/2024	ND	Non-Detect				Bottle # 91	2402071
5602000-092DW	Drinking fountain Not in use no water					NOT IN USE		NOT IN USE	
5602000-093DW	Drinking fountain	2/2/2024	ND	Non-Detect				Bottle # 93	2402071
5602000-094WB	Water bottle fill station	2/2/2024	ND	Non-Detect				Bottle # 94	2402071
5602000-095BF	Students mens bathroom faucet Rm 134	2/2/2024	2.71	Low				Bottle # 95	2402071
5602000-096NS	Nurse office sink Rm 314	2/2/2024	2.82	Low				Bottle # 96	2402071

Springfield High School
ODE Building # 05602000

Fixture ID #	Fixture Description per Location	Initial Test Date	Initial Test Result (ppb)	Initial Level	Final Retest Date	Final Test Result (ppb)	Final Level	Notes	Order No.:
5602000-097BF	Nurse bathroom faucet 1 Staff	2/2/2024	3.20	Low				Bottle # 97	2402071
5602000-098BF	Nurse bathroom faucet 2 Gender	2/2/2024	8.27	Moderate				Bottle # 98	2402071
5602000-099SF	Rm 319 Staff Faucet	2/2/2024	8.20	Moderate				Bottle # 99	2402071
5602000-100CF	RM 330 Classroom faucet	2/2/2024	50.50	Action Req	Science Room	Labelled no-drinking		Bottle # 100	2402071
5602000-101CF	RM 331 Classroom faucet 1	2/2/2024	108.00	Action Req	Science Room	Labelled no-drinking		Bottle # 101	2402071
5602000-102CF	RM 331 Classroom faucet 2	2/2/2024	16.50	Action Req	Science Room	Labelled no-drinking		Bottle # 102	2402072
5602000-103CF	RM 331 Classroom faucet 3	2/2/2024	24.60	Action Req	Science Room	Labelled no-drinking		Bottle # 103	2402072
5602000-104CF	RM 331 Classroom faucet 4	2/2/2024	29.80	Action Req	Science Room	Labelled no-drinking		Bottle # 104	2402072
5602000-105CF	RM 331 Classroom faucet 5	2/2/2024	17.50	Action Req	Science Room	Labelled no-drinking		Bottle # 105	2402072
5602000-106CF	RM 331 Classroom faucet 6	2/2/2024	18.60	Action Req	Science Room	Labelled no-drinking		Bottle # 106	2402072
5602000-107SF	Library staff faucet Rm 354 open area	2/2/2024	35.00	Action Req	5/30/2025	Results Pending		Bottle # 107	2402072
5602000-108BF	Student women's bathroom faucet Rm 530 A	2/2/2024	69.00	Action Req	5/30/2025	Results Pending		Bottle # 108	2402072
5602000-109BF	Student women's bathroom faucet B	2/2/2024	63.40	Action Req	5/30/2025	Results Pending		Bottle # 109	2402072
5602000-110BF	Student women's bathroom faucet C	2/2/2024	24.50	Action Req	5/30/2025	Results Pending		Bottle # 110	2402072
5602000-111BF	Student women's bathroom faucet D	2/2/2024	16.90	Action Req	5/30/2025	Results Pending		Bottle # 111	2402072
5602000-112DW	Drinking fountain 1 Not in use no water							NOT IN USE	
5602000-113DW	Drinking fountain 2	2/2/2024	9.59	Moderate				Bottle # 113	2402072
5602000-114BF	Students mens bathroom faucet Rm 534 A	2/2/2024	22.00	Action Req	5/30/2025	Results Pending		Bottle # 114	2402072
5602000-115BF	Students mens bathroom faucet B	2/2/2024	4.56	Low				Bottle # 115	2402072
5602000-116BF	Students mens bathroom faucet C	2/2/2024	5.39	Moderate				Bottle # 116	2402072
5602000-117BF	Students mens bathroom faucet D	2/2/2024	13.00	High				Bottle # 117	2402072
5602000-118CF	RM 557 classroom faucet	2/2/2024	15.70	Action Req	5/30/2025	Results Pending		Bottle # 118	2402072
5602000-119CF	RM 550 classroom faucet	2/2/2024	5.11	Moderate				Bottle # 119	2402072
5602000-120SF	Rm 510 Staff faucet	2/2/2024	13.00	High				Bottle # 120	2402072
5602000-121BF	2nd floor main building Boys Bathroom Faucet Room 234 Not in use no water							NOT IN USE	
5602000-122DW	Drinking fountain 1	2/2/2024	3.41	Low				Bottle # 122	2402072
5602000-123DW	Drinking fountain 2	2/2/2024	2.01	Low				Bottle # 123	2402072
5602000-124BF	Girls bathroom faucet Rm 234	2/2/2024	2.72	Low				Bottle # 124	2402074
5602000-125SF	Rm 213 Staff Faucet	2/2/2024	11.40	High				Bottle # 125	2402074
5602000-126CF	Science Wing Room 401 classroom faucet	2/2/2024	85.50	Action Req	Science Room	Labelled no-drinking		Bottle # 126	2402074
5602000-127CF	Room 401 classroom faucet	2/2/2024	290.00	Action Req	Science Room	Labelled no-drinking		Bottle # 127	2402074
5602000-128CF	Room 401 classroom faucet	2/2/2024	67.60	Action Req	Science Room	Labelled no-drinking		Bottle # 128	2402074
5602000-129CF	Room 401 classroom faucet	2/2/2024	470.00	Action Req	Science Room	Labelled no-drinking		Bottle # 129	2402074
5602000-130CF	Room 401 classroom faucet	2/2/2024	39.40	Action Req	Science Room	Labelled no-drinking		Bottle # 130	2402074
5602000-131CF	Room 401 classroom faucet	2/2/2024	21.30	Action Req	Science Room	Labelled no-drinking		Bottle # 131	2402074
5602000-131.50CF	Room 402 Classroom Faucet	2/2/2024	177.00	Action Req	Science Room	Labelled no-drinking		Bottle #131.50	2402076
5602000-131.75CF	Room 402 Clasroom Faucet				Science Room	Labelled no-drinking		Bottle 131.75	
5602000-132CF	Room421 Classroom Faucet	2/2/2024	14.80	High				Bottle # 132	2402074
5602000-133CF	Room421 Classroom Faucet	2/2/2024	16.80	Action Req	Science Room	Labelled no-drinking		Bottle # 133	2402074
5602000-134CF	Room421 Classroom Faucet	2/2/2024	139.00	Action Req	Science Room	Labelled no-drinking		Bottle # 134	2402074
5602000-135CF	Room421 Classroom Faucet	2/2/2024	144.00	Action Req	Science Room	Labelled no-drinking		Bottle # 135	2402074
5602000-136CF	Room421 Classroom Faucet	2/2/2024	178.00	Action Req	Science Room	Labelled no-drinking		Bottle # 136	2402074
5602000-137CF	Room421 Classroom Faucet	2/2/2024	157.00	Action Req	Science Room	Labelled no-drinking		Bottle # 137	2402074
5602000-138CF	Room 403 Classroom faucet Not in use no water							NOT IN USE	
5602000-139CF	Room 403 Classroom faucet	2/2/2024	7.74	Moderate				Bottle # 139	2402074
5602000-140CF	Room 403 Classroom faucet	2/2/2024	6.12	Moderate				Bottle # 140	2402074
5602000-141SF	Room 404 Staff Faucet	2/2/2024	32.80	Action Req	Science Room	Labelled no-drinking		Bottle # 141	2402074
5602000-142CF	Room 418 Classroom Faucet	2/2/2024	35.50	Action Req	Science Room	Labelled no-drinking		Bottle # 142	2402074
5602000-143CF	Room 418 Classroom Faucet	2/2/2024	103.00	Action Req	Science Room	Labelled no-drinking		Bottle # 143	2402074
5602000-144CF	Room 418 Classroom Faucet	2/2/2024	31.40	Action Req	Science Room	Labelled no-drinking		Bottle # 144	2402074

Springfield High School									
ODE Building # 05602000									
Fixture ID #	Fixture Description per Location	Initial Test Date	Initial Test Result (ppb)	Initial Level	Final Retest Date	Final Test Result (ppb)	Final Level	Notes	Order No.:
5602000-145CF	Room 418 Classroom Faucet	2/2/2024	108.00	Action Req	Science Room	Labelled no-drinking		Bottle # 145	2402076
5602000-146CF	Room 418 Classroom Faucet	2/2/2024	ND	Non-Detect				Bottle # 146	2402076
5602000-147CF	Room 418 Classroom Faucet	2/2/2024	6.20	Moderate				Bottle # 147	2402076
5602000-148CF	Room 418 Classroom Faucet	2/2/2024	8.87	Moderate				Bottle # 148	2402076
5602000-149CF	Room 418 Classroom Faucet	2/2/2024	12.60	High				Bottle # 149	2402076
5602000-150CF	Room 415 Classroom faucet	2/2/2024	35.60	Action Req	Science Room	Labelled no-drinking		Bottle # 150	2402076
5602000-151CF	Room 415 Classroom faucet Not in use no water							NOT IN USE	
5602000-152CF	Room 414 Classroom Faucet	2/2/2024	2.38	Low				Bottle # 152	2402076
5602000-153CF	Room 414 Classroom Faucet	2/2/2024	5.95	Moderate				Bottle # 153	2402076
5602000-154CF	Room 405 Classroom faucet	2/2/2024	113.00	Action Req	Science Room	Labelled no-drinking		Bottle # 154	2402076
5602000-154.5CF	Room 405 Classroom faucet	2/2/2024	28.50	Action Req	Science Room	Labelled no-drinking		Bottle # 154.5	2402076
5602000-155CF	Room 405 Classroom faucet	2/2/2024	41.00	Action Req	Science Room	Labelled no-drinking		Bottle # 155	2402076
5602000-160CF	Room 406 Classroom Faucet	2/2/2024	62.80	Action Req	Science Room	Labelled no-drinking		Bottle # 160	2402076
5602000-161CF	Room 406 Staff faucet	2/2/2024	10.60	High				Bottle # 161	2402076
5602000-162CF	Room 409 Classroom Faucet	2/2/2024	92.10	Action Req	Science Room	Labelled no-drinking		Bottle # 162	2402076
5602000-163CF	Room 409 Classroom Faucet	2/2/2024	59.40	Action Req	Science Room	Labelled no-drinking		Bottle # 163	2402076
5602000-164CF	Room 409 Classroom Faucet	2/2/2024	69.50	Action Req	Science Room	Labelled no-drinking		Bottle # 164	2402076
5602000-165CF	Room 409 Classroom Faucet	2/2/2024	33.60	Action Req	Science Room	Labelled no-drinking		Bottle # 165	2402076
5602000-166CF	Room 409 Classroom Faucet	2/2/2024	72.60	Action Req	Science Room	Labelled no-drinking		Bottle # 166	2402076
5602000-167CF	Room 409 Classroom Faucet	2/2/2024	38.20	Action Req	Science Room	Labelled no-drinking		Bottle # 167	2402076
5602000-168CF	Room 410 Classroom Faucet	2/2/2024	45.50	Action Req	Science Room	Labelled no-drinking		Bottle # 168	2402076
5602000-169CF	Room 410 Classroom Faucet	2/2/2024	51.00	Action Req	Science Room	Labelled no-drinking		Bottle # 169	2402076
5602000-170CF	Room 411 Classroom Faucet	2/2/2024	32.20	Action Req	Science Room	Labelled no-drinking		Bottle # 170	2402076
5602000-171CF	Room 411 Classroom Faucet	2/2/2024	241.00	Action Req	Science Room	Labelled no-drinking		Bottle # 171	2402076
5602000-171.50CF	Room 412 Classroom Faucet				Science Room	Labelled no-drinking		Bottle # 171.50	
5602000-171.75CF	Room 412 Classroom Faucet				Science Room	Labelled no-drinking		Bottle # 171.75	
5602000-172BF	RM 630 Girls Bathroom Faucet	2/2/2024	ND	Non-Detect				Bottle # 172	2402076
5602000-173DW	Drinking fountain	2/2/2024	2.43	Low				Bottle # 173	2402076
5602000-174DW	Drinking fountain	2/2/2024	2.82	Low				Bottle # 174	2402076
5602000-175BF	Rm 634 Bathroom Faucet	2/2/2024	ND	Non-Detect				Bottle # 175	2402076
5602000-176SF	Math wing Room 456 Staff Faucet	2/2/2024	26.30	Action Req	5/30/2025	Results Pending		Bottle # 176	2402076
5602000-177BF	Silke Field men's bathroom faucet 1 (clockwise)							Bottle # 177	
5602000-178BF	Silke Field men's bathroom faucet 2							Bottle # 178	
5602000-179BF	Silke Field men's bathroom faucet 3							Bottle # 179	
5602000-180BF	Silke Field men's bathroom faucet 4							Bottle # 180	
5602000-181BF	Silke Field women bathroom faucet 1 (clockwise)							Bottle # 181	
5602000-182BF	Silke Field women bathroom faucet 2							Bottle # 182	
5602000-183BF	Silke Field women bathroom faucet 3							Bottle # 183	
5602000-184BF	Silke Field women bathroom faucet 4							Bottle # 184	
5602000-185DW	Training room next to concessions drinking water fountain							Bottle # 185	
5602000-186DW	Training room next to concessions drinking water fountain							Bottle # 186	
5602000-187SF	Concessions staff faucet near ice machine							Bottle # 187	
5602000-188SF	Concessions staff faucet near drink fridge							Bottle # 188	
5602000-189DW	Track field drinking water fountain ADA 1							Bottle # 189	
5602000-190DW	Track field drinking water fountain 2							Bottle # 190	
5602000-191DW	Track field drinking water fountain 3							Bottle # 191	
5602000-192DW	Track field drinking water fountain 4							Bottle # 192	
5602000-193DW	Track field drinking water fountain 5							Bottle # 193	
5602000-194DW	Track field drinking water fountain 6							Bottle # 194	