

Two Rivers/ Dos Rios Elementary									
ODE Building # 50591000									
Fixture ID #	Fixture Description per Location	Test Dates	Initial Test Result (ppb)	Initial Level	Final Retest Date	Final Test Result (ppb)	Final Level	Notes	Order No:
50591000-042DW	Drinking water fountain outside room 20	3/16/2023	15.50	Action Req	5/21/2025	4.63	Low		2303684
50591000-043DW	Classroom 17 drinking water fountain	3/16/2023	3.24	Low					2303684
50591000-044CF	Classroom 17 classroom faucet	3/16/2023	2.42	Low					2303684
50591000-045BF	Boys bathroom faucet	3/16/2023	2.08	Low					2303684
50591000-046BF	Boys bathroom faucet	3/16/2023	ND	Non-Detect					2303684
50591000-047BF	Boys bathroom faucet	3/16/2023	ND	Non-Detect					2303684
50591000-048BF	Girls bathroom faucet	3/16/2023	ND	Non-Detect					2303684
50591000-049BF	Girls bathroom faucet	3/16/2023	ND	Non-Detect					2303684
50591000-050BF	Girls bathroom faucet	3/16/2023	ND	Non-Detect					2303684
50591000-051BF	Bathroom faucet across from room 25	3/16/2023	ND	Non-Detect					2303684
50591000-052CF	Classroom 22 classroom faucet	3/16/2023	2.10	Low					2303684
50591000-053CF	Classroom 22 classroom faucet	3/16/2023	10.00	High					2303684
50591000-054KF	Kitchen faucet back entrance	3/16/2023	3.85	Low					2303684
50591000-055SF	Kitchen staff faucet(hand wash)	3/16/2023	2.55	Low					2303684
50591000-056KF	Kitchen faucet dishwasher area	3/16/2023	2.52	Low					2303684
50591000-057BF	Bathroom faucet kitchen	3/16/2023	ND	Non-Detect					2303684
50591000-058KF	Kitchen faucet	3/16/2023	2.86	Low					2303684
50591000-059KF	Kitchen Faucet back window	3/16/2023	4.10	Low					2303684
50591000-060DW	Classroom 7 drinking water fountain - Not In Use							NOT IN USE	

Walterville Elementary									
ODE Building # 05581100									
Fixture ID #	Fixture Description per Location	Initial Test Date	Initial Test Result (ppb)	Initial Level	Final Retest Date	Final Test Result (ppb)	Final Level	Notes	Order No.:
05581100-001NS	Health room Faucet	1/19/2023	ND	Non-Detect					2302879
05581100-002DW	Health room drinking fountain	1/19/2023	ND	Non-Detect					2302879
05581100-003BF	Office bathroom (north)	1/19/2023	ND	Non-Detect					2302879
05581100-004BF	Office bathroom (south)	1/19/2023	ND	Non-Detect					2302879
05581100-005SF	Office breakroom faucet	1/19/2023	ND	Non-Detect					2302879
05581100-006BF	East Boys bathroom faucet (north)	1/19/2023	ND	Non-Detect					2302879
05581100-007BF	East Boys bathroom faucet (middle)	1/19/2023	ND	Non-Detect					2302879
05581100-008BF	East Boys bathroom faucet (south)	1/19/2023	ND	Non-Detect					2302879
05581100-009BF	East Girls bathroom faucet (north)	1/19/2023	ND	Non-Detect					2302879
05581100-010BF	East Girls bathroom faucet (middle)	1/19/2023	ND	Non-Detect					2302879
05581100-011BF	East Girls bathroom faucet (south)	1/19/2023	ND	Non-Detect					2302879
05581100-012CF	Room #9 faucet	1/19/2023	ND	Non-Detect					2302879
05581100-013DW	Room #9 drinking fountain	1/19/2023	ND	Non-Detect					2302879
05581100-014CF	Room #10 faucet	1/19/2023	ND	Non-Detect					2302879
05581100-015DW	Room #10 drinking fountain	1/19/2023	ND	Non-Detect					2302879
05581100-016CF	Room #11 faucet	1/19/2023	ND	Non-Detect					2302879
05581100-017DW	Room #11 drinking fountain	1/19/2023	ND	Non-Detect					2302879
05581100-018CF	Room #12 faucet	1/19/2023	3.32	Low					2302879
05581100-019DW	Room #12 drinking fountain	1/19/2023	3.09	Low					2302879
05581100-020BF	Center Boys bathroom faucet (north)	1/19/2023	ND	Non-Detect					2302879
05581100-021BF	Center Boys bathroom faucet (middle)	1/19/2023	ND	Non-Detect					2302879
05581100-022BF	Center Boys bathroom faucet (south)	1/19/2023	2.26	Low					2302879
05581100-023BF	Center Girls bathroom faucet (north)	1/19/2023	2.04	Low					2302879
05581100-024BF	Center Girls bathroom faucet (middle)	1/19/2023	ND	Non-Detect					2302879
05581100-025BF	Center Girls bathroom faucet (south)	1/19/2023	ND	Non-Detect					2302879
05581100-026CF	Room #5 faucet	1/19/2023	ND	Non-Detect					2302879
05581100-027DW	Room #5 drinking fountain	1/19/2023	ND	Non-Detect					2302879
05581100-028CF	Room #6 faucet	1/21/2023	ND	Non-Detect					2302879
05581100-029DW	Room #6 drinking fountain	1/21/2023	ND	Non-Detect					2302879
05581100-030CF	Room #7 faucet	1/19/2023	7.20	Moderate					2302879
05581100-031DW	Room #7 drinking fountain	1/19/2023	ND	Non-Detect					2302879
05581100-032CF	Room #8 faucet	1/19/2023	18.40	Action Req					2302879
05581100-033DW	Room #8 drinking fountain	1/19/2023	ND	Non-Detect					2302879
05581100-034BF	West Boys bathroom faucet (west)	1/19/2023	ND	Non-Detect					2302879
05581100-035BF	West Boys bathroom faucet (middle)	1/19/2023	2.19	Low					2302879