

Walterville Elementary									
ODE Building # 05581100									
Fixture ID #	Fixture Description per Location	Initial Test Date	Initial Test Result (ppb)	Initial Level	Final Retest Date	Final Test Result (ppb)	Final Level	Notes	Order No.:
05581100-001NS	Health room Faucet	1/19/2023	ND	Non-Detect					2302879
05581100-002DW	Health room drinking fountain	1/19/2023	ND	Non-Detect					2302879
05581100-003BF	Office bathroom (north)	1/19/2023	ND	Non-Detect					2302879
05581100-004BF	Office bathroom (south)	1/19/2023	ND	Non-Detect					2302879
05581100-005SF	Office breakroom faucet	1/19/2023	ND	Non-Detect					2302879
05581100-006BF	East Boys bathroom faucet (north)	1/19/2023	ND	Non-Detect					2302879
05581100-007BF	East Boys bathroom faucet (middle)	1/19/2023	ND	Non-Detect					2302879
05581100-008BF	East Boys bathroom faucet (south)	1/19/2023	ND	Non-Detect					2302879
05581100-009BF	East Girls bathroom faucet (north)	1/19/2023	ND	Non-Detect					2302879
05581100-010BF	East Girls bathroom faucet (middle)	1/19/2023	ND	Non-Detect					2302879
05581100-011BF	East Girls bathroom faucet (south)	1/19/2023	ND	Non-Detect					2302879
05581100-012CF	Room #9 faucet	1/19/2023	ND	Non-Detect					2302879
05581100-013DW	Room #9 drinking fountain	1/19/2023	ND	Non-Detect					2302879
05581100-014CF	Room #10 faucet	1/19/2023	ND	Non-Detect					2302879
05581100-015DW	Room #10 drinking fountain	1/19/2023	ND	Non-Detect					2302879
05581100-016CF	Room #11 faucet	1/19/2023	ND	Non-Detect					2302879
05581100-017DW	Room #11 drinking fountain	1/19/2023	ND	Non-Detect					2302879
05581100-018CF	Room #12 faucet	1/19/2023	3.32	Low					2302879
05581100-019DW	Room #12 drinking fountain	1/19/2023	3.09	Low					2302879
05581100-020BF	Center Boys bathroom faucet (north)	1/19/2023	ND	Non-Detect					2302879
05581100-021BF	Center Boys bathroom faucet (middle)	1/19/2023	ND	Non-Detect					2302879
05581100-022BF	Center Boys bathroom faucet (south)	1/19/2023	2.26	Low					2302879
05581100-023BF	Center Girls bathroom faucet (north)	1/19/2023	2.04	Low					2302879
05581100-024BF	Center Girls bathroom faucet (middle)	1/19/2023	ND	Non-Detect					2302879
05581100-025BF	Center Girls bathroom faucet (south)	1/19/2023	ND	Non-Detect					2302879
05581100-026CF	Room #5 faucet	1/19/2023	ND	Non-Detect					2302879
05581100-027DW	Room #5 drinking fountain	1/19/2023	ND	Non-Detect					2302879
05581100-028CF	Room #6 faucet	1/21/2023	ND	Non-Detect					2302879
05581100-029DW	Room #6 drinking fountain	1/21/2023	ND	Non-Detect					2302879
05581100-030CF	Room #7 faucet	1/19/2023	7.20	Moderate					2302879
05581100-031DW	Room #7 drinking fountain	1/19/2023	ND	Non-Detect					2302879
05581100-032CF	Room #8 faucet	1/19/2023	18.40	Action Req					2302879
05581100-033DW	Room #8 drinking fountain	1/19/2023	ND	Non-Detect					2302879
05581100-034BF	West Boys bathroom faucet (west)	1/19/2023	ND	Non-Detect					2302879
05581100-035BF	West Boys bathroom faucet (middle)	1/19/2023	2.19	Low					2302879

Walterville Elementary									
ODE Building # 05581100									
Fixture ID #	Fixture Description per Location	Initial Test Date	Initial Test Result (ppb)	Initial Level	Final Retest Date	Final Test Result (ppb)	Final Level	Notes	Order No.:
05581100-036BF	West Boys bathroom faucet (east)	1/19/2023	ND	Non-Detect					2302879
05581100-037BF	West Girls bathroom faucet (west)	1/19/2023	ND	Non-Detect					2302879
05581100-038BF	West Girls bathroom faucet (middle)	1/19/2023	ND	Non-Detect					2302879
05581100-039BF	West Girls bathroom faucet (east)	1/19/2023	ND	Non-Detect					2302879
05581100-040CF	Room #1 faucet	1/19/2023	ND	Non-Detect					2302879
05581100-041DW	Room #1 drinking fountain	1/19/2023	2.15	Low					2302879
05581100-042CF	Room #2 faucet	1/19/2023	ND	Non-Detect					2302879
05581100-043DW	Room #2 drinking fountain	1/19/2023	ND	Non-Detect					2302879
05581100-044CF	Room #3 faucet	1/19/2023	ND	Non-Detect					2302879
05581100-045DW	Room #3 drinking fountain	1/19/2023	ND	Non-Detect					2302879
05581100-046CF	Room #4 faucet	1/19/2023	193.00	Action Req	5/29/2025			Results Pending	2302879
05581100-047DW	Room #4 drinking fountain	1/19/2023	ND	Non-Detect					2302879
05581100-048BF	Gym bathroom faucet	1/19/2023	3.41	Low					2302879
05581100-049DW	Gym drinking fountain	1/19/2023	ND	Non-Detect					2302879
05581100-050WB	Gym bottle filler	1/19/2023	ND	Non-Detect					2302879
05581100-051KF	Kitchen (west)	2/27/2023	ND	Non-Detect					2302882
05581100-052KF	Kitchen (middle)	2/27/2023	ND	Non-Detect					2302882
05581100-053KF	Kitchen (east)	2/27/2023	ND	Non-Detect					2302882