

Yolanda Elementary  
 ODE Building #05591200

Redo or double check Map in comparison to fixture ID coding for future testing

Fixture ID #	Fixture Description per Location	Initial Test Date	Initial Test Result (ppb)	Initial Level	Final Retest Date	Final Test Result (ppb)	Final Level	Notes	Order No.:
05591200-001NS	Nurse office sink	3/2/2023	4.23	Low					2303093
05591200-002BF	Nurse office bathroom faucet	3/2/2023	ND	Non-Detect					2303093
05591200-003BF	Staff bathroom faucet	3/2/2023	2.58	Low					2303093
05591200-004BF	Staff bathroom faucet	3/2/2023	2.63	Low					2303093
05591200-005SF	Staff Faucet	3/2/2023	ND	Non-Detect					2303093
05591200-006SF	Staff Faucet	3/2/2023	ND	Non-Detect					2303093
05591200-007DW	Cafeteria drinking water fountain	3/2/2023	ND	Non-Detect					2303093
05591200-008BF	Cafeteria Bottle Fill Station	3/2/2023	ND	Non-Detect					2303093
05591200-009KF	Kitchen Faucet near dishwasher	3/2/2023	3.52	Low					2303093
05591200-010KF	Kitchen Faucet Middle	3/2/2023	3.15	Low					2303093
05591200-011KF	Kitchen Faucet single on east	3/2/2023	4.60	Low					2303093
05591200-012BF	Bathroom Faucet in kitchen staff restroom	3/2/2023	11.70	High					2303093
05591200-013BF	Gym girls restroom Bathroom Faucet	3/2/2023	2.21	Low					2303093
05591200-014DW	Gym girls restroom Drinking water faucet	3/2/2023	ND	Non-Detect					2303093
05591200-015BF	Gym Staff restroom Bathroom Faucet	3/2/2023	7.30	Moderate					2303093
05591200-016BF	Gym Boys restroom bathroom faucet	3/2/2023	4.08	Low					2303093
05591200-017DW	Gym Boys restroom Drinking Water fountain	3/2/2023	ND	Non-Detect					2303093
05591200-018DW	Gym main entrance Drinking Water fountain	3/2/2023	ND	Non-Detect					2303093
05591200-019DW	Building C Classroom 18 Drinking Water Fountain	3/2/2023	4.14	Low					2303093
05591200-020CF	Classroom 18 Classroom Faucet	3/2/2023	2.61	Low					2303093
05591200-021DW	Classroom 17 Drinking Water Fountain	3/2/2023	5.54	Moderate					2303093
05591200-022CF	Classroom 17 Classroom Faucet	3/2/2023	ND	Non-Detect					2303093
05591200-023DW	Classroom 16 Drinking Water Fountain	3/2/2023	ND	Non-Detect					2303093
05591200-024CF	Classroom 16 Classroom Faucet	3/2/2023	3.67	Low					2303093
05591200-025DW	Classroom 15 Drinking Water Fountain	3/2/2023	3.06	Low					2303093
05591200-026CF	Classroom 15 Classroom Faucet	3/2/2023	2.11	Low					2303093
05591200-027DW	Classroom 14 Drinking Water Fountain	3/2/2023	ND	Non-Detect					2303093
05591200-028CF	Classroom 14 Classroom Faucet	3/2/2023	3.65	Low					2303093
05591200-029DW	Classroom 13 Drinking Water Fountain	3/2/2023	7.82	Moderate					2303093
05591200-030CF	Classroom 13 Classroom Faucet	3/2/2023	2.67	Low					2303093
05591200-031DW	Building B Classroom 12 Drinking Water Fountain	3/2/2023	ND	Non-Detect					2303093
05591200-032CF	Classroom 12 Classroom Faucet	3/2/2023	4.34	Low					2303093
05591200-033DW	Classroom 11 Drinking Water Fountain	3/2/2023	2.24	Low					2303093
05591200-034CF	Classroom 11 Classroom Faucet	3/2/2023	ND	Non-Detect					2303093
05591200-035DW	Classroom 10 Drinking Water Fountain	3/2/2023	ND	Non-Detect					2303093
05591200-036CF	Classroom 10 Classroom Faucet	3/2/2023	ND	Non-Detect					2303093
05591200-037DW	Classroom 09 Drinking Water Fountain	3/2/2023	ND	Non-Detect					2303093
05591200-038CF	Classroom 09 Classroom Faucet	3/2/2023	ND	Non-Detect					2303093
05591200-039DW	Classroom 08 Drinking Water Fountain	3/2/2023	ND	Non-Detect					2303093
05591200-040CF	Classroom 08 Classroom Faucet	3/2/2023	ND	Non-Detect					2303093
05591200-041DW	Classroom 07 Drinking Water Fountain	3/2/2023	4.26	Low					2303093
05591200-042CF	Classroom 07 Classroom Faucet	3/2/2023	ND	Non-Detect					2303093
05591200-043DW	Building D classroom 19 Drinking Water Fountain	3/2/2023	ND	Non-Detect					2303093
05591200-044CF	Classroom 19 Classroom Faucet	3/2/2023	ND	Non-Detect					2303093
05591200-045DW	Classroom 20 Drinking water Fountain	3/2/2023	ND	Non-Detect					2303093
05591200-046CF	Classroom 20 Classroom Faucet	3/2/2023	ND	Non-Detect					2303093

Yolanda Elementary					Redo or double check Map in comparison to fixture ID coding for future testing				
ODE Building #05591200									
Fixture ID #	Fixture Description per Location	Initial Test Date	Initial Test Result (ppb)	Initial Level	Final Retest Date	Final Test Result (ppb)	Final Level	Notes	Order No.:
05591200-047BF	Student restroom Bathroom Faucet	3/2/2023	ND	Non-Detect					2303093
05591200-048BF	Staff restroom Bathroom Faucet	3/2/2023	ND	Non-Detect					2303093
05591200-049DW	Building A Classroom 6 Drinking Water Fountain	3/2/2023	ND	Non-Detect					2303093
05591200-050CF	Classroom 6 Classroom Faucet	3/2/2023	ND	Non-Detect					2303093
05591200-051DW	Classroom 5 Drinking Water Fountain	3/2/2023	ND	Non-Detect					2303097
05591200-052CF	Classroom 5 Classroom Faucet	3/2/2023	ND	Non-Detect					2303097
05591200-053DW	Classroom 4 Drinking Water Fountain	3/2/2023	2.07	Low					2303097
05591200-054CF	Classroom 4 Classroom Faucet	3/2/2023	ND	Non-Detect					2303097
05591200-055BF	Bathroom Faucet east	3/2/2023	ND	Non-Detect					2303097
05591200-056BF	Bathroom Faucet mid	3/2/2023	ND	Non-Detect					2303097
05591200-057BF	Bathroom Faucet mid	3/2/2023	ND	Non-Detect					2303097
05591200-058BF	Bathroom Faucet west	3/2/2023	ND	Non-Detect					2303097
05591200-059DW	Classroom 3 Drinking Water Faucet	3/2/2023	ND	Non-Detect					2303097
05591200-060CF	Classroom 3 Classroom Faucet	3/2/2023	ND	Non-Detect					2303097
05591200-061DW	Classroom 2 Drinking Water Faucet	3/2/2023	ND	Non-Detect					2303097
05591200-062CF	Classroom 2 Classroom Faucet	3/2/2023	ND	Non-Detect					2303097
05591200-063DW	Classroom 1 Drinking Water Faucet	3/2/2023	ND	Non-Detect					2303097
05591200-064CF	Classroom 1 Classroom Faucet	3/2/2023	ND	Non-Detect					2303097
05591200-065WB	Gym main entrance Bottle Fill station								

**Add In As 19 when the ODE number is Updated before testing again**