

DOH Result Line Number	Sample Order Number	ICOS Building Name	Site Map Building Name	Location description	 Type	Results (ppb)- Entered Manually, Check DOH Report
1	25	Bldg C	Bldg A	Workroom	Sink faucet	285
2	29	Bldg B	Bldg B	South Workroom	Sink faucet	97
3	44	Bldg B	Bldg B	North Work room	Sink faucet	91
4	19	Bldg C	Bldg A	Classroom 4	Sink faucet	83
5	42	Bldg B	Bldg B	Classroom 12	Sink faucet	40
6	63	Bldg F	Bldg D	Classroom 25	Sink faucet	14
7	3	Bldg D	Bldg C	Health Room	Sink faucet	11
8	32	Bldg B	Bldg B	Classroom 7	Sink faucet	11
9	6	Bldg D	Bldg C	Library	Sink faucet	8
10	46	Bldg B	Bldg B	Classroom 13	Sink faucet	8
11	40	Bldg B	Bldg B	Classroom 11	Sink faucet	7
12	28	Bldg E	Bldg B	Classroom 22	Sink faucet	7
13	43	Bldg B	Bldg B	Classroom 12	Water fountain	6
14	50	Bldg B	Bldg B	Classroom 15	Sink faucet	6
15	37	Bldg B	Bldg B	Classroom 10	Sink faucet	5
16	23	Bldg C	Bldg A	Classroom 6	Sink faucet	5
17	52	Bldg B	Bldg B	Classroom 16	Sink faucet	5
18	54	Bldg B	Bldg B	Classroom 17	Sink faucet	5
19	56	Bldg B	Bldg B	Classroom 18	Sink faucet	5
20	5	Bldg D	Bldg C	Staff lounge	Water fountain	4
21	36	Bldg B	Bldg B	Classroom 9	Sink faucet	4
22	48	Bldg B	Bldg B	Classroom 14	Sink faucet	4
23	10	Bldg D	Bldg C	Classroom 19	Water fountain	4
24	26	Bldg E	Bldg B	Classroom 21	Sink faucet	4
25	8	Bldg D	Bldg C	Classroom 20	Water fountain	3

DOH Result Line Number	Sample Order Number	ICOS Building Name	Site Map Building Name	Location description	 Type	Results (ppb)- Entered Manually, Check DOH Report
26	20	Bldg C	Bldg A	Classroom 4	Water fountain	3
27	21	Bldg C	Bldg A	Classroom 5	Sink faucet	3
28	24	Bldg C	Bldg A	Classroom 6	Water fountain	3
29	57	Bldg B	Bldg B	Classroom 18	Water fountain	3
30	64	Bldg F	Bldg D	Classroom 25	Water fountain	3
31	4	Bldg D	Bldg C	Staff lounge	Sink faucet	2
32	7	Bldg D	Bldg C	Classroom 20	Sink faucet	2
33	33	Bldg B	Bldg B	Classroom 7	Water fountain	2
34	34	Bldg B	Bldg B	Classroom 8	Sink faucet	2
35	35	Bldg B	Bldg B	Classroom 8	Water fountain	2
36	39	Bldg B	Bldg B	Classroom 10	Water fountain	2
37	47	Bldg B	Bldg B	Classroom 13	Water fountain	2
38	13	Bldg C	Bldg A	Classroom 1	Sink faucet	2
39	15	Bldg C	Bldg A	Classroom 2	Sink faucet	2
40	18	Bldg C	Bldg A	Classroom 3	Water fountain	2
41	49	Bldg B	Bldg B	Classroom 14	Water fountain	2
42	51	Bldg B	Bldg B	Classroom 15	Water fountain	2
43	53	Bldg B	Bldg B	Classroom 16	Water fountain	2
44	60	Bldg E	Bldg B	Classroom 24	Water fountain	2
45	61	Bldg E	Bldg B	Classroom 23	Sink faucet	2
46	31	Bldg B	Bldg B	hall - Left of Room 9	Water fountain	1
47	38	Bldg B	Bldg B	Classroom 9	Water fountain	1
48	11	Bldg C	Bldg A	hall - left of room 3	Water fountain	1
49	17	Bldg C	Bldg A	Classroom 3	Sink faucet	1
50	55	Bldg B	Bldg B	Classroom 17	Water fountain	1

DOH Result Line Number	Sample Order Number	ICOS Building Name	Site Map Building Name	Location description	 Type	Results (ppb)- Entered Manually, Check DOH Report
51	58	Bldg E	Bldg B	Hall - right of Rm 24	Water fountain	1
52	1	Bldg A	Bldg D	Gym hall	Water fountain	<1
53	2	Bldg A	Bldg D	Gym hall	Bottle filler	<1
54	30	Bldg E	Bldg B	Classroom 22	Water fountain	<1
55	41	Bldg B	Bldg B	Classroom 11	Water fountain	<1
56	45	Bldg B	Bldg B	Hall - Right of Room 16	Water fountain	<1
57	9	Bldg D	Bldg C	Classroom 19	Sink faucet	<1
58	12	Bldg C	Bldg A	hall - left of room 3	Bottle filler	<1
59	14	Bldg C	Bldg A	Classroom 1	Water fountain	<1
60	16	Bldg C	Bldg A	Classroom 2	Water fountain	<1
61	22	Bldg C	Bldg A	Classroom 5	Water fountain	<1
62	27	Bldg E	Bldg B	Classroom 21	Water fountain	<1
63	59	Bldg E	Bldg B	Classroom 24	Sink faucet	<1
64	62	Bldg E	Bldg B	Classroom 23	Water fountain	<1