

Lead in School Drinking Water Report

Terrace Park Elementary School



EXPLANATION OF TESTING AND RESULTS

Results in this report represent sampling conducted by Washington State Department of Health (DOH). Per [RCW 28A.210.410](#) sampling and testing protocols, samples were collected as first-draw. Depending on size of the school(s) and number of drinking water fixtures, multiple dates for collecting samples may have been necessary to meet sampling and testing protocols.

[RCW 28A.210.410](#) does not require remediation for fixtures testing at 5 ppb and under. DOH offers post-remediation testing only for outlets that initially tested above 5 ppb. After a school completes remediation, DOH will provide up to two post-remediation sampling visits. If after the second post-remediation sampling, outlets test above 5 ppb, the district will be responsible for finding a contractor to conduct additional sampling and testing. For questions regarding sampling, testing, and results, please email: leadfreekids@doh.wa.gov.

DEFINITIONS

Fixture Housing
Location

Room/space where
fixture is located
(i.e. room number,
gym, playground)

Fixture Housing Type

Structure that contains
the individual fixtures
where water samples
were collected from.
Fixture housing may
contain one or more
individual fixture for
sampling.

Fixture Location
Details

Location within a
room or space where
fixture housing is
located, starting to the
left of the entrance and
rotating clockwise, of
the total number of
fixture housings in a
room or space
(e.g. 1/5, 2/5)

Fixture Type

Tap, Sprayer, Water
Fountain, Water Bottle
Filler, Ice maker

Fixture Position

Left, Center, Right

Date(s) collected: 2025-05-06

Date(s) analyzed: 2025-05-15

.	Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
1	394616	Unit A - Main Building	Sink - Multi-Compartment	E203	1 of 1	Tap	center	71
2	394095	Unit A - Main Building	Sink	B102	1 of 1	Tap	center	14
3	394091	Unit A - Main Building	Sink	Teaching Kitchen	1 of 1	Tap	center	13
4	394619	Unit A - Main Building	Sink	D200 Flex	1 of 1	Tap	center	9
5	394587	Unit A - Main Building	Fountain/Tap Combo	C102	1 of 1	Water Fountain	right	7
6	394093	Unit A - Main Building	Sink	A105	1 of 1	Tap	center	5
7	394109	Unit A - Main Building	Fountain/Tap Combo	F108	1 of 1	Water Fountain	right	5
8	394605	Unit A - Main Building	Fountain	F104	1 of 1	Water Fountain	center	5
9	394610	Unit A - Main Building	Sink	E204	1 of 2 projector screen side	Tap	center	5

	Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
10	394099	Unit A - Main Building	Sink	C100 Flex	1 of 1	Tap	center	4
11	394107	Unit A - Main Building	Fountain/Tap Combo	D104	1 of 1	Water Fountain	right	4
12	394581	Unit A - Main Building	Fountain/Tap Combo	C105	1 of 1	Water Fountain	right	4
13	394595	Unit A - Main Building	Sink	D100 Flex	1 of 1	Tap	center	4
14	394112	Unit A - Main Building	Sink	E100 Flex	1 of 1	Tap	center	3
15	394591	Unit A - Main Building	Fountain/Tap Combo	C104	1 of 1	Water Fountain	right	3
16	394611	Unit A - Main Building	Sink	E204	2 of 2 left of small whiteboard	Tap	center	3
17	394101	Unit A - Main Building	Fountain/Tap Combo	D103	1 of 1	Water Fountain	right	2
18	394114	Unit A - Main Building	Fountain/Tap Combo	E104	1 of 1	Water Fountain	right	2
19	394116	Unit A - Main Building	Fountain/Tap Combo	E105	1 of 1	Water Fountain	right	2

	Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
20	394121	Unit A - Main Building	Fountain/Tap Combo	D204	1 of 1	Water Fountain	right	2
21	394123	Unit A - Main Building	Fountain/Tap Combo	D205	1 of 1	Water Fountain	right	2
22	394124	Unit A - Main Building	Fountain/Tap Combo	D206	1 of 1	Tap	center	2
23	394129	Unit A - Main Building	Fountain/Tap Combo	D202	1 of 1	Water Fountain	right	2
24	394131	Unit A - Main Building	Fountain/Tap Combo	D201	1 of 1	Water Fountain	right	2
25	394583	Unit A - Main Building	Fountain/Tap Combo	C106	1 of 1	Water Fountain	right	2
26	394589	Unit A - Main Building	Fountain/Tap Combo	C101	1 of 1	Water Fountain	right	2
27	394597	Unit A - Main Building	Fountain/Tap Combo	D105	1 of 1	Water Fountain	right	2
28	394609	Unit A - Main Building	Sink	E200 Flex	1 of 1	Tap	center	2
29	394613	Unit A - Main Building	Fountain/Tap Combo	E205	1 of 1	Water Fountain	right	2
30	394088	Unit A - Main Building	Sink	Kitchen	1 of 1	Tap	center	1

	Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
31	394096	Unit A - Main Building	Sink	B101	1 of 1	Tap	center	1
32	394103	Unit A - Main Building	Fountain/Tap Combo	D102	1 of 1	Water Fountain	right	1
33	394104	Unit A - Main Building	Fountain/Tap Combo	D101	1 of 1	Tap	center	1
34	394105	Unit A - Main Building	Fountain/Tap Combo	D101	1 of 1	Water Fountain	right	1
35	394118	Unit A - Main Building	Fountain/Tap Combo	E106	1 of 1	Water Fountain	right	1
36	394125	Unit A - Main Building	Fountain/Tap Combo	D206	1 of 1	Water Fountain	right	1
37	394126	Unit A - Main Building	Fountain/Tap Combo	D203	1 of 1	Tap	center	1
38	394127	Unit A - Main Building	Fountain/Tap Combo	D203	1 of 1	Water Fountain	right	1
39	394584	Unit A - Main Building	Fountain/Tap Combo	C103	1 of 1	Tap	center	1
40	394586	Unit A - Main Building	Fountain/Tap Combo	C102	1 of 1	Tap	center	1
41	394598	Unit A - Main Building	Fountain/Tap Combo	D106	1 of 1	Tap	center	1

.	Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
42	394599	Unit A - Main Building	Fountain/Tap Combo	D106	1 of 1	Water Fountain	right	1
43	394600	Unit A - Main Building	Fountain/Tap Combo	E103	1 of 1	Water Fountain	right	1
44	394601	Unit A - Main Building	Fountain/Tap Combo	E102	1 of 1	Tap	center	1
45	394602	Unit A - Main Building	Fountain/Tap Combo	E102	1 of 1	Water Fountain	right	1
46	394604	Unit A - Main Building	Fountain/Tap Combo	E101	1 of 1	Water Fountain	right	1
47	394615	Unit A - Main Building	Fountain/Tap Combo	E206	1 of 1	Water Fountain	right	1
48	394617	Unit A - Main Building	Fountain/Tap Combo	E201	1 of 1	Tap	center	1
49	394618	Unit A - Main Building	Fountain/Tap Combo	E201	1 of 1	Water Fountain	right	1
50	394089	Unit A - Main Building	Fountain	Gym	1 of 2 next to bathrooms	Water Fountain	center	<1
51	394090	Unit A - Main Building	Fountain	Gym	2 of 2 next to exit	Water Fountain	center	<1

	Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
52	394092	Unit A - Main Building	Sink	Health Room	1 of 1	Tap	center	<1
53	394094	Unit A - Main Building	Sink	A109	1 of 1	Tap	center	<1
54	394097	Unit A - Main Building	Fountain - Multi-Level	C100 Bathrooms	1 of 1	Water Fountain	left	<1
55	394098	Unit A - Main Building	Fountain - Multi-Level	C100 Bathrooms	1 of 1	Water Fountain	right	<1
56	394100	Unit A - Main Building	Fountain/Tap Combo	D103	1 of 1	Tap	center	<1
57	394102	Unit A - Main Building	Fountain/Tap Combo	D102	1 of 1	Tap	center	<1
58	394106	Unit A - Main Building	Fountain/Tap Combo	D104	1 of 1	Tap	center	<1
59	394108	Unit A - Main Building	Fountain/Tap Combo	F108	1 of 1	Tap	center	<1
60	394110	Unit A - Main Building	Fountain - Multi-Level	E100 Bathrooms	1 of 1	Water Fountain	left	<1
61	394111	Unit A - Main Building	Fountain - Multi-Level	E100 Bathrooms	1 of 1	Water Fountain	right	<1
62	394113	Unit A - Main Building	Fountain/Tap Combo	E104	1 of 1	Tap	center	<1

	Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
63	394115	Unit A - Main Building	Fountain/Tap Combo	E105	1 of 1	Tap	center	<1
64	394117	Unit A - Main Building	Fountain/Tap Combo	E106	1 of 1	Tap	center	<1
65	394119	Unit A - Main Building	Fountain/Tap Combo	E103	1 of 1	Tap	center	<1
66	394120	Unit A - Main Building	Fountain/Tap Combo	D204	1 of 1	Tap	center	<1
67	394122	Unit A - Main Building	Fountain/Tap Combo	D205	1 of 1	Tap	center	<1
68	394128	Unit A - Main Building	Fountain/Tap Combo	D202	1 of 1	Tap	center	<1
69	394130	Unit A - Main Building	Fountain/Tap Combo	D201	1 of 1	Tap	center	<1
70	394580	Unit A - Main Building	Fountain/Tap Combo	C105	1 of 1	Tap	center	<1
71	394582	Unit A - Main Building	Fountain/Tap Combo	C106	1 of 1	Tap	center	<1
72	394585	Unit A - Main Building	Fountain/Tap Combo	C103	1 of 1	Water Fountain	right	<1
73	394588	Unit A - Main Building	Fountain/Tap Combo	C101	1 of 1	Tap	center	<1

	Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
74	394590	Unit A - Main Building	Fountain/Tap Combo	C104	1 of 1	Tap	center	<1
75	394592	Unit A - Main Building	Fountain - Multi-Level with Bottle Filler	D100 Bathrooms	1 of 1	Water Fountain	left	<1
76	394593	Unit A - Main Building	Fountain - Multi-Level with Bottle Filler	D100 Bathrooms	1 of 1	Water Fountain	right	<1
77	394594	Unit A - Main Building	Fountain - Multi-Level with Bottle Filler	D100 Bathrooms	1 of 1	Water Bottle Filler	left	<1
78	394596	Unit A - Main Building	Fountain/Tap Combo	D105	1 of 1	Tap	center	<1
79	394603	Unit A - Main Building	Fountain/Tap Combo	E101	1 of 1	Tap	center	<1
80	394606	Unit A - Main Building	Fountain - Multi-Level with Bottle Filler	E200 Bathrooms	1 of 1	Water Fountain	left	<1
81	394607	Unit A - Main Building	Fountain - Multi-Level with Bottle Filler	E200 Bathrooms	1 of 1	Water Fountain	right	<1
82	394608	Unit A - Main Building	Fountain - Multi-Level with Bottle Filler	E200 Bathrooms	1 of 1	Water Bottle Filler	center	<1

	Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Fixture Position	Lead Test Result (ppb)
83	394612	Unit A - Main Building	Fountain/Tap Combo	E205	1 of 1	Tap	center	<1
84	394614	Unit A - Main Building	Fountain/Tap Combo	E206	1 of 1	Tap	center	<1