

SAMPLENAME	LABSAMPID	MATRIX	SAMPDATE	METHODCODE	ANALYTE	RESULT	RL	UNITS
BES-Field Blank	AD20088-01	Drinking Water	5/7/2025 5:48	01-Metals 200.8 Lead (Pb)	Lead	ND	1.00	µg/L
BES-1-POE-Rm5-CF-P	AD20088-02	Drinking Water	5/7/2025 5:49	01-Metals 200.8 Lead (Pb)	Lead	ND	1.00	µg/L
BES-1-Rm4-CF-P	AD20088-03	Drinking Water	5/7/2025 5:50	01-Metals 200.8 Lead (Pb)	Lead	ND	1.00	µg/L
BES-1-Rm2/3-CF-P	AD20088-04	Drinking Water	5/7/2025 5:51	01-Metals 200.8 Lead (Pb)	Lead	ND	1.00	µg/L
BES-1-Rm1-CF-P	AD20088-05	Drinking Water	5/7/2025 5:52	01-Metals 200.8 Lead (Pb)	Lead	ND	1.00	µg/L
BES-1-Rm6-CF-P	AD20088-06	Drinking Water	5/7/2025 5:54	01-Metals 200.8 Lead (Pb)	Lead	1.37	1.00	µg/L
BES-1-Rm7-CF-P	AD20088-07	Drinking Water	5/7/2025 5:55	01-Metals 200.8 Lead (Pb)	Lead	4.98	1.00	µg/L
BES-1-Rm10-CF-P	AD20088-08	Drinking Water	5/7/2025 5:56	01-Metals 200.8 Lead (Pb)	Lead	ND	1.00	µg/L
BES-1-Rm8-CF-P	AD20088-09	Drinking Water	5/7/2025 5:57	01-Metals 200.8 Lead (Pb)	Lead	1.04	1.00	µg/L
BES-1-Rm9-CF-P	AD20088-10	Drinking Water	5/7/2025 5:58	01-Metals 200.8 Lead (Pb)	Lead	10.1	1.00	µg/L
BES-1-HRmS3-BT-P	AD20088-11	Drinking Water	5/7/2025 5:59	01-Metals 200.8 Lead (Pb)	Lead	ND	1.00	µg/L
BES-1-HRm-S3-WC-P	AD20088-12	Drinking Water	5/7/2025 6:00	01-Metals 200.8 Lead (Pb)	Lead	ND	1.00	µg/L
BES-1-RmS1-CF-P	AD20088-13	Drinking Water	5/7/2025 6:03	01-Metals 200.8 Lead (Pb)	Lead	4.81	1.00	µg/L
BES-1-Rm12-CF-P	AD20088-14	Drinking Water	5/7/2025 6:04	01-Metals 200.8 Lead (Pb)	Lead	ND	1.00	µg/L
BES-1-Rm13-CF-P	AD20088-15	Drinking Water	5/7/2025 6:05	01-Metals 200.8 Lead (Pb)	Lead	1.38	1.00	µg/L
BES-1-Rm18-CF-P	AD20088-16	Drinking Water	5/7/2025 6:06	01-Metals 200.8 Lead (Pb)	Lead	3.10	1.00	µg/L
BES-1-Rm14-CF-P	AD20088-17	Drinking Water	5/7/2025 6:07	01-Metals 200.8 Lead (Pb)	Lead	ND	1.00	µg/L
BES-1-Rm19-CF-P	AD20088-18	Drinking Water	5/7/2025 6:08	01-Metals 200.8 Lead (Pb)	Lead	1.23	1.00	µg/L
BES-1-Rm15-CF-P	AD20088-19	Drinking Water	5/7/2025 6:09	01-Metals 200.8 Lead (Pb)	Lead	1.66	1.00	µg/L
BES-1-Rm20-CF-P	AD20088-20	Drinking Water	5/7/2025 6:10	01-Metals 200.8 Lead (Pb)	Lead	1.27	1.00	µg/L
BES-1-Rm16-CF-P	AD20088-21	Drinking Water	5/7/2025 6:11	01-Metals 200.8 Lead (Pb)	Lead	2.04	1.00	µg/L
BES-1-Rm21-CF-P	AD20088-22	Drinking Water	5/7/2025 6:12	01-Metals 200.8 Lead (Pb)	Lead	1.72	1.00	µg/L
BES-1-HRmA13-TF-P	AD20088-23	Drinking Water	5/7/2025 6:15	01-Metals 200.8 Lead (Pb)	Lead	ND	1.00	µg/L
BES-1-Nur-NS1-P	AD20088-24	Drinking Water	5/7/2025 6:17	01-Metals 200.8 Lead (Pb)	Lead	ND	1.00	µg/L
BES-1-Nur-NS2-P	AD20088-25	Drinking Water	5/7/2025 6:18	01-Metals 200.8 Lead (Pb)	Lead	ND	1.00	µg/L
BES-1-Rm22-CF-P	AD20088-26	Drinking Water	5/7/2025 6:20	01-Metals 200.8 Lead (Pb)	Lead	ND	1.00	µg/L
BES-1-RS4-TF-P	AD20088-27	Drinking Water	5/7/2025 6:21	01-Metals 200.8 Lead (Pb)	Lead	ND	1.00	µg/L
BES-1-Rm32-CF-P	AD20088-28	Drinking Water	5/7/2025 6:22	01-Metals 200.8 Lead (Pb)	Lead	1.78	1.00	µg/L
BES-1-Rm33-CF-P	AD20088-29	Drinking Water	5/7/2025 6:23	01-Metals 200.8 Lead (Pb)	Lead	2.67	1.00	µg/L
BES-1-HRmM6-BT-P	AD20088-30	Drinking Water	5/7/2025 6:25	01-Metals 200.8 Lead (Pb)	Lead	ND	1.00	µg/L
BES-1-Rm41-CF-P	AD20088-31	Drinking Water	5/7/2025 6:27	01-Metals 200.8 Lead (Pb)	Lead	ND	1.00	µg/L
BES-1-Rm40-CF-P	AD20088-32	Drinking Water	5/7/2025 6:28	01-Metals 200.8 Lead (Pb)	Lead	ND	1.00	µg/L
BES-1-Rm42-CF-P	AD20088-33	Drinking Water	5/7/2025 6:29	01-Metals 200.8 Lead (Pb)	Lead	ND	1.00	µg/L

BES-1-Rm43-CF-P	AD20088-34	Drinking Water	5/7/2025 6:30	01-Metals 200.8 Lead (Pb)	Lead	ND	1.00	µg/L
BES-1-Rm44-CF-P	AD20088-35	Drinking Water	5/7/2025 6:31	01-Metals 200.8 Lead (Pb)	Lead	ND	1.00	µg/L
BES-1-Kit-IM-P	AD20088-36	Drinking Water	5/7/2025 6:35	01-Metals 200.8 Lead (Pb)	Lead	ND	1.00	µg/L
BES-1-Kit-FP1-P	AD20088-37	Drinking Water	5/7/2025 6:36	01-Metals 200.8 Lead (Pb)	Lead	ND	1.00	µg/L
BES-1-Kit-FP2-P	AD20088-38	Drinking Water	5/7/2025 6:37	01-Metals 200.8 Lead (Pb)	Lead	1.35	1.00	µg/L
BES-1-Kit-SP-P	AD20088-39	Drinking Water	5/7/2025 6:39	01-Metals 200.8 Lead (Pb)	Lead	ND	1.00	µg/L

Exceeds EPA Action Limit ( > 15.5ppb)

Bldg ID - Floor - Room / Location ID - Outlet Type / Number in Sequence - (P)rimary / (F)lush

OUTLET TYPE

BF = Bathroom Faucet

CF = Classroom Faucet

DW = Drinking Water Fountain

FP = Food Prep

HS = Hand Sink

IM = Ice Machine

KC = Kitchen Outlet, Cold

KT= Kettle

SB = Sink/Bubbler Combination

TF/TS = Teachers Faucet

WC = Water Cooler

BT = Bottle Filler

HB = Hose Bib

ST = Steamer

SP = Sprayer