



CERTIFICATE OF ANALYSIS

Customer : Garden State Environmental
555 South Broad Street, Suite K
Glen Rock, NJ 07452

Project ID : Stafford BOE (Intermediate School) (9001), 1000 Mckinley Avenue, Stafford NJ
PAS Project ID : P25-03529

Matrix : Drinking Water
Report Date : 5/19/2025

PAS Sample ID	Client ID	Analysis	Results	Units	DF	PQL	MDL	MCL	Method	Date Sampled	Date Analyzed
P25-03529-01	SIMS-1-IM01A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/25/25 08:15	5/12/25 10:51
P25-03529-02	SIMS-1-S01A	Lead	0.910 J	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/25/25 08:18	5/12/25 11:07
P25-03529-03	SIMS-1-WC05A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/25/25 08:19	5/12/25 11:19
P25-03529-04	SIMS-1-B01A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/25/25 08:20	5/12/25 11:23
P25-03529-05	SIMS-1-S02A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/25/25 08:23	5/12/25 11:27
P25-03529-06	SIMS-1-S03A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/25/25 08:23	5/12/25 11:31
P25-03529-07	SIMS-1-WC01A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/25/25 08:25	5/12/25 11:35
P25-03529-08	SIMS-1-BF01A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/25/25 08:25	5/12/25 11:39
P25-03529-09	SIMS-1-WC02A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/25/25 08:26	5/12/25 11:43
P25-03529-10	SIMS-1-BF02A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/25/25 08:26	5/12/25 11:47
P25-03529-11	SIMS-1-WC03A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/25/25 08:27	5/12/25 11:51
P25-03529-12	SIMS-1-BF03A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/25/25 08:27	5/12/25 12:03
P25-03529-13	SIMS-1-B03A	Lead	1.72 J	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/25/25 08:29	5/12/25 12:07
P25-03529-14	SIMS-1-S04A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/25/25 08:30	5/12/25 12:11
P25-03529-15	SIMS-1-B04A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/25/25 08:31	5/12/25 12:16
P25-03529-16	SIMS-1-B06A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/25/25 08:32	5/12/25 12:20
P25-03529-17	SIMS-1-B07A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/25/25 08:33	5/12/25 12:24
P25-03529-18	SIMS-1-B08A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/25/25 08:34	5/12/25 12:28
P25-03529-19	SIMS-1-B09A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/25/25 08:35	5/12/25 12:32
P25-03529-20	SIMS-1-B10A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/25/25 08:36	5/12/25 12:36
P25-03529-21	SIMS-1-B11A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/25/25 08:37	5/12/25 12:48
P25-03529-22	SIMS-1-B12A	Lead	1.11 J	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/25/25 08:38	5/12/25 13:04
P25-03529-23	SIMS-1-B13A	Lead	11.6	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/25/25 08:39	5/12/25 13:08
P25-03529-24	SIMS-1-B14A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/25/25 08:42	5/12/25 13:12
P25-03529-25	SIMS-1-B15A	Lead	30.6	ug/L	3	6.00	2.70	15.0 *	SM 3113 B	4/25/25 08:43	5/12/25 14:18
P25-03529-26	SIMS-1-B16A	Lead	1.52 J	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/25/25 08:44	5/12/25 13:20
P25-03529-27	SIMS-1-B17A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/25/25 08:46	5/12/25 13:32
P25-03529-28	SIMS-1-B18A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/25/25 08:47	5/12/25 13:36
P25-03529-29	SIMS-1-B19A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/25/25 08:49	5/12/25 13:40
P25-03529-30	SIMS-1-B20A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/25/25 08:50	5/12/25 13:44
P25-03529-31	SIMS-1-B21A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/25/25 08:51	5/12/25 13:48
P25-03529-32	SIMS-1-B23A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/25/25 08:52	5/12/25 13:52
P25-03529-33	SIMS-1-B25A	Lead	1.11 J	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/25/25 08:54	5/12/25 13:56
P25-03529-34	SIMS-1-B27A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/25/25 08:56	5/12/25 14:00
P25-03529-35	SIMS-1-B28A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/25/25 08:57	5/12/25 14:22
P25-03529-36	SIMS-1-B29A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/25/25 08:58	5/12/25 14:26
P25-03529-37	SIMS-1-B30A	Lead	0.910 J	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/25/25 08:59	5/12/25 14:30
P25-03529-38	SIMS-1-B31A	Lead	1.52 J	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/25/25 09:00	5/12/25 14:34
P25-03529-39	SIMS-1-B32A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/25/25 09:00	5/12/25 14:38
P25-03529-40	SIMS-1-B33A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/25/25 09:01	5/12/25 14:42
P25-03529-41	SIMS-1-B34A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/25/25 09:01	5/12/25 14:46
P25-03529-42	SIMS-1-B35A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/25/25 09:02	5/12/25 15:10
P25-03529-43	SIMS-1-B36A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/25/25 09:03	5/12/25 15:14
P25-03529-44	SIMS-1-B37A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/25/25 09:03	5/12/25 15:18
P25-03529-45	SIMS-1-B38A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/25/25 09:04	5/12/25 15:22
P25-03529-46	SIMS-1-B39A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/25/25 09:05	5/12/25 15:26
P25-03529-47	SIMS-1-B40A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/25/25 09:05	5/12/25 15:30

Except for the parameters tested, York Analytical makes no representation as to the fitness or quality of the water sample taken.

PQL = Practical Quantitation Limit
MDL = Minimum Detection Limit
MCL = Maximum Contaminant Level
DF = Dilution Factor
ND = Analyzed for but not detected
J = Estimated result

* NJ Dept of Education & Dept of Children & Families Action Level

All samples are analyzed in accordance with
New Jersey Department of Environmental
Protection Protocol

Kelly Hogan - Quality Assurance Officer



part of
ALS Limited

Specialists in Drinking Water Testing Technologies ■ Residential ■ Industrial ■ Municipal

York Analytical Laboratory A Division of ALS Limited

2161 WHITESVILLE ROAD TOMS RIVER, NJ 08755 PHONE 732-914-1515 FAX 732-914-1616

NJ Lab Cert. # 15001

CERTIFICATE OF ANALYSIS

Customer : Garden State Environmental
555 South Broad Street, Suite K
Glen Rock, NJ 07452

Project ID : Stafford BOE (Intermediate School) (9001), 1000 Mckinley Avenue, Stafford NJ

Matrix : Drinking Water

PAS Project ID : P25-03529

Report Date : 5/19/2025

PAS Sample ID	Client ID	Analysis	Results	Units	DF	PQL	MDL	MCL	Method	Date Sampled	Date Analyzed
P25-03529-48	SIMS-4-25-FBA	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/25/25 09:06	5/12/25 15:34

Except for the parameters tested, York Analytical makes no representation as to the fitness or quality of the water sample taken.

PQL = Practical Quantitation Limit

MDL = Minimum Detection Limit

MCL = Maximum Contaminant Level

DF = Dilution Factor

ND = Analyzed for but not detected

J = Estimated result

* NJ Dept of Education & Dept of Children & Families Action Level

All samples are analyzed in accordance with
New Jersey Department of Environmental
Protection Protocol

Kelly Hogan - Quality Assurance Officer