

Patuxent High School

2024-2025 Testing Results

Laboratory Name	School Name	Laboratory Reporting Date	Floor #	School Outlet ID/Floor Plan ID	Sample Tap/Outlet Type (code)	Area	Location	Description	Sample Type (Code)	Analysis Date	Lead Sample Result (ppm)	≥ 0.0055 ppm AL?
Water Testing Laboratory of MD	PHS	04/28/2025	2	1a	BF	Hallway	Lobby	Bottle Filler	FD	04/14/2025	<0.0010	No
Water Testing Laboratory of MD	PHS	04/28/2025	2	1b	DFC	Hallway	Lobby	Bottle Filler Fountain	FD	04/14/2025	<0.0010	No
Water Testing Laboratory of MD	PHS	04/28/2025	2	3	DFC	Hallway	outside 208	left fountain	FD	04/14/2025	<0.0010	No
Water Testing Laboratory of MD	PHS	04/28/2025	2	4	DFC	Hallway	outside 208	right fountin	FD	04/14/2025	<0.0010	No
Water Testing Laboratory of MD	PHS	04/28/2025	2	5a	BF	Hallway	outside 265	Bottle Filler	FD	04/14/2025	<0.0010	No
Water Testing Laboratory of MD	PHS	04/28/2025	2	5b	DFC	Hallway	outside 265	Bottle Filler Fountain	FD	04/14/2025	<0.0010	No
Water Testing Laboratory of MD	PHS	04/28/2025	2	7	DFC	Hallway	outside 272	left fountain	FD	04/14/2025	0.0015	No
Water Testing	PHS	04/28/2025	2	8	DFC	Hallway	outside 272	right fountin	FD	04/14/2025	<0.0010	No

Laboratory of MD												
Water Testing Laboratory of MD	PHS	04/28/2025	2	9	DFC	Hallway	outside 288	left fountain	FD	04/14/2025	<0.0010	No
Water Testing Laboratory of MD	PHS	04/28/2025	2	10	DFC	Hallway	outside 288	right fountin	FD	04/14/2025	<0.0010	No
Water Testing Laboratory of MD	PHS	04/28/2025	2	11	DFC	Hallway	outside 292	left fountain	FD	04/14/2025	<0.0010	No
Water Testing Laboratory of MD	PHS	04/28/2025	2	12	DFC	Hallway	outside 292	right fountin	FD	04/14/2025	<0.0010	No
Water Testing Laboratory of MD	PHS	04/28/2025	1	13a	BF	Hallway	Outside G05	Bottle Filler	FD	04/14/2025	<0.0010	No
Water Testing Laboratory of MD	PHS	04/28/2025	1	13b	DFC	Hallway	Outside G05	Bottle Filler Fountain	FD	04/14/2025	<0.0010	No
Water Testing Laboratory of MD	PHS	04/28/2025	3	15a	DFC	Hallway	outside 330	Bottle Filler	FD	04/14/2025	<0.0010	No
Water Testing Laboratory of MD	PHS	04/28/2025	3	15b	DFC	Hallway	outside 330	Bottle Filler Fountain	FD	04/14/2025	<0.0010	No
Water Testing Laboratory	PHS	04/28/2025	3	17	DFC	Hallway	outside 322	left fountain	FD	04/14/2025	<0.0010	No
Water Testing	PHS	04/28/2025	3	18	DFC	Hallway	outside 322	right fountin	FD	04/14/2025	<0.0010	No

Laboratory of MD												
Water Testing Laboratory of MD	PHS	04/28/2025	3	19a	BF	Hallway	outside 344	Bottle Filler	FD	04/14/2025	<0.0010	No
Water Testing Laboratory of MD	PHS	04/28/2025	3	19b	DFC	Hallway	outside 344	Bottle Filler Fountain	FD	04/14/2025	<0.0010	No
Water Testing Laboratory of MD	PHS	04/28/2025	3	21	DFC	Hallway	outside 355	left fountain	FD	04/14/2025	<0.0010	No
Water Testing Laboratory of MD	PHS	04/28/2025	3	22	DFC	Hallway	outside 355	right fountin	FD	04/14/2025	<0.0010	No
Water Testing Laboratory of MD	PHS	04/28/2025	3	23	DFC	Hallway	outside 315	left fountain	FD	04/14/2025	<0.0010	No
Water Testing Laboratory of MD	PHS	04/28/2025	3	24	DFC	Hallway	outside 315	right fountin	FD	04/14/2025	<0.0010	No
Water Testing Laboratory of MD	PHS	04/28/2025	1	25	DFC	Hallway	outside 116	left fountain	FD	04/14/2025	<0.0010	No
Water Testing	PHS	04/28/2025	1	26	DFC	Hallway	outside 116	right fountain	FD	04/14/2025	<0.0010	No
Water Testing Laboratory of MD	PHS	04/28/2025	1	27	DFC	Hallway	outside 105	fountain	FD	04/14/2025	<0.0010	No
Water Testing	PHS	04/28/2025	1	28a	BF	Hallway	outside 142	Bottle Filler	FD	04/14/2025	<0.0010	No

Laboratory of MD												
Water Testing Laboratory of MD	PHS	04/28/2025	1	28b	DFC	Hallway	outside 142	Bottle Filler Fountain	FD	04/14/2025	<0.0010	No
Water Testing Laboratory of MD	PHS	04/28/2025	1	30	DFC	Hallway	outside 133	left fountain	FD	04/14/2025	<0.0010	No
Water Testing Laboratory of MD	PHS	04/28/2025	1	31	DFC	Hallway	outside 133	right fountin	FD	04/14/2025	<0.0010	No
Water Testing Laboratory of MD	PHS	04/28/2025	2	32a	BF	Hallway	outside 216	Bottle Filler	FD	04/14/2025	<0.0010	No
Water Testing Laboratory of MD	PHS	04/28/2025	2	32b	DFC	Hallway	outside 216	Bottle Filler Fountain	FD	04/14/2025	<0.0010	No
Water Testing Laboratory of MD	PHS	04/28/2025	2	34	FC	Classroom	207	faucet	FD	04/14/2025	<0.0010	No
Water Testing Laboratory of MD	PHS	04/28/2025	2	35	FC	Concession stand	by auditorium	faucet	FD	04/14/2025	0.0033	No
Water Testing	PHS	04/28/2025	2	36	SPR	Kitchen	dish washer	sprayer	FD	04/14/2025	<0.0010	No
Water Testing Laboratory of MD	PHS	04/28/2025	2	37	SPR	Kitchen	by handwash sink	sprayer	FD	04/14/2025	0.0011	No
Water Testing	PHS	04/28/2025	2	38	MC	Kitchen	3 compartment sink	left faucet	FD	04/14/2025	<0.0010	No

Laboratory of MD												
Water Testing Laboratory of MD	PHS	04/28/2025	2	39	MC	Kitchen	3 compartment sink	right faucet	FD	04/14/2025	<0.0010	No
Water Testing Laboratory of MD	PHS	04/28/2025	2	40	FC	Kitchen	food prep table	faucet	FD	04/14/2025	<0.0010	No
Water Testing Laboratory of MD	PHS	04/28/2025	2	41	SPR	Kitchen	By walkin freezer/fridge	sprayer	FD	04/14/2025	0.0029	No
Water Testing Laboratory of MD	PHS	04/28/2025	2	42	MC	Kitchen	2 compartment sink	faucet	FD	04/14/2025	<0.0010	No
Water Testing Laboratory of MD	PHS	04/28/2025	2	43	SPR	Kitchen	by ice machine	sprayer	FD	04/14/2025	0.0688	Yes
Water Testing Laboratory of MD	PHS	04/28/2025	2	44	IM	Kitchen		ice machine	FD	04/14/2025	0.0018	No
Water Testing	PHS	04/28/2025	2	45	FC	Kitchen	walk in food prep table	facuet	FD	04/14/2025	<0.0010	No
Water Testing Laboratory of MD	PHS	04/28/2025	2	46	KC	Kitchen	between the dual kettles	kettle filler	FD	04/14/2025	<0.0010	No
Water Testing Laboratory of MD	PHS	04/28/2025	2	47	FC	Work Room	274	faucet	FD	04/14/2025	<0.0010	No
Water Testing	PHS	04/28/2025	2	49	FC	Classroom	285	faucet	FD	04/14/2025	0.004	No

Laboratory of MD												
Water Testing Laboratory of MD	PHS	04/28/2025	2	50	FC	Classroom	299	faucet	FD	04/14/2025	<0.0010	No
Water Testing Laboratory of MD	PHS	04/28/2025	2	52	FC	Lounge	216	faucet	FD	04/14/2025	<0.0010	No
Water Testing Laboratory of MD	PHS	04/28/2025	2	54	IM	Lounge	216	ice machine	FD	04/14/2025	0.0014	No
Water Testing Laboratory of MD	PHS	04/28/2025	2	55	FC	Lounge	228	faucet	FD	04/14/2025	<0.0010	No
Water Testing Laboratory of MD	PHS	04/28/2025	2	56	FC	Nurse's office	229	faucet	FD	04/14/2025	<0.0010	No
Water Testing Laboratory of MD	PHS	04/28/2025	2	57	IM	Nurse's office	229	ice machine	FD	04/14/2025	0.0016	No
Water Testing	PHS	04/28/2025	3	58	FC	Classrom	343	faucet	FD	04/14/2025	<0.0010	No
Water Testing Laboratory of MD	PHS	04/28/2025	1	59	FC	Classrom	104	faucet	FD	04/14/2025	<0.0010	No
Water Testing Laboratory of MD	PHS	04/28/2025	1	61	FC	Home Economics	112	front left faucet	FD	04/14/2025	<0.0010	No
Water Testing	PHS	04/28/2025	1	62	FC	Home Economics	112	back left faucet	FD	04/14/2025	<0.0010	No

Laboratory of MD												
Water Testing Laboratory of MD	PHS	04/28/2025	1	63	FC	Home Economics	112	middle left faucet	FD	04/14/2025	<0.0010	No
Water Testing Laboratory of MD	PHS	04/28/2025	1	64	FC	Home Economics	112	middle right faucet	FD	04/14/2025	<0.0010	No
Water Testing Laboratory of MD	PHS	04/28/2025	1	65	FC	Home Economics	112	back right faucet	FD	04/14/2025	<0.0010	No
Water Testing Laboratory of MD	PHS	04/28/2025	1	66	FC	Home Economics	112	front right faucet	FD	04/14/2025	<0.0010	No
Water Testing Laboratory of MD	PHS	04/28/2025	1	67	FC	Home Economics	112	teacher's faucet	FD	04/14/2025	0.0010	No
Water Testing Laboratory of MD	PHS	04/28/2025	1	72	FC	Trailer	IT Trailer (formerly adult ed)	faucet	FD	04/14/2025	0.0013	No
Water Testing	PHS	04/28/2025	2	75	FC	training room	between locker rooms	back left faucet	FD	04/14/2025	<0.0010	No
Water Testing Laboratory of MD	PHS	04/28/2025	2	76	FC	training room	between locker rooms	back right faucet (mop sink style)	FD	04/14/2025	0.0017	No
Water Testing Laboratory of MD	PHS	04/28/2025	2	77	FC	training room	between locker rooms	front right faucet	FD	04/14/2025	<0.0010	No
Water Testing	PHS	04/28/2025	2	78	IM	training room	between locker rooms	ice machine	FD	04/14/2025	<0.0010	No

[illegible]