

Districtwide Lead in Drinking Water Sampling and Remediation Plan for 2023-2025 Compliance.

Hendrick Hudson CSD

May 2025

Enviroscience Project #26156



2150 Smithtown Ave., Suite 3, Ronkonkoma, NY 11779

T: 631.580.3191 • **F:** 631.580.3195 • **W:** envirohealth.org

DISTRICTWIDE LEAD IN DRINKING WATER SAMPLING AND REMEDIATION PLAN

2023-2025

MAY 2025

ENVIROSCIENCE PROJECT #26156

Prepared for: HENDRICK HUDSON CSD
61 Trolley Road
Montrose, NY 10548

Prepared by: ENVIROSCIENCE CONSULTANTS, LLC
2150 Smithtown Avenue
Ronkonkoma, New York 11779
(631) 580-3191

Project Manager: *Pam Chadderton*

TABLE OF CONTENTS

<u>Section</u>	<u>Title</u>
1.0	Executive Summary
2.0	Sampling Methodology
3.0	Initial Results

Appendices

Appendix A	Hendrick Hudson High School
Appendix B	Blue Mountain Middle School
Appendix C	Buchanan-Verplanck Elementary School
Appendix D	Frank G. Lindsey Elementary School
Appendix E	Furnace Woods Elementary School
Appendix F	Administration Building

1.0 EXECUTIVE SUMMARY

The Hendrick Hudson CSD has developed their Lead in Drinking Water Sampling and Remediation Plan for the 2023-2025 compliance period, as required by the New York State Department of Health (Public Health Law Sections 1370-a and 1110, Subpart 67-4 Lead Testing in School Drinking Water).

In accordance with the regulation, this Lead Remediation Plan is prepared to identify locations deemed as Applicable Drinking Water Sources and report first draw sample results, to mitigate locations where sample results exceed 5 parts per billion, to identify locations deemed as Non-Applicable Water Sources, communicate this designation to building occupants, and to develop strategies for monitoring locations deemed Non-Applicable Water Sources to insure building occupants do not consume water from these locations.

The following locations within the Hendrick Hudson CSD buildings have been deemed Applicable Drinking Water Sources by the administration:

- 1) Water fountains and bottle filling stations;
- 2) Kitchen water faucets and pot fillers used in food preparation;
- 3) Ice machines
- 4) Home Economics classroom sinks
- 5) Nurse's Office and Faculty Room sinks

First draw samples were collected from each of these locations within the district and analyzed by a New York State Department of Health ELAP certified laboratory. The chains of custody are available upon request. For results at or below 5 ppb, no further action is required until 2028. For locations above 5 ppb, options include: second and third draw sample collection to determine source of lead, designation of the location as Non-applicable Water Source, or permanent removal of the fixture from the location. In either case, the result was communicated by Enviroscience Consultants, and the fixture was shut off by the district immediately upon receipt of results.

The following locations within the Hendrick Hudson CSD buildings were deemed Non-Applicable Water Sources by the administration:

- 1) Science Laboratory sinks
- 2) Art Room sinks
- 3) Technical Classroom sinks
- 4) Other Classroom sinks
- 5) Bathroom sinks
- 6) Outside spigots
- 7) Custodial Closet sinks
- 8) Mixed Valve sinks (or hot only)

In these cases, the Hendrick Hudson CSD staff have placed signs adjacent to the fixture to notify occupants that the water is not intended for consumption. To further support this protocol, the following management of the locations is required:

- 1) Science Laboratory sinks - communicate in writing with students that these locations are for science experiments and hand washing only, not for consumption. This is most easily accomplished by including this language in the laboratory safety paperwork distributed to students at the beginning of the school year. This program should be monitored by the respective science teachers, and any deficiencies reported for assessment and revision, if necessary, by the Facilities Department.
- 2) Art Room sinks - communicate in writing to students that these locations are for cleaning of art supplies and hand washing only, not for consumption. This is most easily accomplished by including this language in the course paperwork distributed to students at the beginning of the school year. This program should be monitored by the respective art teachers, and any deficiencies reported for assessment and revision, if necessary, by the Facilities Department.
- 3) Technical Classroom sinks - classrooms in this category often include wood shop or auto mechanics classrooms, where students are to hand wash after bathroom usage or activities as part of a regular hygiene program. This program should be monitored by teachers and staff to ensure consumption is not taking place, and any deficiencies reported for assessment and revision, if necessary, by the Facilities Department.
- 4) Other classroom sinks - classrooms in this category often include elementary classrooms, where students are to hand wash after bathroom usage or activities as part

of a regular hygiene program. This program should be monitored by teachers and staff to ensure consumption is not taking place, and any deficiencies reported for assessment and revision, if necessary, by the Facilities Department.


- 5) Bathroom sinks - in intermediate buildings, signage should be sufficient for communicating the concept of hand washing only. In elementary schools, personal hygiene should be integrated into curriculum to ensure students understand bathroom sinks are for hand washing only, and not consumption. Further, show what the signage looks like in bathrooms, so they learn to recognize its meaning. This program should be monitored by teachers and staff to ensure consumption is not taking place, and any deficiencies reported for assessment and revision, if necessary, by the Facilities Department.
- 6) Outside spigots - all-weather signage will be installed at each location. Further, spigots will have a special key maintained by the custodial staff to ensure that non-authorized persons do not fill sports coolers or use hoses for consumption. This program should be monitored by custodial staff to ensure consumption is not taking place, and any deficiencies reported for assessment and revision, if necessary, by the Facilities Department.
- 7) Custodial Closet sinks - these locations should be accessed by custodial personnel only and locked when not in use. Access to others should be restricted. This program should be monitored by custodial staff to ensure consumption is not taking place, and any deficiencies reported for assessment and revision, if necessary, by the Facilities Department.
- 8) Mixed Valve sinks (or hot only) – per Public Health Law Sections 1370-a and 1110, Subpart 67-4 Lead Testing in School Drinking Water mixed valve or hot water only sources are not required to be sampled. Signage is required for these sources. Signage should be sufficient for communicating the concept of hand washing only. In elementary schools, personal hygiene should be integrated into curriculum to ensure students understand bathroom sinks are for hand washing only, and not consumption. Further, show what the signage looks like so they learn to recognize its meaning. This program should be monitored by teachers and staff to ensure consumption is not taking place, and any deficiencies reported for assessment and revision, if necessary, by the Facilities Department.




All locations deemed non-applicable, but do not have signs, should be taken offline until signs have been posted. Signs are suggested to have pictures that instruct for handwashing only, do not drink.

2.0 SAMPLING METHODOLOGY

In accordance with the regulation, Enviroscience Consultants, LLC performed initial water sampling at the Hendrick Hudson CSD buildings from May 6-8, 2025. Samples were collected in wide-mouth 250 milliliter containers and were collected in the morning hours before the facilities opened. The water sources were not used for at least 8 hours and not more than 18 hours prior to sampling. Unique source numbers and designations were assigned to each source location. Unique sample identification numbers were assigned to each sample taken. The key to fixture type codes, source designations, and the sampling location schematics are shown below.

Code Key for Lead in Water			
Fixture Type Codes			
BF	Bottle Filler	SK	Sink
HB	Hose Bib	SL	Supply Line
IM	Ice Machine	SP	Spigot
OS	Other Source	SPY	Spray
PF	Pot Filler	SS	Slop Sink
		V	Valve
		WC	Water Cooler
		WF	Water Fountain
Source Designations			
App	Applicable	N/A	Non-applicable



<div>SCIENCE ROOM TYPE 1 DIAGRAM</div> 	<div>SCIENCE ROOM TYPE 2 DIAGRAM</div> 	<div>SCIENCE ROOM TYPE 3 DIAGRAM</div> 																																																																																								
<div>SAMPLE IDENTIFICATION (example)</div> <table><tr><th>LOCATION</th><th>SOURCE</th></tr><tr><td>Room 200 - Teacher Station</td><td>SK</td></tr><tr><td>Room 200 - Counter 1 @ (A)</td><td>SK</td></tr><tr><td>Room 200 - Counter 1 @ (B)</td><td>SK</td></tr><tr><td>Room 200 - Counter 2 @ (A)</td><td>SK</td></tr><tr><td>Room 200 - Counter 2 @ (B)</td><td>SK</td></tr><tr><td>Room 200 - Counter 3 @ (A)</td><td>SK</td></tr><tr><td>Room 200 - Counter 3 @ (B)</td><td>SK</td></tr></table>	LOCATION	SOURCE	Room 200 - Teacher Station	SK	Room 200 - Counter 1 @ (A)	SK	Room 200 - Counter 1 @ (B)	SK	Room 200 - Counter 2 @ (A)	SK	Room 200 - Counter 2 @ (B)	SK	Room 200 - Counter 3 @ (A)	SK	Room 200 - Counter 3 @ (B)	SK	<div>SAMPLE IDENTIFICATION (example)</div> <table><tr><th>LOCATION</th><th>SOURCE</th></tr><tr><td>Room 200 - Teacher Station</td><td>SK</td></tr><tr><td>Room 200 - Table 1 @ (A)</td><td>SK</td></tr><tr><td>Room 200 - Table 1 @ (B)</td><td>SK</td></tr><tr><td>Room 200 - Table 2 @ (A)</td><td>SK</td></tr><tr><td>Room 200 - Table 2 @ (B)</td><td>SK</td></tr><tr><td>Room 200 - Table 3 @ (A)</td><td>SK</td></tr><tr><td>Room 200 - Table 3 @ (B)</td><td>SK</td></tr><tr><td>Room 200 - Table 4 @ (A)</td><td>SK</td></tr><tr><td>Room 200 - Table 4 @ (B)</td><td>SK</td></tr><tr><td>Room 200 - Counter 1 @ (A)</td><td>SK</td></tr><tr><td>Room 200 - Counter 1 @ (B)</td><td>SK</td></tr><tr><td>Room 200 - Counter 2 @ (A)</td><td>SK</td></tr><tr><td>Room 200 - Counter 2 @ (B)</td><td>SK</td></tr><tr><td>Room 200 - Counter 3 @ (A)</td><td>SK</td></tr><tr><td>Room 200 - Counter 3 @ (C)</td><td>SK</td></tr></table>	LOCATION	SOURCE	Room 200 - Teacher Station	SK	Room 200 - Table 1 @ (A)	SK	Room 200 - Table 1 @ (B)	SK	Room 200 - Table 2 @ (A)	SK	Room 200 - Table 2 @ (B)	SK	Room 200 - Table 3 @ (A)	SK	Room 200 - Table 3 @ (B)	SK	Room 200 - Table 4 @ (A)	SK	Room 200 - Table 4 @ (B)	SK	Room 200 - Counter 1 @ (A)	SK	Room 200 - Counter 1 @ (B)	SK	Room 200 - Counter 2 @ (A)	SK	Room 200 - Counter 2 @ (B)	SK	Room 200 - Counter 3 @ (A)	SK	Room 200 - Counter 3 @ (C)	SK	<div>SAMPLE IDENTIFICATION (example)</div> <table><tr><th>LOCATION</th><th>SOURCE</th></tr><tr><td>Room 200 - Teacher Station</td><td>SK</td></tr><tr><td>Room 200 - POD 1 @ (A)</td><td>SK</td></tr><tr><td>Room 200 - POD 1 @ (B)</td><td>SK</td></tr><tr><td>Room 200 - POD 1 @ (C)</td><td>SK</td></tr><tr><td>Room 200 - POD 1 @ (D)</td><td>SK</td></tr><tr><td>Room 200 - POD 1 @ (E)</td><td>SK</td></tr><tr><td>Room 200 - POD 1 @ (F)</td><td>SK</td></tr><tr><td>Room 200 - POD 2 @ (A)</td><td>SK</td></tr><tr><td>Room 200 - POD 2 @ (B)</td><td>SK</td></tr><tr><td>Room 200 - POD 2 @ (C)</td><td>SK</td></tr><tr><td>Room 200 - POD 2 @ (D)</td><td>SK</td></tr><tr><td>Room 200 - POD 2 @ (E)</td><td>SK</td></tr><tr><td>Room 200 - POD 2 @ (F)</td><td>SK</td></tr><tr><td>Room 200 - POD 3 @ (A)</td><td>SK</td></tr><tr><td>Room 200 - POD 3 @ (B)</td><td>SK</td></tr><tr><td>Room 200 - POD 3 @ (C)</td><td>SK</td></tr><tr><td>Room 200 - POD 3 @ (D)</td><td>SK</td></tr><tr><td>Room 200 - POD 3 @ (E)</td><td>SK</td></tr><tr><td>Room 200 - POD 3 @ (F)</td><td>SK</td></tr></table>	LOCATION	SOURCE	Room 200 - Teacher Station	SK	Room 200 - POD 1 @ (A)	SK	Room 200 - POD 1 @ (B)	SK	Room 200 - POD 1 @ (C)	SK	Room 200 - POD 1 @ (D)	SK	Room 200 - POD 1 @ (E)	SK	Room 200 - POD 1 @ (F)	SK	Room 200 - POD 2 @ (A)	SK	Room 200 - POD 2 @ (B)	SK	Room 200 - POD 2 @ (C)	SK	Room 200 - POD 2 @ (D)	SK	Room 200 - POD 2 @ (E)	SK	Room 200 - POD 2 @ (F)	SK	Room 200 - POD 3 @ (A)	SK	Room 200 - POD 3 @ (B)	SK	Room 200 - POD 3 @ (C)	SK	Room 200 - POD 3 @ (D)	SK	Room 200 - POD 3 @ (E)	SK	Room 200 - POD 3 @ (F)	SK
LOCATION	SOURCE																																																																																									
Room 200 - Teacher Station	SK																																																																																									
Room 200 - Counter 1 @ (A)	SK																																																																																									
Room 200 - Counter 1 @ (B)	SK																																																																																									
Room 200 - Counter 2 @ (A)	SK																																																																																									
Room 200 - Counter 2 @ (B)	SK																																																																																									
Room 200 - Counter 3 @ (A)	SK																																																																																									
Room 200 - Counter 3 @ (B)	SK																																																																																									
LOCATION	SOURCE																																																																																									
Room 200 - Teacher Station	SK																																																																																									
Room 200 - Table 1 @ (A)	SK																																																																																									
Room 200 - Table 1 @ (B)	SK																																																																																									
Room 200 - Table 2 @ (A)	SK																																																																																									
Room 200 - Table 2 @ (B)	SK																																																																																									
Room 200 - Table 3 @ (A)	SK																																																																																									
Room 200 - Table 3 @ (B)	SK																																																																																									
Room 200 - Table 4 @ (A)	SK																																																																																									
Room 200 - Table 4 @ (B)	SK																																																																																									
Room 200 - Counter 1 @ (A)	SK																																																																																									
Room 200 - Counter 1 @ (B)	SK																																																																																									
Room 200 - Counter 2 @ (A)	SK																																																																																									
Room 200 - Counter 2 @ (B)	SK																																																																																									
Room 200 - Counter 3 @ (A)	SK																																																																																									
Room 200 - Counter 3 @ (C)	SK																																																																																									
LOCATION	SOURCE																																																																																									
Room 200 - Teacher Station	SK																																																																																									
Room 200 - POD 1 @ (A)	SK																																																																																									
Room 200 - POD 1 @ (B)	SK																																																																																									
Room 200 - POD 1 @ (C)	SK																																																																																									
Room 200 - POD 1 @ (D)	SK																																																																																									
Room 200 - POD 1 @ (E)	SK																																																																																									
Room 200 - POD 1 @ (F)	SK																																																																																									
Room 200 - POD 2 @ (A)	SK																																																																																									
Room 200 - POD 2 @ (B)	SK																																																																																									
Room 200 - POD 2 @ (C)	SK																																																																																									
Room 200 - POD 2 @ (D)	SK																																																																																									
Room 200 - POD 2 @ (E)	SK																																																																																									
Room 200 - POD 2 @ (F)	SK																																																																																									
Room 200 - POD 3 @ (A)	SK																																																																																									
Room 200 - POD 3 @ (B)	SK																																																																																									
Room 200 - POD 3 @ (C)	SK																																																																																									
Room 200 - POD 3 @ (D)	SK																																																																																									
Room 200 - POD 3 @ (E)	SK																																																																																									
Room 200 - POD 3 @ (F)	SK																																																																																									
<div>ENVIROSCIENCE CONSULTANTS INC. 2150 SMITHTOWN AVENUE ROCKYHONKOMA, NY 11779 (631) 580-3191 FAX 580-3195 www.envirohealth.org</div>	<div>WATER SAMPLING METHODOLOGY</div> <div>KEY PLAN NO SCALE</div>	<div>NOT TO SCALE</div> <div>Date: 9/26/2016 By: Robert Cardona</div> <div>DRAWING 2 of 2</div>																																																																																								

3.0 Initial Results

All water source locations in each of the school buildings were assessed. Water source locations identified as drinking water sources were considered Applicable, and first draw samples were collected. Water source locations identified as non-drinking water sources were considered non-applicable and these locations were documented.

The results of the initial sampling and the use of signs warning against water use at non-applicable sources is documented in the School Water Outlet Inventory for each building.

All elevated locations should be taken off line until the remediation is completed. Any other drinking water sources in these buildings that were not functional at the time of initial sampling and have not been tested should be tested before returning to service. All locations deemed non-applicable, but do not have signs, should be taken offline until signs have been posted. Signs are suggested to have pictures that instruct for handwashing only, do not drink.

The following is a summary of results in parts per billion (ppb) of locations in the Hendrick Hudson CSD where sample results were found above 5 ppb:

Hendrick Hudson High School			
SAMPLE LOCATION	RESULT	SAMPLE DATE	REMARKS
Kitchen 127 Kettle Pot Filler spigot	676.0	5/6/2025	Removed from service permanently
Room 121 Home Economics sink	10.0	5/6/2025	Removed from service; pending remediation
Outside by Track water fountain	6.0	5/6/2025	Removed from service; pending remediation
Teacher's Dining Room 125B sink-spray nozzle	7.0	5/6/2025	Removed from service; pending remediation

Blue Mountain Middle School			
SAMPLE LOCATION	RESULT	SAMPLE DATE	REMARKS
Hall by Room 211- ceramic water fountain	32.0	5/7/2025	Removed from service permanently
Life Skills Classroom-sink	8.0	5/7/2025	Removed from service; pending remediation

Buchanan-Verplanck Elementary School			
SAMPLE LOCATION	RESULT	SAMPLE DATE	REMARKS
Kitchen Potfiller by Stove-spigot	7.0	5/8/2025	Removed from service; pending remediation
New Nurse's Office Bathroom sink-left	7.0	5/8/2025	Removed from service; pending remediation
Room 18 water fountain	12.0	5/8/2025	Fixture turned off permanently
Room 19 water fountain	13.0	5/8/2025	Fixture turned off permanently
Room 10 water fountain	8.0	5/8/2025	Fixture turned off permanently
Room 3 Pre-K/Daycare water fountain	8.0	5/8/2025	fixture turned off permanently

Frank G. Lindsey Elementary School			
SAMPLE LOCATION	RESULT	SAMPLE DATE	REMARKS
Room 14 water fountain	12	5/7/2025	Fixture turned off permanently
Nurse's Office Exam Room sink	10.0	5/7/2025	Removed from service; pending remediation

Furnace Woods Elementary School			
SAMPLE LOCATION	RESULT	SAMPLE DATE	REMARKS
Boy's Locker Room Rear Bathroom Sink	18.0	5/8/2025	Removed from service; pending remediation
Staff Room sink	8.0	5/8/2025	Removed from service; pending remediation
Room 3 Bathroom sink	170.0	5/8/2025	Removed from service; pending remediation
Room 2 Bathroom sink	47.0	5/8/2025	Removed from service; pending remediation
Room 1 Bathroom sink	130.0	5/8/2025	Removed from service; pending remediation

Administration Building			
SAMPLE LOCATION	RESULT	SAMPLE DATE	REMARKS
No exceedances			

Appendix A

Hendrick Hudson High School

Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
0001-1	Biomed Lab Room 009 @A	SK	N/A		5/6/2025	-	-	-	Sign
0001-2	Biomed Lab Room 009 @B	SK	N/A		5/6/2025	-	-	-	Sign
0001-3	Biomed Lab Room 009 @C	SK	N/A		5/6/2025	-	-	-	Sign
0002-1	Custodial Closet J03 by Room 010	SS	N/A		5/6/2025	-	-	-	Sign
0003-1	Art Room 008 Counter 1	SK	N/A		5/6/2025	-	-	-	Sign
0003-2	Art Room 008 Counter 2	SK	N/A		5/6/2025	-	-	-	Sign
0004-1	Custodial Closet J02 by Art Room 006	SS	N/A		5/6/2025	-	-	-	Sign
0005-1	Hall by Art Room 006	WF	App	<1.0	5/6/2025	-	-	-	-
0006-1	Boys Bathroom by Art Room 006	SK	N/A		5/6/2025	-	-	-	Sign
0007-1	Art Room 006 Counter 1	SK	N/A		5/6/2025	-	-	-	Sign
0007-2	Art Room 006 Counter 2	SK	N/A		5/6/2025	-	-	-	Sign
0008-1	Art Room 004 Counter 1	SK	N/A		5/6/2025	-	-	-	Sign
0008-2	Art Room 004 Counter 2	SK	N/A		5/6/2025	-	-	-	Sign
0009-1	Girls Bathroom by Art Room 005 @A	SK	N/A		5/6/2025	-	-	-	Sign
0009-2	Girls Bathroom by Art Room 005 @B	SK	N/A		5/6/2025	-	-	-	Sign
0010-1	Hall by Art Room 005	WF	App	<1.0	5/6/2025	-	-	-	-
0011-1	Art Room 005 @A	SK	N/A		5/6/2025	-	-	-	Sign
0011-2	Art Room 005 @B	SK	N/A		5/6/2025	-	-	-	Sign
0012-1	Room 003 (Mrs. Sarles)	SK	N/A		5/6/2025	-	-	-	Sign

Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
0012-2	Room 003 (Mrs. Sarles)	SPY	N/A		5/6/2025	-	-	-	Sign
1001-1	Staff Room 113A	SK	App	<1.0	5/6/2025	-	-	-	-
1002-1	Hall by Room 113	WF	App	<1.0	5/6/2025	-	-	-	-
1002-2	Hall by Room 113 (Bottle Filler)	BF	App	<1.0	5/6/2025	-	-	-	-
1003-1	Nurses Office 110	SK	App	<1.0	5/6/2025	-	-	-	-
1003-2	Nurses Office 110 Eyewash	OS	N/A		5/6/2025	-	-	-	Sign
1003-3	Nurses Office 110 Bathroom	SK	N/A		5/6/2025	-	-	-	Mixed Valve; Sign
1004-1	Hall by Nurses Office 110	WF	App	<1.0	5/6/2025	-	-	-	-
1005-1	Custodial Closet J11 by Nurses Office 110	SS	N/A		5/6/2025	-	-	-	Sign
1006-1	Mens Bathroom by Nurses Office 110 @A	SK	N/A		5/6/2025	-	-	-	Sign
1006-2	Mens Bathroom by Nurses Office 110 @B	SK	N/A		5/6/2025	-	-	-	Mixed Valve; Sign
1007-1	Principal Office Bathroom	SK	N/A		5/6/2025	-	-	-	Sign
1008-2	Womens Bathroom by Asst. Principal Office @B	SK	N/A		5/6/2025	-	-	-	Sign
1009-1	Library Office Room 100	SK	N/A		5/6/2025	-	-	-	Sign
1010-1	Old Tech Room 162	SK	N/A		5/6/2025	-	-	-	Sign
1011-1	Teachers Dining Room 125B	SK	App	<1.0	5/6/2025	-	-	-	-
1011-2	Teachers Dining Room 125B	SPY	NA	7.0	5/6/2025	-	-	-	Sign Posted
1011-3	Teachers Dining Room 125B Coffee Pot Line	OS	App	<1.0	5/6/2025	-	-	-	-
1011-4	Teachers Dining Room 125B Bathroom	SK	N/A		5/6/2025	-	-	-	Sign

Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
1012-1	Mens Bathroom by Room 125B @A	SK	N/A		5/6/2025	-	-	-	Mixed Valve; Sign
1012-2	Mens Bathroom by Room 125B @B	SK	N/A		5/6/2025	-	-	-	Mixed Valve; Sign
1013-1	Hall by Room 125B	WF	App	<1.0	5/6/2025	-	-	-	-
1014-1	Womens Bathroom by Room 125B (Right)	SK	N/A		5/6/2025	-	-	-	Sign
1014-2	Womens Bathroom by Room 125B (Left)	SK	N/A		5/6/2025	-	-	-	Sign
1015-1	Hall by Café Area 125	WF	App	<1.0	5/6/2025	-	-	-	-
1015-2	Hall by Café Area 125 (Bottle Filler)	BF	App	<1.0	5/6/2025	-	-	-	-
1016-1	Kitchen Serving Area 126	IM	App	<1.0	5/6/2025	-	-	-	-
1016-2	Kitchen Serving Area 126 Handwash	SK	N/A		5/6/2025	-	-	-	Sign
1017-1	Kitchen 127 3 Bay (Left)	SK	N/A		5/6/2025	-	-	-	Sign
1017-2	Kitchen 127 3 Bay (Left)	SPY	N/A		5/6/2025	-	-	-	Sign
1017-3	Kitchen 127 3 Bay (Right)	SK	N/A		5/6/2025	-	-	-	Sign
1017-4	Kitchen 127 1 Bay (Left of Pot Filler)	SK	App	2.0	5/6/2025	-	-	-	-
1017-5	Kitchen 127 1 Bay (Right of Pot Filler)	SK	App	<1.0	5/6/2025	-	-	-	-
1017-6	Kitchen 127 Pot Filler	SP	App	676.0	5/6/2025				Removed From Service; Pending Remediation or Removal
1017-7	Kitchen 127 Bathroom	SK	N/A		5/6/2025	-	-	-	Sign
1018-1	Custodial Closet J15 by Room 133	SS	N/A		5/6/2025	-	-	-	Sign
1019-1	Womens Bathroom by Room 133 Unit @A	SK	N/A		5/6/2025	-	-	-	Mixed Valve; Sign
1019-2	Womens Bathroom by Room 133 Unit @B	SK	N/A		5/6/2025	-	-	-	Mixed Valve; Sign

Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
1019-3	Womens Bathroom by Room 133 Unit @C	SK	N/A		5/6/2025	-	-	-	Mixed Valve; Sign
1020-1	Hall by Room 133 (Right)	WF	App		5/6/2025				Removed from Service
1020-2	Hall by Room 133 (Left)	WF	App		5/6/2025				Removed from Service
1021-1	Mens Bathroom by Room 133 Unit 1 @A	SK	N/A		5/6/2025	-	-	-	Mixed Valve; Sign
1021-2	Mens Bathroom by Room 133 Unit 1 @B	SK	N/A		5/6/2025	-	-	-	Mixed Valve; Sign
1021-3	Mens Bathroom by Room 133 Unit 2 @A	SK	N/A		5/6/2025	-	-	-	Mixed Valve; Sign
1021-4	Mens Bathroom by Room 133 Unit 2 @B	SK	N/A		5/6/2025	-	-	-	Mixed Valve; Sign
1022-1	Custodial Closet J13 by Staircase 8 (1R)	SS	N/A		5/6/2025	-	-	-	Sign
1023-1	Mens Bathroom by Staircase 8 (1R) Unit 1 @A	SK	N/A		5/6/2025	-	-	-	Mixed Valve; Sign
1023-3	Mens Bathroom by Staircase 8 (1R) Unit 1 @C	SK	N/A		5/6/2025	-	-	-	Mixed Valve; Sign
1023-4	Mens Bathroom by Staircase 8 (1R) Unit 2 @A	SK	N/A		5/6/2025	-	-	-	Mixed Valve; Sign
1023-5	Mens Bathroom by Staircase 8 (1R) Unit 2 @B	SK	N/A		5/6/2025	-	-	-	Mixed Valve; Sign
1024-1	Womens Bathroom by Staircase 8 (1R) Unit 1 @A	SK	N/A		5/6/2025	-	-	-	Mixed Valve; Sign
1024-2	Womens Bathroom by Staircase 8 (1R) Unit 1 @B	SK	N/A		5/6/2025	-	-	-	Mixed Valve; Sign
1024-3	Womens Bathroom by Staircase 8 (1R) Unit 1 @C	SK	N/A		5/6/2025	-	-	-	Mixed Valve; Sign
1024-4	Womens Bathroom by Staircase 8 (1R) Unit 2 @A	SK	N/A		5/6/2025	-	-	-	Mixed Valve; Sign
1024-5	Womens Bathroom by Staircase 8 (1R) Unit 2 @B	SK	N/A		5/6/2025	-	-	-	Mixed Valve; Sign
1025-1	Room 121 Home Economics	SK	App	10.0	5/6/2025				Removed From Service; Pending Remediation
1026-1	Womens Bathroom by Athletic Director 117 @A	SK	N/A		5/6/2025	-	-	-	Mixed Valve; Sign

Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
1026-2	Womens Bathroom by Athletic Director 117 @B	SK	N/A		5/6/2025	-	-	-	Sign
1026-3	Womens Bathroom by Athletic Director 117 @C	SK	N/A		5/6/2025	-	-	-	Sign
1027-1	Custodial Closet J12 by Athletic Director 117	SS	N/A		5/6/2025	-	-	-	Sign
1028-1	Storage Closet by Athletic Director 117	IM	App	1.0	5/6/2025	-	-	-	-
1029-1	Mens Bathroom by Athletic Office 115A @A	SK	N/A		5/6/2025	-	-	-	Mixed Valve; Sign
1029-2	Mens Bathroom by Athletic Office 115A @B	SK	N/A		5/6/2025	-	-	-	Mixed Valve; Sign
1030-1	Storage Bathroom by Athletic Office 115A	SK	N/A		5/6/2025	-	-	-	Sign
1031-1	Security Office Room 115B Bathroom	SK	N/A		5/6/2025	-	-	-	Sign
1032-1	Coaches Office Bathroom by Gym 115	SK	N/A		5/6/2025	-	-	-	Sign
1033-1	Hall by Gym 115	WF	App	<1.0	5/6/2025	-	-	-	-
1033-2	Hall by Gym 115 (Bottle Filler)	BF	App	<1.0	5/6/2025	-	-	-	-
1034-1	Mens Bathroom by Athletic Dome @A	SK	N/A		5/6/2025	-	-	-	Mixed Valve; Sign
1034-2	Mens Bathroom by Athletic Dome @B	SK	N/A		5/6/2025	-	-	-	Mixed Valve; Sign
1035-1	Womens Bathroom by Athletic Dome @A	SK	N/A		5/6/2025	-	-	-	Mixed Valve; Sign
1035-2	Womens Bathroom by Athletic Dome @B	SK	N/A		5/6/2025	-	-	-	Mixed Valve; Sign
1036-1	Concession Stand 116B	SK	App	<1.0	5/6/2025	-	-	-	-
1037-1	Hall by Athletic Dome 116	WF	App		5/6/2025				Removed from Service
1038-1	Athletic Trainers Office 117B	SK	App	<1.0	5/6/2025	-	-	-	-
2001-1	Mens Bathroom by Room 224 @A	SK	N/A		5/6/2025	-	-	-	Mixed Valve; Sign

Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
2001-2	Mens Bathroom by Room 224 @B	SK	N/A		5/6/2025	-	-	-	Mixed Valve; Sign
2002-1	Custodial Closet J24 by Room 224	SS	N/A		5/6/2025	-	-	-	Sign
2003-1	Womens Bathroom by Room 224 @A	SK	N/A		5/6/2025	-	-	-	Sign
2003-2	Womens Bathroom by Room 224 @B	SK	N/A		5/6/2025	-	-	-	Sign
2003-3	Womens Bathroom by Room 224 @C	SK	N/A		5/6/2025	-	-	-	Sign
2004-1	Hall by Room 224	WF	App	<1.0	5/6/2025	-	-	-	-
2004-2	Hall by Room 224 (Bottle Filler)	BF	App	<1.0	5/6/2025	-	-	-	-
2005-1	Custodial Closet J25 by Room 233	SS	N/A		5/6/2025	-	-	-	Sign
2006-1	Womens Bathroom by Room 233 Unit @A	SK	N/A		5/6/2025	-	-	-	Sign
2006-2	Womens Bathroom by Room 233 Unit @B	SK	N/A		5/6/2025	-	-	-	Sign
2006-3	Womens Bathroom by Room 233 Unit @C	SK	N/A		5/6/2025	-	-	-	Sign
2007-1	Hall by Room 233 (Right)	WF	App		5/6/2025				Removed from Service
2007-2	Hall by Room 233 (Left)	WF	N/A		5/6/2025	-	-	-	Removed from Service
2008-1	Mens Bathroom by Room 233 Unit 1 @A	SK	N/A		5/6/2025	-	-	-	Mixed Valve; Sign
2008-2	Mens Bathroom by Room 233 Unit 1 @B	SK	N/A		5/6/2025	-	-	-	Mixed Valve; Sign
2008-3	Mens Bathroom by Room 233 Unit 2 @A	SK	N/A		5/6/2025	-	-	-	Mixed Valve; Sign
2008-4	Mens Bathroom by Room 233 Unit 2 @B	SK	N/A		5/6/2025	-	-	-	Mixed Valve; Sign
2009-1	Science Room 225 Teacher Station	SK	N/A		5/6/2025	-	-	-	Sign
2009-2	Science Room 225 Counter @A	SK	N/A		5/6/2025	-	-	-	Sign

Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
2009-3	Science Room 225 Table 1 @A	SK	N/A		5/6/2025	-	-	-	Sign
2009-4	Science Room 225 Table 1 @B	SK	N/A		5/6/2025	-	-	-	Sign
2009-5	Science Room 225 Table 2 @A	SK	N/A		5/6/2025	-	-	-	Sign
2009-6	Science Room 225 Table 2 @B	SK	N/A		5/6/2025	-	-	-	Sign
2009-7	Science Room 225 Counter @B	SK	N/A		5/6/2025	-	-	-	Sign
2009-8	Science Room 225 Table 3 @A	SK	N/A		5/6/2025	-	-	-	Sign
2009-9	Science Room 225 Table 3 @B	SK	N/A		5/6/2025	-	-	-	Sign
2009-10	Science Room 225 Table 4 @A	SK	N/A		5/6/2025	-	-	-	Sign
2009-11	Science Room 225 Table 4 @B	SK	N/A		5/6/2025	-	-	-	Sign
2009-12	Science Room 225 Table 5 @A	SK	N/A		5/6/2025	-	-	-	Sign
2009-13	Science Room 225 Table 5 @B	SK	N/A		5/6/2025	-	-	-	Sign
2009-14	Science Room 225 Table 6 @A	SK	N/A		5/6/2025	-	-	-	Sign
2009-15	Science Room 225 Table 6 @B	SK	N/A		5/6/2025	-	-	-	Sign
2011-1	Science Room 237 Teachers Station	SK	N/A		5/6/2025	-	-	-	Sign
2011-2	Science Room 237 Counter @A	SK	N/A		5/6/2025	-	-	-	Sign
2011-3	Science Room 237 Table 1 @A	SK	N/A		5/6/2025	-	-	-	Sign
2011-4	Science Room 237 Table 1 @B	SK	N/A		5/6/2025	-	-	-	Sign
2011-5	Science Room 237 Table 2 @A	SK	N/A		5/6/2025	-	-	-	Sign
2011-6	Science Room 237 Table 2 @B	SK	N/A		5/6/2025	-	-	-	Sign

Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
2011-7	Science Room 237 Table 3 @A	SK	N/A		5/6/2025	-	-	-	Sign
2011-8	Science Room 237 Table 3 @B	SK	N/A		5/6/2025	-	-	-	Sign
2011-9	Science Room 237 Counter @B	SK	N/A		5/6/2025	-	-	-	Sign
2011-10	Science Room 237 Table 4 @A	SK	N/A		5/6/2025	-	-	-	Sign
2011-11	Science Room 237 Table 4 @B	SK	N/A		5/6/2025	-	-	-	Sign
2011-12	Science Room 237 Table 5 @A	SK	N/A		5/6/2025	-	-	-	Sign
2011-13	Science Room 237 Table 5 @B	SK	N/A		5/6/2025	-	-	-	Sign
2011-14	Science Room 237 Table 6 @A	SK	N/A		5/6/2025	-	-	-	Sign
2011-15	Science Room 237 Table 6 @B	SK	N/A		5/6/2025	-	-	-	Sign
2012-1	Science Room 236 Teachers Station	SK	N/A		5/6/2025	-	-	-	Sign
2012-2	Science Room 236 Counter 1	SK	N/A		5/6/2025	-	-	-	Sign
2012-3	Science Room 236 Table 1 @A	SK	N/A		5/6/2025	-	-	-	Sign
2012-4	Science Room 236 Table 1 @B	SK	N/A		5/6/2025	-	-	-	Sign
2012-5	Science Room 236 Table 2 @A	SK	N/A		5/6/2025	-	-	-	Sign
2012-6	Science Room 236 Table 2 @B	SK	N/A		5/6/2025	-	-	-	Sign
2012-7	Science Room 236 Table 3 @A	SK	N/A		5/6/2025	-	-	-	Sign
2012-8	Science Room 236 Table 3 @B	SK	N/A		5/6/2025	-	-	-	Sign
2012-9	Science Room 236 Table 4 @A	SK	N/A		5/6/2025	-	-	-	Sign
2012-10	Science Room 236 Table 4 @B	SK	N/A		5/6/2025	-	-	-	Sign

Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
2012-11	Science Room 236 Table 5 @A	SK	N/A		5/6/2025	-	-	-	Sign
2012-12	Science Room 236 Table 5 @B	SK	N/A		5/6/2025	-	-	-	Sign
2012-13	Science Room 236 Table 6 @A	SK	N/A		5/6/2025	-	-	-	Sign
2012-14	Science Room 236 Table 6 @B	SK	N/A		5/6/2025	-	-	-	Sign
2012-15	Scienec Room 236 Counter 2	SK	N/A		5/6/2025	-	-	-	Sign
2013-1	Science Room 238 Teachers Station	SK	N/A		5/6/2025	-	-	-	Sign
2013-2	Science Room 238 Counter @A	SK	N/A		5/6/2025	-	-	-	Sign
2013-3	Science Room 238 Table 1 @A	SK	N/A		5/6/2025	-	-	-	Sign
2013-4	Science Room 238 Table 1 @B	SK	N/A		5/6/2025	-	-	-	Sign
2013-5	Science Room 238 Table 2 @A	SK	N/A		5/6/2025	-	-	-	Sign
2013-6	Science Room 238 Table 2 @B	SK	N/A		5/6/2025	-	-	-	Sign
2013-7	Science Room 238 Table 3 @A	SK	N/A		5/6/2025	-	-	-	Sign
2013-8	Science Room 238 Table 3 @B	SK	N/A		5/6/2025	-	-	-	Sign
2013-9	Science Room 238 Counter @B	SK	N/A		5/6/2025	-	-	-	Sign
2013-10	Science Room 238 Table 4 @A	SK	N/A		5/6/2025	-	-	-	Sign
2013-11	Science Room 238 Table 4 @B	SK	N/A		5/6/2025	-	-	-	Sign
2013-12	Science Room 238 Table 5 @A	SK	N/A		5/6/2025	-	-	-	Sign
2013-13	Science Room 238 Table 5 @B	SK	N/A		5/6/2025	-	-	-	Sign
2013-14	Science Room 238 Table 6 @A	SK	N/A		5/6/2025	-	-	-	Sign

Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
2013-15	Science Room 238 Table 6 @B	SK	N/A		5/6/2025	-	-	-	Sign
2014-1	Science Prep Room Between 238 & 239 (Left)	SK	N/A		5/6/2025	-	-	-	Sign
2014-2	Science Prep Room Between 238 & 239 (Right)	SK	N/A		5/6/2025	-	-	-	Sign
2015-1	Science Room 239 Teachers Station	SK	N/A		5/6/2025	-	-	-	Sign
2015-2	Science Room 239 Table 1 @A	SK	N/A		5/6/2025	-	-	-	Sign
2015-3	Science Room 239 Table 1 @B	SK	N/A		5/6/2025	-	-	-	Sign
2015-4	Science Room 239 Table 2 @A	SK	N/A		5/6/2025	-	-	-	Sign
2015-5	Science Room 239 Table 2 @B	SK	N/A		5/6/2025	-	-	-	Sign
2015-6	Science Room 239 Table 3 @A	SK	N/A		5/6/2025	-	-	-	Sign
2015-7	Science Room 239 Table 3 @B	SK	N/A		5/6/2025	-	-	-	Sign
2015-8	Science Room 239 Counter @A	SK	N/A		5/6/2025	-	-	-	Sign
2015-9	Science Room 239 Table 4 @A	SK	N/A		5/6/2025	-	-	-	Sign
2015-10	Science Room 239 Table 4 @B	SK	N/A		5/6/2025	-	-	-	Sign
2015-11	Science Room 239 Table 5 @A	SK	N/A		5/6/2025	-	-	-	Sign
2015-12	Science Room 239 Table 5 @B	SK	N/A		5/6/2025	-	-	-	Sign
2015-13	Science Room 239 Table 6 @A	SK	N/A		5/6/2025	-	-	-	Sign
2015-14	Science Room 239 Table 6 @B	SK	N/A		5/6/2025	-	-	-	Sign
2015-15	Science Room 239 Counter @B	SK	N/A		5/6/2025	-	-	-	Sign
2016-1	Science Room 217 Teachers Station	SK	N/A		5/6/2025	-	-	-	Sign

Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
2016-2	Science Room 217 Table 1 @A	SK	N/A		5/6/2025	-	-	-	Sign
2016-3	Science Room 217 Table 1 @B	SK	N/A		5/6/2025	-	-	-	Sign
2016-4	Science Room 217 Table 2 @A	SK	N/A		5/6/2025	-	-	-	Sign
2016-5	Science Room 217 Table 2 @B	SK	N/A		5/6/2025	-	-	-	Sign
2016-6	Science Room 217 Counter @A	SK	N/A		5/6/2025	-	-	-	Sign
2016-7	Science Room 217 Table 3 @A	SK	N/A		5/6/2025	-	-	-	Sign
2016-8	Science Room 217 Table 3 @B	SK	N/A		5/6/2025	-	-	-	Sign
2016-9	Science Room 217 Table 4 @A	SK	N/A		5/6/2025	-	-	-	Sign
2016-10	Science Room 217 Table 4 @B	SK	N/A		5/6/2025	-	-	-	Sign
2016-11	Science Room 217 Counter @B	SK	N/A		5/6/2025	-	-	-	Sign
2016-12	Science Room 217 Table 5 @A	SK	N/A		5/6/2025	-	-	-	Sign
2016-13	Science Room 217 Table 5 @B	SK	N/A		5/6/2025	-	-	-	Sign
2016-14	Science Room 217 Table 6 @A	SK	N/A		5/6/2025	-	-	-	Sign
2016-15	Science Room 217 Table 6 @B	SK	N/A		5/6/2025	-	-	-	Sign
2017-1	Science Prep Room by 217	SK	N/A		5/6/2025	-	-	-	Sign
2017-2	Science Prep Room by 217 (Fume Hood)	SP	N/A		5/6/2025	-	-	-	Sign
2017-3	Science Prep Room by 215	SK	N/A		5/6/2025	-	-	-	Sign
2017-4	Science Prep Room by 215 (Fume Hood)	SP	N/A		5/6/2025	-	-	-	Sign
2018-1	Science Room 215 Teachers Station	SK	N/A		5/6/2025	-	-	-	Sign

Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
2018-2	Science Room 215 Counter @A	SK	N/A		5/6/2025	-	-	-	Sign
2018-3	Science Room 215 Table 1 @A	SK	N/A		5/6/2025	-	-	-	Sign
2018-4	Science Room 215 Table 1 @B	SK	N/A		5/6/2025	-	-	-	Sign
2018-5	Science Room 215 Table 2 @A	SK	N/A		5/6/2025	-	-	-	Sign
2018-6	Science Room 215 Table 2 @B	SK	N/A		5/6/2025	-	-	-	Sign
2018-7	Science Room 215 Table 3 @A	SK	N/A		5/6/2025	-	-	-	Sign
2018-8	Science Room 215 Table 3 @B	SK	N/A		5/6/2025	-	-	-	Sign
2018-9	Science Room 215 Counter @B	SK	N/A		5/6/2025	-	-	-	Sign
2018-10	Science Room 215 Table 4 @A	SK	N/A		5/6/2025	-	-	-	Sign
2018-11	Science Room 215 Table 4 @B	SK	N/A		5/6/2025	-	-	-	Sign
2018-12	Science Room 215 Table 5 @A	SK	N/A		5/6/2025	-	-	-	Sign
2018-13	Science Room 215 Table 5 @B	SK	N/A		5/6/2025	-	-	-	Sign
2018-14	Science Room 215 Table 6 @A	SK	N/A		5/6/2025	-	-	-	Sign
2018-15	Science Room 215 Table 6 @B	SK	N/A		5/6/2025	-	-	-	Sign
2019-1	Custodial Closet J20 by Room 201	SS	N/A		5/6/2025	-	-	-	Sign
2020-1	Hall by Room 202	WF	App	<1.0	5/6/2025	-	-	-	-
2021-1	Womens Bathroom by Room 202 @A	SK	N/A		5/6/2025	-	-	-	Sign
2021-2	Womens Bathroom by Room 202 @B	SK	N/A		5/6/2025	-	-	-	Sign
2022-1	Mens Bathroom by Room 205 @A	SK	N/A		5/6/2025	-	-	-	Sign

Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
2022-2	Mens Bathroom by Room 205 @B	SK	N/A		5/6/2025	-	-	-	Sign
2023-1	Custodial Closet J21 by Room 206	SS	N/A		5/6/2025	-	-	-	Sign
2024-1	Hall by Room 206	WF	App	<1.0	5/6/2025	-	-	-	-
2025-1	Hall by Room 211	WF	App	<1.0	5/6/2025	-	-	-	-
2025-2	Hall by Room 211 (Bottle Filler)	BF	App	<1.0	5/6/2025	-	-	-	-
2026-1	Faculty Womens Bathroom by Room 211 @A	SK	N/A		5/6/2025	-	-	-	Sign
2026-2	Faculty Womens Bathroom by Room 211 @B	SK	N/A		5/6/2025	-	-	-	Sign
2027-1	Womens Bathroom by Staircase 8 (2R) Unit @A	SK	N/A		5/6/2025	-	-	-	Mixed Valve; Sign
2027-2	Womens Bathroom by Staircase 8 (2R) Unit @B	SK	N/A		5/6/2025	-	-	-	Mixed Valve; Sign
2027-3	Womens Bathroom by Staircase 8 (2R) Unit @C	SK	N/A		5/6/2025	-	-	-	Mixed Valve; Sign
2028-1	Mens Bathroom by Staircase 8 (2R) Unit @A	SK	N/A		5/6/2025	-	-	-	Mixed Valve; Sign
2028-2	Mens Bathroom by Staircase 8 (2R) Unit @B	SK	N/A		5/6/2025	-	-	-	Mixed Valve; Sign
2028-3	Mens Bathroom by Staircase 8 (2R) Unit @C	SK	N/A		5/6/2025	-	-	-	Mixed Valve; Sign
2029-1	Custodial Closet J23 by Staircase 8 (2R)	SS	N/A		5/6/2025	-	-	-	Sign
2030-1	Staff Lounge 218 Kitchenette	SK	App	<1.0	5/6/2025	-	-	-	-
2030-2	Staff Lounge 218 Left Staff Bathroom	SK	N/A		5/6/2025	-	-	-	Sign
2030-3	Staff Lounge 218 Right Staff Bathroom	SK	N/A		5/6/2025	-	-	-	Sign
2031-1	Science Prep Room 220A in Teachers Workroom 220	SK	N/A		5/6/2025	-	-	-	Sign
2032-1	Science Room 222 Teachers Station	SK	N/A		5/6/2025	-	-	-	Sign

Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
2032-2	Science Room 222 Table 1 @A	SK	N/A		5/6/2025	-	-	-	Sign
2032-3	Science Room 222 Table 1 @B	SK	N/A		5/6/2025	-	-	-	Sign
2032-4	Science Room 222 Counter @A	SK	N/A		5/6/2025	-	-	-	Sign
2032-5	Science Room 222 Table 2 @A	SK	N/A		5/6/2025	-	-	-	Sign
2032-6	Science Room 222 Table 2 @B	SK	N/A		5/6/2025	-	-	-	Sign
2032-7	Science Room 222 Table 3 @A	SK	N/A		5/6/2025	-	-	-	Sign
2032-8	Science Room 222 Table 3 @B	SK	N/A		5/6/2025	-	-	-	Sign
2032-9	Science Room 222 Counter @B	SK	N/A		5/6/2025	-	-	-	Sign
2032-10	Science Room 222 Table 4 @A	SK	N/A		5/6/2025	-	-	-	Sign
2032-11	Science Room 222 Table 4 @B	SK	N/A		5/6/2025	-	-	-	Sign
2032-12	Science Room 222 Table 5 @A	SK	N/A		5/6/2025	-	-	-	Sign
2032-13	Science Room 222 Table 5 @B	SK	N/A		5/6/2025	-	-	-	Sign
2032-14	Science Room 222 Table 6 @A	SK	N/A		5/6/2025	-	-	-	Sign
2032-15	Science Room 222 Table 6 @B	SK	N/A		5/6/2025	-	-	-	Sign
2033-1	Unisex Bathroom by Room 223 @A	SK	N/A		5/6/2025	-	-	-	Sign
2033-2	Unisex Bathroom by Room 223 @B	SK	N/A		5/6/2025	-	-	-	Sign
2034-1	Hall by Room 223	WF	App		5/6/2025				Removed from Service
2035-1	Old Mens Bathroom/New Records Room @A	SK	N/A		5/6/2025	-	-	-	Sign
2035-2	Old Mens Bathroom/New Records Room @B	SK	N/A		5/6/2025	-	-	-	Sign

Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
2035-3	Old Mens Bathroom/New Records Room @C	SK	N/A		5/6/2025	-	-	-	Sign
2036-1	Science Room 223 Teachers Station	SK	N/A		5/6/2025	-	-	-	Sign
2036-2	Science Room 223 Table 1 @A	SK	N/A		5/6/2025	-	-	-	Sign
2036-3	Science Room 223 Table 1 @B	SK	N/A		5/6/2025	-	-	-	Sign
2036-4	Science Room 223 Table 2 @A	SK	N/A		5/6/2025	-	-	-	Sign
2036-5	Science Room 223 Table 2 @B	SK	N/A		5/6/2025	-	-	-	Sign
2036-6	Science Room 223 Table 3 @A	SK	N/A		5/6/2025	-	-	-	Sign
2036-7	Science Room 223 Table 3 @B	SK	N/A		5/6/2025	-	-	-	Sign
2036-8	Science Room 223 Counter 1	SK	N/A		5/6/2025	-	-	-	Sign
2036-9	Science Room 223 Counter 2	SK	N/A		5/6/2025	-	-	-	Sign
2036-10	Science Room 223 Table 4 @A	SK	N/A		5/6/2025	-	-	-	Sign
2036-11	Science Room 223 Table 4 @B	SK	N/A		5/6/2025	-	-	-	Sign
2036-12	Science Room 223 Table 5 @A	SK	N/A		5/6/2025	-	-	-	Sign
2036-13	Science Room 223 Table 5 @B	SK	N/A		5/6/2025	-	-	-	Sign
2036-14	Science Room 223 Table 6 @A	SK	N/A		5/6/2025	-	-	-	Sign
2036-15	Science Room 223 Table 6 @B	SK	N/A		5/6/2025	-	-	-	Sign
2037-1	Custodial Closet J22 by Room 223	SS	N/A		5/6/2025	-	-	-	Sign
2038-1	Science Room 221 Teachers Station	SK	N/A		5/6/2025	-	-	-	Sign
2038-2	Science Room 221 Table 1 @A	SK	N/A		5/6/2025	-	-	-	Sign

Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
2038-3	Science Room 221 Table 1 @B	SK	N/A		5/6/2025	-	-	-	Sign
2038-4	Science Room 221 Table 2 @A	SK	N/A		5/6/2025	-	-	-	Sign
2038-5	Science Room 221 Table 2 @B	SK	N/A		5/6/2025	-	-	-	Sign
2038-6	Science Room 221 Table 3 @A	SK	N/A		5/6/2025	-	-	-	Sign
2038-7	Science Room 221 Table 3 @B	SK	N/A		5/6/2025	-	-	-	Sign
2038-8	Science Room 221 Counter 1	SK	N/A		5/6/2025	-	-	-	Sign
2038-9	Science Room 221 Counter 2	SK	N/A		5/6/2025	-	-	-	Sign
2038-10	Science Room 221 Table 4 @A	SK	N/A		5/6/2025	-	-	-	Sign
2038-11	Science Room 221 Table 4 @B	SK	N/A		5/6/2025	-	-	-	Sign
2038-12	Science Room 221 Table 5 @A	SK	N/A		5/6/2025	-	-	-	Sign
2038-13	Science Room 221 Table 5 @B	SK	N/A		5/6/2025	-	-	-	Sign
2038-14	Science Room 221 Table 6 @A	SK	N/A		5/6/2025	-	-	-	Sign
2038-15	Science Room 221 Table 6 @B	SK	N/A		5/6/2025	-	-	-	Sign
2039-1	Science Room 219 Teachers Station	SK	N/A		5/6/2025	-	-	-	Sign
2039-2	Science Room 219 Counter @A	SK	N/A		5/6/2025	-	-	-	Sign
2039-3	Science Room 219 Counter @B	SK	N/A		5/6/2025	-	-	-	Sign
0013-1	Boys Locker Room Under Dome @A	SK	N/A		5/6/2025	-	-	-	Sign
0013-2	Boys Locker Room Under Dome @B	SK	N/A		5/6/2025	-	-	-	Sign
0013-3	Boys Locker Room Under Dome @C	SK	N/A		5/6/2025	-	-	-	Sign

Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
0013-4	Boys Locker Room Under Dome @D	SK	N/A		5/6/2025	-	-	-	Sign
0013-5	Boys Locker Room Under Dome Custodial Closet	SS	N/A		5/6/2025	-	-	-	Sign
0014-1	Boys Locker Room 013 Bathroom	SK	N/A		5/6/2025	-	-	-	Sign
0015-1	Custodial Closet J04 by Boys & Girls Locker Room	SS	N/A		5/6/2025	-	-	-	Sign
0016-1	Girls Locker Room 014 Bathroom @A	SK	N/A		5/6/2025	-	-	-	Mixed Valve; Sign
0016-2	Girls Locker Room 014 Bathroom @B	SK	N/A		5/6/2025	-	-	-	Mixed Valve; Sign
0016-3	Girls Locker Room 014 Bathroom @C	SK	N/A		5/6/2025	-	-	-	Mixed Valve; Sign
0016-4	Girls Locker Room (Left)	WF	App		5/6/2025				Removed from Service
0016-5	Girls Locker Room (Right)	WF	App		5/6/2025				Removed from Service
0017-1	Custodian Office	WF	App	<1.0	5/6/2025	-	-	-	-
0017-2	Custodian Office Bathroom	SS	N/A		5/6/2025	-	-	-	Sign
0018-1	Outside by Track	WF	App	6.0	5/6/2025				Removed From Service; Pending Remediation
0018-2	Outside by Track	SP	App	3.0	5/6/2025	-	-	-	-
0019-1	Outside by Track Men's Bathroom	SK	N/A		5/6/2025	-	-	-	Sign

Laboratory Report

NYE Report #: 2502015-33278

May 9, 2025

Project Manager
Enviroscience Consultants, Inc.
2150 Smithtown Avenue
Ronkonkoma, NY 11779

Project: Hendrick Hudson Csd; Hendrick Hudson High School

Dear Project Manager,

Enclosed is the Laboratory Analytical Report for potable water sample(s) received on May 07, 2025. New York Environmental analyzed the samples on May 08, 2025 for Lead (Pb) by EPA Method 200.9 Rev. 2.2.

If there are any questions regarding the analyses, please feel free to contact us at your convenience. New York Environmental is a NELAP accredited laboratory. Attached reported results meet the requirements of the NELAP standards unless otherwise noted.

Samples' analytical results relate only to the samples tested, in the condition received by the laboratory. This report shall not be reproduced except in its entirety without written approval of the laboratory.

We sincerely thank you for your business, and look forward to being of service for your future environmental testing needs.

Sincerely,



Li Tsang, Laboratory Director

Date Collected:	06 May 2025
Date Received:	07 May 2025
Date Analyzed:	08 May 2025

Analytical Method:	EPA 200.9 Rev. 2.2
Analyte, Matrix:	Lead, Potable Water

Lab ID	CID	Sample Location/Description	LOQ	Result	Units	Flag
250507Q005	1	Hall by Art Room 006-WF, Initial	0.001	<0.001	mg/L	
250507Q006	2	Hall by Art Room 005-WF, Initial	0.001	<0.001	mg/L	
250507Q007	3	Staff Room 113A-SK, Initial	0.001	<0.001	mg/L	
250507Q008	4	Hall by Room 113-WF, Initial	0.001	<0.001	mg/L	
250507Q009	5	Hall by Room 113 (Bottle Filler)-BF, Initial	0.001	<0.001	mg/L	
250507Q010	6	Nurses Office 110-SK, Initial	0.001	<0.001	mg/L	
250507Q011	7	Hall by Nurses Office 110-WF, Initial	0.001	<0.001	mg/L	
250507Q012	8	Teachers Dining Room 125B-SK, Initial	0.001	<0.001	mg/L	
250507Q013	9	Hall by Room 125B-WF, Initial	0.001	<0.001	mg/L	
250507Q014	10	Hall by Café Area 125-WF, Initial	0.001	<0.001	mg/L	
250507Q015	11	Hall by Café Area 125 (Bottle Filler)-BF, Initial	0.001	<0.001	mg/L	
250507Q016	12	Kitchen Serving Area 126-IM, Initial	0.001	<0.001	mg/L	
250507Q017	13	Kitchen 127 1 Bay (Left of Pot Filler)-SK, Initial	0.001	0.002	mg/L	
250507Q018	14	Kitchen 127 1 Bay (Right of Pot Filler)-SK, Initial	0.001	<0.001	mg/L	
250507Q019	15	Kitchen 127 Pot Filler-SP, Initial	0.001	0.676	mg/L	E,H
250507Q020	16	Room 121 Home Economics-SK, Initial	0.001	0.010	mg/L	H
250507Q021	17	Storage Closet by Athletic Director 117-IM, Initial	0.001	0.001	mg/L	
250507Q022	18	Hall by Gym 115-WF, Initial	0.001	<0.001	mg/L	
250507Q023	19	Hall by Gym 115 (Bottle Filler)-BF, Initial	0.001	<0.001	mg/L	
250507Q024	20	Athletic Trainers Office 117B-SK, Initial	0.001	<0.001	mg/L	
250507Q025	21	Hall by Room 224-WF, Initial	0.001	<0.001	mg/L	
250507Q026	22	Hall by Room 224 (Bottle Filler)-BF, Initial	0.001	<0.001	mg/L	
250507Q027	23	Hall by Room 202-WF, Initial	0.001	<0.001	mg/L	
250507Q028	24	Hall by Room 206-WF, Initial	0.001	<0.001	mg/L	
250507Q029	25	Hall by Room 211-WF, Initial	0.001	<0.001	mg/L	
250507Q030	26	Hall by Room 211 (Bottle Filler)-BF, Initial	0.001	<0.001	mg/L	

Date Collected:	06 May 2025
Date Received:	07 May 2025
Date Analyzed:	08 May 2025

Analytical Method:	EPA 200.9 Rev. 2.2
Analyte, Matrix:	Lead, Potable Water

Lab ID	CID	Sample Location/Description	LOQ	Result	Units	Flag
250507Q031	27	Staff Lounge 218 Kitchenette-SK, Initial	0.001	<0.001	mg/L	
250507Q032	28	Outside by Track-WF, Initial	0.001	0.006	mg/L	H
250507Q033	29	Outside by Track-SP, Initial	0.001	0.003	mg/L	
250507Q034	30	Custodian Office-WF, Initial	0.001	<0.001	mg/L	
250507Q035	31	Teachers Dining Room 125B-SPY, Initial	0.001	0.007	mg/L	H
250507Q036	32	Teachers Dining Room 125B Coffee Pot Line-OS, Initial	0.001	<0.001	mg/L	
250507Q037	33	Concession Stand 116B-SK, Initial	0.001	<0.001	mg/L	

Comment:

CID: Client ID LOQ: Limit of Quantitation

E: Sample result exceeds instrument calibration, value is estimated.

H: Sample result exceeds applicable regulatory limit.

Appendix B

Blue Mountain Middle School

Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
1001-1	Custodial Locker Room Bathroom	SK	N/A		5/7/2025	-	-	-	Sign
1001-2	Ice Machine Room by Custodial Locker Room	IM	App	<1.0	5/7/2025	-	-	-	-
1002-1	Custodial Office 106 Kitchenette	SK	App	<1.0	5/7/2025	-	-	-	-
1002-2	Custodial Office 106 Kitchenette	SPY	App		5/7/2025				Removed from Service.
1003-1	Custodial Closet by Custodial Office 106	SS	N/A		5/7/2025	-	-	-	Sign
1004-1	Boys Locker Room Bathroom (Left)	SK	N/A		5/7/2025	-	-	-	Mixed Valve; Sign
1004-2	Boys Locker Room Bathroom (Right)	SK	N/A		5/7/2025	-	-	-	Mixed Valve; Sign
1004-3	Boys Locker Room-ceramic water fountain	WF	App	<1.0	5/7/2025	-	-	-	-
1005-1	Shop 'A' Room 103	SK	N/A		5/7/2025	-	-	-	Sign
1006-1	Hall by Room 101	BF	App	<1.0	5/7/2025	-	-	-	-
1006-2	Hall by Room 101	WF	App	<1.0	5/7/2025	-	-	-	-
1007-1	Boys Bathroom by Room 101	SK	N/A		5/7/2025	-	-	-	Sign
1008-1	Girls Bathroom by Room 101 (Left)	SK	N/A		5/7/2025	-	-	-	Sign
1008-2	Girls Bathroom by Room 101 (Right)	SK	N/A		5/7/2025	-	-	-	Sign
1009-1	Fitness Center Room 101	WF	App	<1.0	5/7/2025	-	-	-	-
1010-1	Health Room 102	SK	N/A		5/7/2025	-	-	-	Sign
1011-1	Boys Coaches Office Bathroom	SK	N/A		5/7/2025	-	-	-	Sign
1012-1	Girls Coaches Office Bathroom	SK	N/A		5/7/2025	-	-	-	Sign
1013-1	Girls Locker Room-ceramic water fountain	WF	App	3.0	5/7/2025	-	-	-	-

Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
1013-2	Girls Locker Room Bathroom (Left)	SK	N/A		5/7/2025	-	-	-	Mixed Valve; Sign
1013-3	Girls Locker Room Bathroom (Right)	SK	N/A		5/7/2025	-	-	-	Mixed Valve; Sign
1014-1	Womens Staff Bathroom by Gym	SK	N/A		5/7/2025	-	-	-	Mixed Valve; Sign
1015-1	Mens Staff Bathroom by Gym	SK	N/A		5/7/2025	-	-	-	Sign
1016-1	Custodial Closet by Water Meter Room	SS	N/A		5/7/2025	-	-	-	Sign
1017-1	Nurses Office	SK	App	<1.0	5/7/2025	-	-	-	-
1017-2	Nurses Office Bathroom	SK	App	<1.0	5/7/2025	-	-	-	-
1018-1	Teachers Lounge Kitchenette	SK	App	2.0	5/7/2025	-	-	-	Water Cooler Present
1019-1	Boys Bathroom by Room 153 (Left)	SK	N/A		5/7/2025	-	-	-	Sign
1019-2	Boys Bathroom by Room 153 (Right)	SK	N/A		5/7/2025	-	-	-	Sign
1020-1	Hall by Room 153 (Left)	BF	App	<1.0	5/7/2025	-	-	-	-
1020-2	Hall by Room 153 (Left)	WF	App	<1.0	5/7/2025	-	-	-	-
1020-3	Hall by Room 153 (Right)	WF	App	<1.0	5/7/2025	-	-	-	-
1021-2	Girls Bathroom by Room 153 (Right)	SK	N/A		5/7/2025	-	-	-	Sign
1022-1	Science Room 153 Teachers Station	SK	N/A		5/7/2025	-	-	-	Sign
1022-2	Science Room 153 Counter @ A	SK	N/A		5/7/2025	-	-	-	Sign
1022-3	Science Room 153 Counter @ B	SK	N/A		5/7/2025	-	-	-	Sign
1022-4	Science Room 153 Counter @ C	SK	N/A		5/7/2025	-	-	-	Sign
1023-1	Custodial Closet Room 152	SS	N/A		5/7/2025	-	-	-	Sign

Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
1024-1	Staff Bathroom in PPS Office	SK	N/A		5/7/2025	-	-	-	Sign
2001-1	Custodial Closet by Room 251	SS	N/A		5/7/2025	-	-	-	Sign
2002-1	Boys Bathroom by Room 256 (Left)	SK	N/A		5/7/2025	-	-	-	Sign
2002-2	Boys Bathroom by Room 256 (Right)	SK	N/A		5/7/2025	-	-	-	Sign
2003-1	Hall by Room 256 (Left)	BF	App	<1.0	5/7/2025	-	-	-	-
2003-2	Hall by Room 256 (Left)	WF	App	<1.0	5/7/2025	-	-	-	-
2003-3	Hall by Room 256 (Right)	WF	App	<1.0	5/7/2025	-	-	-	-
2004-1	Girls Bathroom by Room 256 (Left)	SK	N/A		5/7/2025	-	-	-	Sign
2004-2	Girls Bathroom by Room 256 (Right)	SK	N/A		5/7/2025	-	-	-	Sign
2005-1	Science Room 256 Teachers Station	SK	N/A		5/7/2025	-	-	-	Sign
2005-2	Science Room 256 Counter @ A	SK	N/A		5/7/2025	-	-	-	Sign
2005-3	Science Room 256 Counter @ B	SK	N/A		5/7/2025	-	-	-	Sign
2005-4	Science Room 256 Counter @ C	SK	N/A		5/7/2025	-	-	-	Sign
2006-1	Girls Bathroom by Room 211 @ A	SK	N/A		5/7/2025	-	-	-	Sign
2006-2	Girls Bathroom by Room 211 @ B	SK	N/A		5/7/2025	-	-	-	Sign
2006-3	Girls Bathroom by Room 211 @ C	SK	N/A		5/7/2025	-	-	-	Sign
2006-4	Girls Bathroom by Room 211 @ D	SK	N/A		5/7/2025	-	-	-	Sign
2006-5	Girls Bathroom by Room 211 @ E	SK	N/A		5/7/2025	-	-	-	Sign
2007-1	Hall by Room 211-ceramic water fountain	WF	App	32.0	5/7/2025				Removed From Service; Pending Remediation

Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
2008-1	Custodial Closet in Music Hallway	SS	N/A		5/7/2025	-	-	-	Sign
2009-1	Band Room 209 Kitchenette	SK	N/A		5/7/2025	-	-	-	Sign
2010-1	Hall by Band Room 209	BF	App	<1.0	5/7/2025	-	-	-	-
2010-2	Hall by Band Room 209	WF	App	<1.0	5/7/2025	-	-	-	-
2011-1	Room 210	SK	N/A		5/7/2025	-	-	-	Sign
2012-1	Hall by Room 204	BF	App	<1.0	5/7/2025	-	-	-	-
2012-2	Hall by Room 204	WF	App	<1.0	5/7/2025	-	-	-	-
2013-1	Boys Bathroom by Room 204 @ A	SK	N/A		5/7/2025	-	-	-	Sign
2013-2	Boys Bathroom by Room 204 @ B	SK	N/A		5/7/2025	-	-	-	Sign
2013-3	Boys Bathroom by Room 204 @ C	SK	N/A		5/7/2025	-	-	-	Sign
2014-1	Custodial Closet by Room 204	SS	N/A		5/7/2025	-	-	-	Sign
2015-1	Room 204 Counter @ A	SK	N/A		5/7/2025	-	-	-	Sign
2015-2	Room 204 Counter @ B	SK	N/A		5/7/2025	-	-	-	Sign
2015-3	Room 204 Closet	SS	NA		5/7/2025	-	-	-	Sign
2016-1	Life Skills Classroom	SK	App	8.0	5/7/2025				Removed From Service; Pending Remediation
2016-2	Life Skills Laundry Sink	SS	N/A		5/7/2025	-	-	-	Sign
2017-5	Art Room 202 Counter Sink	SK	N/A		5/7/2025	-	-	-	Sign
2017-6	Art Room 202 Counter Sink-rear	SK	N/A		5/7/2025	-	-	-	Sign
2018-1	Art Room 201 Unit @ A	SK	N/A		5/7/2025	-	-	-	Sign

Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
2018-2	Art Room 201 Unit @ B	SK	N/A		5/7/2025	-	-	-	Sign
2019-1	Hall by Room 206-ceramic water fountain	WF	App	4.0	5/7/2025	-	-	-	-
2020-1	Room 205	SK	N/A		5/7/2025	-	-	-	Sign
2020-2	Room 205	SPY	N/A		5/7/2025	-	-	-	Sign
2021-1	Staff Bathroom by Kitchen	SK	N/A		5/7/2025	-	-	-	Sign
2021-2	Faculty Lounge by Kitchen	SK	N/A		5/7/2025	-	-	-	Sign
2021-3	Kitchen Custodial Closet	SP	N/A		5/7/2025	-	-	-	Sign
2021-4	Kitchen Serving Line #1	SK	N/A		5/7/2025	-	-	-	Sign
2021-5	Kitchen Handwash by Serving Line #1	SK	N/A		5/7/2025	-	-	-	Sign
2021-6	Kitchen 2 Bay Prep	SK	App	2.0	5/7/2025	-	-	-	-
2021-7	Kitchen 3 Bay (Left) Dishwash	SK	N/A		5/7/2025	-	-	-	Sign
2021-8	Kitchen 3 Bay (Middle) Dishwash	SPY	N/A		5/7/2025	-	-	-	Sign
2021-9	Kitchen 3 Bay (Middle) Dishwash	SK	N/A		5/7/2025	-	-	-	Sign
2021-10	Kitchen 3 Bay (Right) Dishwash	SK	N/A		5/7/2025	-	-	-	Sign
2021-11	Kitchen 1 Bay Prep	SK	App	<1.0	5/7/2025	-	-	-	-
2021-12	Kitchen Serving Line #2 Handwash	SK	N/A		5/7/2025	-	-	-	Sign
3001-1	Hall by Room 308A	BF	App	<1.0	5/7/2025	-	-	-	-
3001-2	Hall by Room 308A	WF	App	<1.0	5/7/2025	-	-	-	-
3002-1	Room 308A	SK	App	4.0	5/7/2025	-	-	-	-

Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
3003-1	Custodial Closet by Room 306	SS	N/A		5/7/2025	-	-	-	Sign
3004-1	Mens Staff Bathroom by Room 306	SK	N/A		5/7/2025	-	-	-	Sign
3005-1	Hall by Room 306-ceramic water fountain	WF	App	3.0	5/7/2025	-	-	-	-
3006-1	Womens Staff Bathroom by Room 306 (Left)	SK	N/A		5/7/2025	-	-	-	Sign
3006-2	Womens Staff Bathroom by Room 306 (Right)	SK	N/A		5/7/2025	-	-	-	Sign
3007-1	Room 301	SK	N/A		5/7/2025	-	-	-	Sign
3008-1	Science Room 312 Counter 1 @ A	SK	N/A		5/7/2025	-	-	-	Sign
3008-2	Science Room 312 Counter 1 @ B	SK	N/A		5/7/2025	-	-	-	Sign
3008-3	Science Room 312 Counter 2 @ A	SK	N/A		5/7/2025	-	-	-	Sign
3009-1	Girls Bathroom by Room 312 @ A	SK	N/A		5/7/2025	-	-	-	Sign
3009-2	Girls Bathroom by Room 312 @ B	SK	N/A		5/7/2025	-	-	-	Sign
3009-3	Girls Bathroom by Room 312 @ C	SK	N/A		5/7/2025	-	-	-	Sign
3009-4	Girls Bathroom by Room 312 @ D	SK	N/A		5/7/2025	-	-	-	Sign
3010-1	Science Room 314 Counter @ A	SK	N/A		5/7/2025	-	-	-	Sign
3010-2	Science Room 314 Counter @ B	SK	N/A		5/7/2025	-	-	-	Sign
3010-3	Science Room 314 Counter @ C	SK	N/A		5/7/2025	-	-	-	Sign
3010-4	Science Room 314 Counter @ D	SK	N/A		5/7/2025	-	-	-	Sign
3011-1	Room 313	SK	N/A		5/7/2025	-	-	-	Sign
3012-1	Science Room 315 Teachers Station	SK	N/A		5/7/2025	-	-	-	Sign

Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
3012-2	Science Room 315 Counter 1	SK	N/A		5/7/2025	-	-	-	Sign
3012-3	Science Room 315 Counter 2	SK	N/A		5/7/2025	-	-	-	Sign
3013-1	Science Prep Room 300 Counter 1	SK	N/A		5/7/2025	-	-	-	Sign
3013-2	Science Prep Room 300 Counter 2	SK	N/A		5/7/2025	-	-	-	Sign
3014-1	Science Room 317 Teachers Station	SK	N/A		5/7/2025	-	-	-	Sign
3014-2	Science Room 317 Counter 1	SK	N/A		5/7/2025	-	-	-	Sign
3014-3	Science Room 317 Counter 2	SK	N/A		5/7/2025	-	-	-	Sign
3015-1	Science Room 318 Counter @ A	SK	N/A		5/7/2025	-	-	-	Sign
3015-2	Science Room 318 Counter @ B	SK	N/A		5/7/2025	-	-	-	Sign
3015-4	Science Room 318 Counter @ D	SK	N/A		5/7/2025	-	-	-	Sign
3016-1	Hall by Room 316	BF	App	<1.0	5/7/2025				-
3016-2	Hall by Room 316	WF	App	<1.0	5/7/2025	-	-	-	-
3017-1	Boys Bathroom by Room 319 @ A	SK	N/A		5/7/2025	-	-	-	Sign
3017-2	Boys Bathroom by Room 319 @ B	SK	N/A		5/7/2025	-	-	-	Sign
3017-3	Boys Bathroom by Room 319 @ C	SK	N/A		5/7/2025	-	-	-	Sign
3017-4	Boys Bathroom by Room 319 @ D	SK	N/A		5/7/2025	-	-	-	Sign
3018-1	Science Room 319 Counter @ A	SK	N/A		5/7/2025	-	-	-	Sign
3018-2	Science Room 319 Counter @ B	SK	N/A		5/7/2025	-	-	-	Sign
3018-3	Science Room 319 Counter @ C	SK	N/A		5/7/2025	-	-	-	Sign

Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
3018-4	Science Room 319 Counter @ D	SK	N/A		5/7/2025	-	-	-	Sign
3019-1	Custodial Closet by Room 322	SS	N/A		5/7/2025	-	-	-	Sign
3020-1	Faculty Room 'B' by Room 322	SK	N/A		5/7/2025	-	-	-	Sign
3021-1	Hall by Room 326	BF	App	<1.0	5/7/2025	-	-	-	-
3021-2	Hall by Room 326	WF	App	<1.0	5/7/2025	-	-	-	-
3022-1	Custodial Closet by Office 362	SS	N/A		5/7/2025	-	-	-	Sign
3023-1	Office 362	SK	N/A		5/7/2025	-	-	-	Sign
3024-1	Mens Bathroom by Office 362 (Left)	SK	N/A		5/7/2025	-	-	-	Sign
3024-2	Mens Bathroom by Office 362 (Right)	SK	N/A		5/7/2025	-	-	-	Sign
3025-1	Hall by Office 362 -left	WF	App	<1.0	5/7/2025	-	-	-	-
3025-2	Hall by Office 362-right	WF	App	<1.0	5/7/2025	-	-	-	-
3026-1	Womens Bathroom by Office 362 (Left)	SK	N/A		5/7/2025	-	-	-	Sign
3026-2	Womens Bathroom by Office 362 (Right)	SK	N/A		5/7/2025	-	-	-	Sign
3027-1	Room 214	SK	N/A		5/7/2025	-	-	-	Sign

Laboratory Report

NYE Report #: 2502039-33297

May 12, 2025

Project Manager
Enviroscience Consultants, Inc.
2150 Smithtown Avenue
Ronkonkoma, NY 11779

Project: Hendrick Hudson Csd; Blue Mountain Middle School

Dear Project Manager,

Enclosed is the Laboratory Analytical Report for potable water sample(s) received on May 08, 2025. New York Environmental analyzed the samples on May 12, 2025 for Lead (Pb) by EPA Method 200.9 Rev. 2.2.

If there are any questions regarding the analyses, please feel free to contact us at your convenience. New York Environmental is a NELAP accredited laboratory. Attached reported results meet the requirements of the NELAP standards unless otherwise noted.

Samples' analytical results relate only to the samples tested, in the condition received by the laboratory. This report shall not be reproduced except in its entirety without written approval of the laboratory.

We sincerely thank you for your business, and look forward to being of service for your future environmental testing needs.

Sincerely,



Li Tsang, Laboratory Director

Date Collected:	07 May 2025
Date Received:	08 May 2025
Date Analyzed:	12 May 2025

Analytical Method:	EPA 200.9 Rev. 2.2
Analyte, Matrix:	Lead, Potable Water

Lab ID	CID	Sample Location/Description	LOQ	Result	Units	Flag
250508P046	1	Ice Machine Room by Custodial Locker Room-IM, Initial	0.001	<0.001	mg/L	
250508P047	2	Custodial Office 106 Kitchenette-SK, Initial	0.001	<0.001	mg/L	
250508P048	3	Boys Locker Room-ceramic water fountain-WF, Initial	0.001	<0.001	mg/L	
250508P049	4	Hall by Room 101-BF, Initial	0.001	<0.001	mg/L	
250508P050	5	Hall by Room 101-WF, Initial	0.001	<0.001	mg/L	
250508P051	6	Fitness Center Room 101-WF, Initial	0.001	0.001	mg/L	
250508P052	7	Girls Locker Room-ceramic water fountain-WF, Initial	0.001	0.003	mg/L	
250508P053	8	Nurses Office -SK, Initial	0.001	<0.001	mg/L	
250508P054	9	Nurses Office Bathroom-SK, Initial	0.001	<0.001	mg/L	
250508P055	10	Teachers Lounge Kitchenette-SK, Initial	0.001	0.002	mg/L	
250508P056	11	Hall by Room 153 (Left)-BF, Initial	0.001	0.003	mg/L	
250508P057	12	Hall by Room 153 (Left)-WF, Initial	0.001	<0.001	mg/L	
250508P058	13	Hall by Room 153 (Right)-WF, Initial	0.001	<0.001	mg/L	
250508P059	14	Hall by Room 256 (Left)-BF, Initial	0.001	<0.001	mg/L	
250508P060	15	Hall by Room 256 (Left)-WF, Initial	0.001	<0.001	mg/L	
250508P061	16	Hall by Room 256 (Right)-WF, Initial	0.001	<0.001	mg/L	
250508P062	17	Hall by Room 211-ceramic water fountain-WF, Initial	0.001	0.032	mg/L	H
250508P063	18	Hall by Band Room 209-BF, Initial	0.001	<0.001	mg/L	
250508P064	19	Hall by Band Room 209 -WF, Initial	0.001	<0.001	mg/L	
250508P065	20	Hall by Room 204-BF, Initial	0.001	<0.001	mg/L	
250508P066	21	Hall by Room 204-WF, Initial	0.001	<0.001	mg/L	
250508P067	22	Life Skills Classroom-SK, Initial	0.001	0.008	mg/L	H
250508P068	23	Kitchen 2 Bay Prep -SK, Initial	0.001	0.002	mg/L	
250508P069	24	Kitchen 1 Bay Prep-SK, Initial	0.001	<0.001	mg/L	
250508P070	25	Hall by Room 206-ceramic water fountain-WF, Initial	0.001	0.004	mg/L	
250508P071	26	Hall by Room 308A-BF, Initial	0.001	<0.001	mg/L	

Date Collected:	07 May 2025
Date Received:	08 May 2025
Date Analyzed:	12 May 2025

Analytical Method:	EPA 200.9 Rev. 2.2
Analyte, Matrix:	Lead, Potable Water

Lab ID	CID	Sample Location/Description	LOQ	Result	Units	Flag
250508P072	27	Hall by Room 308A -WF, Initial	0.001	<0.001	mg/L	
250508P073	28	Room 308A-SK, Initial	0.001	0.004	mg/L	
250508P074	29	Hall by Room 306-ceramic fountain-WF, Initial	0.001	0.003	mg/L	
250508P075	30	Hall by Room 316 -WF, Initial	0.001	<0.001	mg/L	
250508P076	31	Hall by Room 316 -BF, Initial	0.001	<0.001	mg/L	
250508P077	32	Hall by Room 326 -WF, Initial	0.001	<0.001	mg/L	
250508P078	33	Hall by Room 326 -BF, Initial	0.001	<0.001	mg/L	
250508P079	34	Hall by Office 362 -left -WF, Initial	0.001	<0.001	mg/L	
250508P080	35	Hall by Office 362-right -WF, Initial	0.001	<0.001	mg/L	

Comment:

CID: Client ID LOQ: Limit of Quantitation

H: Sample result exceeds applicable regulatory limit.

Appendix C

Buchanan-Verplanck Elementary School

Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
1001-1	Boiler Room	SP	N/A		5/8/2025	-	-	-	Sign
1002-1	Kitchen 3-Bay (left) Dish Wash	SK	N/A		5/8/2025	-	-	-	Sign
1002-2	Kitchen 3-Bay (middle) Dish Wash	SK	N/A		5/8/2025	-	-	-	Sign
1002-3	Kitchen 3-Bay (right) Dish Wash	SK	N/A		5/8/2025	-	-	-	Sign
1002-4	Kitchen 3-Bay (right) Dish Wash	SK	N/A		5/8/2025	-	-	-	Sign
1002-5	Kitchen Island	SK	App	5.0	5/8/2025	-	-	-	-
1002-6	Kitchen by Stove (Pot Filler)	PF	App	7.0	5/8/2025				Removed from Service; Pending Remediation
1002-7	Kitchen by Serving Line	SK	N/A		5/8/2025	-	-	-	Sign
1002-8	Kitchen Back Handwash Sink	SK	N/A		5/8/2025	-	-	-	Sign
1002-9	Kitchen Handwash	SK	N/A		5/8/2025	-	-	-	Sign
1002-10	Kitchen Custodial Closet	SS	N/A		5/8/2025	-	-	-	Sign
1002-11	Kitchen Staff Bathroom	SK	N/A		5/8/2025	-	-	-	Sign
1003-1	Auditoria	BF	App	<1.0	5/8/2025	-	-	-	-
1003-2	Auditoria	WF	App	<1.0	5/8/2025	-	-	-	-
1004-1	Custodial Office Bathroom	SK	N/A		5/8/2025	-	-	-	Sign
1005-1	Art Room 29 Front (left)	SK	N/A		5/8/2025	-	-	-	Sign
1005-2	Art Room 29 Front (right)	SK	N/A		5/8/2025	-	-	-	Sign
1005-3	Art Room 29 Back (left)	SK	N/A		5/8/2025	-	-	-	Sign

Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
1005-4	Art Room 29 Back (right)	SK	N/A		5/8/2025	-	-	-	Sign
1006-1	Hall by Art Room 29	BF	App	<1.0	5/8/2025	-	-	-	-
1006-2	Hall by Art Room 29	WF	App	<1.0	5/8/2025	-	-	-	-
1007-1	Gym Locker Room	WF	N/A		5/8/2025	-	-	-	Removed from Service
1007-2	Gym Locker Room Bathroom (left)	SK	N/A		5/8/2025	-	-	-	Sign
1007-3	Gym Locker Room Bathroom (right)	SK	N/A		5/8/2025	-	-	-	Sign
1007-4	Gym Phys Ed Office Bathroom	SK	N/A		5/8/2025	-	-	-	Sign
1008-1	Faculty Bathroom by Psychologist's Office	SK	N/A		5/8/2025	-	-	-	Sign
1009-1	Psychologist's Office	SK	N/A		5/8/2025	-	-	-	Sign
1009-2	Psychologist's Office Bathroom	SK	N/A		5/8/2025	-	-	-	Sign
1010-1	Main Office Kitchenette	SK	N/A		5/8/2025	-	-	-	Sign
1011-1	Unisex Bathroom by Main Office	SK	N/A		5/8/2025	-	-	-	Sign
1012-1	Room 1 Pre-K Daycare	WF	App	<1.0	5/8/2025	-	-	-	-
1012-2	Room 1 Pre-K Daycare	SK	N/A		5/8/2025	-	-	-	Sign
1013-1	Room 2 Pre-K Daycare	WF	App	<1.0	5/8/2025	-	-	-	-
1013-2	Room 2 Pre-K Daycare	SK	N/A		5/8/2025	-	-	-	Sign
1014-1	Room 3 Pre-K Daycare	WF	App	8.0	5/8/2025				Removed from Service
1014-2	Room 3 Pre-K Daycare	SK	N/A		5/8/2025	-	-	-	Sign

Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
1015-1	Room 4 Pre-K Daycare	WF	App	1.0	5/8/2025	-	-	-	-
1015-2	Room 4 Pre-K Daycare	SK	N/A		5/8/2025	-	-	-	Sign
1016-1	Room 5	WF	N/A		5/8/2025	-	-	-	Sign
1016-2	Room 5	SK	N/A		5/8/2025	-	-	-	Sign
1017-1	Room 13	WF	App	2.0	5/8/2025	-	-	-	-
1017-2	Room 13	SK	N/A		5/8/2025	-	-	-	Sign
1018-1	Room 14	WF	N/A		5/8/2025	-	-	-	Removed from Service
1018-2	Room 14	SK	N/A		5/8/2025	-	-	-	Removed from Service
1019-1	Room 6	WF	N/A		5/8/2025	-	-	-	Removed from Service
1019-2	Room 6	SK	N/A		5/8/2025	-	-	-	Sign
1020-1	Room 7	WF	N/A		5/8/2025	-	-	-	Removed from Service
1020-2	Room 7	SK	N/A		5/8/2025	-	-	-	Sign
1021-1	Library Work Room	SK	N/A		5/8/2025	-	-	-	Removed from Service
1022-1	Room 8	WF	N/A		5/8/2025	-	-	-	Removed from Service
1022-2	Room 8	SK	N/A		5/8/2025	-	-	-	Sign
1023-1	Room 9	WF	App	4.0	5/8/2025	-	-	-	-
1023-2	Room 9	SK	N/A		5/8/2025	-	-	-	Sign
1024-1	Unisex Bathroom by Library Now Storage	SK	N/A		5/8/2025	-	-	-	Removed from Service

Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
1025-1	Custodial Closet by Library	SS	N/A		5/8/2025	-	-	-	Sign
1026-1	Room 10	WF	App	8.0	5/8/2025				Removed from Service
1026-2	Room 10	SK	N/A		5/8/2025	-	-	-	Sign
1027-1	Room 11	WF	App	<1.0	5/8/2025	-	-	-	-
1027-2	Room 11	SK	N/A		5/8/2025	-	-	-	Sign
1028-1	Room 12	WF	App	<1.0	5/8/2025	-	-	-	-
1028-2	Room 12	SK	N/A		5/8/2025	-	-	-	Sign
1029-1	Room 15	WF	App	<1.0	5/8/2025	-	-	-	-
1029-2	Room 15	SK	N/A		5/8/2025	-	-	-	Sign
1030-1	Hall by Room 15	BF	App	<1.0	5/8/2025	-	-	-	-
1030-2	Hall by Room 15	WF	App	<1.0	5/8/2025	-	-	-	-
1031-2	Room 16	SK	N/A		5/8/2025	-	-	-	Sign
1032-1	Room 22	WF	N/A		5/8/2025	-	-	-	Removed from Service
1032-2	Room 22	SK	N/A		5/8/2025	-	-	-	Sign
1033-1	Room 21	WF	N/A		5/8/2025	-	-	-	Removed from Service
1033-2	Room 21	SK	N/A		5/8/2025	-	-	-	Sign
1034-1	Room 20	WF	N/A		5/8/2025	-	-	-	Removed from Service
1034-2	Room 20	SK	N/A		5/8/2025	-	-	-	Sign

Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
1036-1	Hall by Room 20	BF	App	<1.0	5/8/2025	-	-	-	-
1036-2	Hall by Room 20	WF	App	<1.0	5/8/2025	-	-	-	-
1037-1	Room 19	WF	App	13.0	5/8/2025				Removed from Service
1037-2	Room 19	SK	N/A		5/8/2025	-	-	-	Sign
1038-1	Room 18	WF	App	12.0	5/8/2025				Removed from Service
1038-2	Room 18	SK	N/A		5/8/2025	-	-	-	Sign
1039-1	Room 23	WF	App	2.0	5/8/2025	-	-	-	-
1039-2	Room 23	SK	N/A		5/8/2025	-	-	-	Sign
1040-1	Room 17	WF	N/A		5/8/2025	-	-	-	Removed from Service
1040-2	Room 17	SK	N/A		5/8/2025	-	-	-	Sign
1041-1	Custodial Closet by Room 17	SS	N/A		5/8/2025	-	-	-	Sign
1042-1	Support Services Bathroom (left)	SK	N/A		5/8/2025	-	-	-	Sign
1042-2	Support Services Bathroom (right)	SK	N/A		5/8/2025	-	-	-	Sign
1043-1	Men's Bathroom by Room 17 (left)	SK	N/A		5/8/2025	-	-	-	Sign
1043-2	Men's Bathroom by Room 17 (right)	SK	N/A		5/8/2025	-	-	-	Sign
1044-1	Custodial Closet by Support Services	SS	N/A		5/8/2025	-	-	-	Sign
1045-1	Women's Bathroom by Room 17 (left)	SK	N/A		5/8/2025	-	-	-	Sign
1045-2	Women's Bathroom by Room 17 (right)	SK	N/A		5/8/2025	-	-	-	Sign

Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
1046-1	Playground	WF	N/A		5/8/2025	-	-	-	Removed from Service
1047-1	New Nurse's Office Bathroom Left	SK	App	7.0	5/8/2025	-	-	-	Removed from Service; Pending Remediation
1047-2	New Nurse's Office Bathroom Right	SK	App	5.0	5/8/2025	-	-	-	-

Laboratory Report

NYE Report #: 2502040-33298

May 12, 2025

Project Manager
Enviroscience Consultants, Inc.
2150 Smithtown Avenue
Ronkonkoma, NY 11779

Project: Hendrick Hudson Csd; Buchanan-verplanck Elementary

Dear Project Manager,

Enclosed is the Laboratory Analytical Report for potable water sample(s) received on May 08, 2025. New York Environmental analyzed the samples on May 12, 2025 for Lead (Pb) by EPA Method 200.9 Rev. 2.2.

If there are any questions regarding the analyses, please feel free to contact us at your convenience. New York Environmental is a NELAP accredited laboratory. Attached reported results meet the requirements of the NELAP standards unless otherwise noted.

Samples' analytical results relate only to the samples tested, in the condition received by the laboratory. This report shall not be reproduced except in its entirety without written approval of the laboratory.

We sincerely thank you for your business, and look forward to being of service for your future environmental testing needs.

Sincerely,



Li Tsang, Laboratory Director

Date Collected:	08 May 2025
Date Received:	08 May 2025
Date Analyzed:	12 May 2025

Analytical Method:	EPA 200.9 Rev. 2.2
Analyte, Matrix:	Lead, Potable Water

Lab ID	CID	Sample Location/Description	LOQ	Result	Units	Flag
250508P081	1	Kitchen Island-SK, Initial	0.001	0.005	mg/L	
250508P082	2	Kitchen by Stove (Pot Filler)-PF, Initial	0.001	0.007	mg/L	H
250508P083	3	Auditoria-BF, Initial	0.001	<0.001	mg/L	
250508P084	4	Auditoria-WF, Initial	0.001	<0.001	mg/L	
250508P085	5	Hall by Art Room 29-BF, Initial	0.001	<0.001	mg/L	
250508P086	6	Hall by Art Room 29-WF, Initial	0.001	<0.001	mg/L	
250508P087	7	New Nurse's Office Bathroom Left-SK, Initial	0.001	0.007	mg/L	H
250508P088	8	New Nurse's Office Bathroom Right-SK, Initial	0.001	0.005	mg/L	
250508P089	9	Room 18-WF, Initial	0.001	0.012	mg/L	H
250508P090	10	Room 19-WF, Initial	0.001	0.013	mg/L	H
250508P091	11	Hall by Room 20-BF, Initial	0.001	<0.001	mg/L	
250508P092	12	Hall by Room 20-WF, Initial	0.001	<0.001	mg/L	
250508P093	13	Room 23-WF, Initial	0.001	0.002	mg/L	
250508P094	14	Room 16-WF, Initial	0.001	<0.001	mg/L	
250508P095	15	Hall by Room 15-BF, Initial	0.001	<0.001	mg/L	
250508P096	16	Hall by Room 15-WF, Initial	0.001	<0.001	mg/L	
250508P097	17	Room 15-WF, Initial	0.001	<0.001	mg/L	
250508P098	18	Room 12-WF, Initial	0.001	<0.001	mg/L	
250508P099	19	Room 11-WF, Initial	0.001	<0.001	mg/L	
250508P100	20	Room 10-WF, Initial	0.001	0.008	mg/L	H
250508P101	21	Room 9-WF, Initial	0.001	0.004	mg/L	
250508P102	22	Room 13-WF, Initial	0.001	0.002	mg/L	
250508P103	23	Room 4 Pre-K Daycare-WF, Initial	0.001	0.001	mg/L	
250508P104	24	Room 3 Pre-K Daycare-WF, Initial	0.001	0.008	mg/L	H
250508P105	25	Room 2 Pre-K Daycare-WF, Initial	0.001	<0.001	mg/L	
250508P106	26	Room 1 Pre-K Daycare-WF, Initial	0.001	<0.001	mg/L	



Date Collected:	08 May 2025
Date Received:	08 May 2025
Date Analyzed:	12 May 2025

Analytical Method:	EPA 200.9 Rev. 2.2
Analyte, Matrix:	Lead, Potable Water

Lab ID	CID	Sample Location/Description	LOQ	Result	Units	Flag
--------	-----	-----------------------------	-----	--------	-------	------

Comment:

CID: Client ID LOQ: Limit of Quantitation

H: Sample result exceeds applicable regulatory limit.

Appendix D

Frank G. Lindsey Elementary School

Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
0001-1	Room B4	SK	N/A		5/7/2025	-	-	-	Sign
0001-2	Room B4	WF	App		5/7/2025				Removed from Service
0002-1	Girl's Bathroom by Room B1 (left)	SK	App	<1.0	5/7/2025	-	-	-	-
0002-2	Girl's Bathroom by Room B1 (right)	SK	App	1.0	5/7/2025	-	-	-	-
0003-1	Hall by Room B1	WF	App	1.0	5/7/2025	-	-	-	-
0004-1	Boy's Bathroom by Room B1 (left)	SK	App	1.0	5/7/2025	-	-	-	-
0004-2	Boy's Bathroom by Room B1 (right)	SK	App	<1.0	5/7/2025	-	-	-	-
0005-1	Boiler Room	SS	N/A		5/7/2025	-	-	-	Sign
0006-1	Art Room Counter @ A	SK	N/A		5/7/2025	-	-	-	Sign
0006-2	Art Room Counter @ B	SK	N/A		5/7/2025	-	-	-	Sign
0006-3	Art Room Counter @ C	SK	N/A		5/7/2025	-	-	-	Sign
0006-4	Art Room Counter @ D	SK	N/A		5/7/2025	-	-	-	Sign
0006-5	Art Room Counter @ E	SK	N/A		5/7/2025	-	-	-	Sign
0006-6	Art Room Counter @ F	SK	N/A		5/7/2025	-	-	-	Sign
1001-1	Nurse's Office	SK	App	2.0	5/7/2025	-	-	-	-
1001-2	Nurse's Office Bathroom	SK	App	3.0	5/7/2025	-	-	-	-
1001-3	Nurse's Office Exam Room	SK	App	10.0	5/7/2025				Removed from Service; Pending Remediation
1002-1	Faculty Room	SK	App	<1.0	5/7/2025	-	-	-	-

Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
1002-2	Faculty Room Bathroom	SK	N/A		5/7/2025	-	-	-	Sign
1003-1	Main Office Bathroom	SK	N/A		5/7/2025	-	-	-	Sign
1004-1	Hall by Main Office	WF	App		5/7/2025				Removed from Service
1005-1	Men's Bathroom by Main Office	SK	N/A		5/7/2025	-	-	-	Mixed Valve; Sign
1006-1	Women's Bathroom by Main Office	SK	N/A		5/7/2025	-	-	-	Mixed Valve; Sign
1007-1	Kitchen Island	SK	App	<1.0	5/7/2025	-	-	-	-
1007-2	Kitchen Ice Machine	IM	N/A		5/7/2025	-	-	-	Removed from Service
1007-3	Kitchen 3-Bay (left)	SK	N/A		5/7/2025	-	-	-	Sign
1007-4	Kitchen 3-Bay (left)	SPY	N/A		5/7/2025	-	-	-	Sign
1007-5	Kitchen 3-Bay (right)	SK	N/A		5/7/2025	-	-	-	Sign
1007-6	Kitchen Handwash	SK	N/A		5/7/2025	-	-	-	Sign
1008-1	Custodial Alcove by Kitchen	SS	N/A		5/7/2025	-	-	-	Sign
1010-1	Hall by Room SP1	WF	App	<1.0	5/7/2025	-	-	-	-
1010-2	Hall by Room SP1	BF	App	<1.0	5/7/2025	-	-	-	-
1011-1	Room SP1	SS	N/A		5/7/2025	-	-	-	Sign
1012-1	Custodial Office	SK	N/A		5/7/2025	-	-	-	Sign
1013-1	Room 6	SK	N/A		5/7/2025	-	-	-	Sign
1013-2	Room 6	WF	App		5/7/2025				Removed from Service

Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
1014-1	Room 7	SK	N/A		5/7/2025	-	-	-	Sign
1015-1	Room 8	SK	N/A		5/7/2025	-	-	-	Sign
1016-1	Room 9	SK	N/A		5/7/2025	-	-	-	Sign
1016-2	Room 9	WF	App		5/7/2025	-	-	-	Removed from Service
1017-1	Room 10	SK	N/A		5/7/2025	-	-	-	Sign
1017-2	Room 10	SPY	N/A		5/7/2025	-	-	-	Sign
1018-1	Room 5	SK	N/A		5/7/2025	-	-	-	Sign
1018-2	Room 5 Bathroom (left)	SK	N/A		5/7/2025	-	-	-	Sign
1018-3	Room 5 Bathroom (right)	SK	N/A		5/7/2025	-	-	-	Sign
1018-4	Room 5	WF	App		5/7/2025				Removed from Service
1019-1	Room 4	SK	N/A		5/7/2025	-	-	-	Sign
1019-2	Room 4 Bathroom (left)	SK	N/A		5/7/2025	-	-	-	Sign
1019-3	Room 4 Bathroom (right)	SK	N/A		5/7/2025	-	-	-	Sign
1019-4	Room 4	WF	App	2.0	5/7/2025	-	-	-	-
1020-1	Room 3	SK	N/A		5/7/2025	-	-	-	Sign
1020-2	Room 3 Bathroom	SK	N/A		5/7/2025	-	-	-	Sign
1020-3	Room 3	WF	App		5/7/2025				Removed from Service
1021-1	Room 2	SK	N/A		5/7/2025	-	-	-	Sign

Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
1021-2	Room 2 Bathroom (left)	SK	N/A		5/7/2025	-	-	-	Sign
1021-3	Room 2 Bathroom (right)	SK	N/A		5/7/2025	-	-	-	Sign
1021-4	Room 2	WF	N/A		5/7/2025	-	-	-	Removed from Service
1022-1	Room 1	SK	N/A		5/7/2025	-	-	-	Sign
1022-2	Room 1 Bathroom (left)	SK	N/A		5/7/2025	-	-	-	Sign
1022-3	Room 1 Bathroom (right)	SK	N/A		5/7/2025	-	-	-	Sign
1022-4	Room 1	WF	N/A		5/7/2025	-	-	-	Removed from Service
1023-1	Room SW1	SK	N/A		5/7/2025	-	-	-	Sign
1024-1	Psychologist's Suite Bathroom	SK	App	<1.0	5/7/2025	-	-	-	-
1025-1	Old Boy's Locker Room	SK	App		5/7/2025				Removed from Service
1026-1	Hall by Room 11	WF	App	<1.0	5/7/2025	-	-	-	-
1026-2	Hall by Room 11	BF	App	<1.0	5/7/2025	-	-	-	-
1027-1	Room 11	SK	N/A		5/7/2025	-	-	-	Sign
1027-2	Room 11	WF	App		5/7/2025				Removed from Service
1028-1	Room 12	SK	N/A		5/7/2025	-	-	-	Sign
1028-2	Room 12	WF	App		5/7/2025				Removed from Service
1029-1	Girl's Bathroom (left)	SK	N/A		5/7/2025	-	-	-	Mixed Valve; Sign
1029-2	Girl's Bathroom (right)	SK	N/A		5/7/2025	-	-	-	Mixed Valve; Sign

Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
1030-1	Hall by Room 13	WF	App	<1.0	5/7/2025	-	-	-	-
1030-2	Hall by Room 13	BF	App	<1.0	5/7/2025	-	-	-	-
1031-1	Boy's Bathroom by Room 13 (left)	SK	N/A		5/7/2025	-	-	-	Mixed Valve; Sign
1031-2	Boy's Bathroom by Room 13 (right)	SK	N/A		5/7/2025	-	-	-	Mixed Valve; Sign
1032-1	Room 13	SK	N/A		5/7/2025	-	-	-	Sign
1032-2	Room 13	WF	App		5/7/2025				Removed from Service
1033-1	Room 17	SK	N/A		5/7/2025	-	-	-	Sign
1033-2	Room 17	WF	App		5/7/2025				Removed from Service
1034-1	Custodial Closet by Room 13	SS	N/A		5/7/2025	-	-	-	Sign
1035-1	Room 14	SK	N/A		5/7/2025	-	-	-	Sign
1035-2	Room 14	WF	App	12.0	5/7/2025				Removed from Service; Pending Remediation
1036-1	Room 18	SK	N/A		5/7/2025	-	-	-	Sign
1036-2	Room 18	WF	App	1.0	5/7/2025	-	-	-	-
1037-1	Room 15	SK	N/A		5/7/2025	-	-	-	Sign
1037-2	Room 15	WF	App	<1.0	5/7/2025	-	-	-	-
1038-1	Room 16	SK	N/A		5/7/2025	-	-	-	Sign
1038-2	Room 16	WF	App		5/7/2025				Removed from Service
1039-1	Room 19	SK	App	<1.0	5/7/2025	-	-	-	-

Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
1039-2	Room 19	SPY	App	<1.0	5/7/2025	-	-	-	-
2001-1	Room 28	SK	N/A		5/7/2025	-	-	-	Sign
2002-1	Room 25	SK	N/A		5/7/2025	-	-	-	Sign
2002-2	Room 25	WF	App		5/7/2025				Removed from Service
2003-1	Room 24	SK	N/A		5/7/2025	-	-	-	Sign
2003-2	Room 24	WF	App	<1.0	5/7/2025	-	-	-	-
2004-1	Room 27	SK	N/A		5/7/2025	-	-	-	Sign
2005-1	Room 23	SK	N/A		5/7/2025	-	-	-	Sign
2005-2	Room 23	WF	App		5/7/2025				Removed from Service
2006-1	Room 26	SK	N/A		5/7/2025	-	-	-	Sign
2007-1	Boy's Bathroom by Room 26 (left)	SK	N/A		5/7/2025	-	-	-	Mixed Valve; Sign
2007-2	Boy's Bathroom by Room 26 (right)	SK	N/A		5/7/2025	-	-	-	Mixed Valve; Sign
2008-1	Custodial Closet by Room 26	SS	N/A		5/7/2025	-	-	-	Sign
2009-1	Girl's Bathroom by Room 26 (left)	SK	N/A		5/7/2025	-	-	-	Mixed Valve; Sign
2009-2	Girl's Bathroom by Room 26 (right)	SK	N/A		5/7/2025	-	-	-	Mixed Valve; Sign
2010-1	Hall by Room 26	WF	App	<1.0	5/7/2025	-	-	-	-
2010-2	Hall by Room 26	BF	App	<1.0	5/7/2025	-	-	-	-
2011-1	Room 22	SK	N/A		5/7/2025	-	-	-	Sign

Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
2011-2	Room 22	WF	App		5/7/2025				Removed from Service
2012-1	Library Office	SK	N/A		5/7/2025	-	-	-	Sign
2013-1	By Fan Room	WF	App		5/7/2025				Removed from Service

Laboratory Report

NYE Report #: 2502038-33296

May 12, 2025

Project Manager
Enviroscience Consultants, Inc.
2150 Smithtown Avenue
Ronkonkoma, NY 11779

Project: Hendrick Hudson Csd; Frank G. Lindsey Elementary School

Dear Project Manager,

Enclosed is the Laboratory Analytical Report for potable water sample(s) received on May 08, 2025. New York Environmental analyzed the samples on May 12, 2025 for Lead (Pb) by EPA Method 200.9 Rev. 2.2.

If there are any questions regarding the analyses, please feel free to contact us at your convenience. New York Environmental is a NELAP accredited laboratory. Attached reported results meet the requirements of the NELAP standards unless otherwise noted.

Samples' analytical results relate only to the samples tested, in the condition received by the laboratory. This report shall not be reproduced except in its entirety without written approval of the laboratory.

We sincerely thank you for your business, and look forward to being of service for your future environmental testing needs.

Sincerely,



Li Tsang, Laboratory Director

Date Collected:	07 May 2025
Date Received:	08 May 2025
Date Analyzed:	12 May 2025

Analytical Method:	EPA 200.9 Rev. 2.2
Analyte, Matrix:	Lead, Potable Water

Lab ID	CID	Sample Location/Description	LOQ	Result	Units	Flag
250508P020	1	Kitchen Island - SK, Initial	0.001	<0.001	mg/L	
250508P021	2	Hall by Room SP1 - WF, Initial	0.001	<0.001	mg/L	
250508P022	3	Hall by Room SP1 - BF, Initial	0.001	<0.001	mg/L	
250508P023	4	Room 4 - WF, initial	0.001	0.002	mg/L	
250508P024	5	Psychologists Suite Bathroom - SK, Initial	0.001	<0.001	mg/L	
250508P025	6	Hall by Room 11 - WF, Initial	0.001	<0.001	mg/L	
250508P026	7	Hall By Room 11 - BF, Initial	0.001	<0.001	mg/L	
250508P027	8	Hall by Room 13 - WF, Initial	0.001	<0.001	mg/L	
250508P028	9	Hall by Room 13 - BF, initial	0.001	<0.001	mg/L	
250508P029	10	Room 14 - WF, INitial	0.001	0.012	mg/L	H
250508P030	11	Room 18 - WF, Initial	0.001	0.001	mg/L	
250508P031	12	Room 15 - WF, Initial	0.001	<0.001	mg/L	
250508P032	13	Room 19 - SK, Initial	0.001	<0.001	mg/L	
250508P033	14	Room 19 - SPY, Initial	0.001	<0.001	mg/L	
250508P034	15	Room 24 - WF, Initial	0.001	<0.001	mg/L	
250508P035	16	Hall by Room 26 - WF, Initial	0.001	<0.001	mg/L	
250508P036	17	Hall by Room 26 - BF, Initial	0.001	<0.001	mg/L	
250508P037	18	Girls Bathroom by Room B1 (left) - SK, Initial	0.001	<0.001	mg/L	
250508P038	19	Girls Bathroom by Room B1 (Right) - SK, Initial	0.001	0.001	mg/L	
250508P039	20	Hall by Room B1 - WF, Initial	0.001	0.001	mg/L	
250508P040	21	Boys Bathroom By room B1 (Left) - SK, Initial	0.001	0.001	mg/L	
250508P041	22	Boys Bathroom By room B1 (Right) - SK, Initial	0.001	<0.001	mg/L	
250508P042	23	Faculty Room - SK, Initial	0.001	<0.001	mg/L	
250508P043	24	Nurses Office - SK, Initial	0.001	0.002	mg/L	
250508P044	25	Nurses Office Bathroom - SK, Initial	0.001	0.003	mg/L	
250508P045	26	Nurses Office Exam Room - Sk, Initial	0.001	0.010	mg/L	H

Date Collected:	07 May 2025
Date Received:	08 May 2025
Date Analyzed:	12 May 2025

Analytical Method:	EPA 200.9 Rev. 2.2
Analyte, Matrix:	Lead, Potable Water

Lab ID	CID	Sample Location/Description	LOQ	Result	Units	Flag
--------	-----	-----------------------------	-----	--------	-------	------

Comment:

CID: Client ID LOQ: Limit of Quantitation

H: Sample result exceeds applicable regulatory limit.



Appendix E

Furnace Woods Elementary School

Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
1001-1	Custodial Office Bathroom	SK	N/A		5/8/2025	-	-	-	Sign
1002-1	Custodial Closet by Kitchen	SS	N/A		5/8/2025	-	-	-	Sign
1003-1	Kitchen Staff Bathroom	SK	N/A		5/8/2025	-	-	-	Mixed Valve; Sign
1003-2	Kitchen Island	SK	App	1.0	5/8/2025	-	-	-	-
1003-3	Kitchen 3-Bay (left)	SK	N/A		5/8/2025	-	-	-	Sign
1003-4	Kitchen 3-Bay (center)	SPY	N/A		5/8/2025	-	-	-	Sign
1003-5	Kitchen 3-Bay (right)	SK	N/A		5/8/2025	-	-	-	Sign
1003-6	Dishwashing Station	SK	N/A		5/8/2025	-	-	-	Sign
1004-1	Boy's Locker Room Vestibule	WF	App	1.0	5/8/2025	-	-	-	-
1004-2	Boy's Locker Room Vestibule	BF	App	<1.0	5/8/2025	-	-	-	-
1005-1	Boy's Locker Room Rear Bathroom	SK	App	18.0	5/8/2025				Removed From Service
1006-1	Custodial Closet by Gym	SS	N/A		5/8/2025	-	-	-	Sign
1007-1	Custodial Closet by Cafeteria	SS	N/A		5/8/2025	-	-	-	Sign
1008-1	Room 20	SK	N/A		5/8/2025	-	-	-	Sign
1008-2	Room 20	WF	N/A		5/8/2025	-	-	-	Removed From Service
1009-1	Room 22	SK	N/A		5/8/2025	-	-	-	Sign
1009-2	Room 22	WF	App		5/8/2025				Removed From Service
1010-1	Room 24	SK	N/A		5/8/2025	-	-	-	Sign

Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
1010-2	Room 24	WF	N/A		5/8/2025	-	-	-	Removed From Service
1011-1	Room 26	SK	N/A		5/8/2025	-	-	-	Sign
1011-2	Room 26	WF	N/A		5/8/2025	-	-	-	Removed From Service
1012-1	Room 28	SK	N/A		5/8/2025	-	-	-	Sign
1012-2	Room 28	WF	N/A		5/8/2025	-	-	-	Removed From Service
1013-1	Room 30	SK	N/A		5/8/2025	-	-	-	Sign
1013-2	Room 30	WF	N/A		5/8/2025	-	-	-	Removed From Service
1014-1	Room 29	SK	N/A		5/8/2025	-	-	-	Sign
1014-2	Room 29	WF	N/A		5/8/2025	-	-	-	Removed From Service
1015-1	Room 27	SK	N/A		5/8/2025	-	-	-	Sign
1015-2	Room 27	WF	N/A		5/8/2025	-	-	-	Removed From Service
1016-1	Room 25	SK	N/A		5/8/2025	-	-	-	Sign
1016-2	Room 25	WF	N/A		5/8/2025	-	-	-	Removed From Service
1017-1	Room 23	SK	N/A		5/8/2025	-	-	-	Sign
1017-2	Room 23	WF	N/A		5/8/2025	-	-	-	Removed From Service
1018-1	Room 21	SK	N/A		5/8/2025	-	-	-	Sign
1018-2	Room 21	WF	App		5/8/2025				Removed From Service
1019-1	Boy's Bathroom by Room 22 @ A	SK	N/A		5/8/2025	-	-	-	Mixed Valve; Sign

Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
1019-2	Boy's Bathroom by Room 22 @ B	SK	N/A		5/8/2025	-	-	-	Mixed Valve; Sign
1019-3	Boy's Bathroom by Room 22 @ C	SK	N/A		5/8/2025	-	-	-	Mixed Valve; Sign
1019-4	Boy's Bathroom by Room 22 @ D	SK	N/A		5/8/2025	-	-	-	Mixed Valve; Sign
1020-1	Custodial Closet by Room 22	SS	N/A		5/8/2025	-	-	-	Sign
1021-1	Girl's Bathroom by Room @ Left	SK	N/A	<1.0	5/8/2025	-	-	-	-
1021-2	Girl's Bathroom by Room @ Left Middle	SK	N/A	<1.0	5/8/2025	-	-	-	-
1021-3	Girl's Bathroom by Room @ Right Middle	SK	N/A	1.0	5/8/2025	-	-	-	-
1021-4	Girl's Bathroom by Room @ Right	SK	N/A	3.0	5/8/2025	-	-	-	-
1022-1	Women's Bathroom by Art Room (left)	SK	N/A		5/8/2025	-	-	-	Sign
1022-2	Women's Bathroom by Art Room (right)	SK	N/A		5/8/2025	-	-	-	Sign
1023-1	Men's Bathroom by Art Room (left)	SK	N/A		5/8/2025	-	-	-	Sign
1023-2	Men's Bathroom by Art Room (right)	SK	N/A		5/8/2025	-	-	-	Sign
1024-1	Art Room (front)	SK	N/A		5/8/2025	-	-	-	Sign
1024-2	Art Room (rear)	SK	N/A		5/8/2025	-	-	-	Sign
1025-1	Library	SK	N/A		5/8/2025	-	-	-	Sign
1025-2	Library	SPY	N/A		5/8/2025	-	-	-	Sign
1026-1	ADA Bathroom by Staff Room	SK	N/A		5/8/2025	-	-	-	Sign
1027-1	Staff Room Bathroom	SK	N/A		5/8/2025	-	-	-	Sign

Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
1027-2	Staff Room	SK	App	8.0	5/8/2025				Removed From Service; Pending Remediation
1027-3	Staff Room	SPY	N/A		5/8/2025	-	-	-	Removed From Service
1028-1	Room 7	SK	N/A		5/8/2025	-	-	-	Sign
1029-1	Room 9	SK	N/A		5/8/2025	-	-	-	Sign
1030-1	Room 11	SK	N/A		5/8/2025	-	-	-	Sign
1031-1	Room 13	SK	N/A		5/8/2025	-	-	-	Sign
1031-2	Room 13	WF	N/A		5/8/2025	-	-	-	Removed From Service
1032-1	Room 14	SK	N/A		5/8/2025	-	-	-	Sign
1032-2	Room 14	WF	N/A		5/8/2025	-	-	-	Removed From Service
1033-1	Room 12	SK	N/A		5/8/2025	-	-	-	Sign
1034-1	Room 10	SK	N/A		5/8/2025	-	-	-	Sign
1035-1	Room 8	SK	N/A		5/8/2025	-	-	-	Sign
1035-2	Room 8	WF	N/A		5/8/2025	-	-	-	Removed From Service
1036-1	Nurse's Office	SK	App	1.0	5/8/2025	-	-	-	-
1036-2	Nurse's Office Bathroom	SK	App	4.0	5/8/2025	-	-	-	-
1037-1	Main Office Bathroom	SK	N/A		5/8/2025	-	-	-	Sign
1037-2	Main Office	WF	App	<1.0	5/8/2025	-	-	-	-
1037-3	Main Office	BF	App	<1.0	5/8/2025	-	-	-	-

Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
1038-1	Room 4	SK	N/A		5/8/2025	-	-	-	Sign
1039-1	Room 3	SK	N/A		5/8/2025	-	-	-	Sign
1039-2	Room 3	WF	N/A		5/8/2025	-	-	-	Removed From Service
1039-3	Room 3 Bathroom	SK	App	170.0	5/8/2025				Removed From Service; Pending Remediation
1040-1	Room 2	SK	N/A		5/8/2025	-	-	-	Sign
1040-2	Room 2	WF	N/A		5/8/2025	-	-	-	Removed From Service
1040-3	Room 2 Bathroom	SK	App	47.0	5/8/2025				Removed From Service; Pending Remediation
1041-1	Room 1	SK	N/A		5/8/2025	-	-	-	Sign
1041-2	Room 1	WF	N/A		5/8/2025	-	-	-	Removed From Service
1041-3	Room 1 Bathroom	SK	App	130.0	5/8/2025				Removed From Service; Pending Remediation
1042-1	Cafeteria	BF	App	2.0	5/8/2025	-	-	-	-
1042-2	Cafeteria	WF	App	<1.0	5/8/2025	-	-	-	-

Laboratory Report

NYE Report #: 2502037-33295

May 12, 2025

Project Manager
Enviroscience Consultants, Inc.
2150 Smithtown Avenue
Ronkonkoma, NY 11779

Project: Hendrick Hudson Csd; Furnace Woods Elementary School

Dear Project Manager,

Enclosed is the Laboratory Analytical Report for potable water sample(s) received on May 08, 2025. New York Environmental analyzed the samples on May 12, 2025 for Lead (Pb) by EPA Method 200.9 Rev. 2.2.

If there are any questions regarding the analyses, please feel free to contact us at your convenience. New York Environmental is a NELAP accredited laboratory. Attached reported results meet the requirements of the NELAP standards unless otherwise noted.

Samples' analytical results relate only to the samples tested, in the condition received by the laboratory. This report shall not be reproduced except in its entirety without written approval of the laboratory.

We sincerely thank you for your business, and look forward to being of service for your future environmental testing needs.

Sincerely,



Li Tsang, Laboratory Director

Date Collected:	08 May 2025
Date Received:	08 May 2025
Date Analyzed:	12 May 2025

Analytical Method:	EPA 200.9 Rev. 2.2
Analyte, Matrix:	Lead, Potable Water

Lab ID	CID	Sample Location/Description	LOQ	Result	Units	Flag
250508P002	1	Kitchen Island - Sk, Initial	0.001	0.001	mg/L	
250508P003	2	Boys Locker room Vestible - BF, Initial	0.001	<0.001	mg/L	
250508P004	3	Boys Locker room Vestible - WF, Initial	0.001	0.001	mg/L	
250508P005	4	Boys Locker room Rear Bathroom - SK, Initial	0.001	0.018	mg/L	H
250508P006	5	Girls Bathroom by Room @ Left - SK, Initial	0.001	<0.001	mg/L	
250508P007	6	Girls Bathroom By Room @ Left Middle - SK, Initial	0.001	<0.001	mg/L	
250508P008	7	Girls Bathroom By Room @ Right Middle - SK, Initial	0.001	0.001	mg/L	
250508P009	8	Girls Bathroom By Room @ Right - SK, Initial	0.001	0.003	mg/L	
250508P010	9	Staff Room - SK, Initial	0.001	0.008	mg/L	H
250508P011	10	Nurses Office - SK, Initial	0.001	0.001	mg/L	
250508P012	11	Nurses Office Bathroom - SK, Initial	0.001	0.004	mg/L	
250508P013	12	Main Office - WF, Initial	0.001	<0.001	mg/L	
250508P014	13	Main Office - BF, Initial	0.001	<0.001	mg/L	
250508P015	14	Room 3 Bathroom - SK, Initial	0.001	0.170	mg/L	E,H
250508P016	15	Room 2 Bathroom - SK, Initial	0.001	0.047	mg/L	H
250508P017	16	Room 1 Bathroom - SK, Initial	0.001	0.130	mg/L	E,H
250508P018	17	Cafeteria - BF, initial	0.001	0.002	mg/L	
250508P019	18	Cafeteria - WF, Initial	0.001	<0.001	mg/L	

Comment:

CID: Client ID LOQ: Limit of Quantitation

NA: Sample not analyzed per customer request.

E: Sample result exceeds instrument calibration, value is estimated.

H: Sample result exceeds applicable regulatory limit.

Appendix F

Administration Building

Fixture #	Sample Location	Fixture Type	App or N/A	Latest 1 st Draw Results (ppb)	Latest 1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remarks
1000-1	Outdoor Spigot on Corner by Field	HB	App	2.0	5/8/2025	-	-	-	-

Laboratory Report

NYE Report #: 2502036-33294

May 12, 2025

Project Manager
Enviroscience Consultants, Inc.
2150 Smithtown Avenue
Ronkonkoma, NY 11779

Project: Henrick Hudson Csd; Administration Building

Dear Project Manager,


Enclosed is the Laboratory Analytical Report for potable water sample(s) received on May 08, 2025. New York Environmental analyzed the samples on May 12, 2025 for Lead (Pb) by EPA Method 200.9 Rev. 2.2.

If there are any questions regarding the analyses, please feel free to contact us at your convenience. New York Environmental is a NELAP accredited laboratory. Attached reported results meet the requirements of the NELAP standards unless otherwise noted.

Samples' analytical results relate only to the samples tested, in the condition received by the laboratory. This report shall not be reproduced except in its entirety without written approval of the laboratory.

We sincerely thank you for your business, and look forward to being of service for your future environmental testing needs.

Sincerely,



Li Tsang, Laboratory Director

Date Collected:	08 May 2025
Date Received:	08 May 2025
Date Analyzed:	12 May 2025

Analytical Method:	EPA 200.9 Rev. 2.2
Analyte, Matrix:	Lead, Potable Water

<u>Lab ID</u>	<u>CID</u>	<u>Sample Location/Description</u>	<u>LOQ</u>	<u>Result</u>	<u>Units</u>	<u>Flag</u>
250508P001	1	Outdoor Spigot on Corner by Field - HB, Initial	0.001	0.002	mg/L	

Comment:

CID: Client ID LOQ: Limit of Quantitation