



### CERTIFICATE OF ANALYSIS

**Customer :** Garden State Environmental  
555 South Broad Street, Suite K  
Glen Rock, NJ 07452

**Project ID :** Rahway Madison Elementary School (9248) 944 Madison Ave, Rahway, NJ  
**PAS Project ID :** P25-03566

**Matrix :** Drinking Water  
**Report Date :** 5/20/2025

PAS Sample ID	Client ID	Analysis	Results	Units	DF	PQL	MDL	MCL	Method	Date Sampled	Date Analyzed
P25-03566-01	MAD-1-S17A	Lead	1490	ug/L	250	500	225	15.0 *	SM 3113 B	4/23/25 13:59	5/8/25 20:24
P25-03566-02	MAD-1-S18A	Lead	67.7	ug/L	5	10.0	4.50	15.0 *	SM 3113 B	4/23/25 14:01	5/8/25 20:29
P25-03566-03	MAD-1-H01A	Lead	57.2	ug/L	5	10.0	4.50	15.0 *	SM 3113 B	4/23/25 14:04	5/8/25 20:33
P25-03566-04	MAD-1-S20A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/23/25 14:07	5/8/25 20:37
P25-03566-05	MAD-1-F4A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/23/25 14:10	5/8/25 20:42
P25-03566-06	MAD-1-BF01A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/23/25 14:12	5/8/25 20:46
P25-03566-07	MAD-1-F1A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/23/25 14:14	5/8/25 20:51
P25-03566-08	MAD-1-BF02A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/23/25 14:16	5/8/25 20:55
P25-03566-09	MAD-1-F2A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/23/25 14:20	5/8/25 21:00
P25-03566-10	MAD-1-F3A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/23/25 14:23	5/8/25 21:18
P25-03566-11	MAD-1-F5A	Lead	1.15 J	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/23/25 14:29	5/8/25 21:23
P25-03566-12	MAD-1-F6A	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/23/25 14:33	5/8/25 21:27
P25-03566-13	MAD-4-23-FBA	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	4/23/25 14:34	5/8/25 21:32

Except for the parameters tested, York Analytical makes no representation as to the fitness or quality of the water sample taken.

PQL = Practical Quantitation Limit  
MDL = Minimum Detection Limit  
MCL = Maximum Contaminant Level  
DF = Dilution Factor  
ND = Analyzed for but not detected  
J = Estimated result

\* NJ Dept of Education & Dept of Children & Families Action Level

All samples are analyzed in accordance with  
New Jersey Department of Environmental  
Protection Protocol

Kelly Hogan - Quality Assurance Officer