

Client Sample ID:	BOSGRL (L)	Collected By:	Todd Brant
Sample Matrix:	Drinking Water	Collection Date:	05/06/2025 5:34
Lab Sample ID:	S5E0311-58		

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0134	0.0050 AL	0.0010	mg/L		05/14/25 1724	05/14/25 2254	DLO

Client Sample ID:	BOSGRL (R)	Collected By:	Todd Brant
Sample Matrix:	Drinking Water	Collection Date:	05/06/2025 5:35
Lab Sample ID:	S5E0311-60		

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0113	0.0050 AL	0.0010	mg/L		05/14/25 1724	05/14/25 2257	DLO

Client Sample ID:	BOSBL	Collected By:	Todd Brant
Sample Matrix:	Drinking Water	Collection Date:	05/06/2025 5:36
Lab Sample ID:	S5E0311-61		

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0571	0.0050 AL	0.0010	mg/L		05/15/25 1221	05/15/25 1530	DLO

Client Sample ID:	MR132	Collected By:	Todd Brant
Sample Matrix:	Drinking Water	Collection Date:	05/06/2025 5:05
Lab Sample ID:	S5E0311-22		

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0091	0.0050 AL	0.0010	mg/L		05/14/25 1723	05/14/25 2134	DLO

Client Sample ID:	SOS	Collected By:	Todd Brant
Sample Matrix:	Drinking Water	Collection Date:	05/06/2025 4:53
Lab Sample ID:	S5E0311-12		

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0055	0.0050 AL	0.0010	mg/L		05/14/25 1722	05/14/25 2107	DLO