



# Garden State Laboratories, Inc.

## Report of Analysis

410 Hillside Ave.  
Hillside, NJ 07205

Main Lab  
NJDEP Lab Cert. #20044

Jersey Shore Lab  
NJDEP Lab Cert. #15037

Lakehurst Lab  
NJDEP Lab Cert. #15041

Mathew Klein, M.S., Founder (1916-1996)  
Harvey Klein, M.S., Laboratory Director  
Jordan B. Klein, B.A., Exec. Vice President  
Sharon Ercoliani, B.A. Manager Emerita

Telephone: 800-273-8901  
Email: info@gsllabs.com  
Internet: www.gsllabs.com

For: Tuckerton BOE - Elementary School  
213 Marine St.

Tuckerton, NJ 08087

Laboratory Director:

Report Date: 06/05/2025

Attention: Brian Mathis

Client Number: TUC06

Sample ID: Art Room Eye Wash Sink  
Tuckerton Elementary School

Lab Sample ID: 250522073-01

Site: Collection Date/Time: 05/20/2025 05:47

Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9		1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	05/31/25 14:58	

Sample ID: Steam Room Sink Right of Door  
Tuckerton Elementary School

Lab Sample ID: 250522073-02

Site: Collection Date/Time: 05/20/2025 05:51

Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9		1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	06/02/25 16:16	

Sample ID: Steam Room Sink Left of Door  
Tuckerton Elementary School

Lab Sample ID: 250522073-03

Site: Collection Date/Time: 05/20/2025 05:50

Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9		1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	06/02/25 16:25	

Sample ID: Hall Teach. Room - Sink  
Tuckerton Elementary School

Lab Sample ID: 250522073-04

Site: Collection Date/Time: 05/20/2025 05:57

Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9		1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	06/02/25 16:27	



Garden State Laboratories, Inc.

Sample ID: Teach Rm. - Water Fountain Left Tuckerton Elementary School Lab Sample ID: 250522073-05  
 Site: Collection Date/Time: 05/20/2025 05:54  
 Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9		1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	06/02/25 16:36	

Sample ID: Kitchen - Dishwash Sink Tuckerton Elementary School Lab Sample ID: 250522073-06  
 Site: Collection Date/Time: 05/20/2025 03:17  
 Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9		1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	06/02/25 16:39	

Sample ID: Kitchen - Lg. Prep Sink Tuckerton Elementary School Lab Sample ID: 250522073-07  
 Site: Collection Date/Time: 05/20/2025 03:16  
 Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9		1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	06/02/25 16:41	

Sample ID: Kitchen - Small Prep Sink Tuckerton Elementary School Lab Sample ID: 250522073-08  
 Site: Collection Date/Time: 05/20/2025 03:15  
 Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9		1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	06/03/25 11:19	

Sample ID: Kitchen - Handwash Sink Tuckerton Elementary School Lab Sample ID: 250522073-09  
 Site: Collection Date/Time: 05/20/2025 03:14  
 Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9		1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	06/03/25 11:22	

Sample ID: Kitchen - Bath Sink Tuckerton Elementary School Lab Sample ID: 250522073-10  
 Site: Collection Date/Time: 05/20/2025 03:12  
 Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9		1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	06/03/25 11:30	



Garden State Laboratories, Inc.

Sample ID: Top Floor Old Section - Water Fountain Tuckerton Elementary School  
 Lab Sample ID: 250522073-11

Site: Collection Date/Time: 05/20/2025 05:21

Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9		1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	06/03/25 11:33	

Sample ID: Rm 404 - Sink Tuckerton Elementary School  
 Lab Sample ID: 250522073-12

Site: Collection Date/Time: 05/20/2025 05:19

Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9		1	0.00147 mg/l	0.015	0.00100	0.00055	20044	06/03/25 11:36	

Sample ID: Rm 405 - Sink Tuckerton Elementary School  
 Lab Sample ID: 250522073-13

Site: Collection Date/Time: 05/20/2025 05:25

Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9		1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	06/03/25 11:39	

Sample ID: Rm 406 - Sink Tuckerton Elementary School  
 Lab Sample ID: 250522073-14

Site: Collection Date/Time: 05/20/2025 05:27

Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9		1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	06/03/25 11:42	

Sample ID: Art Room Sink Tuckerton Elementary School  
 Lab Sample ID: 250522073-15

Site: Collection Date/Time: 05/20/2025 05:46

Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9		1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	06/03/25 11:50	

Sample ID: Rm 106 - Water Fountain Tuckerton Elementary School  
 Lab Sample ID: 250522073-16

Site: Collection Date/Time: 05/20/2025 04:03

Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9		1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	06/03/25 11:53	



Garden State Laboratories, Inc.

Sample ID: Rm 205 - Bath Sink Tuckerton Elementary School      Lab Sample ID: 250522073-17  
 Site:      Collection Date/Time: 05/20/2025 04:27  
 Matrix: Potable water      Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9		1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	06/03/25 11:56	

Sample ID: Rm 206 - Bath Sink Tuckerton Elementary School      Lab Sample ID: 250522073-18  
 Site:      Collection Date/Time: 05/20/2025 04:19  
 Matrix: Potable water      Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9		1	0.00254 mg/l	0.015	0.00100	0.00055	20044	06/03/25 11:59	

Sample ID: Rm 200 - Sink Tuckerton Elementary School      Lab Sample ID: 250522073-19  
 Site:      Collection Date/Time: 05/20/2025 04:49  
 Matrix: Potable water      Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9		1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	06/03/25 12:01	

Sample ID: Rm 200 - Water Fountain Tuckerton Elementary School      Lab Sample ID: 250522073-20  
 Site:      Collection Date/Time: 05/20/2025 04:51  
 Matrix: Potable water      Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9		1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	06/03/25 12:04	

Sample ID: Nurses - Work Sink Tuckerton Elementary School      Lab Sample ID: 250522073-21  
 Site:      Collection Date/Time: 05/20/2025 06:10  
 Matrix: Potable water      Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9		1	0.00183 mg/l	0.015	0.00100	0.00055	20044	06/03/25 12:07	

Sample ID: Main Floor Boys - Left Sink Tuckerton Elementary School      Lab Sample ID: 250522073-22  
 Site:      Collection Date/Time: 05/20/2025 06:17  
 Matrix: Potable water      Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9		1	0.00277 mg/l	0.015	0.00100	0.00055	20044	06/03/25 12:10	



Sample ID: Main Floor Boys - Right Sink  
Tuckerton Elementary School      Lab Sample ID: 250522073-23

Site:      Collection Date/Time: 05/20/2025 06:18

Matrix: Potable water      Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9		1	0.00695 mg/l	0.015	0.00100	0.00055	20044	06/03/25 12:13	

Sample ID: Main Floor Girls - Left Sink  
Tuckerton Elementary School      Lab Sample ID: 250522073-24

Site:      Collection Date/Time: 05/20/2025 06:22

Matrix: Potable water      Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9		1	0.00317 mg/l	0.015	0.00100	0.00055	20044	06/03/25 12:15	

Sample ID: Main Floor Girls - Right Sink  
Tuckerton Elementary School      Lab Sample ID: 250522073-25

Site:      Collection Date/Time: 05/20/2025 06:23

Matrix: Potable water      Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9		1	0.00328 mg/l	0.015	0.00100	0.00055	20044	06/03/25 12:27	

Sample ID: Cafe Hall - Water Fountain  
Tuckerton Elementary School      Lab Sample ID: 250522073-26

Site:      Collection Date/Time: 05/20/2025 03:21

Matrix: Potable water      Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9		1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	06/03/25 12:30	

Sample ID: Cafe Hall - Boys Rm Sink  
Tuckerton Elementary School      Lab Sample ID: 250522073-27

Site:      Collection Date/Time: 05/20/2025 03:23

Matrix: Potable water      Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9		1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	06/03/25 12:35	

Sample ID: Cafe Hall - Girls Rm Sink  
Tuckerton Elementary School      Lab Sample ID: 250522073-28

Site:      Collection Date/Time: 05/20/2025 03:26

Matrix: Potable water      Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9		1	0.00107 mg/l	0.015	0.00100	0.00055	20044	06/03/25 12:44	



Garden State Laboratories, Inc.

Sample ID: Primary Hall - Water Fountain Tuckerton Elementary School  
 Lab Sample ID: 250522073-29  
 Site: Collection Date/Time: 05/20/2025 03:30  
 Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9		1	0.00266 mg/l	0.015	0.00100	0.00055	20044	06/03/25 12:47	

Sample ID: Rm 101 Sink Tuckerton Elementary School  
 Lab Sample ID: 250522073-30  
 Site: Collection Date/Time: 05/20/2025 03:39  
 Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9		1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	06/03/25 12:50	

Sample ID: Rm 104 - Sink Tuckerton Elementary School  
 Lab Sample ID: 250522073-31  
 Site: Collection Date/Time: 05/20/2025 03:53  
 Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9		1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	06/03/25 12:52	

Sample ID: Rm 104 - Water Fountain Tuckerton Elementary School  
 Lab Sample ID: 250522073-32  
 Site: Collection Date/Time: 05/20/2025 03:55  
 Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9		1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	06/03/25 13:01	

Sample ID: Rm 105 - Sink Tuckerton Elementary School  
 Lab Sample ID: 250522073-33  
 Site: Collection Date/Time: 05/20/2025 03:57  
 Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9		1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	06/03/25 13:04	

Sample ID: Rm 105 - Water Fountain Tuckerton Elementary School  
 Lab Sample ID: 250522073-34  
 Site: Collection Date/Time: 05/20/2025 03:59  
 Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9		1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	06/03/25 13:06	



Garden State Laboratories, Inc.

Sample ID: Rm 106 - Sink Tuckerton Elementary School      Lab Sample ID: 250522073-35  
 Site:      Collection Date/Time: 05/20/2025 04:02  
 Matrix: Potable water      Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9		1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	06/03/25 13:09	

Sample ID: Rm 204 - Class Sink Tuckerton Elementary School      Lab Sample ID: 250522073-36  
 Site:      Collection Date/Time: 05/20/2025 04:37  
 Matrix: Potable water      Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9		1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	06/03/25 13:12	

Sample ID: Rm 204 - Water Fountain Tuckerton Elementary School      Lab Sample ID: 250522073-37  
 Site:      Collection Date/Time: 05/20/2025 04:38  
 Matrix: Potable water      Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9		1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	06/03/25 13:15	

Sample ID: 90s Playground - Water Fountain Left Tuckerton Elementary School      Lab Sample ID: 250522073-38  
 Site:      Collection Date/Time: 05/20/2025 04:56  
 Matrix: Potable water      Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9		1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	06/03/25 13:18	

Sample ID: 90s Playground - Water Fountain Right Tuckerton Elementary School      Lab Sample ID: 250522073-39  
 Site:      Collection Date/Time: 05/20/2025 04:58  
 Matrix: Potable water      Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9		1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	06/03/25 13:21	



Garden State Laboratories, Inc.

Sample ID: Gym Water Fountain - Hall Tuckerton Elementary School  
 Lab Sample ID: 250522073-40  
 Site: Collection Date/Time: 05/20/2025 04:21  
 Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9		1	0.00411 mg/l	0.015	0.00100	0.00055	20044	06/03/25 13:23	

Sample ID: 90s Building Hall Water Fountain Right Tuckerton Elementary School  
 Lab Sample ID: 250522073-41  
 Site: Collection Date/Time: 05/20/2025 05:10  
 Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9		1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	06/03/25 13:26	

Sample ID: 90s Building Girls Rm Left Tuckerton Elementary School  
 Lab Sample ID: 250522073-42  
 Site: Collection Date/Time: 05/20/2025 05:13  
 Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9		1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	06/03/25 13:38	

Sample ID: 90s Building Girls Rm Right Tuckerton Elementary School  
 Lab Sample ID: 250522073-43  
 Site: Collection Date/Time: 05/20/2025 05:14  
 Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9		1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	06/03/25 13:40	

Sample ID: 90s Building Boys Rm Left Tuckerton Elementary School  
 Lab Sample ID: 250522073-44  
 Site: Collection Date/Time: 05/20/2025 05:15  
 Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9		1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	06/03/25 13:43	

Sample ID: 90s Building Boys Rm Right Tuckerton Elementary School  
 Lab Sample ID: 250522073-45  
 Site: Collection Date/Time: 05/20/2025 05:16  
 Matrix: Potable water Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9		1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	06/03/25 13:49	



Garden State Laboratories, Inc.

Sample ID: Girls Gym Bathroom Sink Left  
Tuckerton Elementary School      Lab Sample ID: 250522073-46

Site:      Collection Date/Time: 05/20/2025 04:24

Matrix: Potable water      Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9		1	0.00151 mg/l	0.015	0.00100	0.00055	20044	06/03/25 13:58	

Sample ID: Girls Gym Bathroom Sink Right  
Tuckerton Elementary School      Lab Sample ID: 250522073-47

Site:      Collection Date/Time: 05/20/2025 04:25

Matrix: Potable water      Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9		1	0.00244 mg/l	0.015	0.00100	0.00055	20044	06/03/25 14:01	

Sample ID: Boys Gym Bathroom Sink Left  
Tuckerton Elementary School      Lab Sample ID: 250522073-48

Site:      Collection Date/Time: 05/20/2025 04:14

Matrix: Potable water      Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9		1	0.00120 mg/l	0.015	0.00100	0.00055	20044	06/03/25 14:04	

Sample ID: Boys Gym Bathroom Sink Right  
Tuckerton Elementary School      Lab Sample ID: 250522073-49

Site:      Collection Date/Time: 05/20/2025 04:15

Matrix: Potable water      Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9		1	0.00115 mg/l	0.015	0.00100	0.00055	20044	06/03/25 14:12	

Sample ID: 90s Building Hall Water  
Fountain Left Tuckerton  
Elementary School      Lab Sample ID: 250522073-50

Site:      Collection Date/Time: 05/20/2025 05:09

Matrix: Potable water      Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9		1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	06/03/25 14:15	



Garden State Laboratories, Inc.

Sample ID: Teach Rm - Water Fountain  
Right Tuckerton Elementary  
School      Lab Sample ID: 250522073-51

Site:      Collection Date/Time: 05/20/2025 05:55

Matrix: Potable water      Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9		1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	06/03/25 14:18	

Sample ID: Teach Rm - Sink Tuckerton  
Elementary School      Lab Sample ID: 250522073-52

Site:      Collection Date/Time: 05/20/2025 05:59

Matrix: Potable water      Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9		1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	06/03/25 14:20	

Sample ID: Teach Rm - Bath Sink Tuckerton  
Elementary School      Lab Sample ID: 250522073-53

Site:      Collection Date/Time: 05/20/2025 06:01

Matrix: Potable water      Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9		1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	06/03/25 14:23	

Sample ID: Main Floor Water Fountain  
Tuckerton Elementary School      Lab Sample ID: 250522073-54

Site:      Collection Date/Time: 05/20/2025 06:04

Matrix: Potable water      Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9		1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	06/03/25 14:26	

Sample ID: Nurses Bath Sink Tuckerton  
Elementary School      Lab Sample ID: 250522073-55

Site:      Collection Date/Time: 05/20/2025 06:11

Matrix: Potable water      Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9		1	0.00114 mg/l	0.015	0.00100	0.00055	20044	06/03/25 14:29	

Sample ID: Rm 200 Bath Sink Tuckerton  
Elementary School      Lab Sample ID: 250522073-56

Site:      Collection Date/Time: 05/20/2025 04:52

Matrix: Potable water      Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9		1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	06/03/25 14:32	



Garden State Laboratories, Inc.

Sample ID: Rm 201 - Bath Sink Tuckerton Elementary School      Lab Sample ID: 250522073-57  
 Site:      Collection Date/Time: 05/20/2025 04:46  
 Matrix: Potable water      Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9		1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	06/03/25 14:34	

Sample ID: Rm 201 - Sink Tuckerton Elementary School      Lab Sample ID: 250522073-58  
 Site:      Collection Date/Time: 05/20/2025 04:45  
 Matrix: Potable water      Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9		1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	06/03/25 14:37	

Sample ID: Rm 201 - Water Fountain Tuckerton Elementary School      Lab Sample ID: 250522073-59  
 Site:      Collection Date/Time: 05/20/2025 04:43  
 Matrix: Potable water      Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9		1	0.00116 mg/l	0.015	0.00100	0.00055	20044	06/03/25 14:52	

Sample ID: Rm 204 - Bath Sink Tuckerton Elementary School      Lab Sample ID: 250522073-60  
 Site:      Collection Date/Time: 05/20/2025 04:40  
 Matrix: Potable water      Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9		1	0.00125 mg/l	0.015	0.00100	0.00055	20044	06/03/25 14:54	

Sample ID: Rm 101 - Water Fountain Tuckerton Elementary School      Lab Sample ID: 250522073-61  
 Site:      Collection Date/Time: 05/20/2025 03:40  
 Matrix: Potable water      Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9		1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	06/03/25 14:57	

Sample ID: Rm 102 - Water Fountain Tuckerton Elementary School      Lab Sample ID: 250522073-62  
 Site:      Collection Date/Time: 05/20/2025 03:45  
 Matrix: Potable water      Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9		1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	06/03/25 15:00	



Garden State Laboratories, Inc.

Sample ID: Rm 103 - Sink Tuckerton Elementary School      Lab Sample ID: 250522073-63  
 Site:      Collection Date/Time: 05/20/2025 03:48  
 Matrix: Potable water      Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9		1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	06/03/25 15:06	

Sample ID: Rm 103 - Water Fountain Tuckerton Elementary School      Lab Sample ID: 250522073-64  
 Site:      Collection Date/Time: 05/20/2025 03:50  
 Matrix: Potable water      Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9		1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	06/03/25 15:14	

Sample ID: Field Blank Tuckerton Elementary School      Lab Sample ID: 250522073-65  
 Site:      Collection Date/Time: 05/23/2025 04:52  
 Matrix: Potable water      Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9		1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	06/04/25 12:44	

Sample ID: Rm 102 Sink Tuckerton Elementary School      Lab Sample ID: 250522073-66  
 Site:      Collection Date/Time: 05/23/2025 04:53  
 Matrix: Potable water      Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9		1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	06/04/25 12:47	

Sample ID: Main Floor Girls Handicap Sink Tuckerton Elementary School      Lab Sample ID: 250522073-67  
 Site:      Collection Date/Time: 05/23/2025 05:06  
 Matrix: Potable water      Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9		1	< 0.00100 mg/l	0.015	0.00100	0.00055	20044	06/04/25 12:50	

Sample ID: Main Floor Boys Handicap Sink Tuckerton Elementary School      Lab Sample ID: 250522073-68  
 Site:      Collection Date/Time: 05/23/2025 05:08  
 Matrix: Potable water      Sample Type: Grab

Analyte	Method	SM YR	DF	Sample Result	MCL	Rep. Limit	MDL	Lab Cert No.	Analysis Date/Time	Qualifiers
Lead, Total Recoverable	EPA 200.9		1	0.00111 mg/l	0.015	0.00100	0.00055	20044	06/04/25 12:53	



Garden State Laboratories, Inc.

*DF=Dilution factor; <=less than, MCL=Maximum Contaminant Level, Rep. Limit=Reporting Limit,  
MDL=Method Detection Limit, SM YR=Standard Methods Publication Year, and NC=Not Certified.  
The liability of Garden State Laboratories, Inc. for services rendered shall in no event exceed the amount of the invoice.  
Main Lab certified by NJDEP #20044-TNI, NY Dept. of Health #11550 and PADEP #68-03680.*

# Garden State Laboratories, Inc.

**Main Lab - 410 Hillside Avenue, Hillside NJ 07205 - NJDEP Lab Cert. #20044**

**Jersey Shore Lab - 54 Main Street, Waretown NJ 08758 - NJDEP Lab Cert. #15037**

Tel. 800-273-8901/908-688-8900 Fax 908-688-8966 www.gslabs.com info@gslabs.com

### Office and Drop off Locations

North Jersey Office: 225 Sparta Avenue, Sparta, NJ 07871 Tel. 973-729-1827

West Jersey Office: 2050 Route 31 North, Glen Gardner, NJ 08826 Tel. 908-537-7414

FOR SAMPLE RECEIVING USE ONLY

DATE/TIME/TEMP. REC'D AT LAB:

5/22/25 13:33 NO EDC

Page \_\_\_\_\_ of \_\_\_\_\_

**GSL CLIENT # TUC06**

### CLIENT INFORMATION (REPORT TO BE SENT TO)

Name: Tuckerton Borough BOE Contact/Authorized by: Rebecca Sprague/Brian Matthis

Mailing Address: 213 Marine St. Phone: 609-296-2858 X223

City/State/Zip: Tuckerton, NJ 08087 Fax:

MICRO #

CHEM. # 250522073-01-05

SAMPLE REC'D BY:

GSL FIELD SAMPLER/PICK-UP

PICK-UP AT DROP OFF LOCATION

DELIVERED BY CLIENT

### SAMPLE INFORMATION

SAMPLE TYPE: DW

SAMPLE LOCATION Tuckerton Elementary School - 213 Marine St, Tuckerton, NJ 08087

Grab	Comp	SAMPLE ID	SAMPLE COLLECTION				ANALYSIS REQUIRED (Print Legibly)	CONTAINER INFORMATION				Lab # Extension
			Date	Time	AM	PM		No.	Type*	Size	Pres.*	
X		Art Room eye wash sink	5/20/25	5:47 AM	X		Lead (First Draw)	1	P	250ml	A	
X		Steam Room Sink Light of air	5/20/25	5:51 AM	X		Lead (First Draw)	1	P	250ml	A	
X		Steam Room sink left of door	5/20/25	5:50 AM	X		Lead (First Draw)	1	P	250ml	A	
X		Hall Teach. Room - sink	5/20/25	5:57 AM	X		Lead (First Draw)	1	P	250ml	A	
X		Teach Rm. - water fountain left	5/20/25	5:54 AM	X		Lead (First Draw)	1	P	250ml	A	

Container Type: P = Plastic G = Glass A = Amber Glass I = Sterile Inho V = Vial Other/Specify: \_\_\_\_\_

Preservation Code: A = Non Preserved B = Sulfuric Acid C = Sodium Hydroxide D = Nitric Acid  
L = Hydrochloric Acid T = Zinc Acetate G = Sodium Iodosulfate H = Ascorbic Acid I = Cooled Other/Specify: \_\_\_\_\_

SUBCONTRACTED WORK

TURNAROUND TIME:  Standard  Rush (IF RUSH REQUESTED) Rush Due by:

SEND TO:

REPORT FORMAT:  Standard Report  Other/Specify:

DATE/TIME:

Standard Report + E2 PWSID#:

METHOD OF SHIPMENT:

### PAYMENT INFORMATION

Sampling/Pick-up Fee: \$  Composite Fee: \$  Rush Fee: \$ Amount Due: \$

Payment Method:  Credit Card Type:  Check #  Other:

Note: **LEAD SAMPLING FOR SCHOOL-BOE Regulations - \*IF BOTTLES ARE NOT FILLED TO THE 250ml LINE, THEY WILL BE REJECTED\***

\* 5/20/25 5:54 AM @ 5/23/25

**SAMPLE CUSTODY EXCHANGES MUST BE DOCUMENTED BELOW EACH TIME SAMPLES CHANGE POSSESSION**

**PLEASE PRINT YOUR NAME LEGIBLY, USE FULL LEGAL SIGNATURE, DATE AND TIME**

Sampled by (PRINT): <u>Rebecca Sprague</u>	Signature: <u>[Signature]</u>	Date/Time: <u>5/20/25 5:54 AM</u>
Client/Client's Representative (PRINT): <u>Rebecca Sprague</u>	Signature: <u>[Signature]</u>	Date/Time: <u>5/20/25 5:45 AM</u>
1. Received/Relinquished by (PRINT): <u>Shelby Swensen</u>	Signature: <u>[Signature]</u>	Date/Time: <u>5/22/25 11:08</u>
2. Received/Relinquished by (PRINT): <u>Kaylee Evans</u>	Signature: <u>[Signature]</u>	Date/Time: <u>5/22/25 13:33</u>

**CHAIN OF CUSTODY RECORD: PRESS HARD AND PRINT CLEARLY - USE BALL POINT PEN**

**IMPORTANT: PRINTED NAMES & SIGNATURES ARE REQUIRED**

# Garden State Laboratories, Inc.

**Main Lab - 410 Hillside Avenue, Hillside NJ 07205 - NJDEP Lab Cert. #20044**  
**Jersey Shore Lab - 54 Main Street, Waretown NJ 08758 - NJDEP Lab Cert. #15037**  
 Tel. 800-273-8901/908-688-8900 Fax 908-688-8966 www.gslabs.com info@gslabs.com

FOR SAMPLE RECEIVING USE ONLY

DATE/TIME/TEMP. REC'D AT LAB:

5/22/25 13:33 NO EOC

Page \_\_\_\_\_ of \_\_\_\_\_

GSL CLIENT # **TUC06**

### Office and Drop off Locations

North Jersey Office: 225 Sparta Avenue, Sparta, NJ 07871 Tel. 973-729-1827

West Jersey Office: 2050 Route 31 North, Glen Gardner, NJ 08826 Tel. 908-537-7414

### CLIENT INFORMATION (REPORT TO BE SENT TO)

Name: Tuckerton Borough BOE Contact/Authorized by: Rebecca Sprague/Brian Matthis  
 Mailing Address: 213 Marine St. Phone: 609-296-2858 X223  
 City/State/Zip: Tuckerton, NJ 08087 Fax:

MICRO #

CHEM. # **250529073-06-10**

SAMPLE REC'D BY:

GSL FIELD SAMPLER/PICK-UP

PICK-UP AT DROP OFF LOCATION

DELIVERED BY CLIENT

### SAMPLE INFORMATION

SAMPLE TYPE: DW

SAMPLE LOCATION Tuckerton Elementary School - 213 Marine St, Tuckerton, NJ 08087

Grab	Comp.	SAMPLE ID	SAMPLE COLLECTION				ANALYSIS REQUIRED (Print Legibly)	CONTAINER INFORMATION				Lab # Extension
			Date	Time	AM	PM		No.	Type*	Size	Pres.*	
X		Kitchen - Dishwash sink	5/20/25	3:17 AM	X		Lead (First Draw)	1	P	250ml	A	
X		Kitchen - Lg. Free sink	5/20/25	3:16 AM	Y		Lead (First Draw)	1	P	250ml	A	
X		Kitchen - small free sink	5/20/25	3:15 AM	X		Lead (First Draw)	1	P	250ml	A	
X		Kitchen - Handwash sink	5/20/25	3:14 AM	X		Lead (First Draw)	1	P	250ml	A	
X		Kitchen - Bath sink	5/20/25	3:12 AM	Y		Lead (First Draw)	1	P	250ml	A	

Container Type: P = Plastic G = Glass A = Amber Glass I = Sterile Ibio V = Vial Other/Specify: \_\_\_\_\_  
 Preservation Code: A = Non Preserved B = Sulfuric Acid C = Sodium Hydroxide D = Nitric Acid  
 E = Hydrochloric Acid F = Zinc Acetate G = Sodium Inosulfate H = Ascorbic Acid I = Cooled Other/Specify: \_\_\_\_\_

SUBCONTRACTED WORK

TURNAROUND TIME:  Standard  Rush (IF RUSH REQUESTED) Rush Due by:

SEND TO:

REPORT FORMAT:  Standard Report  Other/Specify:

DATE/TIME:

Standard Report + E2 PWSID#:

METHOD OF SHIPMENT:

### PAYMENT INFORMATION

Sampling/Pick-up Fee: \$  Composite Fee: \$  Rush Fee: \$ Amount Due: \$

Payment Method:  Credit Card Type:  Check #  Other:

Note: **LEAD SAMPLING FOR SCHOOL-BOE Regulations - \*IF BOTTLES ARE NOT FILLED TO THE 250ml LINE , THEY WILL BE REJECTED\***

**SAMPLE CUSTODY EXCHANGES MUST BE DOCUMENTED BELOW EACH TIME SAMPLES CHANGE POSSESSION**

**PLEASE PRINT YOUR NAME LEGIBLY, USE FULL LEGAL SIGNATURE, DATE AND TIME**

Sampled by (PRINT): <u>Rebecca Sprague</u>	Signature: <u>[Signature]</u>	Date/Time: <u>5/20/25 3:18 AM</u>
Client/Client's Representative (PRINT): <u>Rebecca Sprague</u>	Signature: <u>[Signature]</u>	Date/Time: <u>5/20/25 3:18 AM</u>
1. Received/Relinquished by (PRINT): <u>Shelby Swensen</u>	Signature: <u>[Signature]</u>	Date/Time: <u>5/22/25 11:08</u>
2. Received/Relinquished by (PRINT): <u>Kaylee Evans</u>	Signature: <u>[Signature]</u>	Date/Time: <u>5/22/25 13:33</u>

CHAIN OF CUSTODY RECORD - PRESS HARD AND PRINT CLEARLY - USE BALL POINT PEN  
 IMPORTANT: PRINTED NAMES & SIGNATURES ARE REQUIRED

# Garden State Laboratories, Inc.

**Main Lab - 410 Hillside Avenue, Hillside NJ 07205 - NJDEP Lab Cert. #20044**  
**Jersey Shore Lab - 54 Main Street, Waretown NJ 08758 - NJDEP Lab Cert. #15037**  
 Tel. 800-273-8901/908-688-8900 Fax 908-688-8966 www.gslabs.com info@gslabs.com

### Office and Drop off Locations

North Jersey Office: 225 Sparta Avenue, Sparta, NJ 07871 Tel. 973-729-1827  
 West Jersey Office: 2050 Route 31 North, Glen Gardner, NJ 08826 Tel. 908-537-7414

FOR SAMPLE RECEIVING USE ONLY

DATE/TIME/TEMP. REC'D AT LAB:

5/22/25 13:33 NO EOC

Page \_\_\_\_\_ of \_\_\_\_\_

GSL CLIENT # **TUC06**

### CLIENT INFORMATION (REPORT TO BE SENT TO)

Name: Tuckerton Borough BOE Contact/Authorized by: Rebecca Sprague/Brian Matthis  
 Mailing Address: 213 Marine St. Phone: 609-296-2858 X223  
 City/State/Zip: Tuckerton, NJ 08087 Fax:

MICRO #

CHEM. # **250522073-11-15**

SAMPLE REC'D BY:

GSL FIELD SAMPLER/PICK-UP

PICK-UP AT DROP OFF LOCATION

DELIVERED BY CLIENT

### SAMPLE INFORMATION

SAMPLE TYPE: DW  
 SAMPLE LOCATION Tuckerton Elementary School - 213 Marine St, Tuckerton, NJ 08087

Grab	Comp	SAMPLE ID	SAMPLE COLLECTION				ANALYSIS REQUIRED (Print Legibly)		CONTAINER INFORMATION				Lab # Extension
			Date	Time	AM	PM	<input type="checkbox"/> List attached	Total Pages _____	No.	Type*	Size	Pres.*	
X		1st floor old section - water fountain	5/20/25	5:21 AM	X		Lead (First Draw)		1	P	250ml	A	
X		Rm 404 - sink	5/20/25	5:19 AM	X		Lead (First Draw)		1	P	250ml	A	
X		Rm 405 - sink	5/20/25	5:25 AM	X		Lead (First Draw)		1	P	250ml	A	
X		Rm 406 - sink	5/20/25	5:27 AM	X		Lead (First Draw)		1	P	250ml	A	
X		Art room sink	5/20/25	5:46 AM	X		Lead (First Draw)		1	P	250ml	A	

Container Type: P = Plastic G = Glass A = Amber Glass I = Sterile Ithio V = Vial Other/Specify: \_\_\_\_\_  
 Preservation Code: A = Non Preserved B = Sulfuric Acid C = Sodium Hydroxide D = Nitric Acid  
 E = Hydrochloric Acid F = Zinc Acetate G = Sodium Inosulfate H = Ascorbic Acid I = Cooled Other/Specify: \_\_\_\_\_

SUBCONTRACTED WORK

TURNAROUND TIME:  Standard  Rush (IF RUSH REQUESTED) Rush Due by:

SEND TO:

REPORT FORMAT:  Standard Report  Other/Specify:

DATE/TIME:

Standard Report + E2 PWSID#:

METHOD OF SHIPMENT:

### PAYMENT INFORMATION

Sampling/Pick-up Fee: \$  Composite Fee: \$  Rush Fee: \$ Amount Due: \$

Payment Method:  Credit Card Type:  Check #  Other:

Note: **LEAD SAMPLING FOR SCHOOL-BOE Regulations - \*IF BOTTLES ARE NOT FILLED TO THE 250ml LINE, THEY WILL BE REJECTED\***

5/20/25 5:46 AM (P) 5/23/25

SAMPLE CUSTODY EXCHANGES MUST BE DOCUMENTED BELOW EACH TIME SAMPLES CHANGE POSSESSION

PLEASE PRINT YOUR NAME LEGIBLY, USE FULL LEGAL SIGNATURE, DATE AND TIME

Sampled by (PRINT): Rebecca Sprague

Signature: [Signature]

Client/Client's Representative (PRINT): Rebecca Sprague

Signature: [Signature]

Date/Time: 5/20/25 5:47 AM

1. Received/Relinquished by (PRINT): Shelby Swearingen

Signature: [Signature]

Date/Time: 5/22/25 11:08

2. Received/Relinquished by (PRINT): Kaylee Evans

Signature: [Signature]

Date/Time: 5/22/25 13:33

CHAIN OF CUSTODY RECORD - PRESS HARD AND PRINT CLEARLY - USE BALL POINT PEN  
 IMPORTANT: PRINTED NAMES & SIGNATURES ARE REQUIRED

CHAIN OF CUSTODY RECORD - PRESS HARD AND PRINT CLEARLY - USE BALL POINT PEN

IMPORTANT: PRINTED NAMES & SIGNATURES ARE REQUIRED

# Garden State Laboratories, Inc.

**Main Lab - 410 Hillside Avenue, Hillside NJ 07205 - NJDEP Lab Cert. #20044**  
**Jersey Shore Lab - 54 Main Street, Waretown NJ 08758 - NJDEP Lab Cert. #15037**  
 Tel. 800-273-8901/908-688-8900 Fax 908-688-8966 www.gslabs.com info@gslabs.com

### Office and Drop off Locations

North Jersey Office: 225 Sparta Avenue, Sparta, NJ 07871 Tel. 973-729-1827  
 West Jersey Office: 2050 Route 31 North, Glen Gardner, NJ 08826 Tel. 908-537-7414

FOR SAMPLE RECEIVING USE ONLY

DATE/TIME/TEMP. REC'D AT LAB:

5/22/25 13:33 No EOC

Page \_\_\_\_\_ of \_\_\_\_\_

**GSL CLIENT # TUC06**

MICRO #

CHEM. # 250522073-16-20

SAMPLE REC'D BY:

GSL FIELD SAMPLER/PICK-UP

PICK-UP AT DROP OFF LOCATION

DELIVERED BY CLIENT

### CLIENT INFORMATION (REPORT TO BE SENT TO)

Name: Tuckerton Borough BOE Contact/Authorized by: Rebecca Sprague/Brian Matthis  
 Mailing Address: 213 Marine St. Phone: 609-296-2858 X223  
 City/State/Zip: Tuckerton, NJ 08087 Fax:

### SAMPLE INFORMATION

SAMPLE TYPE: DW  
 SAMPLE LOCATION Tuckerton Elementary School - 213 Marine St, Tuckerton, NJ 08087

Grab	Comp	SAMPLE ID	SAMPLE COLLECTION				ANALYSIS REQUIRED (Print Legibly)	CONTAINER INFORMATION				Lab # Extension
			Date	Time	AM	PM		No.	Type*	Size	Pres.*	
X		Rm 106 - water fountain	5/20/25	4:03AM	Y		Lead (First Draw)	1	P	250ml	A	
X		Rm - 205 - bath sink	5/20/25	4:27AM	Y		Lead (First Draw)	1	P	250ml	A	
X		Rm - 206 - bath sink	5/20/25	4:19AM	Y		Lead (First Draw)	1	P	250ml	A	
X		Rm - 200 - sink	5/20/25	4:49AM	Y		Lead (First Draw)	1	P	250ml	A	
X		Rm 200 - water fountain	5/20/25	4:51AM	Y		Lead (First Draw)	1	P	250ml	A	

⇒ Container Type: P = Plastic G = Glass A = Amber Glass I = Sterile Ithio V = Vial Other/Specify: \_\_\_\_\_  
 ⇒ Preservation Code: A = Non Preserved B = Sulfuric Acid C = Sodium Hydroxide D = Nitric Acid  
 E = Hydrochloric Acid F = Zinc Acetate G = Sodium Ithiosulfate H = Ascorbic Acid I = Colored Other/Specify: \_\_\_\_\_

SUBCONTRACTED WORK

TURNAROUND TIME:  Standard  Rush (IF RUSH REQUESTED) Rush Due by: \_\_\_\_\_  
 REPORT FORMAT:  Standard Report  Other/Specify: \_\_\_\_\_  
 Standard Report + E2 PWSID#: \_\_\_\_\_

SEND TO:

DATE/TIME:

METHOD OF SHIPMENT:

### PAYMENT INFORMATION

Sampling/Pick-up Fee: \$  Composite Fee: \$  Rush Fee: \$ Amount Due: \$  
 Payment Method:  Credit Card Type:  Check #  Other:

Note: **LEAD SAMPLING FOR SCHOOL-BOE Regulations - \*IF BOTTLES ARE NOT FILLED TO THE 250ml LINE , THEY WILL BE REJECTED\***

**SAMPLE CUSTODY EXCHANGES MUST BE DOCUMENTED BELOW EACH TIME SAMPLES CHANGE POSSESSION**

**PLEASE PRINT YOUR NAME LEGIBLY, USE FULL LEGAL SIGNATURE, DATE AND TIME**

Sampled by (PRINT): <u>Rebecca Sprague</u>	Signature: <u>[Signature]</u>	Date/Time: <u>5/20/25 4:53AM</u>
Client/Client's Representative (PRINT): <u>Rebecca Sprague</u>	Signature: <u>[Signature]</u>	Date/Time: <u>5/20/25 3:58AM</u>
1. Received/Relinquished by (PRINT): <u>Shelby Swenden</u>	Signature: <u>[Signature]</u>	Date/Time: <u>5/22/25 1108</u>
2. Received/Relinquished by (PRINT): <u>Megan Howanich</u>	Signature: <u>[Signature]</u>	Date/Time: <u>5/22/25 13:33</u>

# Garden State Laboratories, Inc.

**Main Lab - 410 Hillside Avenue, Hillside NJ 07205 - NJDEP Lab Cert. #20044**  
**Jersey Shore Lab - 54 Main Street, Waretown NJ 08758 - NJDEP Lab Cert. #15037**  
 Tel. 800-273-8901/908-688-8900 Fax 908-688-8966 www.gslabs.com info@gslabs.com

FOR SAMPLE RECEIVING USE ONLY

DATE/TIME/TEMP. REC'D AT LAB:

5/22/25 13:33 No EDC

Page \_\_\_\_\_ of \_\_\_\_\_

**GSL CLIENT # TUC06**

### Office and Drop off Locations

North Jersey Office: 225 Sparta Avenue, Sparta, NJ 07871 Tel. 973-729-1827

West Jersey Office: 2050 Route 31 North, Glen Gardner, NJ 08826 Tel. 908-537-7414

### CLIENT INFORMATION (REPORT TO BE SENT TO)

Name: Tuckerton Borough BOE Contact/Authorized by: Rebecca Sprague/Brian Matthis  
 Mailing Address: 213 Marine St. Phone: 609-296-2858 X223  
 City/State/Zip: Tuckerton, NJ 08087 Fax:

MICRO #  
 CHEM. #250522073-21-25

SAMPLE REC'D BY:

- GSL FIELD SAMPLER/PICK-UP  
 PICK-UP AT DROP OFF LOCATION  
 DELIVERED BY CLIENT

### SAMPLE INFORMATION

SAMPLE TYPE: DW  
 SAMPLE LOCATION Tuckerton Elementary School - 213 Marine St, Tuckerton, NJ 08087

Grab	Comp	SAMPLE ID	SAMPLE COLLECTION				ANALYSIS REQUIRED (Print Legibly)	CONTAINER INFORMATION				Lab # Extension
			Date	Time	AM	PM		No.	Type*	Size	Pres.*	
X		Nurses - work sink	5/20/25	6:10 AM	X		Lead (First Draw)	1	P	250ml	A	
X		main floor boys - left sink	5/20/25	6:17 AM	X		Lead (First Draw)	1	P	250ml	A	
X		main floor boys right sink	5/20/25	6:18 AM	X		Lead (First Draw)	1	P	250ml	A	
X		main floor girls - left sink	5/20/25	6:22 AM	X		Lead (First Draw)	1	P	250ml	A	
X		main floor girls - right sink	5/20/25	6:23 AM	X		Lead (First Draw)	1	P	250ml	A	

⇒ Container type: P = Plastic G = Glass A = Amber Glass T = Sterile Thio V = Vial Other/Specify: \_\_\_\_\_  
 ⇒ Preservation Code: A = Non Preserved B = Sulfuric Acid C = Sodium Hydroxide D = Nitric Acid  
 E = Hydrochloric Acid F = Zinc Acetate G = Sodium Iodosulfate H = Ascorbic Acid I = Looled Other/Specify: \_\_\_\_\_

SUBCONTRACTED WORK

TURNAROUND TIME:  Standard  Rush (IF RUSH REQUESTED) Rush Due by: \_\_\_\_\_  
 REPORT FORMAT:  Standard Report  Other/Specify: \_\_\_\_\_  
 Standard Report + E2 PWSID#: \_\_\_\_\_

SEND TO: \_\_\_\_\_  
 DATE/TIME: \_\_\_\_\_  
 METHOD OF SHIPMENT: \_\_\_\_\_

### PAYMENT INFORMATION

Sampling/Pick-up Fee: \$  Composite Fee: \$  Rush Fee: \$ Amount Due: \$  
 Payment Method:  Credit Card Type:  Check #  Other:

Note: **LEAD SAMPLING FOR SCHOOL-BOE Regulations - \*IF BOTTLES ARE NOT FILLED TO THE 250ml LINE , THEY WILL BE REJECTED\***

**SAMPLE CUSTODY EXCHANGES MUST BE DOCUMENTED BELOW EACH TIME SAMPLES CHANGE POSSESSION**  
**PLEASE PRINT YOUR NAME LEGIBLY, USE FULL LEGAL SIGNATURE, DATE AND TIME**

Sampled by (PRINT): <u>Rebecca Sprague</u>	Signature: <u>[Signature]</u>	Date/Time: <u>5/20/25 6:29 AM</u>
Client/Client's Representative (PRINT): <u>Rebecca Sprague</u>	Signature: <u>[Signature]</u>	Date/Time: <u>5/20/25 6:48 AM</u>
1. Received/Relinquished by (PRINT): <u>Shelby Swenson</u>	Signature: <u>[Signature]</u>	Date/Time: <u>5/22/25 11:08</u>
2. Received/Relinquished by (PRINT): <u>Megan Hovanich</u>	Signature: <u>[Signature]</u>	Date/Time: <u>5/22/25 13:33</u>

CHAIN OF CUSTODY RECORD - PRESS HARD AND PRINT CLEARLY - USE BALL POINT PEN  
 IMPORTANT: PRINTED NAMES & SIGNATURES ARE REQUIRED

# Garden State Laboratories, Inc.

**Main Lab - 410 Hillside Avenue, Hillside NJ 07205 - NJDEP Lab Cert. #20044**

**Jersey Shore Lab - 54 Main Street, Waretown NJ 08758 - NJDEP Lab Cert. #15037**

Tel. 800-273-8901/908-688-8900 Fax 908-688-8966 www.gslabs.com info@gslabs.com

### Office and Drop off Locations

North Jersey Office: 225 Sparta Avenue, Sparta, NJ 07871 Tel. 973-729-1827

West Jersey Office: 2050 Route 31 North, Glen Gardner, NJ 08826 Tel. 908-537-7414

FOR SAMPLE RECEIVING USE ONLY

DATE/TIME/TEMP. REC'D AT LAB:

5/22/25 13:33 No EOC

Page \_\_\_\_\_ of \_\_\_\_\_

**GSL CLIENT # TUC06**

MICRO #

CHEM. # 250522073-26-30

SAMPLE REC'D BY:

GSL FIELD SAMPLER/PICK-UP

PICK-UP AT DROP OFF LOCATION

DELIVERED BY CLIENT

### CLIENT INFORMATION (REPORT TO BE SENT TO)

Name: Tuckerton Borough BOE Contact/Authorized by: Rebecca Sprague/Brian Matthis

Mailing Address: 213 Marine St. Phone: 609-296-2858 X223

City/State/Zip: Tuckerton, NJ 08087 Fax:

### SAMPLE INFORMATION

SAMPLE TYPE: DW

SAMPLE LOCATION Tuckerton Elementary School - 213 Marine St, Tuckerton, NJ 08087

Grab	Comp	SAMPLE ID	SAMPLE COLLECTION				ANALYSIS REQUIRED (Print Legibly)	CONTAINER INFORMATION				Lab # Extension
			Date	Time	AM	PM		No.	Type*	Size	Pres.*	
X		Cafe Hall - water fountain	5/20/25	3:21 AM	X		Lead (First Draw)	1	P	250ml	A	
X		Cafe Hall - Boys Rm sink	5/20/25	3:23 AM	X		Lead (First Draw)	1	P	250ml	A	
X		Cafe Hall - Girls Rm sink	5/20/25	3:26 AM	X		Lead (First Draw)	1	P	250ml	A	
X		Primary Hall - water fountain	5/20/25	3:30 AM	X		Lead (First Draw)	1	P	250ml	A	
X		101 sink	5/20/25	3:39 AM	X		Lead (First Draw)	1	P	250ml	A	

Container Type: P = Plastic G = Glass A = Amber Glass I = Sterile Thio V = Vial Other/Specify: \_\_\_\_\_

Preservation Code: A = Non Preserved B = Sulfuric Acid C = Sodium Hydroxide D = Nitric Acid  
E = Hydrochloric Acid F = Zinc Acetate G = Sodium Inosulfate H = Ascorbic Acid I = Labeled Other/Specify: \_\_\_\_\_

SUBCONTRACTED WORK

TURNAROUND TIME:  Standard  Rush (IF RUSH REQUESTED) Rush Due by:

SEND TO:

REPORT FORMAT:  Standard Report  Other/Specify:

DATE/TIME:

Standard Report + E2 PWSID#:

METHOD OF SHIPMENT:

### PAYMENT INFORMATION

Sampling/Pick-up Fee: \$  Composite Fee: \$  Rush Fee: \$ Amount Due: \$

Payment Method:  Credit Card Type:  Check #  Other:

Note: **LEAD SAMPLING FOR SCHOOL-BOE Regulations - \*IF BOTTLES ARE NOT FILLED TO THE 250ml LINE , THEY WILL BE REJECTED\***

**SAMPLE CUSTODY EXCHANGES MUST BE DOCUMENTED BELOW EACH TIME SAMPLES CHANGE POSSESSION**

**PLEASE PRINT YOUR NAME LEGIBLY, USE FULL LEGAL SIGNATURE, DATE AND TIME**

Sampled by (PRINT): <u>Rebecca Sprague</u>	Signature: <u>[Signature]</u>	Date/Time: <u>5/20/25 3:40 AM</u>
Client/Client's Representative (PRINT): <u>Rebecca Sprague</u>	Signature: <u>[Signature]</u>	Date/Time: <u>5/20/25 3:20 AM</u>
1. Received/Relinquished by (PRINT): <u>Shelby Swensen</u>	Signature: <u>[Signature]</u>	Date/Time: <u>5/22/25 11:08</u>
2. Received/Relinquished by (PRINT): <u>Megan Howard</u>	Signature: <u>[Signature]</u>	Date/Time: <u>5/22/25 13:33</u>

CHAIN OF CUSTODY RECORD - PRESS HARD AND PRINT CLEARLY - USE BALL POINT PEN  
IMPORTANT: PRINTED NAMES & SIGNATURES ARE REQUIRED

# Garden State Laboratories, Inc.

**Main Lab - 410 Hillside Avenue, Hillside NJ 07205 - NJDEP Lab Cert. #20044**  
**Jersey Shore Lab - 54 Main Street, Waretown NJ 08758 - NJDEP Lab Cert. #15037**  
 Tel. 800-273-8901/908-688-8900 Fax 908-688-8966 www.gslabs.com info@gslabs.com

### Office and Drop off Locations

North Jersey Office: 225 Sparta Avenue, Sparta, NJ 07871 Tel. 973-729-1827  
 West Jersey Office: 2050 Route 31 North, Glen Gardner, NJ 08826 Tel. 908-537-7414

FOR SAMPLE RECEIVING USE ONLY

DATE/TIME/TEMP. REC'D AT LAB:

5/22/25 13:33 No ETC

Page \_\_\_\_\_ of \_\_\_\_\_

**GSL CLIENT # TUC06**

### CLIENT INFORMATION (REPORT TO BE SENT TO)

Name: Tuckerton Borough BOE Contact/Authorized by: Rebecca Sprague/Brian Matthis  
 Mailing Address: 213 Marine St. Phone: 609-296-2858 X223  
 City/State/Zip: Tuckerton, NJ 08087 Fax:

MICRO #

CHEM. # 250522073-31-35

SAMPLE REC'D BY:

- GSL FIELD SAMPLER/PICK-UP  
 PICK-UP AT DROP OFF LOCATION  
 DELIVERED BY CLIENT

### SAMPLE INFORMATION

SAMPLE TYPE: DW  
 SAMPLE LOCATION Tuckerton Elementary School - 213 Marine St, Tuckerton, NJ 08087

Grab	Comp.	SAMPLE ID	SAMPLE COLLECTION				ANALYSIS REQUIRED (Print Legibly)	CONTAINER INFORMATION				Lab # Extension
			Date	Time	AM	PM		No.	Type*	Size	Pres.*	
X		Rm 104 - Sink	5/20/25	3:53 AM	Y		Lead (First Draw)	1	P	250ml	A	
X		Rm 104 - water fountain	5/20/25	3:55 AM	Y		Lead (First Draw)	1	P	250ml	A	
X		Rm 105 - Sink	5/20/25	3:57 AM	Y		Lead (First Draw)	1	P	250ml	A	
X		Rm 105 - water fountain	5/20/25	3:59 AM	Y		Lead (First Draw)	1	P	250ml	A	
X		Rm 106 - Sink	5/20/25	4:02 AM	Y		Lead (First Draw)	1	P	250ml	A	

⇒ \*Container type: P = Plastic G = Glass A = Amber Glass I = Sterile Thro V = Vial Other/Specify: \_\_\_\_\_  
 ⇒ \*Preservation Code: A = Non Preserved B = Sulfuric Acid C = Sodium Hydroxide D = Nitric Acid  
 E = Hydrochloric Acid F = Zinc Acetate G = Sodium Iminosulfate H = Ascorbic Acid I = Cooled Other/Specify: \_\_\_\_\_

SUBCONTRACTED WORK

TURNAROUND TIME:  Standard  Rush (IF RUSH REQUESTED) Rush Due by: \_\_\_\_\_  
 REPORT FORMAT:  Standard Report  Other/Specify: \_\_\_\_\_  
 Standard Report + E2 PWSID#: \_\_\_\_\_

SEND TO: \_\_\_\_\_  
 DATE/TIME: \_\_\_\_\_  
 METHOD OF SHIPMENT: \_\_\_\_\_

### PAYMENT INFORMATION

Sampling/Pick-up Fee: \$  Composite Fee: \$  Rush Fee: \$ Amount Due: \$  
 Payment Method:  Credit Card Type:  Check #  Other:

Note: **LEAD SAMPLING FOR SCHOOL-BOE Regulations - \*IF BOTTLES ARE NOT FILLED TO THE 250ml LINE , THEY WILL BE REJECTED\***

**SAMPLE CUSTODY EXCHANGES MUST BE DOCUMENTED BELOW EACH TIME SAMPLES CHANGE POSSESSION  
 PLEASE PRINT YOUR NAME LEGIBLY, USE FULL LEGAL SIGNATURE, DATE AND TIME**

Sampled by (PRINT): <u>Rebecca Sprague</u>	Signature: <u>[Signature]</u>	Date/Time: <u>5/20/25 3:50 AM</u>
Client/Client's Representative (PRINT): <u>Rebecca Sprague</u>	Signature: <u>[Signature]</u>	Date/Time: <u>5/22/25 1108</u>
1. Received/Relinquished by (PRINT): <u>Shelby Swensen</u>	Signature: <u>[Signature]</u>	Date/Time: <u>5/22/25 13:33</u>
2. Received/Relinquished by (PRINT): <u>LINDA SCHWARTZ</u>	Signature: <u>[Signature]</u>	Date/Time: <u>5/22/25 13:33</u>

The liability of Garden State Laboratories, Inc. for services rendered shall in no event exceed the amount of the invoice.  
 Main Lab certified by NJ Dept. of Health, NJDEP-TN1, NY Dept. of Health #11550 and PADEP #68-03680

CHAIN OF CUSTODY RECORD - PRESS HARD AND PRINT CLEARLY - USE BALL POINT PEN  
 IMPORTANT: PRINTED NAMES & SIGNATURES ARE REQUIRED

# Garden State Laboratories, Inc.

**Main Lab - 410 Hillside Avenue, Hillside NJ 07205 - NJDEP Lab Cert. #20044**  
**Jersey Shore Lab - 54 Main Street, Waretown NJ 08758 - NJDEP Lab Cert. #15037**  
 Tel. 800-273-8901/908-688-8900 Fax 908-688-8966 www.gslabs.com info@gslabs.com

FOR SAMPLE RECEIVING USE ONLY

DATE/TIME/TEMP. REC'D AT LAB:  
 5/22/25 13:33 No EOC

### Office and Drop off Locations

North Jersey Office: 225 Sparta Avenue, Sparta, NJ 07871 Tel. 973-729-1827  
 West Jersey Office: 2050 Route 31 North, Glen Gardner, NJ 08826 Tel. 908-537-7414

Page \_\_\_\_\_ of \_\_\_\_\_

**GSL CLIENT # TUC06**

### CLIENT INFORMATION (REPORT TO BE SENT TO)

MICRO # \_\_\_\_\_  
 CHEM. # 250522073-36-40  
 SAMPLE REC'D BY:  
 GSL FIELD SAMPLER/PICK-UP  
 PICK-UP AT DROP OFF LOCATION  
 DELIVERED BY CLIENT

Name: Tuckerton Borough BOE Contact/Authorized by: Rebecca Sprague/Brian Matthis  
 Mailing Address: 213 Marine St. Phone: 609-296-2858 X223  
 City/State/Zip: Tuckerton, NJ 08087 Fax: \_\_\_\_\_

### SAMPLE INFORMATION

SAMPLE TYPE: DW  
 SAMPLE LOCATION Tuckerton Elementary School - 213 Marine St, Tuckerton, NJ 08087

Grab	Comp.	SAMPLE ID	SAMPLE COLLECTION				ANALYSIS REQUIRED (Print Legibly)	CONTAINER INFORMATION				Lab # Extension
			Date	Time	AM	PM		No.	Type*	Size	Pres.*	
X		Rm 204 - Class Sink	5/20/25	4:37am	X		Lead (First Draw)	1	P	250ml	A	
X		Rm 204 - water fountain	5/20/25	4:38AM	X		Lead (First Draw)	1	P	250ml	A	
X		90's Playground - water fountain left	5/20/25	4:56AM	X		Lead (First Draw)	1	P	250ml	A	
X		90's Playground - water fountain right	5/20/25	4:58AM	?		Lead (First Draw)	1	P	250ml	A	
X		Gym water fountain - Hall	5/20/25	4:21pm	X		Lead (First Draw)	1	P	250ml	A	

Container Type: P = Plastic G = Glass A = Amber Glass I = Sterile Ithio V = Vial Other/Specify: \_\_\_\_\_  
 Preservation Code: A = Non Preserved B = Sulfuric Acid C = Sodium Hydroxide D = Nitric Acid  
 E = Hydrochloric Acid F = Zinc Acetate G = Sodium Ithiosulfate H = Ascorbic Acid I = Labeled Other/Specify: \_\_\_\_\_

SUBCONTRACTED WORK

TURNAROUND TIME:  Standard  Rush (If RUSH REQUESTED) Rush Due by: \_\_\_\_\_  
 REPORT FORMAT:  Standard Report  Other/Specify: \_\_\_\_\_  
 Standard Report + E2 PWSID#: \_\_\_\_\_

SEND TO: \_\_\_\_\_  
 DATE/TIME: \_\_\_\_\_  
 METHOD OF SHIPMENT: \_\_\_\_\_

### PAYMENT INFORMATION

Sampling/Pick-up Fee: \$  Composite Fee: \$  Rush Fee: \$ Amount Due: \$  
 Payment Method:  Credit Card Type:  Check #  Other: \_\_\_\_\_

Note: **LEAD SAMPLING FOR SCHOOL-BOE Regulations - \*IF BOTTLES ARE NOT FILLED TO THE 250ml LINE , THEY WILL BE REJECTED\***

**SAMPLE CUSTODY EXCHANGES MUST BE DOCUMENTED BELOW EACH TIME SAMPLES CHANGE POSSESSION**  
**PLEASE PRINT YOUR NAME LEGIBLY, USE FULL LEGAL SIGNATURE, DATE AND TIME**

Sampled by (PRINT): <u>Rebecca Sprague</u>	Signature: <u>[Signature]</u>	Date/Time: <u>5/20/25 5:00am</u>
Client/Client's Representative (PRINT): <u>Rebecca Sprague</u>	Signature: <u>[Signature]</u>	Date/Time: <u>5/20/25 4:38am</u>
1. Received/Relinquished by (PRINT): <u>Shelby Swensen</u>	Signature: <u>[Signature]</u>	Date/Time: <u>5/22/25 1108</u>
2. Received/Relinquished by (PRINT): <u>LINDA SCHWENGER</u>	Signature: <u>[Signature]</u>	Date/Time: <u>5/22/25 13:33</u>

The liability of Garden State Laboratories, Inc. for services rendered shall in no event exceed the amount of the invoice.  
 Main Lab certified by NJ Dept. of Health, NJDEP-TNI, NY Dept. of Health #11550 and PADEP #68-03680

CHAIN OF CUSTODY RECORD - PRESS HARD AND PRINT CLEARLY - USE BALL POINT PEN  
 IMPORTANT: PRINTED NAMES & SIGNATURES ARE REQUIRED

CHAIN OF CUSTODY RECORD - PRESS HARD AND PRINT CLEARLY - USE BALL POINT PEN

IMPORTANT: PRINTED NAMES & SIGNATURES ARE REQUIRED

# Garden State Laboratories, Inc.

**Main Lab - 410 Hillside Avenue, Hillside NJ 07205 - NJDEP Lab Cert. #20044**

**Jersey Shore Lab - 54 Main Street, Waretown NJ 08758 - NJDEP Lab Cert. #15037**

Tel. 800-273-8901/908-688-8900 Fax 908-688-8966 www.gslabs.com info@gslabs.com

### Office and Drop off Locations

North Jersey Office: 225 Sparta Avenue, Sparta, NJ 07871 Tel. 973-729-1827

West Jersey Office: 2050 Route 31 North, Glen Gardner, NJ 08826 Tel. 908-537-7414

FOR SAMPLE RECEIVING USE ONLY

DATE/TIME/TEMP. REC'D AT LAB:

5/22/25 13:33 No EDC

Page \_\_\_\_\_ of \_\_\_\_\_

**GSL CLIENT # TUC06**

MICRO #

CHEM. # 250522073-41-45

SAMPLE REC'D BY:

GSL FIELD SAMPLER/PICK-UP

PICK-UP AT DROP OFF LOCATION

DELIVERED BY CLIENT

### CLIENT INFORMATION (REPORT TO BE SENT TO)

Name: Tuckerton Borough BOE Contact/Authorized by: Rebecca Sprague/Brian Matthis

Mailing Address: 213 Marine St. Phone: 609-296-2858 X223

City/State/Zip: Tuckerton, NJ 08087 Fax:

### SAMPLE INFORMATION

SAMPLE TYPE: DW

SAMPLE LOCATION Tuckerton Elementary School - 213 Marine St, Tuckerton, NJ 08087

Grab	Comp	SAMPLE ID	SAMPLE COLLECTION				ANALYSIS REQUIRED (Print Legibly)	CONTAINER INFORMATION				Lab # Extension
			Date	Time	AM	PM		No.	Type*	Size	Pres.*	
X		90's Building Hall water fountain right	5/20/25	5:10am	Y		1	P	250ml	A		
X		90's Building Girls Rm Left	5/20/25	5:13am	Y		1	P	250ml	A		
X		90's Building Girls Rm Right	5/20/25	5:14am	Y		1	P	250ml	A		
X		90's Building Boys Rm Left	5/20/25	5:15am	Y		1	P	250ml	A		
X		90's Building Boys Rm Right	5/20/25	5:16am	Y		1	P	250ml	A		

Container type: P = Plastic G = Glass A = Amber Glass II = Sterile Irio V = Vial Other/Specify: \_\_\_\_\_

Preservation Code: A = Non Preserved B = Sulfuric Acid C = Sodium Hydroxide D = Nitric Acid  
E = Hydrochloric Acid F = Zinc Acetate G = Sodium Iodosulfate H = Ascorbic Acid I = Cooled Other/Specify: \_\_\_\_\_

SUBCONTRACTED WORK

TURNAROUND TIME:  Standard  Rush (if RUSH REQUESTED) Rush Due by:

SEND TO:

REPORT FORMAT:  Standard Report  Other/Specify:

DATE/TIME:

Standard Report + E2 PWSID#:

METHOD OF SHIPMENT:

### PAYMENT INFORMATION

Sampling/Pick-up Fee: \$  Composite Fee: \$  Rush Fee: \$ Amount Due: \$

Payment Method:  Credit Card Type:  Check #  Other:

Note: **LEAD SAMPLING FOR SCHOOL-BOE Regulations - \*IF BOTTLES ARE NOT FILLED TO THE 250ml LINE , THEY WILL BE REJECTED\***

**SAMPLE CUSTODY EXCHANGES MUST BE DOCUMENTED BELOW EACH TIME SAMPLES CHANGE POSSESSION**

**PLEASE PRINT YOUR NAME LEGIBLY, USE FULL LEGAL SIGNATURE, DATE AND TIME**

Sampled by (PRINT): <u>Rebecca Sprague</u>	Signature: <u>[Signature]</u>	Date/Time: <u>5/20/25 5:16 am</u>
Client/Client's Representative (PRINT): <u>Rebecca Sprague</u>	Signature: <u>[Signature]</u>	Date/Time: <u>5/20/25 5:08 am</u>
1. Received/Relinquished by (PRINT): <u>Shelby Swensen</u>	Signature: <u>[Signature]</u>	Date/Time: <u>5/22/25 1108</u>
2. Received/Relinquished by (PRINT): <u>Megan Howard</u>	Signature: <u>[Signature]</u>	Date/Time: <u>5/22/25 13:33</u>

CHAIN OF CUSTODY RECORD - PRESS HARD AND PRINT CLEARLY - USE BALL POINT PEN

# Garden State Laboratories, Inc.

**Main Lab - 410 Hillside Avenue, Hillside NJ 07205 - NJDEP Lab Cert. #20044**  
**Jersey Shore Lab - 54 Main Street, Waretown NJ 08758 - NJDEP Lab Cert. #15037**  
 Tel. 800-273-8901/908-688-8900 Fax 908-688-8966 www.gslabs.com info@gslabs.com

FOR SAMPLE RECEIVING USE ONLY

DATE/TIME/TEMP. REC'D AT LAB:

5/22/25 13:33 No EOC

### Office and Drop off Locations

North Jersey Office: 225 Sparta Avenue, Sparta, NJ 07871 Tel. 973-729-1827  
 West Jersey Office: 2050 Route 31 North, Glen Gardner, NJ 08826 Tel. 908-537-7414

Page \_\_\_\_\_ of \_\_\_\_\_

**GSL CLIENT # TUC06**

### CLIENT INFORMATION (REPORT TO BE SENT TO)

Name: Tuckerton Borough BOE Contact/Authorized by: Rebecca Sprague/Brian Matthis  
 Mailing Address: 213 Marine St. Phone: 609-296-2858 X223  
 City/State/Zip: Tuckerton, NJ 08087 Fax:

MICRO #

CHEM. # 250522073-46-50

SAMPLE REC'D BY:

- GSL FIELD SAMPLER/PICK-UP  
 PICK-UP AT DROP OFF LOCATION  
 DELIVERED BY CLIENT

### SAMPLE INFORMATION

SAMPLE TYPE: DW  
 SAMPLE LOCATION Tuckerton Elementary School - 213 Marine St, Tuckerton, NJ 08087

Grab	Comp	SAMPLE ID	SAMPLE COLLECTION				ANALYSIS REQUIRED (Print Legibly)	CONTAINER INFORMATION				Lab # Extension
			Date	Time	AM	PM		No.	Type*	Size	Pres.*	
X		Girls Gym Bathroom sink left	5/20/25	4:24am	X		Lead (First Draw)	1	P	250ml	A	
X		Girls Gym Bathroom sink right	5/20/25	4:25am	X		Lead (First Draw)	1	P	250ml	A	
X		Boys Gym Bathroom sink left	5/20/25	4:34am	X		Lead (First Draw)	1	P	250ml	A	
X		Boys Gym Bathroom sink right	5/20/25	4:35am	X		Lead (First Draw)	1	P	250ml	A	
X		905 Building Hall water fountain left	5/20/25	5:09am	X		Lead (First Draw)	1	P	250ml	A	

⇒ Container type: P = Plastic G = Glass A = Amber Glass I = Sterile Ithio V = Vial Other/Specify: \_\_\_\_\_  
 ⇒ Preservation Code: A = Non Preserved B = Sulfuric Acid C = Sodium Hydroxide D = Nitric Acid  
 E = Hydrochloric Acid F = Zinc Acetate G = Sodium Ithiosulfate H = Ascorbic Acid I = Cooled Other/Specify: \_\_\_\_\_

SUBCONTRACTED WORK

TURNAROUND TIME:  Standard  Rush (IF RUSH REQUESTED) Rush Due by: \_\_\_\_\_  
 REPORT FORMAT:  Standard Report  Other/Specify: \_\_\_\_\_  
 Standard Report + E2 PWSID#: \_\_\_\_\_

SEND TO: \_\_\_\_\_  
 DATE/TIME: \_\_\_\_\_  
 METHOD OF SHIPMENT: \_\_\_\_\_

### PAYMENT INFORMATION

Sampling/Pick-up Fee: \$  Composite Fee: \$  Rush Fee: \$ Amount Due: \$  
 Payment Method:  Credit Card Type:  Check #  Other:

Note: **LEAD SAMPLING FOR SCHOOL-BOE Regulations - \*IF BOTTLES ARE NOT FILLED TO THE 250ml LINE , THEY WILL BE REJECTED\***

### SAMPLE CUSTODY EXCHANGES MUST BE DOCUMENTED BELOW EACH TIME SAMPLES CHANGE POSSESSION

PLEASE PRINT YOUR NAME LEGIBLY, USE FULL LEGAL SIGNATURE, DATE AND TIME

Sampled by (PRINT): Rebecca Sprague	Signature: <i>Rebecca Sprague</i>	Date/Time: 5/20/25 4:29am
Client/Client's Representative (PRINT): Rebecca Sprague	Signature: <i>Rebecca Sprague</i>	Date/Time: 5/22/25 11:08
1. Received/Relinquished by (PRINT): Shelby Swensen	Signature: <i>Shelby Swensen</i>	Date/Time: 5/22/25 13:33
2. Received/Relinquished by (PRINT): Megan Hawanich	Signature: <i>Megan Hawanich</i>	Date/Time: 5/22/25 13:33

The liability of Garden State Laboratories, Inc. for services rendered shall in no event exceed the amount of the invoice.  
 Main Lab certified by NJ Dept. of Health, NJDEP-TN1, NY Dept. of Health #11550 and PADEP #68-03680

# Garden State Laboratories, Inc.

**Main Lab - 410 Hillside Avenue, Hillside NJ 07205 - NJDEP Lab Cert. #20044**  
**Jersey Shore Lab - 54 Main Street, Waretown NJ 08758 - NJDEP Lab Cert. #15037**  
 Tel. 800-273-8901/908-688-8900 Fax 908-688-8966 www.gslabs.com info@gslabs.com

FOR SAMPLE RECEIVING USE ONLY

DATE/TIME/TEMP. REC'D AT LAB:

5/22/25 13:33 No EOC

Page \_\_\_\_\_ of \_\_\_\_\_

**GSL CLIENT # TUC06**

### Office and Drop off Locations

North Jersey Office: 225 Sparta Avenue, Sparta, NJ 07871 Tel. 973-729-1827

West Jersey Office: 2050 Route 31 North, Glen Gardner, NJ 08826 Tel. 908-537-7414

### CLIENT INFORMATION (REPORT TO BE SENT TO)

Name: Tuckerton Borough BOE Contact/Authorized by: Rebecca Sprague/Brian Matthis  
 Mailing Address: 213 Marine St. Phone: 609-296-2858 X223  
 City/State/Zip: Tuckerton, NJ 08087 Fax:

MICRO #

CHEM. # 250522073-51-55

SAMPLE REC'D BY:

GSL FIELD SAMPLER/PICK-UP

PICK-UP AT DROP OFF LOCATION

DELIVERED BY CLIENT

### SAMPLE INFORMATION

SAMPLE TYPE: DW  
 SAMPLE LOCATION Tuckerton Elementary School - 213 Marine St, Tuckerton, NJ 08087

Grab	Comp	SAMPLE ID	SAMPLE COLLECTION				ANALYSIS REQUIRED (Print Legibly)	CONTAINER INFORMATION				Lab # Extension
			Date	Time	AM	PM		No.	Type*	Size	Pres.*	
X		Teach Rm - water fountain right	5/20/25	5:55 AM	X		Lead (First Draw)	1	P	250ml	A	
X		Teach Rm - sink	5/20/25	5:59 AM	X		Lead (First Draw)	1	P	250ml	A	
X		Teach Rm - Bath sink	5/20/25	6:01 AM	X		Lead (First Draw)	1	P	250ml	A	
X		Main floor water fountain	5/20/25	6:04 AM	X		Lead (First Draw)	1	P	250ml	A	
X		Nurse's Bath sink	5/20/25	6:11 AM	X		Lead (First Draw)	1	P	250ml	A	

Container type: P = Plastic G = Glass A = Amber Glass I = Sterile I/ho V = Vial Other/Specify: \_\_\_\_\_  
 \*Preservation Code: A = Non Preserved B = Sulfuric Acid C = Sodium Hydroxide D = Nitric Acid  
 E = Hydrochloric Acid F = Zinc Acetate G = Sodium Iodosulfate H = Ascorbic Acid I = L-Ascorbic Acid Other/Specify: \_\_\_\_\_

SUBCONTRACTED WORK

TURNAROUND TIME:  Standard  Rush (If RUSH REQUESTED) Rush Due by: \_\_\_\_\_  
 REPORT FORMAT:  Standard Report  Other/Specify: \_\_\_\_\_  
 Standard Report + E2 PWSID#: \_\_\_\_\_

SEND TO:

DATE/TIME:

METHOD OF SHIPMENT:

### PAYMENT INFORMATION

Sampling/Pick-up Fee: \$  Composite Fee: \$  Rush Fee: \$ Amount Due: \$  
 Payment Method:  Credit Card Type:  Check #  Other:

Note: **LEAD SAMPLING FOR SCHOOL-BOE Regulations - \*IF BOTTLES ARE NOT FILLED TO THE 250ml LINE , THEY WILL BE REJECTED\***

**SAMPLE CUSTODY EXCHANGES MUST BE DOCUMENTED BELOW EACH TIME SAMPLES CHANGE POSSESSION**  
**PLEASE PRINT YOUR NAME LEGIBLY, USE FULL LEGAL SIGNATURE, DATE AND TIME**

Sampled by (PRINT): <u>Rebecca Sprague</u>	Signature: <u>[Signature]</u>	Date/Time: <u>5/20/25 6:11 AM</u>
Client/Client's Representative (PRINT): <u>Rebecca Sprague</u>	Signature: <u>[Signature]</u>	Date/Time: <u>5/20/25 5:59 AM</u>
1. Received/Relinquished by (PRINT): <u>Shelby Swensen</u>	Signature: <u>[Signature]</u>	Date/Time: <u>5/22/25 11:08</u>
2. Received/Relinquished by (PRINT): <u>Megan Howanich</u>	Signature: <u>[Signature]</u>	Date/Time: <u>5/22/25 13:33</u>

CHAIN OF CUSTODY RECORD - PRESS HARD AND PRINT CLEARLY - USE BALL POINT PEN

IMPORTANT: PRINTED NAMES & SIGNATURES ARE REQUIRED

# Garden State Laboratories, Inc.

**Main Lab - 410 Hillside Avenue, Hillside NJ 07205 - NJDEP Lab Cert. #20044**  
**Jersey Shore Lab - 54 Main Street, Waretown NJ 08758 - NJDEP Lab Cert. #15037**  
 Tel. 800-273-8901/908-688-8900 Fax 908-688-8966 www.gslabs.com info@gslabs.com

FOR SAMPLE RECEIVING USE ONLY

DATE/TIME/TEMP. REC'D AT LAB:

5/22/25 13:33 No EOC

Page \_\_\_\_\_ of \_\_\_\_\_

GSL CLIENT # **TUC06**

### Office and Drop off Locations

North Jersey Office: 225 Sparta Avenue, Sparta, NJ 07871 Tel. 973-729-1827

West Jersey Office: 2050 Route 31 North, Glen Gardner, NJ 08826 Tel. 908-537-7414

### CLIENT INFORMATION (REPORT TO BE SENT TO)

Name: Tuckerton Borough BOE Contact/Authorized by: Rebecca Sprague/Brian Matthis  
 Mailing Address: 213 Marine St. Phone: 609-296-2858 X223  
 City/State/Zip: Tuckerton, NJ 08087 Fax:

MICRO #

CHEM. # **250522073-56-60**

SAMPLE REC'D BY:

- GSL FIELD SAMPLER/PICK-UP  
 PICK-UP AT DROP OFF LOCATION  
 DELIVERED BY CLIENT

### SAMPLE INFORMATION

SAMPLE TYPE: DW  
 SAMPLE LOCATION Tuckerton Elementary School - 213 Marine St, Tuckerton, NJ 08087

Grab	Comp	SAMPLE ID	SAMPLE COLLECTION				ANALYSIS REQUIRED (Print Legibly)		CONTAINER INFORMATION				Lab # Extension	
			Date	Time	AM	PM	<input type="checkbox"/> List attached	Total Pages _____	No.	Type*	Size	Pres.*		
X		Rm 200 Bath sink	5/20/25	4:52 AM	X		Lead (First Draw)	<input type="checkbox"/>		1	P	250ml	A	
X		Rm 201 - Bath sink	5/20/25	4:46	X		Lead (First Draw)	<input type="checkbox"/>		1	P	250ml	A	
X		Rm 201 sink	5/20/25	4:45	X		Lead (First Draw)	<input type="checkbox"/>		1	P	250ml	A	
X		Rm 201 - water fountain	5/20/25	4:43	X		Lead (First Draw)	<input type="checkbox"/>		1	P	250ml	A	
X		Rm 209 - Bath sink	5/20/25	4:40	X		Lead (First Draw)	<input type="checkbox"/>		1	P	250ml	A	

Container type: P = Plastic G = Glass A = Amber Glass I = Sterile I/10 V = Vial Other/Specify: \_\_\_\_\_  
 Preservation Code: A = Non Preserved B = Sulfuric Acid C = Sodium Hydroxide D = Nitric Acid  
 E = Hydrochloric Acid F = Zinc Acetate G = Sodium Itriosulfate H = Ascorbic Acid I = Labeled Other/Specify: \_\_\_\_\_

SUBCONTRACTED WORK

TURNAROUND TIME:  Standard  Rush (IF RUSH REQUESTED) Rush Due by:

SEND TO:

REPORT FORMAT:  Standard Report  Other/Specify:

DATE/TIME:

Standard Report + E2 PWSID#:

METHOD OF SHIPMENT:

### PAYMENT INFORMATION

Sampling/Pick-up Fee: \$  Composite Fee: \$  Rush Fee: \$ Amount Due: \$

Payment Method:  Credit Card Type:  Check #  Other:

Note: **LEAD SAMPLING FOR SCHOOL-BOE Regulations - \*IF BOTTLES ARE NOT FILLED TO THE 250ml LINE, THEY WILL BE REJECTED\***

sample #73-56 (Room 200 Bath Sink), time on EOC states 4:52 for collection; tag on bottle states 4:46 L.S. 5/22/25  
 291-ent confirmed time on chain (SM) 5/23/25

SAMPLE CUSTODY EXCHANGES MUST BE DOCUMENTED BELOW EACH TIME SAMPLES CHANGE POSSESSION

PLEASE PRINT YOUR NAME LEGIBLY, USE FULL LEGAL SIGNATURE, DATE AND TIME

Sampled by (PRINT): <b>Rebecca Sprague</b>	Signature: <i>Rebecca Sprague</i>	Date/Time: 5/20/25 4:53 AM
Client/Client's Representative (PRINT): <b>Rebecca Sprague</b>	Signature: <i>Rebecca Sprague</i>	Date/Time: 5/20/25 3:58 AM
1. Received/Relinquished by (PRINT): <b>Shelby Swensen</b>	Signature: <i>Shelby Swensen</i>	Date/Time: 5/22/25 11:08
2. Received/Relinquished by (PRINT): <b>LINDA SCHNEIDER</b>	Signature: <i>Linda Schneider</i>	Date/Time: 5/22/25 13:33

CHAIN OF CUSTODY RECORD - PRESS HARD AND PRINT CLEARLY - USE BALL POINT PEN  
 IMPORTANT: PRINTED NAMES & SIGNATURES ARE REQUIRED

5/23/25

# Garden State Laboratories, Inc.

**Main Lab - 410 Hillside Avenue, Hillside NJ 07205 - NJDEP Lab Cert. #20044**

**Jersey Shore Lab - 54 Main Street, Waretown NJ 08758 - NJDEP Lab Cert. #15037**

Tel. 800-273-8901/908-688-8900 Fax 908-688-8966 www.gslabs.com info@gslabs.com

### Office and Drop off Locations

North Jersey Office: 225 Sparta Avenue, Sparta, NJ 07871 Tel. 973-729-1827

West Jersey Office: 2050 Route 31 North, Glen Gardner, NJ 08826 Tel. 908-537-7414

FOR SAMPLE RECEIVING USE ONLY

DATE/TIME/TEMP. REC'D AT LAB:

5/22/25 13:33 No EOC

Page \_\_\_\_\_ of \_\_\_\_\_

**GSL CLIENT # TUC06**

MICRO #

CHEM. # 250522073-61-64

SAMPLE REC'D BY: mh 5/22/25

GSL FIELD SAMPLER/PICK-UP

PICK-UP AT DROP OFF LOCATION

DELIVERED BY CLIENT

### CLIENT INFORMATION (REPORT TO BE SENT TO)

Name: Tuckerton Borough BOE Contact/Authorized by: Rebecca Sprague/Brian Matthis

Mailing Address: 213 Marine St. Phone: 609-296-2858 X223

City/State/Zip: Tuckerton, NJ 08087 Fax:

### SAMPLE INFORMATION

SAMPLE TYPE: DW

SAMPLE LOCATION Tuckerton Elementary School - 213 Marine St, Tuckerton, NJ 08087

Grab	Comp	SAMPLE ID	SAMPLE COLLECTION				ANALYSIS REQUIRED (Print Legibly)	CONTAINER INFORMATION				Lab # Extension
			Date	Time	AM	PM		No.	Type*	Size	Pres.*	
X		Rm 101 water fountain	5/22/25	3:40am	X		Lead (First Draw)	1	P	250ml	A	
X		<del>Rm 102 sink</del> 211 @ 5/22/25	5/22/25	3:44am	X		Lead (First Draw)	1	P	250ml	A	
X		Rm 102 - water fountain	5/22/25	3:45 pm	X		Lead (First Draw)	1	P	250ml	A	
X		Rm 103 - sink	5/22/25	3:48 am	X		Lead (First Draw)	1	P	250ml	A	
X		Rm 103 - water fountain	5/22/25	3:50am	X		Lead (First Draw)	1	P	250ml	A	

⇒ \*Container type: P = Plastic G = Glass A = Amber Glass I = Sterile Ithio V = Vial Other/Specify: \_\_\_\_\_  
 ⇒ \*Preservation Code: A = Non Preserved B = Sulfuric Acid C = Sodium Hydroxide D = Nitric Acid  
 E = Hydrochloric Acid F = Zinc Acetate G = Sodium Ithiosulfate H = Ascorbic Acid I = Looera Other/Specify: \_\_\_\_\_

SUBCONTRACTED WORK

TURNAROUND TIME:  Standard  Rush (IF RUSH REQUESTED) Rush Due by:

SEND TO:

REPORT FORMAT:  Standard Report  Other/Specify:

DATE/TIME:

Standard Report + E2 PWSID#:

METHOD OF SHIPMENT:

### PAYMENT INFORMATION

Sampling/Pick-up Fee: \$  Composite Fee: \$  Rush Fee: \$ Amount Due: \$

Payment Method:  Credit Card Type:  Check #  Other:

Note: **LEAD SAMPLING FOR SCHOOL-BOE Regulations - \*IF BOTTLES ARE NOT FILLED TO THE 250ml LINE , THEY WILL BE REJECTED\***

**SAMPLE CUSTODY EXCHANGES MUST BE DOCUMENTED BELOW EACH TIME SAMPLES CHANGE POSSESSION**

**PLEASE PRINT YOUR NAME LEGIBLY, USE FULL LEGAL SIGNATURE, DATE AND TIME**

Sampled by (PRINT): Rebecca Sprague

Signature: *Rebecca Sprague*

Client/Client's Representative (PRINT): Rebecca Sprague

Signature: *Rebecca Sprague*

Date/Time: 5/20/25 3:40am

1. Received/Relinquished by (PRINT): Shelby Swensen

Signature: *Shelby Swensen*

Date/Time: 5/22/25 1108

2. Received/Relinquished by (PRINT): Megan Howanich

Signature: *Megan Howanich*

Date/Time: 5/22/25 13:33

CHAIN OF CUSTODY RECORD - PRESS HARD AND PRINT CLEARLY - USE BALL POINT PEN

IMPORTANT: PRINTED NAMES & SIGNATURES ARE REQUIRED

# Garden State Laboratories, Inc.

**Main Lab - 410 Hillside Avenue, Hillside NJ 07205 - NJDEP Lab Cert. #20044**  
**Jersey Shore Lab - 54 Main Street, Waretown NJ 08758 - NJDEP Lab Cert. #15037**  
 Tel. 800-273-8901/908-688-8900 Fax 908-688-8966 www.gslabs.com info@gslabs.com

FOR SAMPLE RECEIVING USE ONLY

DATE/TIME/TEMP. REC'D AT LAB:

5/23/25 8:53 No ROC

### Office and Drop off Locations

North Jersey Office: 225 Sparta Avenue, Sparta, NJ 07871 Tel. 973-729-1827  
 West Jersey Office: 2050 Route 31 North, Glen Gardner, NJ 08826 Tel. 908-537-7414

Page \_\_\_\_\_ of \_\_\_\_\_

**GSL CLIENT # TUC06**

### CLIENT INFORMATION (REPORT TO BE SENT TO)

Name: Tuckerton Borough BOE Contact/Authorized by: Rebecca Sprague/Brian Matthis  
 Mailing Address: 213 Marine St. Phone: 609-296-2858 X223  
 City/State/Zip: Tuckerton, NJ 08087 Fax:

MICRO #

CHEM. # 250522073-65-68

SAMPLE REC'D BY:

### SAMPLE INFORMATION

SAMPLE TYPE: DW  
 SAMPLE LOCATION: Tuckerton Elementary School - 213 Marine St, Tuckerton, NJ 08087

GSL FIELD SAMPLER/PICK-UP

PICK-UP AT DROP OFF LOCATION

DELIVERED BY CLIENT

Grab	Comp	SAMPLE ID	SAMPLE COLLECTION				ANALYSIS REQUIRED (Print Legibly)	CONTAINER INFORMATION				Lab # Extension
			Date	Time	AM	PM		No.	Type*	Size	Pres.*	
X		Field Blank	5/23/25	4:52 AM	X		1	P	250ml	A		
X		Rm 102 Sink	5/23/25	4:53 AM	X		1	P	250ml	A		
X		Main floor Girls Handicap sink	5/23/25	5:06 AM	X		1	P	250ml	A		
X		Main floor Boys Handicap sink	5/23/25	5:08 AM	X		1	P	250ml	A		

\*Container type: P=Plastic G=Glass A=Amber Glass I=Sterile Ithio V=Vial Other/Specify: \_\_\_\_\_  
 \*Preservation Code: A=Non Preserved B=Sulfuric Acid C=Sodium Hydroxide D=Nitric Acid  
 E=Hydrochloric Acid F=Zinc Acetate G=Sodium Inosulfate H=Ascorbic Acid I=Loose Other/Specify: \_\_\_\_\_

SUBCONTRACTED WORK

TURNAROUND TIME:  Standard  Rush (If RUSH REQUESTED) Rush Due by:

SEND TO:

REPORT FORMAT:  Standard Report  Other/Specify:

DATE/TIME:

Standard Report + E2 PWSID#:

METHOD OF SHIPMENT:

### PAYMENT INFORMATION

Sampling/Pick-up Fee: \$  Composite Fee: \$  Rush Fee: \$ Amount Due: \$

Payment Method:  Credit Card Type:  Check #  Other:

Note: **LEAD SAMPLING FOR SCHOOL-BOE Regulations - \*IF BOTTLES ARE NOT FILLED TO THE 250ml LINE , THEY WILL BE REJECTED\***

**SAMPLE CUSTODY EXCHANGES MUST BE DOCUMENTED BELOW EACH TIME SAMPLES CHANGE POSSESSION**  
**PLEASE PRINT YOUR NAME LEGIBLY, USE FULL LEGAL SIGNATURE, DATE AND TIME**

Sampled by (PRINT): <u>Rebecca Sprague</u>	Signature: <u>[Signature]</u>	
Client/Client's Representative (PRINT): <u>Rebecca Sprague</u>	Signature: <u>[Signature]</u>	Date/Time: <u>5/23/25 8:52 AM</u>
1. Received/Relinquished by (PRINT): <u>Rebecca Sprague - Stephen Marsh</u>	Signature: <u>[Signature]</u>	Date/Time: <u>5/23/25 8:53</u>
2. Received/Relinquished by (PRINT):	Signature:	Date/Time:

CHAIN OF CUSTODY RECORD - PRESS HARD AND PRINT CLEARLY - USE BALL POINT PEN

IMPORTANT: PRINTED NAMES & SIGNATURES ARE REQUIRED