

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax:cs@emsl.com
EMSL-CIN-01

EMSL Order ID: 012521274
LIMS Reference ID: AD21274
EMSL Customer ID: ATNJ23

Attention: Steve Leon
ATI [ATNJ23]
58 Route 46 Suite 229
Budd Lake, NJ 07828
(973) 349-6911
steve@trainwithati.com

Project Name: Freehold - Elton Adelphia

Customer PO:
EMSL Sales Rep: David Prince
Received: 05/19/2025 09:00
Reported: 06/04/2025 19:37

Analytical Results

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: 1/Men Bath Sink Aux Gym 2 Lims Reference ID: AD21274-01 Matrix: Drinking Water Sampled: 03/28/25 12:45:00									
Metals									
Lead	1.12		1	1.00	µg/L	05/29/25 16:06	06/04/25 12:00	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 2/Health Bathroom Sink Lims Reference ID: AD21274-02 Matrix: Drinking Water Sampled: 03/28/25 12:47:00									
Metals									
Lead	ND		1	1.00	µg/L	05/29/25 16:06	06/04/25 12:06	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 3/D Wing Boys Bath Lims Reference ID: AD21274-03 Matrix: Drinking Water Sampled: 03/28/25 12:49:00									
Metals									
Lead	ND		1	1.00	µg/L	05/29/25 16:06	06/04/25 12:08	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 4/A Wing Women Sink Lims Reference ID: AD21274-04 Matrix: Drinking Water Sampled: 03/28/25 12:50:00									
Metals									
Lead	ND		1	1.00	µg/L	05/29/25 16:06	06/04/25 12:10	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 5/Team Room A Boys Sink Lims Reference ID: AD21274-05 Matrix: Drinking Water Sampled: 03/28/25 12:52:00									
Metals									
Lead	8.9		1	1.00	µg/L	05/29/25 16:06	06/04/25 12:12	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 6/Main Office Left Bubbler Lims Reference ID: AD21274-06 Matrix: Drinking Water Sampled: 03/28/25 12:54:00									
Metals									
Lead	ND		1	1.00	µg/L	05/29/25 16:06	06/04/25 12:18	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 7/A Wing Mens Sink Lims Reference ID: AD21274-07 Matrix: Drinking Water Sampled: 03/28/25 12:56:00									
Metals									
Lead	ND		1	1.00	µg/L	05/29/25 16:06	06/04/25 12:19	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 8/Health Office Ice Maker Lims Reference ID: AD21274-08 Matrix: Drinking Water Sampled: 03/28/25 12:58:00									
Metals									
Lead	ND		1	1.00	µg/L	05/29/25 13:13	05/30/25 16:26	JW1	EPA 200.8 (Dig)/EPA 200.8
Sample: 9/A Wing Bubbler Lims Reference ID: AD21274-09 Matrix: Drinking Water Sampled: 03/28/25 13:00:00									
Metals									
Lead	ND		1	1.00	µg/L	05/29/25 16:06	06/04/25 12:21	PL	EPA 200.8 (DA)/EPA 200.8

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax:cs@emsl.com
EMSL-CIN-01

EMSL Order ID: 012521274
LIMS Reference ID: AD21274
EMSL Customer ID: ATNJ23

Attention: Steve Leon
ATI [ATNJ23]
58 Route 46 Suite 229
Budd Lake, NJ 07828
(973) 349-6911
steve@trainwithati.com

Project Name: Freehold - Elton Adelphia

Customer PO:
EMSL Sales Rep: David Prince
Received: 05/19/2025 09:00
Reported: 06/04/2025 19:37

Analytical Results
(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: 10/Faculty Serve Cafe Sink Lims Reference ID: AD21274-10 Matrix: Drinking Water Sampled: 03/28/25 13:03:00									
Metals									
Lead	ND		1	1.00	µg/L	05/29/25 16:06	06/04/25 12:23	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 11/RLA Restroom Sink Lims Reference ID: AD21274-11 Matrix: Drinking Water Sampled: 03/28/25 13:05:00									
Metals									
Lead	2.44		1	1.00	µg/L	05/29/25 16:06	06/04/25 12:25	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 12/Admin Mens 1st Floor Sink Lims Reference ID: AD21274-12 Matrix: Drinking Water Sampled: 03/28/25 13:07:00									
Metals									
Lead	3.28		1	1.00	µg/L	05/29/25 16:06	06/04/25 12:27	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 13/E Wing 2nd Floor of 201 Bubbler Lims Reference ID: AD21274-13 Matrix: Drinking Water Sampled: 03/28/25 13:09:00									
Metals									
Lead	ND		1	1.00	µg/L	05/29/25 16:06	06/04/25 12:33	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 14/Girls Locker Room Sink Lims Reference ID: AD21274-14 Matrix: Drinking Water Sampled: 03/28/25 13:11:00									
Metals									
Lead	1.28		1	1.00	µg/L	05/29/25 16:06	06/04/25 12:35	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 15/Custodial Room Sink Lims Reference ID: AD21274-15 Matrix: Drinking Water Sampled: 03/28/25 13:13:00									
Metals									
Lead	ND		1	1.00	µg/L	05/29/25 16:06	06/04/25 12:41	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 16/D Wing 2nd Floor Bubbler Lims Reference ID: AD21274-16 Matrix: Drinking Water Sampled: 03/28/25 13:15:00									
Metals									
Lead	ND		1	1.00	µg/L	05/29/25 16:06	06/04/25 12:42	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 17/B Wing Bubbler Lims Reference ID: AD21274-17 Matrix: Drinking Water Sampled: 03/28/25 13:17:00									
Metals									
Lead	ND		1	1.00	µg/L	05/29/25 16:06	06/04/25 12:44	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 18/D Wing Men Sink Lims Reference ID: AD21274-18 Matrix: Drinking Water Sampled: 03/28/25 13:18:00									
Metals									
Lead	3.97		1	1.00	µg/L	05/29/25 16:06	06/04/25 12:46	PL	EPA 200.8 (DA)/EPA 200.8

Attention: Steve Leon
ATI [ATNJ23]
58 Route 46 Suite 229
Budd Lake, NJ 07828
(973) 349-6911
steve@trainwithati.com

Project Name: Freehold - Elton Adelphia

Customer PO:
EMSL Sales Rep: David Prince
Received: 05/19/2025 09:00
Reported: 06/04/2025 19:37

Analytical Results (Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: 19/Athlete Trainer Sink									
Lims Reference ID:			AD21274-19		Matrix: Drinking Water			Sampled: 03/28/25 13:20:00	
Metals									
Lead	ND		1	1.00	µg/L	05/29/25 16:06	06/04/25 12:48	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 20/Boys Locker Room Sink									
Lims Reference ID:			AD21274-20		Matrix: Drinking Water			Sampled: 03/28/25 13:22:00	
Metals									
Lead	1.05		1	1.00	µg/L	05/29/25 16:06	06/04/25 12:50	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 21/D Wing Bubbler									
Lims Reference ID:			AD21274-21		Matrix: Drinking Water			Sampled: 03/28/25 13:25:00	
Metals									
Lead	ND		1	1.00	µg/L	05/29/25 16:15	06/04/25 13:02	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 22/RLA Gym Water Fountain									
Lims Reference ID:			AD21274-22		Matrix: Drinking Water			Sampled: 03/28/25 13:27:00	
Metals									
Lead	1.41		1	1.00	µg/L	05/29/25 16:15	06/04/25 13:08	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 23/E Wing Second Floor Bubbler									
Lims Reference ID:			AD21274-23		Matrix: Drinking Water			Sampled: 03/28/25 13:29:00	
Metals									
Lead	ND		1	1.00	µg/L	05/29/25 16:15	06/04/25 13:10	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 24/Women Sink D Wing									
Lims Reference ID:			AD21274-24		Matrix: Drinking Water			Sampled: 03/28/25 13:31:00	
Metals									
Lead	3.00		1	1.00	µg/L	05/29/25 16:15	06/04/25 13:12	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 25/Cafeteria Sink Main									
Lims Reference ID:			AD21274-25		Matrix: Drinking Water			Sampled: 03/28/25 13:33:00	
Metals									
Lead	ND		1	1.00	µg/L	05/29/25 16:15	06/04/25 13:14	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 26/Women Bath Sink Aux Gym 2									
Lims Reference ID:			AD21274-26		Matrix: Drinking Water			Sampled: 03/28/25 13:34:00	
Metals									
Lead	3.20		1	1.00	µg/L	05/29/25 16:15	06/04/25 13:20	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 27/B Wing Girls Bath Sink									
Lims Reference ID:			AD21274-27		Matrix: Drinking Water			Sampled: 03/28/25 13:36:00	
Metals									
Lead	2.04		1	1.00	µg/L	05/29/25 16:15	06/04/25 13:22	PL	EPA 200.8 (DA)/EPA 200.8

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax:cs@emsl.com
EMSL-CIN-01

EMSL Order ID: 012521274
LIMS Reference ID: AD21274
EMSL Customer ID: ATNJ23

Attention: Steve Leon
ATI [ATNJ23]
58 Route 46 Suite 229
Budd Lake, NJ 07828
(973) 349-6911
steve@trainwithati.com

Project Name: Freehold - Elton Adelphia

Customer PO:
EMSL Sales Rep: David Prince
Received: 05/19/2025 09:00
Reported: 06/04/2025 19:37

Analytical Results
(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: 28/Guidance Kitchen Sink Lims Reference ID: AD21274-28 Matrix: Drinking Water Sampled: 03/28/25 13:38:00									
Metals									
Lead	2.24		1	1.00	µg/L	05/29/25 16:15	06/04/25 13:24	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 29/A Wing Women Bathroom Sink Lims Reference ID: AD21274-29 Matrix: Drinking Water Sampled: 03/28/25 13:40:00									
Metals									
Lead	1.50		1	1.00	µg/L	05/29/25 16:15	06/04/25 13:25	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 30/C Wing 2nd Floor Bubbler Lims Reference ID: AD21274-30 Matrix: Drinking Water Sampled: 03/28/25 13:42:00									
Metals									
Lead	ND		1	1.00	µg/L	05/29/25 16:15	06/04/25 13:27	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 31/Cafeteria Bubbler Lims Reference ID: AD21274-31 Matrix: Drinking Water Sampled: 03/28/25 13:44:00									
Metals									
Lead	ND		1	1.00	µg/L	05/29/25 16:15	06/04/25 13:29	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 32/Ice Machine Athletic Trainer Lims Reference ID: AD21274-32 Matrix: Drinking Water Sampled: 03/28/25 13:46:00									
Metals									
Lead	ND		1	1.00	µg/L	05/29/25 13:13	05/30/25 16:29	JW1	EPA 200.8 (Dig)/EPA 200.8
Sample: 33/Boys Locker Room Sink Team Room Lims Reference ID: AD21274-33 Matrix: Drinking Water Sampled: 03/28/25 13:48:00									
Metals									
Lead	ND		1	1.00	µg/L	05/29/25 16:15	06/04/25 13:35	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 34/Health Office Sink Lims Reference ID: AD21274-34 Matrix: Drinking Water Sampled: 03/28/25 13:50:00									
Metals									
Lead	ND		1	1.00	µg/L	05/29/25 16:15	06/04/25 13:37	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 35/D Wing Boys Restroom Sink Lims Reference ID: AD21274-35 Matrix: Drinking Water Sampled: 03/28/25 13:52:00									
Metals									
Lead	8.53		1	1.00	µg/L	05/29/25 16:15	06/04/25 13:43	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 36/C Wing 2nd Floor #2 Bubbler Lims Reference ID: AD21274-36 Matrix: Drinking Water Sampled: 03/28/25 13:54:00									
Metals									
Lead	ND		1	1.00	µg/L	05/29/25 16:15	06/04/25 13:45	PL	EPA 200.8 (DA)/EPA 200.8

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax:cs@emsl.com
EMSL-CIN-01

EMSL Order ID: 012521274
LIMS Reference ID: AD21274
EMSL Customer ID: ATNJ23

Attention: Steve Leon
ATI [ATNJ23]
58 Route 46 Suite 229
Budd Lake, NJ 07828
(973) 349-6911
steve@trainwithati.com

Project Name: Freehold - Elton Adelphia

Customer PO:
EMSL Sales Rep: David Prince
Received: 05/19/2025 09:00
Reported: 06/04/2025 19:37

Analytical Results
(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: 37/Main Office Bathroom Lims Reference ID: AD21274-37 Matrix: Drinking Water Sampled: 03/28/25 13:56:00									
Metals									
Lead	1.65		1	1.00	µg/L	05/29/25 16:15	06/04/25 13:47	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 38/D Wing 2nd Fl #2 Bubbler Lims Reference ID: AD21274-38 Matrix: Drinking Water Sampled: 03/28/25 13:58:00									
Metals									
Lead	ND		1	1.00	µg/L	05/29/25 16:15	06/04/25 13:48	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 39/Attendance Office Bathroom Sink Lims Reference ID: AD21274-39 Matrix: Drinking Water Sampled: 03/28/25 13:59:00									
Metals									
Lead	3.61		1	1.00	µg/L	05/29/25 16:15	06/04/25 13:50	PL	EPA 200.8 (DA)/EPA 200.8
Sample: 40/Faculty Cafe Fountain Lims Reference ID: AD21274-40 Matrix: Drinking Water Sampled: 03/28/25 14:12:00									
Metals									
Lead	1.07		1	1.00	µg/L	05/29/25 16:15	06/04/25 13:52	PL	EPA 200.8 (DA)/EPA 200.8

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax:cs@emsl.com
EMSL-CIN-01

EMSL Order ID: 012521274**LIMS Reference ID:** AD21274**EMSL Customer ID:** ATNJ23

Attention: Steve Leon
ATI [ATNJ23]
58 Route 46 Suite 229
Budd Lake, NJ 07828
(973) 349-6911
steve@trainwithati.com

Project Name: Freehold - Elton Adelphia

Customer PO:
EMSL Sales Rep: David Prince
Received: 05/19/2025 09:00
Reported: 06/04/2025 19:37

Certified Analyses included in this Report

Analyte	Certifications
<i>EPA 200.8 in Drinking Water</i>	
Lead	NJDEP

List of Certifications

Code	Description	Number	Expires
PADEP	Pennsylvania Department of Environmental Protection	2845.25	11/30/2025
NYSDOH	New York State Department of Health ELAP	10872	04/01/2025
NJDEP	New Jersey Department of Environmental Protection	03036	06/30/2025
MADEP	Massachusetts Department of Environmental Protection	M-NJ337	06/30/2025
CTDPH	Connecticut Department of Public Health	PH-0270	06/23/2026
California ELAP	California Water Boards	1877	06/30/2025
AIHA LAP	American Industrial Hygiene Association (AIHA LAP, LLC)	100194	05/01/2025
A2LA	A2LA Environmental Certificate	2845.01	07/31/2026

Please see the specific Field of Testing (FOT) on www.emsl.com <<http://www.emsl.com>> for a complete listing of parameters for which EMSL is certified.

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax:cs@emsl.com
EMSL-CIN-01

EMSL Order ID: 012521274
LIMS Reference ID: AD21274
EMSL Customer ID: ATNJ23

Attention: Steve Leon
ATI [ATNJ23]
58 Route 46 Suite 229
Budd Lake, NJ 07828
(973) 349-6911
steve@trainwithati.com

Project Name: Freehold - Elton Adelphia

Customer PO:
EMSL Sales Rep: David Prince
Received: 05/19/2025 09:00
Reported: 06/04/2025 19:37

Notes and Definitions

Item	Definition
P2	Sample was preserved at the lab prior to analysis.
(Dig)	For metals analysis, sample was digested.
[2C]	Reported from the second channel in dual column analysis.
DA	Direct Analysis
DF	Dilution Factor
MDL	Method Detection Limit.
ND	Analyte was NOT DETECTED at or above the detection limit.
NR	Spike/Surrogate showed no recovery.
Q	Qualifier
RCS	Respirable Crystalline Silica
RL	Reporting Limit
Wet	Sample is not dry weight corrected.

Measurement of uncertainty and any applicable definitions of method modifications are available upon request. Per EPA NLLAP policy, sample results are not blank corrected.

Owen McKenna Laboratory Manager or other approved signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted.

Lead Chain of Custody

EMSL Order Number / Lab Use Only


EMSL Analytical, Inc.
200 Route 130 North
Cinnaminson, NJ 08077

EMSL ANALYTICAL, INC.
TESTING LABS • PRODUCTS • TRAINING


PHONE: (800) 220-3675

EMAIL: CinnaminsonLeadLab@emsl.com

AD 21274

Customer Information	Customer ID: ATI (ATNJ23)		Billing ID:	
	Company Name: ATI (Alfa Training International)		Company Name: Same as customer info	
	Contact Name: Steve Leon		Billing Contact:	
	Street Address: 58 Route 46 Suite 229		Street Address:	
	City, State, Zip: Budd Lake, NJ 07828	Country:	City, State, Zip:	Country:
Phone: 9733496911		Phone:		
Email(s) for Report: steve@trainwithati.com		Email(s) for Invoice:		
Project Information				
Project Name/No: Freehold - Elton Adelphia			Purchase Order:	
EMSL LIMS Project ID: (If applicable, EMSL will provide)		US State where samples collected:	State of Connecticut (CT) must select project location: ☐ Commercial (Taxable) ☐ Residential (Non-Taxable)	
Sampled By Name: Steve Leon		Sampled By Signature: 		No. of Samples in Shipment
Turn-Around-Time (TAT)				
☐ 3 Hour ☐ 6 Hour ☐ 24 Hour ☐ 32 Hour ☐ 48 Hour ☐ 72 Hour ☐ 96 Hour ☐ 1 Week ☒ 2 Week				
Please call ahead for large projects and/or turnaround times 6 Hours or Less. *32 Hour TAT available for select tests only; samples must be submitted by 11:30am.				
MATRIX	METHOD	INSTRUMENT	REPORTING LIMIT	SELECTION
CHIPS ☐ % by wt. ☐ ppm (mg/kg) ☐ mg/cm ²	SW 846-7000B	Flame Atomic Absorption	0.008% (80ppm)	☐
*Reporting Limit based on a minimum 0.25g sample weight. **Not appropriate for Ceramic Tiles - XRF is recommended	SW 846-6010D*	ICP-OES	0.0004% (4ppm)	☐
AIR	NIOSH 7082	Flame Atomic Absorption	4µg/filter	☐
	NIOSH 7300M / NIOSH 7303M	ICP-OES	0.5µg/filter	☐
	NIOSH 7300M / NIOSH 7303M	ICP-MS	0.05µg/filter	☐
WIPE ☐ ASTM ☐ NON-ASTM	SW 846-7000B	Flame Atomic Absorption	10µg/wipe	☐
If no box is checked, non-ASTM Wipe is assumed	SW 846-6010D	ICP-OES	1.0µg/wipe	☐
TCLP	SW 846-1311 / 7000B / SM 3111B	Flame Atomic Absorption	0.4 mg/L (ppm)	☐
	SW 846-1311 / SW 846-6010D*	ICP-OES	0.1 mg/L (ppm)	☐
SPLP	SW 846-1312 / 7000B / SM 3111B	Flame Atomic Absorption	0.4 mg/L (ppm)	☐
	SW 846-1312 / SW 846-6010D*	ICP-OES	0.1 mg/L (ppm)	☐
TTLC	22 CCR App. II, 7000B	Flame Atomic Absorption	40mg/kg (ppm)	☐
	22 CCR App. II, SW 846-6010D*	ICP-OES	2mg/kg (ppm)	☐
STLC	22 CCR App. II, 7000B	Flame Atomic Absorption	0.4 mg/L (ppm)	☐
	22 CCR App. II, SW 846-6010D*	ICP-OES	0.1 mg/L (ppm)	☐
Soil	SW 846-7000B	Flame Atomic Absorption	40mg/kg (ppm)	☐
	SW 846-6010D*	ICP-OES	2mg/kg (ppm)	☐
Wastewater	SM 3111B / SW 846-7000B	Flame Atomic Absorption	0.4 mg/L (ppm)	☐
Unpreserved ☐	EPA 200.7	ICP-OES	0.020 mg/L (ppm)	☐
Preserved with HNO3 ☐ PH<2	EPA 200.5	ICP-OES	0.003 mg/L (ppm)	☐
Drinking Water	EPA 200.8	ICP-MS	0.001 mg/L (ppm)	☒
Unpreserved ☒				☐
Preserved with HNO3 ☐ PH<2				☐
TSP/SPM Filter	40 CFR Part 50	ICP-OES	12 µg/filter	☐
Other:				☐

Sample Number	Sample Location	Volume / Area	Date / Time Sampled
1	Men Bath Sink Aux Gym 2	200 uL	3/28/25 12:45
2	Health Bathroom Sink	200 uL	3/28/25 12:47
3	D Wing Boys Bath	200 uL	3/28/25 12:49
4	A Wing Women Sink	200 uL	3/28/25 12:50
5	Team Room A Boys Sink	200 uL	3/28/25 12:52

Method of Shipment: Preserved w/ HNO3 @ 10% v/v		Sample Condition Upon Receipt: 1'	
Relinquished by: Steve Leon	Date/Time: 3/28/25	Relinquished by: EC - WI	Date/Time: 5/16/25 12:50pm
Relinquished by:	Date/Time:	Relinquished by:  (CP)	Date/Time: 5/19/25 0900

Controlled Document - CQC-25 Lead R17 05/09/2022

*6010C Available Upon Request

☐ AGREE TO ELECTRONIC SIGNATURE (By checking, I consent to signing this Chain of Custody document by electronic signature.)

EMSL Analytical, Inc.'s Laboratory Terms and Conditions are incorporated into this Chain of Custody by reference in their entirety. Submission of samples to EMSL Analytical, Inc. constitutes acceptance and acknowledgment of all terms and conditions by Customer.

Page 8 of 10

Lead Chain of Custody

EMSL Order Number / Lab Use Only

EMSL Analytical, Inc.
200 Route 130 North
Cinnaminson, NJ 08077

EMSL ANALYTICAL, INC.
TESTING LABS • PRODUCTS • TRAINING

A021274

PHONE: (800) 220-3675

EMAIL: CinnaminsonLeadLab@emsl.com

Additional Pages of the Chain of Custody are only necessary if needed for additional sample information

Special Instructions and/or Regulatory Requirements (Sample Specifications, Processing Methods, Limits of Detection, etc.)

Sample Number	Sample Location	Volume / Area	Date / Time Sampled
6	Main Office Left Bubble	200 uL	3/28/25 12:54
7	HWing Men Sink	200 uL	3/28/25 12:54
8	Health Office Tee Maker	200 uL	3/28/25 12:58
9	HWing Bubble	200 uL	3/28/25 1:00
10	Faculty Service Life Sink	200 uL	3/28/25 1:03
11	RLA Restroom Sink	200 uL	3/28/25 1:05
12	Admin Mens 1st Floor Sink	200 uL	3/28/25 1:07
13	EWing 2nd Floor 201 Bubble	200 uL	3/28/25 1:09
14	Girls Locker Room Sink	200 uL	3/28/25 1:11
15	Restroom 1004 Sink	200 uL	3/28/25 1:13
16	DWing 2nd Floor Bubble	200 uL	3/28/25 1:15
17	BWing Bubble	200 uL	3/28/25 1:17
18	DWing Men Sink	200 uL	3/28/25 1:18
19	Athlete Trainer Sink	200 uL	3/28/25 1:20
20	Boys Locker Room Sink	200 uL	3/28/25 1:22
21	DWing Bubble	200 uL	3/28/25 1:25
22	RLA Gym Water Fountain	200 uL	3/28/25 1:27
23	EWing Second Floor Bubble	200 uL	3/28/25 1:29
24	Women Sink DWing	200 uL	3/28/25 1:31
25	Cafeteria Sink Main	200 uL	3/28/25 1:33
26	Women Bath Sink Aux 2	200 uL	3/28/25 1:34
27	BWing Girls Bath Sink	200 uL	3/28/25 1:36
28	Guidance Kitchen Sink	200 uL	3/28/25 1:38
29	HWing Women Restroom Sink	200 uL	3/28/25 1:40
30	EWing 2nd Floor Bubble	200 uL	3/28/25 1:42

Method of Shipment:

Sample Condition Upon Receipt:

Relinquished by:

Date/Time:

Received by:

Date/Time:

Relinquished by:

Date/Time:

Received by:

Date/Time:

Controlled Document - C0C-25 Lead R17 05/09/2022

☐ AGREE TO ELECTRONIC SIGNATURE (By checking, I consent to signing this Chain of Custody document by electronic signature.)

EMSL Analytical, Inc.'s Laboratory Terms and Conditions are incorporated into this Chain of Custody by reference in their entirety. Submission of samples to EMSL Analytical, Inc. constitutes acceptance and acknowledgment of all terms and conditions by Customer.

Emsl Order Number / Lab Use Only

EMAIL: CinnaminsonLeadLab@emsl.com

Additional Pages of the Chain of Custody are only necessary if needed for additional sample information

Special Instructions and/or Regulatory Requirements (Sample Specifications, Processing Methods, Limits of Detection, etc.)

AD21274

Method of Shipment:		Sample Condition Upon Receipt:	
Relinquished by:	Date/Time:	Received by: KCC - WI	Date/Time 5/16/20 12:
Relinquished by:	Date/Time:	Received by:	Date/Time

Controlled Document - COC-25 Lead R17 05/09/2022

☐ **AGREE TO ELECTRONIC SIGNATURE** (By checking, I consent to signing this Chain of Custody document by electronic signature.)

EMSL Analytical, Inc.'s Laboratory Terms and Conditions are incorporated into this Chain of Custody by reference in their entirety. Submission of samples to EMSL Analytical, Inc. constitutes acceptance and acknowledgment of all terms and conditions by Customer.