



part of
ALS Limited

Specialists in Drinking Water Testing Technologies ■ Residential ■ Industrial ■ Municipal

York Analytical Laboratory A Division of ALS Limited

2161 WHITESVILLE ROAD TOMS RIVER, NJ 08755 PHONE 732-914-1515 FAX 732-914-1616

NJ Lab Cert. # 15001

CERTIFICATE OF ANALYSIS

Customer : Strategic Environmental
25 Butternut Lane
Bayville, NJ 08721

Project ID : Red Bank Primary School, 222 River Road, Red Bank NJ 07710

PAS Project ID : P25-00622

Matrix : Drinking Water

Report Date : 1/24/2025

| PAS Sample ID | Client ID | Analysis | Results | Units | DF | PQL | MDL | MCL | Method | Date Sampled | Date Analyzed |
|---------------|------------------------|----------|---------|-------|----|------|-------|--------|-----------|---------------|---------------|
| P25-00622-01 | PS18FP209G KT 1st Draw | Lead | ND | ug/L | 1 | 2.00 | 0.900 | 15.0 * | SM 3113 B | 1/21/25 06:33 | 1/22/25 15:06 |
| | | | | | | | | | | | |
| P25-00622-02 | PS18FP209G Flush | Lead | ND | ug/L | 1 | 2.00 | 0.900 | 15.0 * | SM 3113 B | 1/21/25 06:33 | 1/22/25 15:10 |

Except for the parameters tested, York Analytical makes no representation as to the fitness or quality of the water sample taken.

PQL = Practical Quantitation Limit

MDL = Minimum Detection Limit

MCL = Maximum Contaminant Level

DF = Dilution Factor

ND = Analyzed for but not detected

J = Estimated result

* Federal Action Level

All samples are analyzed in accordance with
New Jersey Department of Environmental
Protection Protocol

Kelly Hogan - Quality Assurance Officer

Customer: Strategic Environmental Services
Address: 25 Butternut Lane
Bayville, NJ 08721
Phone: (732) 269-4204

School Name: Red Bank Primary School
School Address: 222 River Road Red Bank
Sampled By: [Signature] 07710
Print Name: JBonanno
RESULTS TO: ibonnes@aol.com

| Sample ID Location | Date / Time Sampled | Matrix Code | Grab or Comp | Flush Sample | Fiber Present | # Containers | Glass or Plastic | Analysis | LAB ID |
|--------------------------|---------------------|-------------|--------------|--------------|---------------|--------------|------------------|----------|--------------|
| PS18 FP 2096 KT 1st Draw | 6:33 am | DW | Grab | | | 1 | 250 ml Plastic | Lead | P2S-00622-01 |
| PS18 FP 2096 Flush | 6:33 am | DW | Grab | | | 1 | 250 ml Plastic | Lead | P2S-00622-02 |
| | | DW | Grab | | | 1 | 250 ml Plastic | Lead | |
| | | DW | Grab | | | 1 | 250 ml Plastic | Lead | |
| | | DW | Grab | | | 1 | 250 ml Plastic | Lead | |
| | | DW | Grab | | | 1 | 250 ml Plastic | Lead | |
| | | DW | Grab | | | 1 | 250 ml Plastic | Lead | |
| | | DW | Grab | | | 1 | 250 ml Plastic | Lead | |
| | | DW | Grab | | | 1 | 250 ml Plastic | Lead | |
| | | DW | Grab | | | 1 | 250 ml Plastic | Lead | |
| | | DW | Grab | | | 1 | 250 ml Plastic | Lead | |
| | | DW | Grab | | | 1 | 250 ml Plastic | Lead | |
| | | DW | Grab | | | 1 | 250 ml Plastic | Lead | |
| | | DW | Grab | | | 1 | 250 ml Plastic | Lead | |
| | | DW | Grab | | | 1 | 250 ml Plastic | Lead | |
| | | DW | Grab | | | 1 | 250 ml Plastic | Lead | |
| | | DW | Grab | | | 1 | 250 ml Plastic | Lead | |
| | | DW | Grab | | | 1 | 250 ml Plastic | Lead | |
| | | DW | Grab | | | 1 | 250 ml Plastic | Lead | |
| | | DW | Grab | | | 1 | 250 ml Plastic | Lead | |
| | | DW | Grab | | | 1 | 250 ml Plastic | Lead | |

SAMPLES REC'D UNPRESERVED. PRESERVED IN LAB.

Page 1 of 1 Deliverables: PDF Std. ☒ PDF Reduce ☐ PDF Full ☐ EDD ☐ Date/Time Preserved with HNO3: 1000 on 11/01 ^{TF}

MATRIX CODES: GW = Ground Water, WW = Waste Water, SW = Surface Water, DW = Drinking Water, S = Soil, L = Liquid, SD = Sludge, B = Blank, K = Solid (specify):

PRESERVATIVE CODES: 0 = Ice, 1 = HCl, 2 = H2SO4, 3 = NaOH, 4 = HNO3, 5 = Other

| | Print Name: | Signature: | Company: | Date + Time |
|---------------|-------------------|-------------|----------|-------------|
| Relinquished: | JBonanno SEC Inc. | [Signature] | | 11/21/25 |
| Received: | LAURE FIDLEY VIC | [Signature] | | 09: AM |
| Relinquished: | | | | |
| Received: | | | | |
| Relinquished: | | | | |
| Received: | | | | |

* Retest of Kettle after Repairing Jan 2025