



Red Bank Borough Public Schools

Dream BIG...We'll Help You Get There!

76 Branch Avenue | Red Bank, NJ 07701
732-758-1507 | 732-212-1356 (FAX)
rbb.k12.nj.us | @RedBankSup | rumagej@rbb.k12.nj.us

Jared J. Rumage, Ed.D.
Superintendent of Schools



February 3, 2025

Dear Red Bank Borough School District Community,

Our school system is committed to protecting student, teacher, and staff health. To protect our community and be in compliance with the Department of Education regulations, Red Bank Borough School District tested our schools' drinking water for lead. There was one sample location of drinking water/food preparation with a result greater than the action level of 15 µg/l (parts per billion [ppb]). It was located in the cafeteria kitchen kettle. This kettle had not been used in food preparation for over 2 years. However, since the kettle could potentially be put back into service, it was disconnected, new supply lines and faucet were installed and the kettle was retested.

No results were over the allowable limits at the Primary School.

A copy of the test results is available on the school website under the Business Office tab and in our central office for inspection by the public, including students, teachers, other school personnel, and parents, and can be viewed between the hours of 8:30 a.m. and 3:30 p.m. For more information about water quality in our schools, contact Thomas Berger, Director of Facilities at the Red Bank Borough School District, 732-758-1500 x1505.

Sincerely,

Jared J. Rumage, Ed.D.

Superintendent of Schools



Red Bank Borough Public Schools

Dream BIG...We'll Help You Get There!

76 Branch Avenue | Red Bank, NJ 07701
732-758-1507 | 732-212-1356 (FAX)
rbb.k12.nj.us | @RedBankSup | rumagej@rbb.k12.nj.us

Jared J. Rumage, Ed.D.
Superintendent of Schools



3 de febrero de 2025

Estimada comunidad del Distrito Escolar del Municipio de Red Bank,

Nuestro sistema escolar está comprometido a proteger la salud de los estudiantes, maestros y personal. Para proteger a nuestra comunidad y estar en conformidad con las regulaciones del Departamento de Educación, el Distrito Escolar del Municipio de Red Bank analizó el agua potable de nuestras escuelas para plomo. Hubo una ubicación de muestra de agua potable/preparación de alimentos con un resultado superior al nivel de acción de 15 µg/l (partes por billón [ppb]). Se encontraba en el hervidor de la cocina de la cafetería. Este hervidor no se había utilizado en la preparación de alimentos durante más de 2 años. Sin embargo, dado que el hervidor podía volver a ponerse en servicio, se desconectó, se instalaron nuevos conductos de suministro y un grifo y se volvió a analizar el hervidor.

Ningún resultado superó los límites permitidos en la Escuela Primaria.

Una copia de los resultados de la prueba está disponible en el sitio web de la escuela bajo la pestaña Oficina de Negocios y en nuestra oficina central para la inspección por el público, incluidos los estudiantes, maestros, otro personal de la escuela, y los padres, y se puede ver entre las horas de 8:30 a.m. y 3:30 p.m. Para obtener más información acerca de la calidad del agua en nuestras escuelas, póngase en contacto con Thomas Berger, Director de Instalaciones en el Distrito Escolar del Municipio de Red Bank, 732-758-1500 x1505.

Atentamente,

Jared J. Rumage, Ed.D.

Superintendente de Escuelas