

June 11, 2025

Zach Nannestad Douglas County School District 2812 N. Highway 85 Castle Rock, CO 80109

Re: DCSD Wilcox Building 620 Wilcox St, Castle Rock, CO 80104 Radon Sampling Assessment

Dear Mr. Nannestad

Quality Environmental Services & Technologies Inc. (QUEST) is pleased to assist Douglas County School District with the ongoing radon survey of its schools. At your request, QUEST conducted radon testing at Wilcox School, located at 620 Wilcox St.

Nineteen (19) AirChek radon test kits were placed on June 3, 2025, and (19) were retrieved on June 5, 2025. The attached laboratory results specify radon concentrations to be all within the EPA guideline of 4 pCi/L for acceptable radon concentrations.

If you have any questions, or if we may be of additional assistance, please contact QUEST, Inc. at 303-935-1573. We look forward to our continued association.

Sincerely,

Robert A. Woellner

Robeld W.M.

President/Industrial Hygienist

NEHA: NRPP Certification #105324RT

Attachment: Laboratory Report

Mertited

Robert Head Environmental Technician NRPP Certified Field Technician

Radon test result report for: WILCOX BUILDING MAIN

Kit #	Room Id	Started	Ended	pCi/L	Analyzed
11546783	101	2025-06-03 @ 11:00 am	2025-06-05 @ 12:00 pm	< 0.3	2025-06-09
11546784	101	2025-06-03 @ 11:00 am	2025-06-05 @ 12:00 pm	0.9	2025-06-09
11546785	101 (D)	2025-06-03 @ 11:00 am	2025-06-05 @ 12:00 pm	< 0.3	2025-06-09
11546782	103	2025-06-03 @ 11:00 am	2025-06-05 @ 12:00 pm	0.5	2025-06-09
12073899	112	2025-06-03 @ 11:00 am	2025-06-05 @ 12:00 pm	< 0.3	2025-06-09
12073894	113	2025-06-03 @ 11:00 am	2025-06-05 @ 12:00 pm	< 0.3	2025-06-09
12073896	120	2025-06-03 @ 11:00 am	2025-06-05 @ 12:00 pm	2.2	2025-06-09
11546777	BRIDGET SANTOYA	2025-06-03 @ 11:00 am	2025-06-05 @ 12:00 pm	0.6	2025-06-09
11546781	CINDY CLOSE	2025-06-03 @ 11:00 am	2025-06-05 @ 12:00 pm	< 0.3	2025-06-09
12073895	CUSTODIAL	2025-06-03 @ 11:00 am	2025-06-05 @ 12:00 pm	0.9	2025-06-09
11546775	ELIZABETH MAI	2025-06-03 @ 11:00 am	2025-06-05 @ 12:00 pm	< 0.3	2025-06-09
11546776	ELIZABETH MAI (D)	2025-06-03 @ 11:00 am	2025-06-05 @ 12:00 pm	< 0.3	2025-06-09
11546778	JENNIFER HUBBARD	2025-06-03 @ 11:00 am	2025-06-05 @ 12:00 pm	0.6	2025-06-09
12073900	LOUNGE	2025-06-03 @ 11:00 am	2025-06-05 @ 12:00 pm	0.6	2025-06-09
11546773	MAIN ROOM N	2025-06-03 @ 11:00 am	2025-06-05 @ 12:00 pm	< 0.3	2025-06-09
11546774	MAIN ROOM S	2025-06-03 @ 11:00 am	2025-06-05 @ 12:00 pm	0.5	2025-06-09
11546779	MISTY BURKHART	2025-06-03 @ 11:00 am	2025-06-05 @ 12:00 pm	< 0.3	2025-06-09
12073898	NURSE OFFICE	2025-06-03 @ 11:00 am	2025-06-05 @ 12:00 pm	1.0	2025-06-09
12073897	NURSE OFFICE (INTERIOR OFFICE)	2025-06-03 @ 11:00 am	2025-06-05 @ 12:00 pm	0.9	2025-06-09

Air Chek 1936 Butler Bridge Rd, Mills River, NC 28759-3892 Phone: (828) 684-0893 Fax: (828) 684-8498