



June 13, 2025

Zach Nannestad
Douglas County School District
2812 N. Highway 85
Castle Rock, CO 80109

**Re: Larkspur Elementary School
1103 Perry Park Ave, Larkspur, CO 80118
Radon Sampling Assessment**

Dear Mr. Nannestad

Quality Environmental Services & Technologies Inc. (QUEST) is pleased to assist Douglas County School District with the ongoing radon survey of its schools. At your request, QUEST conducted radon testing at Larkspur Elementary School, located at 1103 Perry Park Ave.

Thirty-six (36) AirChek radon test kits were placed on May 28, 2025, and (36) were retrieved on May 30, 2025. The attached laboratory results specify radon concentrations to be all within the EPA guideline of 4 pCi/L for acceptable radon concentrations.

If you have any questions, or if we may be of additional assistance, please contact QUEST, Inc. at 303-935-1573. We look forward to our continued association.

Sincerely,

A handwritten signature in black ink, appearing to read "Robert A. Woellner".

Robert A. Woellner
President/Industrial Hygienist
NEHA: NRPP Certification #105324RT

A handwritten signature in black ink, appearing to read "Robert Head".

Robert Head
Environmental Technician
NRPP Certified Field Technician

Attachment: Laboratory Report

Radon test result report for:
LARKSPUR ES
MAIN

Kit #	Room Id	Started	Ended	pCi/L	Analyzed
12073904	10	2025-05-28 @ 11:00 am	2025-05-30 @ 12:00 pm	< 0.3	2025-06-02
12073901	11	2025-05-28 @ 11:00 am	2025-05-30 @ 12:00 pm	< 0.3	2025-06-02
12073905	12	2025-05-28 @ 11:00 am	2025-05-30 @ 12:00 pm	< 0.3	2025-06-02
12073907	13	2025-05-28 @ 11:00 am	2025-05-30 @ 12:00 pm	< 0.3	2025-06-02
12073906	14	2025-05-28 @ 11:00 am	2025-05-30 @ 12:00 pm	< 0.3	2025-06-02
12073929	20	2025-05-28 @ 11:00 am	2025-05-30 @ 12:00 pm	< 0.3	2025-06-02
12073930	21	2025-05-28 @ 11:00 am	2025-05-30 @ 12:00 pm	< 0.3	2025-06-02
12073933	23	2025-05-28 @ 11:00 am	2025-05-30 @ 12:00 pm	< 0.3	2025-06-02
12073909	24	2025-05-28 @ 11:00 am	2025-05-30 @ 12:00 pm	< 0.3	2025-06-02
12073908	25	2025-05-28 @ 11:00 am	2025-05-30 @ 12:00 pm	< 0.3	2025-06-02
12073910	26	2025-05-28 @ 11:00 am	2025-05-30 @ 12:00 pm	< 0.3	2025-06-02
12073913	27	2025-05-28 @ 11:00 am	2025-05-30 @ 12:00 pm	< 0.3	2025-06-02
12073912	27 (B)	2025-05-28 @ 11:00 am	2025-05-30 @ 12:00 pm	< 0.3	2025-06-02
12073911	27 (D)	2025-05-28 @ 11:00 am	2025-05-30 @ 12:00 pm	< 0.3	2025-06-02
12073928	34	2025-05-28 @ 11:00 am	2025-05-30 @ 12:00 pm	< 0.3	2025-06-02
12073925	35	2025-05-28 @ 11:00 am	2025-05-30 @ 12:00 pm	< 0.3	2025-06-02
12073926	37	2025-05-28 @ 11:00 am	2025-05-30 @ 12:00 pm	< 0.3	2025-06-02
12073914	39	2025-05-28 @ 11:00 am	2025-05-30 @ 12:00 pm	< 0.3	2025-06-02
12073915	41	2025-05-28 @ 11:00 am	2025-05-30 @ 12:00 pm	< 0.3	2025-06-02
12073916	44	2025-05-28 @ 11:00 am	2025-05-30 @ 12:00 pm	< 0.3	2025-06-02
12073917	45	2025-05-28 @ 11:00 am	2025-05-30 @ 12:00 pm	< 0.3	2025-06-02
12073918	46	2025-05-28 @ 11:00 am	2025-05-30 @ 12:00 pm	< 0.3	2025-06-02
12073919	47	2025-05-28 @ 11:00 am	2025-05-30 @ 12:00 pm	< 0.3	2025-06-02
12073920	48	2025-05-28 @ 11:00 am	2025-05-30 @ 12:00 pm	< 0.3	2025-06-02
12073921	49	2025-05-28 @ 11:00 am	2025-05-30 @ 12:00 pm	< 0.3	2025-06-02
12073922	50	2025-05-28 @ 11:00 am	2025-05-30 @ 12:00 pm	< 0.3	2025-06-02
12073924	51	2025-05-28 @ 11:00 am	2025-05-30 @ 12:00 pm	< 0.3	2025-06-02
12073923	51 (D)	2025-05-28 @ 11:00 am	2025-05-30 @ 12:00 pm	< 0.3	2025-06-02
12073932	56	2025-05-28 @ 11:00 am	2025-05-30 @ 12:00 pm	< 0.3	2025-06-02
12074005	6	2025-05-28 @ 11:00 am	2025-05-30 @ 12:00 pm	< 0.3	2025-06-02
12073902	8	2025-05-28 @ 11:00 am	2025-05-30 @ 12:00 pm	< 0.3	2025-06-02
12073903	9	2025-05-28 @ 11:00 am	2025-05-30 @ 12:00 pm	< 0.3	2025-06-02
12074003	GYM N	2025-05-28 @ 11:00 am	2025-05-30 @ 12:00 pm	< 0.3	2025-06-02
12074002	GYM S	2025-05-28 @ 11:00 am	2025-05-30 @ 12:00 pm	< 0.3	2025-06-02
12074001	GYM S (D)	2025-05-28 @ 11:00 am	2025-05-30 @ 12:00 pm	< 0.3	2025-06-02
12073931	LIBRARY	2025-05-28 @ 11:00 am	2025-05-30 @ 12:00 pm	< 0.3	2025-06-02