



June 17, 2025

Zach Nannestad  
Douglas County School District  
2812 N. Highway 85  
Castle Rock, CO 80109

**Re: DCSD Bridge North  
8250 Park Meadows Dr., in Lone Tree, CO  
Radon Sampling Assessment**

Dear Mr. Nannestad:

Quality Environmental Services & Technologies Inc. (QUEST) is pleased to assist Douglas County School District with the ongoing radon survey of its schools. At your request, QUEST conducted radon testing at Bridge North, located at 8250 Park Meadows Drive in Lone Tree, Colorado.

Eight (8) AirChek radon test kits were placed on June 3, 2025, and they were retrieved on June 5, 2025. The attached laboratory results specify radon concentrations to be all within the EPA guideline of 4 pCi/L for acceptable radon concentrations.

If you have any questions, or if we may be of additional assistance, please contact QUEST, Inc. at 303-935-1573. We look forward to our continued association.

Sincerely,

A handwritten signature in black ink, appearing to read "Robert A. Woellner".

Robert A. Woellner  
Founder/Industrial Hygienist  
NEHA: NRPP Certification #105324RT

A handwritten signature in black ink, appearing to read "Robert Head".

Robert Head  
Environmental Technician

Attachment: Laboratory Report

---

June 9, 2025

**\*\* LABORATORY ANALYSIS REPORT \*\***

---

Radon test result report for:  
**DCSD - BRIDGE NORTH  
MAIN**

---

Kit #	Room Id	Started	Ended	pCi/L	Analyzed
12073890	100	2025-06-03 @ 11:00 am	2025-06-05 @ 11:00 am	2.2	2025-06-09
12073891	100	2025-06-03 @ 11:00 am	2025-06-05 @ 11:00 am	2.4	2025-06-09
12073893	100 (B)	2025-06-03 @ 11:00 am	2025-06-05 @ 11:00 am	< 0.3	2025-06-09
12073892	100 (D)	2025-06-03 @ 11:00 am	2025-06-05 @ 11:00 am	2.5	2025-06-09
12073888	101	2025-06-03 @ 11:00 am	2025-06-05 @ 11:00 am	4.0	2025-06-09
12073886	LOUNGE	2025-06-03 @ 11:00 am	2025-06-05 @ 11:00 am	3.5	2025-06-09
12073889	NE CLASSROOM	2025-06-03 @ 11:00 am	2025-06-05 @ 11:00 am	2.8	2025-06-09
12073887	OFFICE	2025-06-03 @ 11:00 am	2025-06-05 @ 11:00 am	3.9	2025-06-09

---

Air Chek 1936 Butler Bridge Rd, Mills River, NC 28759-3892 Phone: (828) 684-0893 Fax: (828) 684-8498