

June 17, 2025

Zach Nannestad Douglas County School District 2812 N. Highway 85 Castle Rock, CO 80109

Re: North Transportation

8236 Carder Court in Littleton, CO 80125

Radon Sampling Assessment

Dear Mr. Nannestad:

Quality Environmental Services & Technologies Inc. (QUEST) is pleased to assist Douglas County School District with the ongoing radon survey of its schools. At your request, QUEST conducted radon testing at North Transportation, located at 8236 Carder Court in Littleton, Colorado.

Twenty-one (21) AirChek radon test kits were placed on June 3, 2025, and were retrieved on June 5, 2025. The attached laboratory report identifies that radon concentrations in all tested locations meet the EPA guideline of 4 pCi/L for acceptable radon concentrations. As such, no additional mitigation or sampling is needed.

If you have any questions, or if we may be of additional assistance, please contact QUEST, Inc. at 303-935-1573. We look forward to our continued association.

Sincerely,

Robert A. Woellner

Pould hell

Founder/Industrial Hygienist

NEHA: NRPP Certification #105324RT

Robert Head

Environmental Technician

Attachment: Laboratory Report

Radon test result report for: NORTH TRANSPORTATION MAIN

| Kit# | Room Id | Started | Ended | pCi/L | Analyzed |
|----------|-------------|----------------------|----------------------|-------|------------|
| 12094857 | 116 | 2025-06-03 @ 1:00 pm | 2025-06-05 @ 2:00 pm | 1.4 | 2025-06-09 |
| 12094855 | 117 | 2025-06-03 @ 1:00 pm | 2025-06-05 @ 2:00 pm | 1.6 | 2025-06-09 |
| 12094856 | 117A | 2025-06-03 @ 1:00 pm | 2025-06-05 @ 2:00 pm | 1.4 | 2025-06-09 |
| 12094854 | 118 | 2025-06-03 @ 1:00 pm | 2025-06-05 @ 2:00 pm | 0.6 | 2025-06-09 |
| 12094853 | 120 | 2025-06-03 @ 1:00 pm | 2025-06-05 @ 2:00 pm | 0.9 | 2025-06-09 |
| 12094852 | 120 A | 2025-06-03 @ 1:00 pm | 2025-06-05 @ 2:00 pm | 0.8 | 2025-06-09 |
| 12094850 | 121 | 2025-06-03 @ 1:00 pm | 2025-06-05 @ 2:00 pm | 0.6 | 2025-06-09 |
| 12094851 | 121 (D) | 2025-06-03 @ 1:00 pm | 2025-06-05 @ 2:00 pm | < 0.3 | 2025-06-09 |
| 12094846 | 125 | 2025-06-03 @ 1:00 pm | 2025-06-05 @ 2:00 pm | 0.9 | 2025-06-09 |
| 12094848 | 127 | 2025-06-03 @ 1:00 pm | 2025-06-05 @ 2:00 pm | 1.0 | 2025-06-09 |
| 12094847 | 133 | 2025-06-03 @ 1:00 pm | 2025-06-05 @ 2:00 pm | 1.1 | 2025-06-09 |
| 12094844 | 145 | 2025-06-03 @ 1:00 pm | 2025-06-05 @ 2:00 pm | 0.9 | 2025-06-09 |
| 12094843 | COMMON AREA | 2025-06-03 @ 1:00 pm | 2025-06-05 @ 2:00 pm | 0.8 | 2025-06-09 |
| 12094849 | CONFERENCE | 2025-06-03 @ 1:00 pm | 2025-06-05 @ 2:00 pm | 0.6 | 2025-06-09 |
| 12094841 | GARAGE N | 2025-06-03 @ 1:00 pm | 2025-06-05 @ 2:00 pm | < 0.3 | 2025-06-09 |
| 12094842 | GARAGE S | 2025-06-03 @ 1:00 pm | 2025-06-05 @ 2:00 pm | 0.7 | 2025-06-09 |
| 12094861 | GYM (B) | 2025-06-03 @ 1:00 pm | 2025-06-05 @ 2:00 pm | < 0.3 | 2025-06-09 |
| 12094860 | GYM (D) | 2025-06-03 @ 1:00 pm | 2025-06-05 @ 2:00 pm | 1.3 | 2025-06-09 |
| 12094859 | GYM N | 2025-06-03 @ 1:00 pm | 2025-06-05 @ 2:00 pm | 1.3 | 2025-06-09 |
| 12094858 | GYM S | 2025-06-03 @ 1:00 pm | 2025-06-05 @ 2:00 pm | 1.2 | 2025-06-09 |
| 12094845 | WORK SHOP | 2025-06-03 @ 1:00 pm | 2025-06-05 @ 2:00 pm | 0.8 | 2025-06-09 |

Air Chek 1936 Butler Bridge Rd, Mills River, NC 28759-3892 Phone: (828) 684-0893 Fax: (828) 684-8498