



June 17, 2025

Zach Nannestad
Douglas County School District
2812 N. Highway 85
Castle Rock, CO 80109

**Re: South Ridge Elementary School
1100 South Street in Castle Rock, CO 80104
Radon Sampling Assessment**

Dear Mr. Nannestad:

Quality Environmental Services & Technologies Inc. (QUEST) is pleased to assist Douglas County School District with the ongoing radon survey of its schools. At your request, QUEST conducted radon testing at South Ridge Elementary School, located at 1100 South Street in Castle Rock, Colorado.

Forty-five (45) AirChek radon test kits were placed on May 28, 2025 and were retrieved on May 30, 2025. The attached laboratory results specify radon concentrations to be all within the EPA guideline of 4 pCi/L for acceptable radon concentrations.

If you have any questions, or if we may be of additional assistance, please contact QUEST, Inc. at 303-935-1573. We look forward to our continued association.

Sincerely,

A handwritten signature in black ink, appearing to read "Robert A. Woellner".

Robert A. Woellner
Founder/Industrial Hygienist
NEHA: NRPP Certification #105324RT

A handwritten signature in black ink, appearing to read "Robert Head".

Robert Head
Environmental Technician

Attachment: Laboratory Report

Radon test result report for:
SOUTH RIDGE ES
MAIN

Kit #	Room Id	Started	Ended	pCi/L	Analyzed
12074006	100	2025-05-28 @ 12:00 pm	2025-05-30 @ 1:00 pm	0.6	2025-06-02
12074009	111	2025-05-28 @ 12:00 pm	2025-05-30 @ 1:00 pm	0.8	2025-06-02
12074007	114	2025-05-28 @ 12:00 pm	2025-05-30 @ 1:00 pm	0.6	2025-06-02
12074013	130	2025-05-28 @ 12:00 pm	2025-05-30 @ 1:00 pm	0.6	2025-06-02
12074046	140	2025-05-28 @ 12:00 pm	2025-05-30 @ 2:00 pm	< 0.3	2025-06-02
12074045	210	2025-05-28 @ 12:00 pm	2025-05-30 @ 2:00 pm	0.5	2025-06-02
12074044	220	2025-05-28 @ 12:00 pm	2025-05-30 @ 2:00 pm	< 0.3	2025-06-02
12074043	230	2025-05-28 @ 12:00 pm	2025-05-30 @ 1:00 pm	0.6	2025-06-02
12074042	240	2025-05-28 @ 12:00 pm	2025-05-30 @ 1:00 pm	0.6	2025-06-02
12074040	250	2025-05-28 @ 12:00 pm	2025-05-30 @ 1:00 pm	< 0.3	2025-06-02
12074038	260	2025-05-28 @ 12:00 pm	2025-05-30 @ 1:00 pm	< 0.3	2025-06-02
12074039	260 (D)	2025-05-28 @ 12:00 pm	2025-05-30 @ 1:00 pm	0.6	2025-06-02
12074026	302	2025-05-28 @ 12:00 pm	2025-05-30 @ 1:00 pm	0.6	2025-06-02
12074028	302 (B)	2025-05-28 @ 12:00 pm	2025-05-30 @ 1:00 pm	< 0.3	2025-06-02
12074027	302 (D)	2025-05-28 @ 12:00 pm	2025-05-30 @ 1:00 pm	< 0.3	2025-06-02
12074030	303	2025-05-28 @ 12:00 pm	2025-05-30 @ 1:00 pm	0.6	2025-06-02
12074011	304	2025-05-28 @ 12:00 pm	2025-05-30 @ 1:00 pm	0.6	2025-06-02
12074029	310	2025-05-28 @ 12:00 pm	2025-05-30 @ 1:00 pm	1.3	2025-06-02
12074033	320	2025-05-28 @ 12:00 pm	2025-05-30 @ 1:00 pm	0.6	2025-06-02
12074014	320	2025-05-28 @ 12:00 pm	2025-05-30 @ 1:00 pm	0.7	2025-06-02
12074034	330	2025-05-28 @ 12:00 pm	2025-05-30 @ 1:00 pm	0.7	2025-06-02
12074035	340	2025-05-28 @ 12:00 pm	2025-05-30 @ 1:00 pm	< 0.3	2025-06-02
12074036	350	2025-05-28 @ 12:00 pm	2025-05-30 @ 1:00 pm	0.7	2025-06-02
12074037	360	2025-05-28 @ 12:00 pm	2025-05-30 @ 1:00 pm	< 0.3	2025-06-02
12074041	430	2025-05-28 @ 12:00 pm	2025-05-30 @ 1:00 pm	< 0.3	2025-06-02
12074015	510	2025-05-28 @ 12:00 pm	2025-05-30 @ 1:00 pm	1.1	2025-06-02
12074016	510 (D)	2025-05-28 @ 12:00 pm	2025-05-30 @ 1:00 pm	1.1	2025-06-02
12074017	520	2025-05-28 @ 12:00 pm	2025-05-30 @ 1:00 pm	0.8	2025-06-02
12074018	530	2025-05-28 @ 12:00 pm	2025-05-30 @ 1:00 pm	0.9	2025-06-02
12074021	540	2025-05-28 @ 12:00 pm	2025-05-30 @ 1:00 pm	1.0	2025-06-02
12074022	550	2025-05-28 @ 12:00 pm	2025-05-30 @ 1:00 pm	0.8	2025-06-02
12074019	560	2025-05-28 @ 12:00 pm	2025-05-30 @ 1:00 pm	0.5	2025-06-02
12074020	570	2025-05-28 @ 12:00 pm	2025-05-30 @ 1:00 pm	0.6	2025-06-02
12074012	580	2025-05-28 @ 12:00 pm	2025-05-30 @ 1:00 pm	0.9	2025-06-02
12074024	610	2025-05-28 @ 12:00 pm	2025-05-30 @ 1:00 pm	0.6	2025-06-02
12074025	620	2025-05-28 @ 12:00 pm	2025-05-30 @ 1:00 pm	0.6	2025-06-02
12074023	630	2025-05-28 @ 12:00 pm	2025-05-30 @ 1:00 pm	0.9	2025-06-02

June 2, 2025

**** LABORATORY ANALYSIS REPORT ****

Radon test result report for:
SOUTH RIDGE ES
MAIN

Kit #	Room Id	Started	Ended	pCi/L	Analyzed
12074048	CAFETERIA E	2025-05-28 @ 12:00 pm	2025-05-30 @ 2:00 pm	0.7	2025-06-02
12074047	CAFETERIA W	2025-05-28 @ 12:00 pm	2025-05-30 @ 2:00 pm	< 0.3	2025-06-02
12074008	COPY	2025-05-28 @ 12:00 pm	2025-05-30 @ 1:00 pm	0.6	2025-06-02
12074049	GYM	2025-05-28 @ 12:00 pm	2025-05-30 @ 2:00 pm	< 0.3	2025-06-02
12074051	GYM (B)	2025-05-28 @ 12:00 pm	2025-05-30 @ 2:00 pm	< 0.3	2025-06-02
12074050	GYM (D)	2025-05-28 @ 12:00 pm	2025-05-30 @ 2:00 pm	< 0.3	2025-06-02
12074032	LIBRARY S	2025-05-28 @ 12:00 pm	2025-05-30 @ 1:00 pm	1.9	2025-06-02
12074010	OFFICE	2025-05-28 @ 12:00 pm	2025-05-30 @ 1:00 pm	0.5	2025-06-02

Air Chek 1936 Butler Bridge Rd, Mills River, NC 28759-3892 Phone: (828) 684-0893 Fax: (828) 684-8498