

ENVIRONMENTAL LABWORKS, INC.

June 12, 2025

Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Dear James,

The following are results of the analyses performed on water samples from **Ulster BOCES CITL - Port Ewen, NY** received at the laboratory on 05/27/25.

Date/Time Collected: 05/23/25 6:17-6:37am First Draw
Collected By: UC BOCES
Project ID: 05272505
Secondary ID: UL251928-40

LOCATION/ SAMPLE ID	PARAMETER	RESULTS	Q	ACTION LEVEL	ANALYZED
Water Cooler O/S 122 05272505-1	EPA 200.8 Lead	<0.0010 mg/L		0.005 mg/L	06/04/25
Bottle Fill O/S 122 05272505-2	EPA 200.8 Lead	<0.0010 mg/L		0.005 mg/L	06/04/25
125 Sink 5 05272505-3	EPA 200.8 Lead	<0.0010 mg/L		0.005 mg/L	06/04/25
125 Sink 3 05272505-4	EPA 200.8 Lead	<0.0010 mg/L		0.005 mg/L	06/04/25
125 Sink 4 05272505-5	EPA 200.8 Lead	<0.0010 mg/L		0.005 mg/L	06/04/25
212 Teacher's Lounge Sink 05272505-6	EPA 200.8 Lead	<0.0010 mg/L		0.005 mg/L	06/04/25
Water Cooler 2 nd Floor 05272505-7	EPA 200.8 Lead	<0.0010 mg/L		0.005 mg/L	06/04/25
Bottle Fill 2 nd Floor 05272505-8	EPA 200.8 Lead	<0.0010 mg/L		0.005 mg/L	06/04/25
227 Sink 3 05272505-9	EPA 200.8 Lead	<0.0010 mg/L		0.005 mg/L	06/04/25
227 Sink 1 05272505-10	EPA 200.8 Lead	<0.0010 mg/L		0.005 mg/L	06/04/25

PO Box 733
Marlboro, NY 12542
Phone 845-236-7823
Fax 845-236-3911
NYSDOH #10824

ENVIRONMENTAL LABWORKS, INC.

Ulster BOCES CITL Port Ewen - 05272505


LOCATION/ SAMPLE ID	PARAMETER	RESULTS	Q	ACTION LEVEL	ANALYZED
227 Sink 2 05272505-11	EPA 200.8 Lead	<0.0010 mg/L		0.005 mg/L	06/04/25
225 Sink 2 05272505-12	EPA 200.8 Lead	0.0106 mg/L	X	0.005 mg/L	06/04/25
225 Sink 1 05272505-13	EPA 200.8 Lead	<0.0010 mg/L		0.005 mg/L	06/04/25

Qualifier(Q):

X - Value exceeds Maximum Contaminant Level or other Regulatory Level.

The data contained in this report were obtained using EPA or other approved methodologies. This laboratory or any outside laboratory used are NYSDOH certified for these analyses. Vendor laboratory used was ELAP #11549. The results in this report apply to the samples received by the laboratory, analyzed in accordance with the chain of custody document. This analytical report may only be reproduced in its entirety.

Thank you,



for Michael F. Lupi
Technical Director