

ENVIRONMENTAL LABWORKS, INC.

June 12, 2025

Ulster BOCES
 175 Route 32 North
 New Paltz, NY 12561

Dear James,

The following are results of the analyses performed on water samples from **Ulster BOCES Anna Devine - 1372 Old Post Rd., Ulster Park, NY** received at the laboratory on 05/27/25.

Date/Time Collected: 05/23/25 6:58-7:10am First Draw
 Collected By: UC BOCES
 Project ID: 05272504
 Secondary ID: UL251920-27

LOCATION/ SAMPLE ID	PARAMETER	RESULTS	Q	ACTION LEVEL	ANALYZED
Kitchen Sink 1 05272504-1	EPA 200.8 Lead	0.0551 mg/L	X	0.005 mg/L	06/03/25
Kitchen Food Prep Sprayer 05272504-2	EPA 200.8 Lead	0.0046 mg/L		0.005 mg/L	06/03/25
Kitchen Sink 6 05272504-3	EPA 200.8 Lead	0.0042 mg/L		0.005 mg/L	06/03/25
Kitchen Sink 4 05272504-4	EPA 200.8 Lead	0.0042 mg/L		0.005 mg/L	06/03/25
Kitchen Sink 4 Sprayer 05272504-5	EPA 200.8 Lead	0.0064 mg/L	X	0.005 mg/L	06/03/25
Instructional Kitchen Sink 05272504-6	EPA 200.8 Lead	0.0038 mg/L		0.005 mg/L	06/03/25
Teachers Lounge Sink 05272504-7	EPA 200.8 Lead	0.0058 mg/L	X	0.005 mg/L	06/03/25
Main Office Sink 05272504-8	EPA 200.8 Lead	0.0091 mg/L	X	0.005 mg/L	06/03/25

Qualifier(Q):

X - Value exceeds Maximum Contaminant Level or Regulatory Level.


PO Box 733
Marlboro, NY 12542
Phone 845-236-7823
Fax 845-236-3911
NYSDOH #10824

ENVIRONMENTAL LABWORKS, INC.

Ulster BOCES Anna Devine - 05272504

The data contained in this report were obtained using EPA or other approved methodologies. This laboratory or any outside laboratory used are NYSDOH certified for these analyses. Vendor laboratory used was ELAP #11549. The results in this report apply to the samples received by the laboratory, analyzed in accordance with the chain of custody document. This analytical report may only be reproduced in its entirety.

Thank you,



for Michael F. Lupi
Technical Director