



20-21 Wagaraw Road – Bldg. 35E, Fair Lawn, NJ 07410
(973) 636-9145/Email:info@envirovisionconsultants.com
NJ DOH IEHA Lic.# 1097

CLIENT: Tenaflly Public Schools

Project Number 24-117

PROJECT: Lead in Drinking Water

Tenaflly Middle School

ADDRESS: 10 Sunset Lane, Tenaflly, NJ 07670

Report Date: May 6, 2025

Field Technician: Cathy DiNardo

As per your request, EnviroVision Consultants, Inc. was contracted by Tenaflly School District to conduct Lead (Pb) in drinking water sampling at the Tenaflly Middle School on April 15, 2025. The sample locations, in addition to unique sample location codes were determined / assigned by school district personnel. The school district performed the proper flushing of the outlets prior to sampling and EnviroVision was instructed to collect only first draw samples for this sampling event. The school district's corresponding flushing logs should be attached to this report.

The facility was closed at the time of sampling in order to prevent occupants from utilizing any water outlets. After flushing, the water in the facility must remain motionless in the plumbing fixtures for a minimum of 8 hours, but no more than 48 hours. Cold water samples were collected in pre-cleaned high-density polyethylene (HDPE) 250mL wide mouth bottles.

The sample was analyzed at EMSL Analytical, Inc. in Cinnaminson, New Jersey (NJDEP#03036), accredited in accordance with NELAC (National Environmental Laboratory Accreditation Conference). The analytical method utilized was inductively coupled plasma mass spectrometry ICP-MS (EPA 200.8).

Thirty-two samples were collected from Tenaflly Middle School. In addition, a required blank was collected and analyzed for Quality Assurance purposes.

Results: Thirty-one of the samples analyzed were either "None Detected" or less than the EPA established threshold for lead in drinking water. However, one of the samples was above the allowable limit established by the United States Environmental Protection Agency (US EPA) of 15 parts per billion (ppb) or ug/L.

When a water outlet/faucet meets or exceeds the US EPA threshold, EnviroVision recommends that the outlet/faucet be put out of service until the system can be further evaluated and proper remedial action is achieved.

TENAFLY MIDDLE SCHOOL - LEAD (Pb) in Water Results of Concern

Outlet ID/Sample Number	Location	Results
MS SS 17	Girls Coaches Office	20.7 ppb

Note* 1ppb = 1ug/L

Due to the elevated levels in the above-mentioned outlets, we recommend that some or all of the following steps be taken at this time.

- Closure of the affected water outlet(s) until the system can be further evaluated and proper remedial action is achieved.
- Removal and replacement with non-lead containing fixtures.
- Installation of filtration systems.
- Development of a Flushing Program for those taps high in lead and turbidity (this may include automatic flushing systems).
- Contact the local water utility company to obtain information about their corrosion control procedures and how it might affect the District's control plans.
- Permanent closure of outlet(s).

Once the remedial action(s) are complete, follow up testing is required to ensure alterations/replacement to plumbing fixtures has lowered the amount of lead to acceptable levels.

Should you have any questions, or if we could be of any further assistance, please feel free to contact our office. EnviroVision looks forward to providing you with the service and attention to detail you have come to expect from us.

Sincerely,
EnviroVision Consultants, Inc.

Cathy DiNardo

Cathy DiNardo, Project Manager

Attached: Lab results, associated data sheets

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax:cs@emsl.com
EMSL-CIN-01

EMSL Order ID: 012517708
LIMS Reference ID: AD17708
EMSL Customer ID: RAMA51

Attention: Info

EnviroVision Consultants, Inc [RAMA51]
20-21 Wagaraw Rd, Bldg 35E
Fair Lawn, NJ 07410
(973) 636-9145
info@envirovisionconsultants.com

Project Name:

24-117 - Tenafly Middle School - 10 Sunset
Lane, Tenafly, NJ 07670

Customer PO:**EMSL Sales Rep:**

Sheryl Steinmetz

Received:

04/17/2025 09:00

Reported:

05/02/2025 13:08

Analytical Results

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: MSWC3-F/Hall by Custodian Room Lims Reference ID: AD17708-01 Matrix: Drinking Water Sampled: 04/15/25 08:03:00									
Metals									
Lead	ND	1		1.00	µg/L	04/25/25 17:16	04/28/25 21:18	PL	EPA 200.8 (DA)/EPA 200.8
Sample: MSWC3-BF/Hall by Custodian Room Lims Reference ID: AD17708-02 Matrix: Drinking Water Sampled: 04/15/25 08:03:00									
Metals									
Lead	ND	1		1.00	µg/L	04/25/25 17:16	04/28/25 21:24	PL	EPA 200.8 (DA)/EPA 200.8
Sample: MSS17/Girls Coaches Office - Sink Lims Reference ID: AD17708-03 Matrix: Drinking Water Sampled: 04/15/25 08:11:00									
Metals									
Lead	20.7	1		1.00	µg/L	04/25/25 17:16	04/28/25 21:26	PL	EPA 200.8 (DA)/EPA 200.8
Sample: MSWC27-F/Hall by 102 Lims Reference ID: AD17708-04 Matrix: Drinking Water Sampled: 04/15/25 08:17:00									
Metals									
Lead	ND	1		1.00	µg/L	04/25/25 17:16	04/28/25 21:27	PL	EPA 200.8 (DA)/EPA 200.8
Sample: MSWC27-BF/Hall by 102 Lims Reference ID: AD17708-05 Matrix: Drinking Water Sampled: 04/15/25 08:17:00									
Metals									
Lead	ND	1		1.00	µg/L	04/25/25 17:16	04/28/25 21:29	PL	EPA 200.8 (DA)/EPA 200.8
Sample: MSS29/Boys Coaches Office Sink Lims Reference ID: AD17708-06 Matrix: Drinking Water Sampled: 04/15/25 08:20:00									
Metals									
Lead	7.69	1		1.00	µg/L	04/25/25 17:16	04/28/25 21:35	PL	EPA 200.8 (DA)/EPA 200.8
Sample: MSWC38-F/Cafeteria Lims Reference ID: AD17708-07 Matrix: Drinking Water Sampled: 04/15/25 08:25:00									
Metals									
Lead	ND	1		1.00	µg/L	04/25/25 17:16	04/28/25 21:37	PL	EPA 200.8 (DA)/EPA 200.8
Sample: MSWC38-BF/Cafeteria Lims Reference ID: AD17708-08 Matrix: Drinking Water Sampled: 04/15/25 08:25:00									
Metals									
Lead	ND	1		1.00	µg/L	04/25/25 17:16	04/28/25 21:39	PL	EPA 200.8 (DA)/EPA 200.8
Sample: MSS48/Kitchen Sink Lims Reference ID: AD17708-09 Matrix: Drinking Water Sampled: 04/15/25 08:30:00									
Metals									
Lead	4.97	1		1.00	µg/L	04/25/25 17:16	04/28/25 21:41	PL	EPA 200.8 (DA)/EPA 200.8

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077
 Telephone: 856-858-4800 Fax: cs@emsl.com
 EMSL-CIN-01

EMSL Order ID: 012517708
LIMS Reference ID: AD17708
EMSL Customer ID: RAMA51

Attention: Info

EnviroVision Consultants, Inc [RAMA51]
 20-21 Wagaraw Rd, Bldg 35E
 Fair Lawn, NJ 07410
 (973) 636-9145
 info@envirovisionconsultants.com

Project Name:

24-117 - Tenafly Middle School - 10 Sunset
 Lane, Tenafly, NJ 07670

Customer PO:**EMSL Sales Rep:**

Sheryl Steinmetz

Received:

04/17/2025 09:00

Reported:

05/02/2025 13:08

Analytical Results

(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: MSS49/Kitchen Sink Lims Reference ID: AD17708-10 Matrix: Drinking Water Sampled: 04/15/25 08:30:00									
Metals									
Lead	5.22	1		1.00	µg/L	04/25/25 17:16	04/28/25 21:43	PL	EPA 200.8 (DA)/EPA 200.8
Sample: MSIM47/Kitchen Ice Machine Lims Reference ID: AD17708-11 Matrix: Drinking Water Sampled: 04/15/25 08:31:00									
Metals									
Lead	ND	1		1.00	µg/L	04/25/25 17:16	04/28/25 21:45	PL	EPA 200.8 (DA)/EPA 200.8
Sample: MSWC53-F/Hall by Cafeteria Lims Reference ID: AD17708-12 Matrix: Drinking Water Sampled: 04/15/25 08:34:00									
Metals									
Lead	ND	1		1.00	µg/L	04/25/25 17:16	04/28/25 21:50	PL	EPA 200.8 (DA)/EPA 200.8
Sample: MSWC53-BF/Hall by Cafeteria Lims Reference ID: AD17708-13 Matrix: Drinking Water Sampled: 04/15/25 08:34:00									
Metals									
Lead	ND	1		1.00	µg/L	04/25/25 17:16	04/28/25 21:52	PL	EPA 200.8 (DA)/EPA 200.8
Sample: MSWC71-F/Hall by 106 Lims Reference ID: AD17708-14 Matrix: Drinking Water Sampled: 04/15/25 08:40:00									
Metals									
Lead	ND	1		1.00	µg/L	04/25/25 17:16	04/28/25 21:58	PL	EPA 200.8 (DA)/EPA 200.8
Sample: MSWC71-BF/Hall by 106 Lims Reference ID: AD17708-15 Matrix: Drinking Water Sampled: 04/15/25 08:40:00									
Metals									
Lead	ND	1		1.00	µg/L	04/25/25 17:16	04/28/25 22:00	PL	EPA 200.8 (DA)/EPA 200.8
Sample: MSS75/Rm 113 Lims Reference ID: AD17708-16 Matrix: Drinking Water Sampled: 04/15/25 08:46:00									
Metals									
Lead	2.00	1		1.00	µg/L	04/28/25 13:23	04/29/25 17:14	JW1	EPA 200.8 (Dig)/EPA 200.8
Sample: MSS74/Rm 114 Lims Reference ID: AD17708-17 Matrix: Drinking Water Sampled: 04/15/25 08:50:00									
Metals									
Lead	4.78	1		1.00	µg/L	04/25/25 17:16	04/28/25 22:02	PL	EPA 200.8 (DA)/EPA 200.8
Sample: MSWDU82/Faculty Lounge 1st Floor Lims Reference ID: AD17708-18 Matrix: Drinking Water Sampled: 04/15/25 08:52:00									
Metals									
Lead	ND	1		1.00	µg/L	04/25/25 17:16	04/28/25 22:04	PL	EPA 200.8 (DA)/EPA 200.8

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax:cs@emsl.com
EMSL-CIN-01

EMSL Order ID: 012517708
LIMS Reference ID: AD17708
EMSL Customer ID: RAMA51

Attention: Info

EnviroVision Consultants, Inc [RAMA51]
20-21 Wagaraw Rd, Bldg 35E
Fair Lawn, NJ 07410
(973) 636-9145
info@envirovisionconsultants.com

Project Name:

24-117 - Tenaflly Middle School - 10 Sunset
Lane, Tenaflly, NJ 07670

Customer PO:**EMSL Sales Rep:**

Sheryl Steinmetz

Received:

04/17/2025 09:00

Reported:

05/02/2025 13:08

Analytical Results
(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: MSS81/Faculty Lounge - Sink Lims Reference ID: AD17708-19 Matrix: Drinking Water Sampled: 04/15/25 08:52:00									
Metals									
Lead	1.05	1		1.00	µg/L	04/25/25 17:16	04/28/25 22:06	PL	EPA 200.8 (DA)/EPA 200.8
Sample: MSWC101/New Wing 1st Floor Hall Lims Reference ID: AD17708-20 Matrix: Drinking Water Sampled: 04/15/25 08:59:00									
Metals									
Lead	ND	1		1.00	µg/L	04/25/25 17:16	04/28/25 22:08	PL	EPA 200.8 (DA)/EPA 200.8
Sample: MSWC102-F/New Wing 1st Floor Hall Lims Reference ID: AD17708-21 Matrix: Drinking Water Sampled: 04/15/25 09:00:00									
Metals									
Lead	ND	1		1.00	µg/L	04/25/25 17:16	04/28/25 22:10	PL	EPA 200.8 (DA)/EPA 200.8
Sample: MSWC102-BF/New Wing 1st Floor Hall Lims Reference ID: AD17708-22 Matrix: Drinking Water Sampled: 04/15/25 09:00:00									
Metals									
Lead	ND	1		1.00	µg/L	04/25/25 17:17	04/28/25 22:21	PL	EPA 200.8 (DA)/EPA 200.8
Sample: MSWC116-F/2nd Floor Hall by Elevator Lims Reference ID: AD17708-23 Matrix: Drinking Water Sampled: 04/15/25 09:10:00									
Metals									
Lead	ND	1		1.00	µg/L	04/25/25 17:17	04/28/25 22:27	PL	EPA 200.8 (DA)/EPA 200.8
Sample: MSWC116-BF/2nd Floor Hall by Elevator Lims Reference ID: AD17708-24 Matrix: Drinking Water Sampled: 04/15/25 09:10:00									
Metals									
Lead	ND	1		1.00	µg/L	04/25/25 17:17	04/28/25 22:29	PL	EPA 200.8 (DA)/EPA 200.8
Sample: MSWC134-F/2nd Floor Hall by 201 Lims Reference ID: AD17708-25 Matrix: Drinking Water Sampled: 04/15/25 09:14:00									
Metals									
Lead	ND	1		1.00	µg/L	04/25/25 17:17	04/28/25 22:31	PL	EPA 200.8 (DA)/EPA 200.8
Sample: MSWC134-BF/2nd Floor Hall by 201 Lims Reference ID: AD17708-26 Matrix: Drinking Water Sampled: 04/15/25 09:14:00									
Metals									
Lead	ND	1		1.00	µg/L	04/25/25 17:17	04/28/25 22:33	PL	EPA 200.8 (DA)/EPA 200.8
Sample: MSWC140-F/2nd Floor Hall by 212 Lims Reference ID: AD17708-27 Matrix: Drinking Water Sampled: 04/15/25 09:18:00									
Metals									
Lead	ND	1		1.00	µg/L	04/25/25 17:17	04/28/25 22:38	PL	EPA 200.8 (DA)/EPA 200.8

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax:cs@emsl.com
EMSL-CIN-01

EMSL Order ID: 012517708
LIMS Reference ID: AD17708
EMSL Customer ID: RAMA51

Attention: Info

EnviroVision Consultants, Inc [RAMA51]
20-21 Wagaraw Rd, Bldg 35E
Fair Lawn, NJ 07410
(973) 636-9145
info@envirovisionconsultants.com

Project Name:

24-117 - Tenaflly Middle School - 10 Sunset
Lane, Tenaflly, NJ 07670

Customer PO:**EMSL Sales Rep:**

Sheryl Steinmetz

Received:

04/17/2025 09:00

Reported:

05/02/2025 13:08

Analytical Results

(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: MSWC140-BF/2nd Floor Hall by 212 Lims Reference ID: AD17708-28 Matrix: Drinking Water Sampled: 04/15/25 09:18:00									
Metals									
Lead	ND	1		1.00	µg/L	04/25/25 17:17	04/28/25 22:40	PL	EPA 200.8 (DA)/EPA 200.8
Sample: MSS141/Library Office - Sink Lims Reference ID: AD17708-29 Matrix: Drinking Water Sampled: 04/15/25 09:22:00									
Metals									
Lead	3.78	1		1.00	µg/L	04/25/25 17:17	04/28/25 22:42	PL	EPA 200.8 (DA)/EPA 200.8
Sample: MSWC152/2nd Floor New Wing Hall Lims Reference ID: AD17708-30 Matrix: Drinking Water Sampled: 04/15/25 09:25:00									
Metals									
Lead	ND	1		1.00	µg/L	04/25/25 17:17	04/28/25 22:44	PL	EPA 200.8 (DA)/EPA 200.8
Sample: MSWC151-F/2nd Floor New Wing Hall Lims Reference ID: AD17708-31 Matrix: Drinking Water Sampled: 04/15/25 09:30:00									
Metals									
Lead	ND	1		1.00	µg/L	04/25/25 17:17	04/28/25 22:46	PL	EPA 200.8 (DA)/EPA 200.8
Sample: MSWC151-BF/2nd Floor New Wing Hall Lims Reference ID: AD17708-32 Matrix: Drinking Water Sampled: 04/15/25 09:30:00									
Metals									
Lead	ND	1		1.00	µg/L	04/25/25 17:17	04/28/25 22:48	PL	EPA 200.8 (DA)/EPA 200.8
Sample: MS-B/Blank Lims Reference ID: AD17708-33 Matrix: Drinking Water Sampled: 04/15/25 09:35:00									
Metals									
Lead	ND	1		1.00	µg/L	04/25/25 17:17	04/28/25 22:54	PL	EPA 200.8 (DA)/EPA 200.8

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax:cs@emsl.com
EMSL-CIN-01

EMSL Order ID: 012517708**LIMS Reference ID:** AD17708**EMSL Customer ID:** RAMA51**Attention:** Info

EnviroVision Consultants, Inc [RAMA51]
20-21 Wagaraw Rd, Bldg 35E
Fair Lawn, NJ 07410
(973) 636-9145
info@envirovisionconsultants.com

Project Name:

24-117 - Tenaflly Middle School - 10 Sunset
Lane, Tenaflly, NJ 07670

Customer PO:**EMSL Sales Rep:****Received:****Reported:**

Sheryl Steinmetz
04/17/2025 09:00
05/02/2025 13:08

Certified Analyses included in this Report

Analyte	Certifications
<i>EPA 200.8 in Drinking Water</i>	
Lead	NJDEP

List of Certifications

Code	Description	Number	Expires
PADEP	Pennsylvania Department of Environmental Protection	2845.25	11/30/2025
NYSDOH	New York State Department of Health ELAP	10872	04/01/2025
NJDEP	New Jersey Department of Environmental Protection	03036	06/30/2025
MADEP	Massachusetts Department of Environmental Protection	M-NJ337	06/30/2025
CTDPH	Connecticut Department of Public Health	PH-0270	06/23/2026
California ELAP	California Water Boards	1877	06/30/2025
AIHA LAP	American Industrial Hygiene Association (AIHA LAP, LLC)	100194	05/01/2025
A2LA	A2LA Environmental Certificate	2845.01	07/31/2026

Please see the specific Field of Testing (FOT) on www.emsl.com <<http://www.emsl.com>> for a complete listing of parameters for which EMSL is certified.

**EMSL Analytical, Inc.**

200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax:cs@emsl.com
EMSL-CIN-01

EMSL Order ID: 012517708
LIMS Reference ID: AD17708
EMSL Customer ID: RAMA51

Attention: Info

EnviroVision Consultants, Inc [RAMA51]
20-21 Wagaraw Rd, Bldg 35E
Fair Lawn, NJ 07410
(973) 636-9145
info@envirovisionconsultants.com

Project Name:

24-117 - Tenaflly Middle School - 10 Sunset
Lane, Tenaflly, NJ 07670

Customer PO:**EMSL Sales Rep:**

Sheryl Steinmetz

Received:

04/17/2025 09:00

Reported:

05/02/2025 13:08

Notes and Definitions

Item	Definition
(Dig)	For metals analysis, sample was digested.
[2C]	Reported from the second channel in dual column analysis.
DA	Direct Analysis
DF	Dilution Factor
MDL	Method Detection Limit.
ND	Analyte was NOT DETECTED at or above the detection limit.
NR	Spike/Surrogate showed no recovery.
Q	Qualifier
RCS	Respirable Crystalline Silica
RL	Reporting Limit
Wet	Sample is not dry weight corrected.

Measurement of uncertainty and any applicable definitions of method modifications are available upon request. Per EPA NLLAP policy, sample results are not blank corrected.

Owen McKenna Laboratory Manager or other approved signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted.



AD 17108
20-21 Wagawag Road - Bldg. 35E, Fair Lawn, NJ 07410
(973) 636-9145 / info@envirovisionconsultants.com
NJDOH IHEA Lic #: 1097

CLIENT Tenafly Public Schools
PROJECT Tenafly Middle School
TECH(s) C. DiNardo

ADDRESS 500 Tenafly Road, Tenafly NJ 07670
ADDRESS 10 Sunset Lane, Tenafly NJ 07670
SAMPLING DATE 4/15/25 PROJ # 24-117

LEAD IN DRINKING WATER DATA SHEET

SAMPLE ID	Date/Time Collected	SAMPLE LOCATION	OBSERVATIONS
MSWC3-F	4/15/25 8:03AM	Hall By Custodian Room	
MSWC3-BF	4/15/25 8:03AM	Hall By Custodian Room	
MSS17	4/15/25 8:11AM	Girls Coaches Office - sink	
MSWC27-F	4/15/25 8:19AM	Hall By 102	
MSWC27-BF	4/15/25 8:17AM	Hall By 102	
MSS29	4/15/25 8:20AM	Boys Coaches Office sink	
MSWC38-F	4/15/25 8:25AM	Cafeteria	
MSWC38-BF	4/15/25 8:25AM	Cafeteria	
MSS48	4/15/25 8:30AM	Kitchen sink	
MSS49	4/15/25 8:30AM	Kitchen sink	

CHAIN OF CUSTODY

Relinquished By:	Received By:	Date & Time
<i>C. DiNardo</i>	<i>Annunzio (WT)</i>	4/17/25 0900

ANALYSIS:
☒ Unpreserved, via EPA 200.8 ICP-MS (0.001mg/L (ppm))
☐ Preserved with HNO₃, via EPA 200.8 ICP-MS (0.001 mg/L (ppm))

Matrix: Drinking Water, Sample Type: Grab

Sample(s) Temperature Upon Receipt (Lab Only): _____

Bottle Size: 250 mL, wide mouth

TURNAROUND TIME 2 DAYS / WEEKS

EMAIL RESULTS TO info@envirovisionconsultants.com

LABORATORY SUBMITTED TO:	
LAB ORDER #	

PAGE 1 OF 3



AD17708

20-21 Wagaraw Road - Bldg. 35E, Fair Lawn, NJ 07410
(973) 636-9145 / info@envirovisionconsultants.com
NJDOH IHEA Lic #: 1097

CLIENT Tenafly Public Schools

ADDRESS 500 Tenafly Road, Tenafly NJ 07670

PROJECT Tenafly Middle School

ADDRESS 10 Sunset Lane, Tenafly NJ 07670

TECH(s) C. DiNardo

SAMPLING DATE 4/15/25

PROJ # 24-117

LEAD IN DRINKING WATER DATA SHEET

SAMPLE ID	Date/Time Collected	SAMPLE LOCATION	OBSERVATIONS
MSIM 47	4/15/25 831 AM	Kitchen I De Maphwe	
MSWC 53-F	4/15/25 834 AM	Hall By Cafeteria	
MSWC 53-BF	4/15/25 834 AM	Hall By Cafeteria	
MSWC 71-F	4/15/25 840 AM	Hall By 106	
MSWC 71-BF	4/15/25 840 AM	Hall By 106	
MSS 75	4/15/25 846 AM	Rm 113	
MSS 74	4/15/25 850 AM	Rm 114	
MSWDU 82	4/15/25 852 AM	Faculty Lounge 1st Floor	
MSS 81	4/15/25 852 AM	Faculty Lounge - Sink	
MSWC 101	4/15/25 859 AM	New wing 1st Floor hall	
MSWC 102-F	4/15/25 900 AM	New wing 1st Floor hall	
MSWC 102-BF	4/15/25 900 AM	New wing 1st Floor hall	
MSWC 116-F	4/15/25 910 AM	2nd Floor hall By elevator	
MSWC 116-BF	4/15/25 910 AM	2nd Floor hall By elevator	
MSWC 134-F	4/15/25 914 AM	2nd Floor hall By 201	
MSWC 134-BF	4/15/25 914 AM	2nd Floor hall By 201	
MSWC 140-F	4/15/25 918 AM	2nd Floor hall By 212	
MSWC 140-BF	4/15/25 918 AM	2nd Floor hall By 212	



NJDOH IHEA Lic #: 1097

24-117

PROJ

OBSERVATIONS