EnviroVision Consultants, Inc.
20-21 Wagaraw Road – Bldg. 35E, Fair Lawn, NJ 07410
(973) 636-9145/Email:info@envirovisionconsultants.com
NJ DOH IEHA Lic.# 1097

CLIENT: Tenafly Public Schools
PROJECT: Lead in Drinking Water
ADDRESS: 75 Tenafly Road, Tenafly, NJ 07670
Field Technician: Cathy DiNardo

Project Number 24-117
Stillman Elementary School
Report Date: May 6, 2025

As per your request, EnviroVision Consultants, Inc. was contracted by Tenafly School District to conduct Lead (Pb) in drinking water sampling at Stillman Elementary School on April 15, 2025. The sample locations, in addition to unique sample location codes were determined / assigned by school district personnel. The school district performed the proper flushing of the outlets prior to sampling and EnviroVision was instructed to collect only first draw samples for this sampling event. The school district's corresponding flushing logs should be attached to this report.

The facility was closed at the time of sampling in order to prevent occupants from utilizing any water outlets. After flushing, the water in the facility must remain motionless in the plumbing fixtures for a minimum of 8 hours, but no more than 48 hours. Cold water samples were collected in pre-cleaned high-density polyethylene (HDPE) 250mL wide mouth bottles.

The sample was analyzed at EMSL Analytical, Inc. in Cinnaminson, New Jersey (NJDEP#03036), accredited in accordance with NELAC (National Environmental Laboratory Accreditation Conference). The analytical method utilized was inductively coupled plasma mass spectrometry ICP-MS (EPA 200.8).

Results: Seventeen samples were collected from Stillman Elementary School. All of the samples analyzed were either "None Detected" or less than the US EPA established threshold for lead in drinking water of 15 parts per billion (ppb or ug/L). In addition, a required blank was collected and analyzed for Quality Assurance purposes.

Should you have any questions, or if we could be of any further assistance, please feel free to contact our office. EnviroVision looks forward to providing you with the service and attention to detail you have come to expect from us.

Sincerely,
EnviroVision Consultants, Inc.

Cathy DiNardo

Cathy DiNardo, Project Manager

Attached: Lab results, associated data sheets

EMSL Analytical, Inc.

200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax:cs@emsl.com
EMSL-CIN-01

EMSL Order ID: 012517611
LIMS Reference ID: AD17611
EMSL Customer ID: RAMA51

Attention: Results
EnviroVision Consultants, Inc [RAMA51]
20-21 Wagaraw Rd, Bldg 35E
Fair Lawn, NJ 07410
(973) 636-9145
envirovision@optonline.net

Project Name: #24-117 / Stillman Elementary School - 75 Tenafly Road, Tenafly, NJ 07670

Customer PO:
EMSL Sales Rep: Sheryl Steinmetz
Received: 04/17/2025 09:00
Reported: 05/01/2025 16:43

Analytical Results

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: WSSWC34-F/Hall By Rm 310		**Lims Reference ID:**		**AD17611-01**	**Matrix: Drinking Water**				**Sampled: 04/14/25 14:13:00**
Metals									
Lead	ND		1	1.00	µg/L	04/28/25 11:36	04/29/25 08:22	PL	EPA 200.8 (DA)/EPA 200.8
Sample: WSSWC347-BF/Hall By Rm 310		**Lims Reference ID:**		**AD17611-02**	**Matrix: Drinking Water**				**Sampled: 04/14/25 14:13:00**
Metals									
Lead	ND		1	1.00	µg/L	04/28/25 11:36	04/29/25 08:28	PL	EPA 200.8 (DA)/EPA 200.8
Sample: WSSS20/Media Center		**Lims Reference ID:**		**AD17611-03**	**Matrix: Drinking Water**				**Sampled: 04/14/25 14:15:00**
Metals									
Lead	5.96		1	1.00	µg/L	04/28/25 11:36	04/29/25 08:30	PL	EPA 200.8 (DA)/EPA 200.8
Sample: WSSWC11-F/Hall By Boys Restrm By Gym		**Lims Reference ID:**		**AD17611-04**	**Matrix: Drinking Water**				**Sampled: 04/14/25 14:15:00**
Metals									
Lead	ND		1	1.00	µg/L	04/28/25 11:36	04/29/25 08:32	PL	EPA 200.8 (DA)/EPA 200.8
Sample: WSSWC11-BF/Hall By Boys Restrm By Gym		**Lims Reference ID:**		**AD17611-05**	**Matrix: Drinking Water**				**Sampled: 04/14/25 14:15:00**
Metals									
Lead	ND		1	1.00	µg/L	04/28/25 11:36	04/29/25 08:34	PL	EPA 200.8 (DA)/EPA 200.8
Sample: WSSWC55-F/Hall By Rm 121		**Lims Reference ID:**		**AD17611-06**	**Matrix: Drinking Water**				**Sampled: 04/14/25 14:16:00**
Metals									
Lead	ND		1	1.00	µg/L	04/28/25 11:36	04/29/25 08:39	PL	EPA 200.8 (DA)/EPA 200.8
Sample: WSSWC55-BF/Hall By Rm 121		**Lims Reference ID:**		**AD17611-07**	**Matrix: Drinking Water**				**Sampled: 04/14/25 14:16:00**
Metals									
Lead	ND		1	1.00	µg/L	04/28/25 11:36	04/29/25 08:41	PL	EPA 200.8 (DA)/EPA 200.8
Sample: WSSWC44/Hall By Rm 123		**Lims Reference ID:**		**AD17611-08**	**Matrix: Drinking Water**				**Sampled: 04/14/25 14:18:00**
Metals									
Lead	ND		1	1.00	µg/L	04/28/25 11:36	04/29/25 08:43	PL	EPA 200.8 (DA)/EPA 200.8
Sample: WSSS12/Kitchen		**Lims Reference ID:**		**AD17611-09**	**Matrix: Drinking Water**				**Sampled: 04/14/25 14:20:00**
Metals									
Lead	10.6		1	1.00	µg/L	04/28/25 11:36	04/29/25 08:45	PL	EPA 200.8 (DA)/EPA 200.8

EMSL Analytical, Inc.

200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax:cs@emsl.com
EMSL-CIN-01

EMSL Order ID: 012517611
LIMS Reference ID: AD17611
EMSL Customer ID: RAMA51

Attention: Results
EnviroVision Consultants, Inc [RAMA51]
20-21 Wagaraw Rd, Bldg 35E
Fair Lawn, NJ 07410
(973) 636-9145
envirovision@optonline.net

Project Name: #24-117 / Stillman Elementary School - 75 Tenafly Road, Tenafly, NJ 07670

Customer PO:
EMSL Sales Rep: Sheryl Steinmetz
Received: 04/17/2025 09:00
Reported: 05/01/2025 16:43

Analytical Results
(Continued)

Analyte	Result	Q	DF	RL	Units	Prepared Date/Time	Analyzed Date/Time	Analyst Initials	Prep /Analytical Method
Sample: WSSS15/Nurse-Sink		**Lims Reference ID:**		**AD17611-10**	**Matrix: Drinking Water**				**Sampled: 04/14/25 14:30:00**
Metals									
Lead	4.05		1	1.00	µg/L	04/28/25 11:36	04/29/25 08:47	PL	EPA 200.8 (DA)/EPA 200.8
Sample: WSSS16/Nurse-Sink		**Lims Reference ID:**		**AD17611-11**	**Matrix: Drinking Water**				**Sampled: 04/14/25 14:30:00**
Metals									
Lead	5.06		1	1.00	µg/L	04/28/25 11:36	04/29/25 08:49	PL	EPA 200.8 (DA)/EPA 200.8
Sample: WSSS3/Faculty Rm-Sink		**Lims Reference ID:**		**AD17611-12**	**Matrix: Drinking Water**				**Sampled: 04/14/25 14:30:00**
Metals									
Lead	2.08		1	1.00	µg/L	04/28/25 11:36	04/29/25 08:55	PL	EPA 200.8 (DA)/EPA 200.8
Sample: WSSWC18/Room 701-Fountain		**Lims Reference ID:**		**AD17611-13**	**Matrix: Drinking Water**				**Sampled: 04/14/25 14:31:00**
Metals									
Lead	ND		1	1.00	µg/L	04/28/25 11:36	04/29/25 08:57	PL	EPA 200.8 (DA)/EPA 200.8
Sample: WSSWC69-F/Hall By 201		**Lims Reference ID:**		**AD17611-14**	**Matrix: Drinking Water**				**Sampled: 04/14/25 14:34:00**
Metals									
Lead	ND		1	1.00	µg/L	04/28/25 11:36	04/29/25 09:02	PL	EPA 200.8 (DA)/EPA 200.8
Sample: WSSWC69-BF/Hall By 201		**Lims Reference ID:**		**AD17611-15**	**Matrix: Drinking Water**				**Sampled: 04/14/25 14:34:00**
Metals									
Lead	ND		1	1.00	µg/L	04/28/25 11:36	04/29/25 09:04	PL	EPA 200.8 (DA)/EPA 200.8
Sample: WSSWC70-F/Hall By 204		**Lims Reference ID:**		**AD17611-16**	**Matrix: Drinking Water**				**Sampled: 04/14/25 14:35:00**
Metals									
Lead	ND		1	1.00	µg/L	04/28/25 11:36	04/29/25 09:06	PL	EPA 200.8 (DA)/EPA 200.8
Sample: WSSWC70-BF/Hall By 204		**Lims Reference ID:**		**AD17611-17**	**Matrix: Drinking Water**				**Sampled: 04/14/25 14:35:00**
Metals									
Lead	ND		1	1.00	µg/L	04/28/25 11:36	04/29/25 09:08	PL	EPA 200.8 (DA)/EPA 200.8
Sample: WSS-B/Blank		**Lims Reference ID:**		**AD17611-18**	**Matrix: Drinking Water**				**Sampled: 04/14/25 14:36:00**
Metals									
Lead	ND		1	1.00	µg/L	04/28/25 11:36	04/29/25 09:10	PL	EPA 200.8 (DA)/EPA 200.8

EMSL Analytical, Inc.

200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax:cs@emsl.com
EMSL-CIN-01

EMSL Order ID: 012517611
LIMS Reference ID: AD17611
EMSL Customer ID: RAMA51

Attention: Results
EnviroVision Consultants, Inc [RAMA51]
20-21 Wagaraw Rd, Bldg 35E
Fair Lawn, NJ 07410
(973) 636-9145
envirovision@optonline.net

Project Name: #24-117 / Stillman Elementary School - 75 Tenafly Road, Tenafly, NJ 07670

Customer PO:
EMSL Sales Rep: Sheryl Steinmetz
Received: 04/17/2025 09:00
Reported: 05/01/2025 16:43

Certified Analyses included in this Report

Analyte	Certifications
EPA 200.8 in Drinking Water	
Lead	NJDEP

List of Certifications

Code	Description	Number	Expires
PADEP	Pennsylvania Department of Environmental Protection	2845.25	11/30/2025
NYSDOH	New York State Department of Health ELAP	10872	04/01/2025
NJDEP	New Jersey Department of Environmental Protection	03036	06/30/2025
MADEP	Massachusetts Department of Environmental Protection	M-NJ337	06/30/2025
CTDPH	Connecticut Department of Public Health	PH-0270	06/23/2026
California ELAP	California Water Boards	1877	06/30/2025
AIHA LAP	American Industrial Hygiene Association (AIHA LAP, LLC)	100194	05/01/2025
A2LA	A2LA Environmental Certificate	2845.01	07/31/2026

Please see the specific Field of Testing (FOT) on www.emsl.com <http://www.emsl.com> for a complete listing of parameters for which EMSL is certified.

EMSL Analytical, Inc.

200 Route 130, Cinnaminson, NJ, 08077
Telephone: 856-858-4800 Fax:cs@emsl.com
EMSL-CIN-01

EMSL Order ID: 012517611
LIMS Reference ID: AD17611
EMSL Customer ID: RAMA51

Attention: Results
EnviroVision Consultants, Inc [RAMA51]
20-21 Wagaraw Rd, Bldg 35E
Fair Lawn, NJ 07410
(973) 636-9145
envirovision@optonline.net

Project Name: #24-117 / Stillman Elementary School - 75 Tenafly Road, Tenafly, NJ 07670

Customer PO:
EMSL Sales Rep: Sheryl Steinmetz
Received: 04/17/2025 09:00
Reported: 05/01/2025 16:43

Notes and Definitions

Item	Definition
(Dig)	For metals analysis, sample was digested.
[2C]	Reported from the second channel in dual column analysis.
DA	Direct Analysis
DF	Dilution Factor
MDL	Method Detection Limit.
ND	Analyte was NOT DETECTED at or above the detection limit.
NR	Spike/Surrogate showed no recovery.
Q	Qualifier
RCS	Respirable Crystalline Silica
RL	Reporting Limit
Wet	Sample is not dry weight corrected.

Measurement of uncertainty and any applicable definitions of method modifications are available upon request. Per EPA NLLAP policy, sample results are not blank corrected.

Owen McKenna Laboratory Manager or other approved signatory

EMSL maintains liability limited to cost of analysis. Interpretation and use of test results are the responsibility of the client. This report relates only to the samples reported above, and may not be reproduced, except in full, without written approval by EMSL. EMSL bears no responsibility for sample collection activities or analytical method limitations. The report reflects the samples as received. Results are generated from the field sampling data (sampling volumes and areas, locations, etc.) provided by the client on the Chain of Custody. Samples are within quality control criteria and met method specifications unless otherwise noted.

AD 17611

EnviroVision Consultants, Inc.
20-21 Wagaraw Road – Bldg. 35E, Fair Lawn, NJ 07410
(973) 636-9145 / info@envirovisionconsultants.com
NJDOH IHEA Lic #: 1097

CLIENT	Tenafly Public Schools	ADDRESS	500 Tenafly Road, Tenafly NJ 07670		
PROJECT	Stillman Elementary School	ADDRESS	75 Tenafly Road, Tenafly NJ 07670		
TECH(s)	C. DiNardo	SAMPLING DATE	4/15/25	PROJ #	24-117

LEAD IN DRINKING WATER DATA SHEET

SAMPLE ID	Date/Time Collected	SAMPLE LOCATION	OBSERVATIONS
WSSWC 34-F	4/14/25 213pm	Hall By Rm 310	
WSS WC 34-BF	4/14/25 213pm	Hall By Rm 310	
WSS S 20	4/14/25 215pm	Media Center	
WSS WC 11-F	4/14/25 215pm	Hall By Boys Restrm By Gym	
WSS WC 11-BF	4/14/25 215pm	Hall By Boys Restrm By Gym	
WSS WC 55-F	4/14/25 216pm	Hall By Rm 121	
WSS WC 55-BF	4/14/25 216 pm	Hall By Rm 121	
WSS WC 44	4/14/25 218pm	Hall By Rm 123	
WSS S12	4/14/25 220pm	Kitchen	

CHAIN OF CUSTODY

Relinquished By:	Received By:	Date & Time
C DiNardo	Donnelly (WSI)	4/17/25 0900
	HNO_3 added 4/18/25 1125	

ANALYSIS:
X Unpreserved, via EPA 200.8 ICP-MS (0.001mg/L (ppm))
___ Preserved with HNO_3, via EPA 200.8 ICP-MS (0.001 mg/L (ppm))

Matrix: Drinking Water, Sample Type: Grab
Sample(s) Temperature Upon Receipt (Lab Only): _____
Bottle Size: 250 mL, wide mouth

TURNAROUND TIME 2 DAYS / WEEKS

EMAIL RESULTS TO | info@envirovisionconsultants.com

LABORATORY SUBMITTED TO:	
LAB ORDER #	

PAGE 1 OF 2

AD 17611

EnviroVision Consultants, Inc.

20-21 Wagaraw Road – Bldg. 35E, Fair Lawn, NJ 07410
(973) 636-9145 / info@envirovisionconsultants.com
NJDOH IHEA Lic #: 1097

CLIENT	Tenafly Public Schools	ADDRESS	500 Tenafly Road, Tenafly NJ 07670		
PROJECT	Stillman Elementary School	ADDRESS	75 Tenafly Road, Tenafly NJ 07670		
TECH(s)	C. DiNardo	SAMPLING DATE	4/15/25	PROJ #	24-117

LEAD IN DRINKING WATER DATA SHEET

SAMPLE ID	Date/Time Collected	SAMPLE LOCATION	OBSERVATIONS
WSS S15	4/15/25 230	nurse -sink	
WSS S16	4/15/25 230	nurse - sink	
WSS S3	4/15/25 230	Faculty Rm sink	
WSS WC18	4/15/25 231	Room 101 Fountain	
WSS WC69-F	4/15/25 234	Hall By 201	
WSS WC69-BF	4/15/25 234	Hall By 201	
WSS WC70-F	4/15/25 235	Hall By 204	
WSS WC 70-BF	4/15/25 235	Hall By 204	
WSS-FB	4/15/25 236	Blank	

PAGE 2 OF 2