

SPRINGVILLE_BOND INSTALLED WBF_LOCATION	SAMPLE ID	DATE	PRELIMINARY LEAD RESULT (ppb)	FINAL SAMPLE DATE	FINAL LEAD RESULT (ppb)
Cafeteria Fountain (Left)	SES-001DW	3/19/2025	44.4	4/3/2025	7.5
Cafeteria Fountain (Right)	SES-002DW	3/19/2025	17.7	4/3/2025	3.9
Cafeteria Bottle Filler	SES-003WB	3/19/2025	11.1	4/11/2025	2.1